

August 15, 2025

Memo to: Newton Energy Commission Chair Philip Hanser
From: Peter J. Barrer and Denise Freed
Re: GSEP in Newton 2024
Cc: Bob Persons, Ellie Goldberg, Nathan Phillips

Summary

The Newton Gas Pipes Team, a volunteer non-governmental group, has completed an investigation into National Grid's Gas System Enhancement Program (GSEP) plans and National Grid's pipeline replacement and leak repair projects in Newton for calendar year 2024. We are investigating to what degree National Grid's (NG) leak repair and pipeline replacement activities are in the interest of the City and its resident gas ratepayers.

As Newton residents work to reduce carbon emissions, the leaky gas distribution system will be phased out as it becomes obsolete. Under GSEP, however, National Grid's continued investments in the outdated gas pipe system will impose unnecessary costs on ratepayers and perhaps taxpayers.

This report follows similar investigations of GSEP in Newton for [2022](#) and [2023](#) as well as across all [National Grid territory for 2024](#).

We found that the current GSEP does not serve the interests of Newton and does not align with the City's Climate Action Plan goal of eliminating fossil fuel carbon emissions by 2050.

The City's priorities have evolved since the implementation of GSEP in 2014. The City now recognizes that even leaks classified as non-hazardous can still pose significant risks to health and the environment and that the City needs a plan for retiring the gas system entirely.

National Grid replaces most of its pipes in Newton without obtaining specific approval from the City Council through a Grant of Location (GOL). Although NGrid submits its GSEP plans to the DPU, the plans lack details showing all the specific street segments; as a result, Newton elected officials have little information or control over gas pipe construction in Newton streets. Newton should alter its procedures to receive detailed GSEP street segment statements (which may require action by the DPU) and to require City Council GOL review for all non-emergency pipe replacement projects.

Gas leaks are a significant contributor to Newton's greenhouse gas emissions. However, "leak-prone" pipe replacement dominates current GSEP expenses, and this pipe replacement has been ineffective in reducing existing gas leaks. Leak repair is less expensive and more effective for reducing leaks than pipe replacement. In coordination with National Grid, Newton

should now prioritize repairing gas leaks as quickly as possible. To achieve this goal while minimizing ratepayer costs, the GSEP program needs to be completely overhauled and aligned with the climate goal of eliminating gas by 2050.

Detailed Highlights

- \$19,076,705 was charged to GSEP for work in Newton in 2024.
- Almost all of the eliminated leak extent (a measure of environmental harm attributable to a Grade 3 leak, the least hazardous class) was treated by lower-cost leak repair and not by pipe replacement.
- Repair of large leaks is far more cost-effective than pipe replacement. (factor of 200!)
- Over 75% of the length of pipes installed was not preceded by a Grant of Location approved by Newton's City Council
- Pipe replacement cost was \$658 per ft or \$3,474,000 per mile; this is the basis to compare the cost effectiveness of electrification as a non-pipeline alternative.
- Approximately \$4,000,000 was spent on work that was not specifically based on the safety priority of the pipes.
- Some new leaks appeared on lengths of pipe (or the service lines connected to them) after the pipe had been replaced under GSEP.
- Over the past five years, measured gas leak extent in Newton has been reduced by 75%

Introduction

The Newton Gas Pipes non-governmental volunteer team compiles publicly available data about the Newton gas distribution system operated by National Grid. We are working with public records of Gas System Enhancement Program (GSEP) plans, end-of-year accounting reports (GREC), end-of-year Service Quality reports (SQARs), and quarterly gas leak reports filed with the Mass. Department of Public Utilities (DPU), in addition to street surveys and other data from Newton public records.

The pipe replacement program requires National Grid to evaluate leak-prone pipe segments to prioritize replacing pipes that are at significant risk of developing high-impact leaks that could be explosive. It requires National Grid to repair the dangerous leaks, and permits accelerated cost recovery for replacing leak-prone pipes. GSEP also permits accelerated cost recovery for pipes whose replacement can be coordinated with other public works jobs.

The Massachusetts legislature established GSEP in 2014 to increase the safety and reliability of the gas distribution system. This plan was made in the context of an aging system of pipes that would be used for the foreseeable future. GSEP provided a framework for classifying and repairing hazardous leaks, replacing leak-prone pipes, and expanding the gas infrastructure to replace what were considered more polluting energy sources.

However, even “non-hazardous” leaks pose health risks and can contribute significantly to greenhouse gas emissions and additional costs to consumers. To address the leak problem, the

legislature in 2017 added the repair of high-volume methane leaks to the scope of GSEP. These leaks are classified as “non-hazardous” but still have a Significant Environmental Impact (SEI).

The DPU has defined the various gas leak grades. Grade 1 leaks are hazardous and must be repaired immediately. Grade 2 leaks are non-hazardous, but could become hazardous in the near future and must be repaired within a year. Grade 3 leaks are non-hazardous and are expected to remain non-hazardous. Grade 3 leaks initially designated after January 1, 2018 are required to be repaired or eliminated within eight years. Grade 3 SEI leaks are those larger than 2,000 square feet, as measured by the leak extent method, and are required to be repaired within 1-3 years.

We are investigating the degree to which GSEP work is in the interest of the City and its resident gas ratepayers.

Methodology

Data for this investigation were compiled from National Grid’s filings submitted to the DPU. Most of these filings were downloaded from the DPU’s web-based “file room.”

Each fall NGrid files GSEP plans for the coming year, and simultaneously, files less-detailed GSEP plans (“lookaheads”) for the following four years. We focused on the 2024 GSEP plan. However, allowing for the possibility that a previous GSEP installation may have been delayed, we searched all GSEP plans back to 2019. Allowing for an unexpected acceleration of a GSEP installation, we also searched GSEP “lookaheads”¹ covering the period 2020 through 2029. We compiled GSEP plans for 2019 through 2024 into a single table, which is linked as [Table L1](#). We compiled lookahead plans for 2020 to 2023, 2021 to 2024, 2022 to 2025, 2023 to 2026, 2024 to 2027, 2025 to 2028, and 2026 to 2029 in linked [Table L2](#).

To compile the cost data supporting this investigation, we downloaded the CY 2024 GREC report from the DPU file room (Docket 25-GREC-03). National Grid filed its Reconciliation “GREC” report for the 2024 GSEP expenses on May 1, 2025.

We obtained gas leak data from two often coincident sources: the NG Service Quality (SQ) Report for calendar year 2024, dated March 1, 2025, and detailed leak reports produced for the DPU on a quarterly basis which can be obtained by public records request. The SQ report lists all reported leaks and identifies which ones were eliminated during the year, a summary of the quarterly snapshots. The quarterly reports provide a more complete chronology, allowing corroboration of leak conditions with dates of pipe replacement etc., but omit NGrid’s assessments of both whether a given leak can be dealt with through a planned replacement, and whether or not the leak is SEI.

¹ Our use of the word “lookahead” refers to NGrid’s reports that anticipate pipe replacements four years out from the following calendar year, a total of five years, in compliance with regulations in 220 CMR 114.

Regarding leak repair, GSEP also provides incentivized cost recovery for the repair of Grade 3 Significant Environmental Impact (G3SEI) leaks. We compiled and analyzed the GSEP plans for such repairs in 2024, as well as the actual 2024 costs in the GREC filing.

We extracted Newton data from all the NGrid reports, analyzed the 2024 GREC filings to determine what kind of work the 2024 costs actually funded, and compiled reports of how gas leaks were eliminated in 2024.

Results: GSEP cost summary for Newton in 2024

Table 1 below summarizes GSEP costs in Newton as reported in the GREC filing by National Grid. In addition to leak repair and pipe main replacement, GSEP also allows costs to replace “service” pipes to individual buildings. Note that this table does not include the expense of repairing grade 3 non-SEI (smaller) leaks, since such repair costs are not reimbursed through GSEP and are not reported. National Grid has stated that the annual repair cost for Grade 1, Grade 2, and smaller, non-SEI Grade 3 leaks, which are not reported in GSEP, is substantially greater than the annual cost to repair SEI Grade 3 leaks.

There were fifteen SEI leaks in Newton repaired and charged in the GREC for 2024, accounting for 95,439 sq ft of leak extent; the total charge for these fifteen leaks was \$70,906.

Table 1 2024 GSEP costs in Newton

GSEP costs for repairing large leaks	\$70,906	0.4%
GSEP costs for pipe replacements	\$14,952,606	78.4%
CISBOT ²	\$2,591,729	13.6%
lining	\$0	0%
GSEP costs for in-service projects ³	\$1,461,464	7.7%
GSEP costs for service replacements ⁴	\$0.00	0%
Total	\$19,076,705	100%

² CISBOT is a robotic method of repairing a gas pipe without full excavation

³ These repairs were required on pipes that had already been replaced. Note that our Newton Gaspipes Team 2022 GSEP investigation incorrectly described the meaning of “in service replacements”.

⁴ Service replacements connect the main in the street to the customer’s building.

Results: Pipe replacement

Analysis of 2024 GSEP pipe replacement costs as displayed in the GREC filing

We separated the costs reported in the 2024 GREC into the following five categories of projects, displayed in Table 2.

- A. Projects that were anticipated in the GSEP plans for 2024.
- B. Projects that appeared in any other year's GSEPs or lookaheads.⁵
- C. Projects that did not appear in GSEP plans and were attributed to "encroachment."
- D. Projects that did not appear in GSEP plans but had a prioritization assessment and were done because of a "pave opportunity".
- E. Projects that were not in GSEP plans, that had no priority assessment, and were accomplished in accordance with Newton DPW coordination.

Table 2: 2024 GSEP pipe replacement costs compared to plans

Category	Number of projects	GSEP cost
A.	2	\$1,547,092
B.	6	\$9,018,314
C.	3	\$117,440
D.	1	\$118,402
E.	3	\$4,151,359
Total	15	\$14,952,607

⁵ Category B includes one project that is attributed to "encroachment" but does not have a prioritization assessment.

Table 3 below consolidates results from Table 2.

Table 3 Consolidated analysis of 2023 GSEP pipe replacement costs

Description	GSEP cost	Pct.
All projects in a GSEP plan or lookahead (A plus B)	\$10,565,406	70.6%
Projects that were not in GSEP plans but addressed encroachment from other utilities or had a priority assessment. (C plus D)	\$235,842	1.6%
Projects without GSEP prioritization that were completed in coordination with Newton Public Works. (E)	\$4,151,359	27.8%
Total	\$14,952,607	100.0%

Note that 27.8% of the costs originated in coordination with Newton Public Works in the context of maintaining the gas infrastructure for the indefinite future.

Pipe replacement projects charged to GSEP in 2024 are shown in the linked [Table L3](#). The table lists each pipe replacement project. If the project appeared in a prior GSEP plan, the previous plan is also noted in the table.

We found that most of Newton GSEP's work in 2024 was not preceded by a City Council vote for a Grant of Location (GOL). According to state law, a GOL must be approved by the city before any excavation of public roads. However, only 24% of the GSEP pipe length in 2024 was approved with a GOL, as shown in Table 4 below. At Newton's Public Facilities Committee meeting on December 4, 2024, National Grid stated that it follows a "two-foot rule" that exempts the need for GOL approval. Newton Gas Pipes Team has yet to see written documentation of the rule.

Table 4 Grants of Location preceding GSEP work

	Number of projects	Length of pipeline installed (ft.)	Pct. of length
Projects that had a GOL	2	5,644	24%
Projects that did not have a GOL	13	17,725	76%
Total	15	23,369	100%

Results - GSEP expenditures to reduce leak extent by leak repair are much more cost-effective than expenditures by pipe replacement.

The 2024 experience shows that repair of large leaks is more cost-effective by a factor of 200.

Table 5 Cost effectiveness of GSEP leak elimination methods

	Number of leaks	Cost	Leak extent sf	Cost per leak
Large Leak Repair G3SEI	15	\$70,906	95,439	\$4,727
Pipe Replacement	12	\$14,952,606	12,109	\$1,079,384

GREC reported an expense of \$70,906 over the year to repair 15 G3SEI leaks comprising 95,439 sq. ft. according to the latest measurements reported in 2024.

Through pipe replacement, in 2024, GSEP may have addressed as many as 12 leaks comprising 12,109 sq. ft. leak extent measured at last check before the start of the replacement; only 5 of these leaks were ever classified as G3SEI.⁶

Seven of the 15 replacement projects included at least one of these 12 leaks.⁷ See linked [Table L4](#) where we looked at all the reported leaks from Q1 2024 to Q2 2025 along the locations where pipes were replaced. These leaks include Grade 1, Grade 2, and Grade 3 leaks.

Six Grade 1 leaks and two Grade 2 leaks were first reported during the replacement period, which indicates that these pipes were in a fragile state. At least three leaks were reported after the replacements were completed. These leaks might be in the service lines or other pipes at those locations. We conclude that replacing or repairing pipes does not prevent all new leaks, which illustrates the fragility of the whole gas distribution system.

Results - Leaks in Newton during 2024

We analyzed the National Grid Service Quality Report to collect information about how all Newton leaks were treated in 2024 regardless of whether the cost appeared in GSEP or outside of GSEP. Our analysis found the following:

⁶ The cost of pipe replacement work orders that addressed at least one leak repair was \$6,824,962.

⁷ However, three of the 12 leaks are not yet listed as being repaired, including one of the G3SEI leaks. These three leaks have a combined leak extent of 3,375 sq. ft.

- Total reported leaks as of Jan 1, 2024: 515 leaks comprising 305,767 sq. ft. leak extent
[Table L5](#)
 - 3 Grade 1 leaks
 - 20 Grade 2 leaks
 - 492 Grade 3 leaks comprising 305,767 sq. ft. leak extent
- Total reported leaks as of Jan 1, 2025: 374 leaks comprising 266,103 sq. ft. leak extent
[Table L6](#)
 - 3 Grade 1 leaks
 - 15 Grade 2 leaks
 - 356 Grade 3 leaks comprising 266,103 sq. ft. leak extent
- A total of 424 leaks were eliminated during 2024, including 192 Grade 3 leaks comprising 157,330 sq. ft. of leak extent.⁸
- 63% of the eliminated leak extent for Grade 3 leaks was accomplished by leak repair. Only 4% of the eliminated leak extent for Grade 3 leaks was accomplished by pipe replacement. The remainder, 33% of the eliminated leak extent, resulted from a variety of circumstances, including leaks that ceased to be observable, duplicate leak accounting, or other factors.
- 286 new leaks were recorded during 2024 ($374 + 424 + 3^9 - 515 = 286$).
 - 138 new Grade 1 leaks
 - 68 new Grade 2 leaks
 - 80 new Grade 3 leaks
- 25 leaks that were non-hazardous in January 2024 were “upgraded” to a higher risk category during the year and 24 of these leaks were eliminated

[Table L7](#) lists all the leaks that were eliminated in 2024 along with the circumstances of their elimination.

[Table L8](#) lists leaks that were eliminated by leak repair without being upgraded to a more hazardous category.

[Table L9](#) lists leaks eliminated by pipe replacement (GSEP and non-GSEP)

[Table L10](#) lists leaks “eliminated otherwise”, such as by being upgraded first, by repair of a nearby leak, or by some circumstance other than repair

[Table L11](#) aggregates National Grid’s statement of how leaks were “Eliminated Otherwise”

⁸ Additionally, three leaks that appeared in the December 31, 2023 leak report did not appear afterwards in leak reports.

⁹ See footnote directly above.

Table 6 aggregates how leaks were eliminated, according to National Grid categories.

Table 6 Leak Elimination in 2024

How eliminated	Count (All grades)	Count (Grade 3)	Leak extent sq. ft. (Grade 3)	% leak extent
Simple repair	280	68	99,107	63%
Pipe replacement	14	10	6,471	4%
Eliminated by the leak repair of other leaks or after being upgraded	11	7	9,250	6%
Eliminated by circumstances other than leak repair or pipe replacement	119	107	42,502	27%
Total	390	137	157,330	100%

Note that of the 119 leaks that were eliminated by “circumstances other than leak repair or pipe replacement,” 99 were reported as NO READS, even though they had been previously recorded to have a total of 38,092 sq. ft. of leak extent, including a 25,000 sq. ft. leak on Hammond Street and College Road. The leak extent reported as NO READS in 2024 is significantly higher than the numbers in 2022 and 2023.

Results - Leak History in Newton since December 31, 2019

Table 7 summarizes the status of reported gas leaks in Newton at the end of each quarter. Significantly, over the course of nearly five years, the extent of reported leaks has been reduced by 75%. Among the explanations for this reduction are rapid leak repair efforts, a focus on repairing SEI leaks, changes in measured leak extent after the first measurement, and a reduction in the number of new leaks.

Newton has a valuable opportunity to review its coordination with National Grid to ensure the continuous elimination of large leaks.

Table 7 Newton Reported Leak History since January 1, 2020¹⁰

National Grid Report Date	Number of Unrepaired Leaks	Total Leak Extent of unrepaired leaks	Percentage Reduction in Total Leak Extent from Previous Quarter
03/31/2020	856	793,062	
06/30/2020	765	648,712	18%
09/30/2020	733	554,243	15%
12/31/2020	714	520,851	6%
03/31/2021	691	568,224	-9%
06/30/2021	678	567,029	0%
09/30/2021	672	565,074	0%
12/31/2021	639	601,857	-7%
03/31/2022	622	548,597	9%
06/30/2022	639	582,140	-6%
09/30/2022	619	529,339	9%
12/31/2022	588	477,736	10%
03/31/2023	573	364,170	24%
06/30/2023	566	328,240	10%
09/30/2023	545	319,140	3%
12/31/2023	507	287,317	10%
03/31/2024	495	286,502	0%
06/30/2024	504	311,616	-9%
09/30/2024	437	301,974	3%
12/31/2024	372	266,103	12%
03/31/2025	365	234,611	12%
06/30/2025	376	201,162	14%

As of June 30, 2025, out of 376 total unrepaired leaks in Newton there were 102 unrepaired leaks which at any time in their history qualified as SEI. The sum of the leak extent of these leaks was 98,600 sq ft. which is almost half of the total leak extent in Newton (201,162 sq. ft).

¹⁰. Table 7 has slightly different numbers in this report from our [GSEP report for 2023](#). This year's report deletes leaks in this table which were discovered to be double-counted in previous year reports.

Therefore, repairing SEI leaks is particularly effective in reducing methane releases to the atmosphere. However, the other (roughly) half of the leak extent in Newton is due to non-SEI leaks, which highlights the importance of eliminating as many leaks as possible, even those that are not SEI¹¹.

Conclusions and Recommendations

National Grid's pattern of expenses for replacing pipes and repairing leaks in 2024 was similar to 2022 and 2023.

Gas leak repair is much more cost-effective for reducing gas leaks in the short term than replacing leak-prone pipes. Gas pipe work in Newton should heavily prioritize leak repair and pipe retirement; complete pipe replacement is an expensive choice and should be avoided wherever possible.

To achieve more input and control over pipe replacement, and foster non-fossil alternatives, Newton should alter its procedures to receive detailed GSEP street segment statements (which may require action by the DPU) and to require City Council GOL review for all non-emergency pipe replacement projects. Newton should eliminate the "two-foot rule".

National Grid should be encouraged to continue repairing the most significant leaks as quickly as possible, because leaking methane is a significant current source of greenhouse gases. The plans and results for leak repair in Newton should be published quarterly for accountability.

Newton should amplify its official advocacy to State officials for an overhaul of GSEP to reflect Newton's Climate Action Plan goal of eliminating fossil gas emissions. GSEP needs to emphasize/prioritize the immediate reduction/repair of gas leaks. An overhauled GSEP needs to provide a better balance among public safety, infrastructure cost, and speedy retirement of the gas system.

GSEP should provide incentives to accelerate the retirement of the residential gas infrastructure. This approach would be in contrast to the concept behind the original program, which envisioned the indefinite operation of the gas system.

Appreciations

Thank you to others on the Newton pipes team, including, in particular, Josh Nichols-Barrer.

¹¹ I.e. always less than 2,000 sq ft leak extent and less than 50 barhole

APPENDIX

List of Tables

Num	Title	Page
1	GSEP costs in Newton 2024	4
2	2024 GSEP pipe replacement costs compared to plans	5
3	Consolidated aggregation of 2024 GSEP pipe replacement costs	6
4	Grant of Locations preceding GSEP work	6
5	Cost-effectiveness of leak elimination methods	7
6	Leak Elimination in 2024	9
7	Newton Leak History since January 1, 2020	10
	Linked Tables	
L1	GSEP plans in Newton for the Years 2019 through 2024	
L2	GSEP Lookahead plans for the Years 2020 through 2029	
L3	Pipe replacement projects charged to GSEP in 2024	
L4	Leaks at 2024 Pipe Replacement Sites	
L5	Reported leaks as of Dec. 31, 2022	
L6	Reported leaks as of Dec. 31, 2023	
L7	All leaks eliminated in 2024	
L8	Leaks eliminated by repair in 2024	
L9	Leaks eliminated by pipe replacement	
L10	Leaks “eliminated otherwise” detail	
L11	Aggregation of Leaks Eliminated Otherwise	

Appendix: Guide to GSEP program abbreviations for pipe replacement

Quoted from NGrid filing D.P.U. 23-GREC-03, Exhibit NG-AS/MT-1, May 1, 2023, Page 7

There are 11 types of programs included: (1) "BSMNRPL," which indicates a bare steel main replacement project; (2) "CIMNRPL<10," which is a cast iron main replacement project with pipe diameter less than 10 inches; (3) "CIRE101214," which is a cast iron main replacement project with pipe diameter greater than 8" but less than or equal to 14"; (4) "ENCRCHMTPL," which is a parallel main encroachment; (5) "PWNONREIM," which is a public works non-reimbursable project; (6) "ENCRCHMTUM," which is a main encroachment due to undermining of the existing facility; (7) "H2OINT," a program that addresses recurring customer outages resulting from water intrusion into low-pressure distribution systems through the replacement of existing leak-prone pipe; (8) "REANONLEAK," a program used to replace main that, based on conditions found in the field, is immediately prioritized for replacement regardless of leak history; (9) "ALDYRPL," a program to replace pre-1985 vintage Aldyl-A plastic pipe; (10) "GPLNG," which are system reliability main replacements; and, (11) BRIDGES.

END

Table L1 Newton GSEP pipe replacement plans 2019 to 2025							
Year	Work order number	Street address	Old pipe size (in)	GSEP footage (ft)	Cost estimate	Prioritization Factor	NPA Opportunity
2019	1210486	3-105 CENTRAL AV, NEW, & 15-87 PRESCOTT ST	8	4,500	\$1,712,259		
2019	1196349	5-124 MCCARTHY RD, NEW, 5-65 INDIAN RIDGE RD	8	6,620	\$2,187,841		
2020	1118346	9 - 85 CUMMINGS RD and 15 - 92 NORTH ST CTR	4	2,365	\$908,802		
2020	1196349	5 - 124 MCCARTHY RD and 5 - 65 INDIAN RIDGE RD	8	6,595	\$1,980,850		
2021	1312616	63 - 74 BOWEN ST	4	280	\$136,727		
2021	1350709	1063 - 1125 COMMONWEALTH AVE, LOWELL AVE from COMMONWEALTH AVE to WHITTIER RD and WHITTIER RD	8	1,975	\$1,110,625		
2021	1350723	374 - 430 HOMER ST and 1095 - 1125 COMMONWEALTH AVE	12	1,775	\$1,023,397		
2022	1199164	17 - 117 MOULTON ST and 1 - 15 COLGATE CIR	6	2,425	\$1,009,605		
2022	1325241	21 - 203 LAKE AVE CTR and LAKE TER	5	2,700	\$1,185,717		
2022	1343154	14 - 63 BOWDOIN ST and 60 - 93 FOREST ST	3	1,290	\$633,506		
2022	1384498	616 - 692 BOYLSTON ST and 5 - 16 WALNUT HILL RD	6	1,250	\$587,398		
2022	1384741	308 - 374 HOMER ST and WALNUT ST and HOMER ST	12	725	\$787,348		
2022	1395791	7 - 93 HANCOCK ST and 32 - 94 WOODLAND RD	3	2,045	\$899,139		
2022	1400142	388 - 450 LEXINGTON ST and 2060 - 2111 COMMONWEALTH AVE	12	2,105	\$2,128,966		
2023	1350723	374 - 430 HOMER ST and 1095 - 1125 COMMONWEALTH AVE	12	1,945	\$1,058,970		
2023	1400142	388 - 450 LEXINGTON ST and 2060 - 2111 COMMONWEALTH AVE	12	2,105	\$2,095,991		
2023	1421227	7 - 80 WADE ST	6	1,020	\$605,472		
2023	1421288	18 - 109 AUBURN ST and CURVE ST	12	1,355	\$916,102		
2023	1421438	1046 - 1267 CENTRE ST, PELHAM ST and LANGLEY RD from CENTRE ST to PELHAM ST	10	5,750	\$4,777,446		
2023	1457999	595 - 687 WATERTOWN ST	6	4,530	\$2,617,402		
2023	1458805	1549 - 1649 BEACON ST	12	4,140	\$3,576,325		
2024	1342783	15 - 56 MOODY ST and 250 HAMMOND POND PKWY	4	780	\$617,324		
2024	1421288	18 - 109 AUBURN ST and CURVE ST	12	1,355	\$1,020,896		
2024	1421438	1046 - 1267 CENTRE ST, PELHAM ST and LANGLEY RD from CENTRE ST to PELHAM ST	10	5,750	\$6,070,659		
2024	1441118	1080 - 1136 WALNUT ST and COLUMBUS ST	12	4,185	\$3,285,027		
2024	1444162	3 - 144 ELLIOT ST	10	2,315	\$1,616,987		
2024	1458805	1549 - 1649 BEACON ST	12	4,140	\$4,651,865		
2024	1463413	141 - 258 LINWOOD AVE	6	3,890	\$2,749,745		
2024	1476454	10 - 114 HILLSIDE AVE	6	1,045	\$705,700		
2024	1505036	1 - 109 ESSEX RD	6	3,465	\$2,011,358		
2025	1505036	1-109 ESSEX RD, NEW	6	3,465	\$2,204,601	27.5	Yes - Potential NPA, partial scope
2025	1429616	1-113 GROVE ST, NEW	8	3,055	\$2,008,433	26.8	Yes - Potential NPA, partial scope
2025	1554563	1-134 HANSON RD, NEW	4	3,900	\$2,629,098	24.1	Yes - Potential NPA, partial scope
2025	1463413	141-258 LINWOOD AV, NEW	6	3,890	\$2,877,528	34.9	No - Impact to System Integration
2025	1458805	1549-1649 BEACON ST, NEW	12	4,140	\$5,154,733	31.5	No - Impact to System Integration
2025	1588181	1-85 CRESCENT AV, NEW	4	1,270	\$921,297	24.0	No - Impact to System Integration
2025	1384741	308-374 HOMER ST, NEW, & WALNUT ST	12	725	\$1,098,622	26.5	No - Impact to System Integration

Table L1 Newton GSEP pipe replacement plans 2019 to 2025							
Year	Work order number	Street address	Old pipe size (in)	GSEP footage (ft)	Cost estimate	Prioritization Factor	NPA Opportunity
2025	1444162	3-144 ELLIOT ST, NEW	10	2,400	\$1,765,586	29.0	No - Impact to System Integration
2025	1578640	574-687 GROVE ST, NEW, COLGATE RD & HAGAR ST	4	2,000	\$1,263,590	18.6	Yes - Potential NPA, partial scope
2025	1384498	616-692 BOYLSTON ST, NEW, & 5-16 WALNUT HILL RD	6	1,250	\$789,362	32.8	No - Impact to System Integration
2025	1426947	885-1055 CENTRE ST, NEW, WARD ST & NATHAN RD	12	4,655	\$4,608,350	13.7	No - Impact to System Integration

Table L2 Newton GSEP plans				
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028 and 2026-2029				
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity
2020 - 2023	BACON ST	3	378	
2020 - 2023	631-731 BEACON ST, NEW, & 11-15 COUSENS CIR	4	1,625	
2020 - 2023	BELLEVUE RD	3	254	
2020 - 2023	BELLEVUE ST	3	492	
2020 - 2023	BOWERS ST	3	617	
2020 - 2023	BOYD ST	3	214	
2020 - 2023	347-407 CENTRAL ST, NEW	6	730	
2020 - 2023	CHASE ST	3	876	
2020 - 2023	CHERRY ST	3	51	
2020 - 2023	CHESLEY AV	3	185	
2020 - 2023	CHESTER ST	3	405	
2020 - 2023	COLUMBUS ST	3	613	
2020 - 2023	COPLEY ST	3	482	
2020 - 2023	COURT ST	3	95	
2020 - 2023	CRESCENT AV	3	712	
2020 - 2023	CRYSTAL ST	3	344	
2020 - 2023	DUNCKLEE ST	3	255	
2020 - 2023	EDINBORO CIR	3	131	
2020 - 2023	ERIE AV	3	219	
2020 - 2023	FAIR OAKS AV	3	661	
2020 - 2023	FAIRMONT AV	3	571	
2020 - 2023	FOREST AV	3	95	
2020 - 2023	FOREST ST	3	795	
2020 - 2023	GRASMERE ST	3	204	
2020 - 2023	GREENWOOD AV	3	124	
2020 - 2023	141-192 GROVE ST, NEW, & MYRTLE AV	8	1,000	
2020 - 2023	HANCOCK ST	3	745	
2020 - 2023	HIGHLAND AV	3	435	
2020 - 2023	HIGHLAND PK	3	248	
2020 - 2023	HILLSIDE RD	3	31	
2020 - 2023	HOLLIS ST	3	257	
2020 - 2023	HUNTER ST	3	276	
2020 - 2023	HYDE ST	3	132	
2020 - 2023	4-49 JASSET ST, NEW	4	610	
2020 - 2023	JEWETT ST	3	229	
2020 - 2023	79-143 LANGDON ST, NEW, & 4-35 LAUDHOLM RD	4	2,065	
2020 - 2023	LENOX ST	3	631	
2020 - 2023	LOWELL AV	3	955	
2020 - 2023	LYMAN ST	3	340	
2020 - 2023	MELROSE ST	3	340	
2020 - 2023	MORELAND AV	3	225	
2020 - 2023	17-117 MOULTON ST, NEW, & 1-15 COLGATE CIR	6	1,930	
2020 - 2023	OLD ROGERS ST	3	275	
2020 - 2023	PAUL ST	3	508	
2020 - 2023	PEARL ST	3	369	
2020 - 2023	PERKINS ST	3	83	
2020 - 2023	PLEASANT ST	3	86	
2020 - 2023	PRESCOTT ST	3	275	
2020 - 2023	PROSPECT ST	3	818	
2020 - 2023	PUTNAM ST	3	697	

Table L2 Newton GSEP plans				
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028 and 2026-2029				
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity
2020 - 2023	9-34 RICKER RD, NEW, & 11-20 RICKER TER	6	630	
2020 - 2023	RIVER ST	3	82	
2020 - 2023	42-51 ROCKLAND ST, NEW	8	245	
2020 - 2023	RUSSELL CT	3	310	
2020 - 2023	SHAW ST	3	457	
2020 - 2023	STANDISH ST	3	345	
2020 - 2023	STERLING ST	3	152	
2020 - 2023	SUMNER ST	3	419	
2020 - 2023	TEMPLE ST	3	184	
2020 - 2023	UNDERWOOD AV	3	234	
2020 - 2023	WABAN PK	3	1,140	
2020 - 2023	WABAN ST	3	873	
2020 - 2023	WALKER ST	3	576	
2020 - 2023	WALNUT PK	3	1,217	
2020 - 2023	406-506 WALNUT ST, NEW	12	1,440	
2020 - 2023	WASHINGTON PK	3	911	
2020 - 2023	WEBSTER CT	3	25	
2020 - 2023	WILLARD ST	3	186	
2020 - 2023	112-284 WINCHESTER ST, NEW	12	2,990	
2020 - 2023	WISWALL ST	3	215	
2020 - 2023	WOODBINE ST	3	508	
2021 - 2024	2-66 ALEXANDER RD, NEW, & 67-142 WATCH HILL RD	5	1,965	
2021 - 2024	BACON ST	3	378	
2021 - 2024	631-731 BEACON ST, NEW, & 11-15 COUSENS CIR	4	1,625	
2021 - 2024	BELLEVUE RD	3	254	
2021 - 2024	BELLEVUE ST	3	492	
2021 - 2024	BOWERS ST	3	617	
2021 - 2024	BOYD ST	3	214	
2021 - 2024	347-407 CENTRAL ST, NEW	6	730	
2021 - 2024	CHASE ST	3	876	
2021 - 2024	CHERRY ST	3	51	
2021 - 2024	CHESLEY AV	3	185	
2021 - 2024	CHESTER ST	3	405	
2021 - 2024	COLUMBUS ST	3	613	
2021 - 2024	COPLEY ST	3	482	
2021 - 2024	COURT ST	3	95	
2021 - 2024	CRESCENT AV	3	712	
2021 - 2024	CRYSTAL ST	3	344	
2021 - 2024	DUNCKLEE ST	3	255	
2021 - 2024	EDINBORO CIR	3	131	
2021 - 2024	ERIE AV	3	219	
2021 - 2024	FAIR OAKS AV	3	661	
2021 - 2024	FAIRMONT AV	3	571	
2021 - 2024	FOREST AV	3	95	
2021 - 2024	FOREST ST	3	795	
2021 - 2024	GRASMERE ST	3	204	
2021 - 2024	GREENWOOD AV	3	124	
2021 - 2024	HANCOCK ST	3	745	
2021 - 2024	HIGHLAND AV	3	435	
2021 - 2024	HIGHLAND PK	3	248	

Table L2 Newton GSEP plans				
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028 and 2026-2029				
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity
2021 - 2024	HILLSIDE RD	3	31	
2021 - 2024	HOLLIS ST	3	257	
2021 - 2024	HUNTER ST	3	276	
2021 - 2024	HYDE ST	3	132	
2021 - 2024	4-49 JASSET ST, NEW	4	610	
2021 - 2024	JEWETT ST	3	229	
2021 - 2024	79-143 LANGDON ST, NEW, & 4-35 LAUDHOLM RD	4	2,065	
2021 - 2024	LENOX ST	3	631	
2021 - 2024	LOWELL AV	3	955	
2021 - 2024	LYMAN ST	3	340	
2021 - 2024	MELROSE ST	3	340	
2021 - 2024	MORELAND AV	3	225	
2021 - 2024	17-117 MOULTON ST, NEW, & 1-15 COLGATE CIR	6	1,930	
2021 - 2024	OLD ROGERS ST	3	275	
2021 - 2024	PAUL ST	3	508	
2021 - 2024	PEARL ST	3	369	
2021 - 2024	PERKINS ST	3	83	
2021 - 2024	PLEASANT ST	3	86	
2021 - 2024	PRESCOTT ST	3	275	
2021 - 2024	PROSPECT ST	3	818	
2021 - 2024	PUTNAM ST	3	697	
2021 - 2024	9-34 RICKER RD, NEW, & 11-20 RICKER TER	6	630	
2021 - 2024	RIVER ST	3	82	
2021 - 2024	42-51 ROCKLAND ST, NEW	8	245	
2021 - 2024	RUSSELL CT	3	310	
2021 - 2024	SHAW ST	3	457	
2021 - 2024	STANDISH ST	3	345	
2021 - 2024	STERLING ST	3	152	
2021 - 2024	SUMNER ST	3	419	
2021 - 2024	TEMPLE ST	3	184	
2021 - 2024	UNDERWOOD AV	3	234	
2021 - 2024	WABAN PK	3	1,140	
2021 - 2024	WABAN ST	3	873	
2021 - 2024	WALKER ST	3	576	
2021 - 2024	WALNUT PK	3	1,217	
2021 - 2024	406-506 WALNUT ST, NEW	12	1,440	
2021 - 2024	WASHINGTON PK	3	911	
2021 - 2024	337-647 WASHINGTON ST, NEW	10	3,300	
2021 - 2024	WEBSTER CT	3	25	
2021 - 2024	WILLARD ST	3	186	
2021 - 2024	112-284 WINCHESTER ST, NEW	12	2,990	
2021 - 2024	WISWALL ST	3	215	
2021 - 2024	WOODBINE ST	3	508	
2022 - 2025	ALDEN ST	4	288	
2022 - 2025	2 - 66 ALEXANDER RD and 67 - 142 WALNUT HILL RD	5	1,965	
2022 - 2025	9 - 28 ARDMORE RD and 7 - 14 ARDMORE TER	4	630	
2022 - 2025	631 - 731 BEACON ST and 11 - 15 COUSENS CIR	4	1,625	
2022 - 2025	14 - 63 BOWDOIN ST and 60 - 93 FOREST ST	3	1,290	
2022 - 2025	491 - 565 BOYLSTON ST, DUXBURY RD and LANTERN LN	4	3,635	
2022 - 2025	11 - 56 CARLETON ST	4	820	

Table L2 Newton GSEP plans				
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028 and 2026-2029				
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity
2022 - 2025	347 - 407 CENTRAL ST	6	730	
2022 - 2025	12 - 74 COTTAGE ST, COLUMBIA AVE NUF and CHAMPA ST	4	1,675	
2022 - 2025	9 - 85 CUMMINGS RD and 15 - 92 NORTH ST CTR	4	2,325	
2022 - 2025	14 - 100 ERIE AVE, BOWDOIN ST and HARTFORD ST	4	2,580	
2022 - 2025	33 - 59 GAY ST, FREDERICK ST, HARVARD ST and HARVARD CIR	6	2,895	
2022 - 2025	141 - 192 GROVE ST and MYRTLE AVE	8	1,000	
2022 - 2025	48 - 139 HIGH ST NUF, SUMMER ST and ROCKLAND PL	4	2,485	
2022 - 2025	4 - 49 JASSET ST	4	610	
2022 - 2025	21 - 203 LAKE AVE CTR and LAKE TER	5	2,725	
2022 - 2025	79 - 143 LANGDON ST and 4 - 35 LAUDHOLM RD	4	2,065	
2022 - 2025	256 - 360 LOWELL AVE and 88 - 120 OTIS ST	12	1,875	
2022 - 2025	75 - 171 LOWELL AVE	3	1,535	
2022 - 2025	15 - 56 MOODY ST and 250 HAMMOND POND PKWY	4	780	
2022 - 2025	17 - 117 MOULTON ST and 1 - 15 COLGATE CIR	6	1,930	
2022 - 2025	5 - 90 OLDE FIELD RD, HAGEN RD, PHILBRICK RD and SHELDON RD	2	4,190	
2022 - 2025	9 - 34 RICKER RD and 11 - 20 RICKER TER	6	630	
2022 - 2025	42 - 51 ROCKLAND ST HGH	8	245	
2022 - 2025	337 - 647 WASHINGTON ST	10	3,300	
2022 - 2025	821 - 1251 WASHINGTON ST, DUNSTAN ST, KEMPTON PL and ARMORY ST	10	6,685	
2022 - 2025	112 - 284 WINCHESTER ST	12	2,990	
2023 - 2026	2 - 66 ALEXANDER RD and 67 - 142 WALNUT HILL RD	5	1,965	
2023 - 2026	9 - 28 ARDMORE RD and 7 - 14 ARDMORE TER	4	630	
2023 - 2026	2 - 112 ATHELSTANE RD	6	3,770	
2023 - 2026	150 - 257 AUBURN ST and CENTRAL ST and AUBURN ST	8	2,370	
2023 - 2026	18 - 109 AUBURN ST and CURVE ST	4	1,365	
2023 - 2026	112 - 205 AUBURNDALE AVE	6	3,490	
2023 - 2026	2 - 112 AUBURNDALE AVE, RYAN CT and REBECCA RD	6	1,710	
2023 - 2026	248 - 355 AUBURNDALE AVE	6	3,490	
2023 - 2026	1038 - 1150 BEACON ST	10	2,085	
2023 - 2026	825 - 1013 BEACON ST and LAUREL ST	8	3,365	
2023 - 2026	992 - 1050 BEACON ST, ALBION PL and NEWBURY TER	6	2,275	
2023 - 2026	491 - 565 BOYLSTON ST, DUXBURY RD and LANTERN LN	4	3,635	
2023 - 2026	1 - 73 CANTERBURY RD	8	2,400	
2023 - 2026	11 - 56 CARLETON ST	4	820	
2023 - 2026	347 - 407 CENTRAL ST	6	730	
2023 - 2026	1404 - 1542 CENTRE ST	10	3,095	
2023 - 2026	430 - 497 CENTRE ST and MOUNT IDA ST	10	3,150	
2023 - 2026	930 - 1055 CENTRE ST	10	3,570	
2023 - 2026	1 - 22 CHAMBERLAIN RD	6	3,490	
2023 - 2026	32 - 160 CHERRY ST	6	3,020	
2023 - 2026	1 - 68 COLLEGE RD	12	3,445	
2023 - 2026	1063 - 1125 COMMONWEALTH AVE, LOWELL AVE from COMMONWEALTH AVE to WHITTIER RD and WHITTIER RD	8	1,975	
2023 - 2026	12 - 74 COTTAGE ST, THURSTON RD and CHAMPA ST	4	3,205	
2023 - 2026	9 - 85 CUMMINGS RD and 15 - 92 NORTH ST CTR	4	2,325	
2023 - 2026	9 - 305 CYPRESS ST	6	3,855	
2023 - 2026	8 - 160 DAY ST	6	3,910	

Table L2 Newton GSEP plans				
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028 and 2026-2029				
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity
2023 - 2026	1 - 120 DEVONSHIRE RD	6	3,670	
2023 - 2026	14 - 100 ERIE AVE, BOWDOIN ST and HARTFORD ST	4	2,580	
2023 - 2026	108 - 229 FULLER ST WAB	10	3,780	
2023 - 2026	242 - 326 FULLER ST WAB	10	3,790	
2023 - 2026	32 - 114 GREENLAWN AVE	6	1,770	
2023 - 2026	1 - 125 GROVE ST	8	3,085	
2023 - 2026	141 - 192 GROVE ST and MYRTLE AVE	8	1,000	
2023 - 2026	240 - 450 HAMMOND ST, RESERVOIR AVE and WOODMAN RD	8	2,990	
2023 - 2026	48 - 139 HIGH ST NUF, SUMMER ST and ROCKLAND PL	4	2,485	
2023 - 2026	50 - 180 HIGHLAND ST	6	3,185	
2023 - 2026	230 - 308 HOMER ST and GARLAND RD	8	2,000	
2023 - 2026	374 - 430 HOMER ST and 1095 - 1125 COMMONWEALTH AVE	12	1,775	
2023 - 2026	6 - 150 ISLINGTON RD	6	2,210	
2023 - 2026	4 - 49 JASSET ST	4	610	
2023 - 2026	79 - 143 LANGDON ST and 4 - 35 LAUDHOLM RD	4	2,065	
2023 - 2026	256 - 360 LOWELL AVE and 88 - 120 OTIS ST	12	1,895	
2023 - 2026	75 - 171 LOWELL AVE	3	1,535	
2023 - 2026	15 - 56 MOODY ST and 250 HAMMOND POND PKWY	4	780	
2023 - 2026	158 - 255 NEWTONVILLE AVE	8	2,780	
2023 - 2026	97 - 200 OAK ST	12	2,160	
2023 - 2026	5 - 90 OLDE FIELD RD, HAGEN RD, PHILBRICK RD and SHELDON RD	2	4,190	
2023 - 2026	1 - 35 OWATONNA ST and KAPOsia ST	6	3,515	
2023 - 2026	3 - 76 PARK LN, TARLETON RD and CHAPIN RD	6	4,325	
2023 - 2026	1 - 75 PELHAM ST and LANGLEY RD and PELHAM ST	10	2,295	
2023 - 2026	17 - 78 PLAINFIELD ST and UPLAND RD WAB	6	1,620	
2023 - 2026	4 - 118 PRINCE ST	4	3,880	
2023 - 2026	110 - 128 PROSPECT ST and 5 - 39 TENNYSON RD	3	940	
2023 - 2026	225 - 293 RIVER ST	8	3,520	
2023 - 2026	42 - 51 ROCKLAND ST HGH	8	245	
2023 - 2026	1 - 98 ROWENA RD	8	3,475	
2023 - 2026	4 - 52 SHAW ST	6	3,300	
2023 - 2026	10 - 203 SPIERS RD, ANTONELLIS CIR and J ROADWAY	8	5,800	
2023 - 2026	5 - 90 SUFFOLK RD	8	1,395	
2023 - 2026	4 - 50 SUMNER ST	4	2,145	
2023 - 2026	34 - 64 WABAN AVE	8	2,660	
2023 - 2026	7 - 80 WADE ST	6	1,020	
2023 - 2026	406 - 506 WALNUT ST	12	1,440	
2023 - 2026	337 - 647 WASHINGTON ST	10	3,300	
2023 - 2026	821 - 1251 WASHINGTON ST, DUNSTAN ST, KEMPTON PL and ARMORY ST	10	6,685	
2023 - 2026	229 - 429 WATERTOWN ST	6	2,910	
2023 - 2026	112 - 284 WINCHESTER ST	12	2,990	
2023 - 2026	7 - 154 WOODCHESTER DR	8	3,110	
2023 - 2026	107 - 230 WOODWARD ST and MAYFLOWER TER	8	3,515	
2024 - 2027	2 - 66 ALEXANDER RD and 67 - 142 WALNUT HILL RD	5	1,965	
2024 - 2027	112 - 205 AUBURNDALe AVE	6	4,010	
2024 - 2027	2 - 112 AUBURNDALe AVE, RYAN CT and REBECCA RD	6	1,710	
2024 - 2027	248 - 355 AUBURNDALe AVE	6	3,490	

Table L2 Newton GSEP plans				
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028 and 2026-2029				
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity
2024 - 2027	1038 - 1150 BEACON ST	10	2,085	
2024 - 2027	1665 - 1791 BEACON ST	12	3,410	
2024 - 2027	7 - 61 BRUSH HILL RD	6	3,550	
2024 - 2027	1 - 73 CANTERBURY RD	8	2,400	
2024 - 2027	11 - 56 CARLETON ST	4	820	
2024 - 2027	347 - 407 CENTRAL ST	6	730	
2024 - 2027	1404 - 1542 CENTRE ST	10	4,445	
2024 - 2027	430 - 497 CENTRE ST and MOUNT IDA ST	6	2,770	
2024 - 2027	885 - 1055 CENTRE ST, WARD ST and CENTRE ST and NATHAN RD	12	4,245	
2024 - 2027	1 - 22 CHAMBERLAIN RD	6	3,490	
2024 - 2027	1 - 68 COLLEGE RD	12	3,445	
2024 - 2027	9 - 305 CYPRESS ST	6	2,955	
2024 - 2027	8 - 160 DAY ST	6	3,910	
2024 - 2027	1 - 120 DEVONSHIRE RD	6	3,670	
2024 - 2027	1 - 71 DUNCKLEE ST	6	1,265	
2024 - 2027	144 - 251 ELLIOT ST and MECHANIC ST	12	4,185	
2024 - 2027	3 - 144 ELLIOT ST	10	2,315	
2024 - 2027	14 - 100 ERIE AVE, BOWDOIN ST and HARTFORD ST	4	2,580	
2024 - 2027	108 - 229 FULLER ST WAB	10	3,780	
2024 - 2027	242 - 326 FULLER ST WAB	10	3,770	
2024 - 2027	32 - 114 GREENLAWN AVE	6	1,770	
2024 - 2027	240 - 450 HAMMOND ST, RESERVOIR AVE and WOODMAN RD	8	3,000	
2024 - 2027	50 - 180 HIGHLAND ST	6	3,185	
2024 - 2027	10 - 114 HILLSIDE AVE	6	1,045	
2024 - 2027	230 - 308 HOMER ST and GARLAND RD	8	2,000	
2024 - 2027	308 - 374 HOMER ST and WALNUT ST and HOMER ST	12	725	
2024 - 2027	4 - 49 JASSET ST	4	610	
2024 - 2027	79 - 143 LANGDON ST and 4 - 35 LAUDHOLM RD	4	2,065	
2024 - 2027	1 - 99 LENOX ST	6	3,849	
2024 - 2027	158 - 255 NEWTONVILLE AVE	8	3,640	
2024 - 2027	100 - 200 OAK ST	12	2,160	
2024 - 2027	5 - 90 OLDE FIELD RD, HAGEN RD, PHILBRICK RD and SHELDON RD	2	4,190	
2024 - 2027	3 - 76 PARK LN, TARLETON RD and CHAPIN RD	6	4,325	
2024 - 2027	17 - 78 PLAINFIELD ST and UPLAND RD WAB	6	1,620	
2024 - 2027	1 - 180 PLYMOUTH RD	6	6,240	
2024 - 2027	4 - 118 PRINCE ST	4	4,405	
2024 - 2027	42 - 51 ROCKLAND ST HGH	8	245	
2024 - 2027	1 - 98 ROWENA RD	8	3,900	
2024 - 2027	4 - 52 SHAW ST	6	3,300	
2024 - 2027	10 - 203 SPIERS RD, ANTONELLIS CIR and J ROADWAY	8	5,800	
2024 - 2027	5 - 90 SUFFOLK RD	8	1,395	
2024 - 2027	4 - 50 SUMNER ST	4	2,145	
2024 - 2027	34 - 64 WABAN AVE	8	2,660	
2024 - 2027	1080 - 1136 WALNUT ST and COLUMBUS ST	12	4,185	
2024 - 2027	2251 - 2362 WASHINGTON ST	12	1,770	
2024 - 2027	337 - 647 WASHINGTON ST	10	3,300	
2024 - 2027	229 - 429 WATERTOWN ST	6	3,280	
2024 - 2027	111 - 279 WEBSTER ST	8	2,570	

Table L2 Newton GSEP plans				
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028 and 2026-2029				
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity
2024 - 2027	112 - 284 WINCHESTER ST	12	2,990	
2024 - 2027	7 - 154 WOODCHESTER DR	8	3,170	
2024 - 2027	107 - 230 WOODWARD ST and MAYFLOWER TER	8	3,515	
2025 - 2028	2 - 112 ATHELSTANE RD	6	2,530	
2025 - 2028	150 - 257 AUBURN ST and CENTRAL ST and AUBURN ST	8	2,370	
2025 - 2028	2 - 112 AUBURNDALE AVE, RYAN CT and REBECCA RD	6	1,710	
2025 - 2028	1038 - 1150 BEACON ST	10	2,200	
2025 - 2028	1665 - 1791 BEACON ST	12	3,410	
2025 - 2028	805 - 991 BEACON ST and LAUREL ST	8	3,465	
2025 - 2028	96 - 342 BEACON ST	12	3,015	
2025 - 2028	992 - 1050 BEACON ST	8	2,175	
2025 - 2028	616 - 692 BOYLSTON ST and 5 - 16 WALNUT HILL RD	6	1,250	
2025 - 2028	8 - 150 CEDAR ST	8	3,500	
2025 - 2028	430 - 497 CENTRE ST and MOUNT IDA ST	6	2,770	
2025 - 2028	885 - 1055 CENTRE ST, WARD ST and CENTRE ST and NATHAN RD	12	4,245	
2025 - 2028	32 - 160 CHERRY ST	6	3,450	
2025 - 2028	50 - 275 CONCORD ST	6	3,915	
2025 - 2028	23 - 88 ELINOR RD	6	1,380	
2025 - 2028	144 - 251 ELLIOT ST and MECHANIC ST	12	4,255	
2025 - 2028	1 - 113 GROVE ST	8	3,055	
2025 - 2028	240 - 450 HAMMOND ST, RESERVOIR AVE and WOODMAN RD	8	3,000	
2025 - 2028	1 - 134 HANSON RD	4	3,900	
2025 - 2028	308 - 374 HOMER ST and WALNUT ST and HOMER ST	12	725	
2025 - 2028	100 - 200 OAK ST	12	2,160	
2025 - 2028	5 - 100 OLDE FIELD RD, HAGEN RD, PHILBRICK RD and SHELDON RD	4	4,280	
2025 - 2028	3 - 76 PARK LN, TARLETON RD and CHAPIN RD	6	4,325	
2025 - 2028	1 - 124 PARKER AVE	8	3,925	
2025 - 2028	225 - 293 RIVER ST	8	3,770	
2025 - 2028	85 - 240 VALENTINE ST	8	2,480	
2025 - 2028	1136 - 1208 WALNUT ST and HYDE ST	10	3,340	
2025 - 2028	1750 - 1940 WASHINGTON ST and SETON HILL RD	10	4,815	
2025 - 2028	2251 - 2362 WASHINGTON ST	12	1,770	
2025 - 2028	821 - 1251 WASHINGTON ST, DUNSTAN ST, KEMPTON PL and ARMORY ST	10	6,685	
2025 - 2028	229 - 429 WATERTOWN ST	6	3,280	
2025 - 2028	107 - 230 WOODWARD ST and MAYFLOWER TER	8	3,515	
2026 - 2029	9-305 CYPRESS ST, NEW	6	2,955	No - Critical Main
2026 - 2029	96-342 BEACON ST, NEW	12	3,015	No - Critical Main
2026 - 2029	1038-1150 BEACON ST, NEW	10	2,200	No - Impact to System Integration
2026 - 2029	1046-1267 CENTRE ST, NEW, PELHAM ST, LANGLEY RD	10	5,750	No - Impact to System Integration
2026 - 2029	1-124 PARKER AV, NEW	8	3,925	No - Impact to System Integration
2026 - 2029	1-18 BACON ST, NEW	4	380	No - Impact to System Integration
2026 - 2029	150-257 AUBURN ST, NEW, CENTRAL ST	8	2,370	No - Impact to System Integration
2026 - 2029	1-67 CHASE ST, NEW	8	2,465	No - Impact to System Integration
2026 - 2029	2-112 ATHELSTANE RD, NEW	6	2,530	No - Impact to System Integration
2026 - 2029	2251-2362 WASHINGTON ST, NEW	12	1,770	No - Impact to System Integration
2026 - 2029	225-293 RIVER ST, NEW	8	3,770	No - Impact to System Integration
2026 - 2029	229-429 WATERTOWN ST, NEW	6	3,280	No - Impact to System Integration

Table L2 Newton GSEP plans				
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028 and 2026-2029				
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity
2026 - 2029	240-450 HAMMOND ST, NEW, RESERVOIR AV, WOODMAN RD	8	3,000	No - Impact to System Integration
2026 - 2029	406-506 WALNUT ST, NEW	12	1,450	No - Impact to System Integration
2026 - 2029	4-100 OAK ST, NEW	12	4,810	No - Impact to System Integration
2026 - 2029	50-275 CONCORD ST, NEW	6	3,915	No - Impact to System Integration
2026 - 2029	504-528 BOYLSTON ST, NEW	3	1,010	No - Impact to System Integration
2026 - 2029	8-150 CEDAR ST, NEW	8	3,500	No - Impact to System Integration
2026 - 2029	900-991 BEACON ST, NEW	8	2,500	No - Impact to System Integration
2026 - 2029	107-230 WOODWARD ST, NEW, MAYFLOWER TERR	8	3,515	Yes - Potential NPA
2026 - 2029	1080-1136 WALNUT ST, NEW, COLUMBUS ST	12	4,185	Yes - Potential NPA
2026 - 2029	1-35 OWATONNA ST, NEW, KAPOSIA ST	6	3,515	Yes - Potential NPA
2026 - 2029	1-73 CANTERBURY RD, NEW	8	3,310	Yes - Potential NPA
2026 - 2029	26-188 CHERRY ST, NEW	8	3,800	Yes - Potential NPA
2026 - 2029	4-248 WINDSOR RD, NEW	8	4,045	Yes - Potential NPA
2026 - 2029	11-56 CARLETON ST, NEW	4	820	Yes - Potential NPA, entire scope
2026 - 2029	15-56 MOODY ST, NEW, & 250 HAMMOND POND PKWY	4	780	Yes - Potential NPA, entire scope
2026 - 2029	100-200 OAK ST, NEW	12	2,160	Yes - Potential NPA, partial scope
2026 - 2029	112-284 WINCHESTER ST, NEW	12	2,990	Yes - Potential NPA, partial scope
2026 - 2029	1136-1208 WALNUT ST, NEW, HYDE ST	10	3,255	Yes - Potential NPA, partial scope
2026 - 2029	144-251 ELLIOT ST, NEW, MECHANIC ST	12	4,255	Yes - Potential NPA, partial scope
2026 - 2029	158-255 NEWTONVILLE AV, NEW	8	3,640	Yes - Potential NPA, partial scope
2026 - 2029	1750-1940 WASHINGTON ST, NEW, SETON HILL RD	10	4,815	Yes - Potential NPA, partial scope
2026 - 2029	1958-2150 WASHINGTON ST, NEW	10	5,000	Yes - Potential NPA, partial scope
2026 - 2029	347-407 CENTRAL ST, NEW	6	730	Yes - Potential NPA, partial scope
2026 - 2029	3-76 PARK LN, NEW, TARLETON RD, CHAPIN RD	6	4,325	Yes - Potential NPA, partial scope
2026 - 2029	430-497 CENTRE ST, NEW, MT IDA ST	6	4,070	Yes - Potential NPA, partial scope
2026 - 2029	5-100 OLDE FIELD RD, NEW, HAGEN,PHILBRICK,SHELDON	4	4,280	Yes - Potential NPA, partial scope
2026 - 2029	821-1251 WASHINGTON ST, NEW, DUNSTAN,KEMPTON,ARMOR	10	6,685	Yes - Potential NPA, partial scope
2026 - 2029	92-157 LANGLEY RD, NEW	8	1,275	Yes - Potential NPA, partial scope

Table L3 Pipe replacement projects charged to GSEP in 2024															
Work Order	"DESCRIPTION"	Included in Original List	Actual Project Cost through 12/31/2024	Prioritization Factor	Status as of 12/31/2024	Program ID	Project Approval Date	Project Start Date	Project Completion Date	2024 Project Costs Included in GSEP Filing	Earliest GSEP plan	Latest GSEP plan	Report Category (A-E)	Newton GOL docket	Actual installed footage
1421113	2-112 Auburndale Av, New, Ryan Ct & Rebecca Rd	ADDED	\$800,976	20.1	Completed project added to plan based on permit and resource availability	CIMNRPL<10	7/14/2022	2/27/2024	5/16/2024	\$800,976	2023-6 lookahead	2025-8 lookahead	B	none	1860
1421288	18-109 Auburn St, New, Curve St	YES	\$904,373	20.1	Completed project in CY24 as planned	CIMNRPL<10	8/21/2023	5/29/2024	10/29/2024	\$881,311	2023-6 lookahead	2024 plan	A	none	1412
1451928	2148-2261 Commonwealth Av, New	ADDED	\$3,171,609		Completed project - Public Works	PWNONREIM	4/6/2023	1/2/2024	12/20/2024	\$3,043,360			E	#429-22	3014
1454321	1665-1791 Beacon St, New	ADDED	\$2,585,623	33.5	Completed project added to plan as pre-pave opportunity	CIRE101214	1/3/2023	1/2/2024	10/9/2024	\$2,559,089	2024-7 lookahead	2025-8 lookahead	B	none	3555
1457999	595-687 Watertown St, New	ADDED	\$3,370,266	24.5	Completed project added to plan as pre-pave opportunity	CIMNRPL<10	9/30/2022	7/24/2023	5/24/2024	\$3,177,134		2023 plan	B	none	4675
1466220	15-154 Algonquin Rd, New	ADDED	\$901,974		Completed project - Public Works	PWNONREIM	7/7/2022	1/17/2024	5/23/2024	\$901,974			E	none	1732
1476454	10-114 Hillside Av, New	YES	\$669,190	24.0	Completed project in CY24 as planned	CIMNRPL<10	1/20/2023	5/13/2024	9/30/2024	\$665,780	2024-7 lookahead	2024 plan	A	none	1070
1483734	85-240 Valentine St, New	ADDED	\$1,704,047	13.1	Completed project added to plan as pre-pave opportunity	CIMNRPL<10	6/22/2023	12/4/2023	7/29/2024	\$1,703,729	2025-8 lookahead	2024 lookahead	B	#128-23	2630
1512179	23-88 Elinor Rd, New	ADDED	\$809,979	18.0	Completed project added to plan based on permit and resource availability	BSMNRPL	3/17/2024	5/21/2024	9/30/2024	\$797,966	2025-8 lookahead	2025-8 lookahead	B	none	1415
1515480	504-528 Boylston St, New	ADDED	\$139,234	12.4	Completed project added to plan as pre-pave opportunity	BSMNRPL	9/26/2024	10/23/2024	12/20/2024	\$118,402			D	none	1010
1589951	4 Meredith Ave, New	ADDED	\$26,956		Completed project - Public Works Encroachment	ENCRCHMTPL	4/12/2024	5/23/2024	5/23/2024	\$26,956			C	none	52

Table L3 Pipe replacement projects charged to GSEP in 2024															
Work Order	“DESCRIPTION”	Included in Original List	Actual Project Cost through 12/31/2024	Prioritization Factor	Status as of 12/31/2024	Program ID	Project Approval Date	Project Start Date	Project Completion Date	2024 Project Costs Included in GSEP Filing	Earliest GSEP plan	Latest GSEP plan	Report Category (A-E)	Newton GOL docket	Actual installed footage
1590534	1-49 Jasset St, New	ADDED	\$113,864		Completed project - Public Works Encroachment	ENCRCHMTUM	4/16/2024	9/23/2024	12/20/2024	\$107,669	2020-3 lookahead	2024-7 lookahead	B	none	650
1596193	60 Dwhinda Rd, New	ADDED	\$21,156		Completed project - Public Works Encroachment	ENCRCHMTPL	5/28/2024	7/24/2024	7/26/2024	\$20,410			C	none	52
1596797	103 Collins Rd, New	ADDED	\$70,075		Completed project - Public Works Encroachment	ENCRCHMTPL	6/12/2024	7/29/2024	8/10/2024	\$70,075			C	none	52
1605852	1-14 Bacon Rd, New	ADDED	\$81,674		Completed project - Public Works	PWNONREIM	9/20/2024	11/8/2024	11/26/2024	\$77,776			E	none	190
	Total cost		\$15,370,997									Total footage			23,369
												Average cost per foot			\$658

Table L4 Leaks at Pipe Replacement Sites												
Leak ID	DESCRIPTION	Grade	Leak Extent at time of repair (sq. ft.)	Historical Maximum Leak Extent	Program ID	Leak Classification Date	Leak Repair Date	Project Start Date	Project Completion Date	Work Order	Relation to Replacement	Ngrid Listed repaired by replacement
	2-112 Auburndale Av, New, Ryan Ct & Rebecca Rd				CIMNRPL<10			02/27/2024	05/16/2024	1421113		
7387407	112 Auburndale Av.	1				5/10/2024	5/10/2024				appeared during replacement	
7387993	Auburndale Av. and Harold Ter.	3				05/31/2024	7/23/2024				appeared after replacement	X
	18-109 Auburn St, New, Curve St				CIMNRPL<10			05/29/2024	10/29/2024	1421288		
4788513	22 Auburn St.	3	200	1,575		7/9/2015	10/17/2024				eliminated by other leak repair	
7339913	58 Auburn St.	3	180	216		11/15/2017	12/3/2024				eliminated by replacement	X
7388577	Gilbert St. and Auburn St.	1				7/19/2024	7/19/2024				appeared during replacement	
7389793	Curve St. and Auburn St.	1				9/25/2024	9/25/2024				appeared during replacement	
	2148-2261 Commonwealth Av, New				PWNONREIM			01/02/2024	12/20/2024	1451928		
7387243	2240 Commonwealth Av.	1				5/3/2024	5/6/2024				appeared during replacement	
	1665-1791 Beacon St, New				CIRE101214			01/02/2024	10/09/2024	1454321		
270388	50 Dorset Road	3	375	3,600		4/29/2004					not eliminated	
7336460	1746 Beacon St.	3	900	4,278		7/19/2017	10/10/2024				eliminated by replacement	X
	1802 Beacon St.	3		5,610		12/22/2024					appeared after replacement	
7365118	10 Locke Rd.	3				9/24/2020					not eliminated	
	595-687 Watertown St, New				CIMNRPL<10			07/24/2023	05/24/2024	1457999		
7385439	384 Linwood Av.	2				1/3/2024	2/21/2024				appeared during replacement	
7387253	665 Watertown St.	1				5/4/2024	5/8/2024				duplicate leak	
7387254	665 Watertown St.	1				5/4/2024	5/4/2024				appeared during replacement	
7392954	687 Watertown St.	3		5,092		3/9/2025	4/25/2025				appeared after replacement	
	15-154 Algonquin Rd, New				PWNONREIM			01/17/2024	05/23/2024	1466220		
	10-114 Hillside Av, New				CIMNRPL<10			05/13/2024	09/30/2024	1476454		
7375160	65 Hillside Av.	3	450	1,400		5/17/2022	6/26/2024				upgraded	
7375160	65 Hillside Av.	2				6/26/2024	10/1/2024				eliminated by replacement	X
	85-240 Valentine St, New				CIMNRPL<10			12/04/2023	07/29/2024	1483734		

Table L4 Leaks at Pipe Replacement Sites												
Leak ID	DESCRIPTION	Grade	Leak Extent at time of repair (sq. ft.)	Historical Maximum Leak Extent	Program ID	Leak Classification Date	Leak Repair Date	Project Start Date	Project Completion Date	Work Order	Relation to Replacement	Ngrid Listed repaired by replacement
338429	30 Ellis Road	3	2,132	2,132		10/13/2010	8/7/2024				eliminated by replacement	
7349893	240 Valentine St.	3	45	1,680		12/17/2018	8/8/2024				eliminated by replacement	X
7356133	151 Valentine St.	3	100	525		8/6/2019	8/8/2024				eliminated by replacement	X
7387874	100 Valentine St.	2				5/3/2024	7/24/2024				appeared during replacement	X
7392769	56 Valentine St.	1				3/10/2025	3/11/2025				appeared after replacement	
	23-88 Elinor Rd, New				BSMNRPL			05/21/2024	09/30/2024	1512179		
338427	65 Elinor Rd.	3	407	1,575		10/9/2010	10/8/2024				eliminated by replacement	X
	504-528 Boylston St, New				BSMNRPL			10/23/2024	12/20/2024	1515480		
7386574	528 Boylston St.	2				3/3/2024	5/16/2024				eliminated through #7387484	
7387484	528 Boylston St.	1				5/14/2024	5/21/2024				eliminated before replacement	
	4 Meredith Ave, New				ENCRCHMTPL			05/23/2024	05/23/2024	1589951		
7386433	4 Meredith Ave.	1				3/19/2024	3/20/2024				eliminated before replacement	
	1-49 Jasset St, New				ENCRCHMTUM			09/23/2024	12/20/2024	1590534		
7385399	21 Jasset St.	1				1/15/2024	1/16/2024				eliminated before replacement	
	60 Dwhinda Rd, New				ENCRCHMTPL			07/24/2024	07/26/2024	1596193		
7387378	60 Dwhinda Rd.	1				5/9/2024	5/9/2024				eliminated before replacement	
	103 Collins Rd, New				ENCRCHMTPL			07/29/2024	08/10/2024	1596797		
7387878	103 Collins Rd.	3	4,320	4,320		5/13/2024	8/15/2024				eliminated by replacement	X
	1-14 Bacon Rd, New				PWNONREIM			11/08/2024	11/26/2024	1605852		
7365477	8 Bacon Rd.	3	3,000	3,000		11/9/2020					not eliminated	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location		Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificatio n)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name	Town/City							Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5866391	HAMMOND ST & COLLEGE RD	NEWTON	3	12/14/2015		Carried Forward	Pending		12/5/2023	25,000	Leak Extent	
7374847	1880 BEACON ST	NEWTON	3	5/2/2022	3/10/2023	Carried Forward	Repaired		5/2/2022	13,120	Leak Extent	
270315	144 ELLIOT ST	NEWTON	3	9/29/2003	1/10/2023	Carried Forward	Repaired		3/25/2022	13,000	Leak Extent	
7374844	1974 WASHINGTON ST	NEWTON	3	4/27/2022		Carried Forward	Pending		12/19/2023	11,016	Leak Extent	
305353	312 KENDRICK ST	NEWTON	3	8/29/2007	2/8/2023	Carried Forward	Repaired		8/3/2022	9,750	Leak Extent	
1065939	53 CHARLESBANK RD	NEWTON	3	8/30/2012		Carried Forward	Pending		8/31/2023	7,500	Leak Extent	
7355567	7 SUNSET RD	NEWTON	3	8/19/2019	2/22/2023	Carried Forward	Repaired		4/15/2022	6,710	Leak Extent	
7369309	129 DORSET RD	NEWTON	3	6/11/2021		Carried Forward	Pending		3/16/2023	6,500	Leak Extent	
7326636	NORTH ST & ALBEMARLE RD	NEWTON	3	6/13/2016		Carried Forward	Pending		7/18/2023	6,400	Leak Extent	
7379000	BEACON ST & OWAISA RD	NEWTON	3	12/17/2022		Carried Forward	Pending		9/26/2023	6,400	Leak Extent	
7364133	121 WINDSOR RD	NEWTON	3	7/30/2020	2/14/2023	Carried Forward	Repaired		6/14/2022	6,000	Leak Extent	
7375166	20 RUTHVEN RD	NEWTON	3	6/1/2022	3/1/2023	Carried Forward	Repaired		6/1/2022	5,640	Leak Extent	
7354710	103 COLLINS RD	NEWTON	3	7/19/2019	3/9/2023	Carried Forward	Repaired		3/1/2023	5,280	Leak Extent	
7325822	25 CORNELL ST	NEWTON	3	4/28/2016	2/9/2023	Carried Forward	Repaired		3/30/2022	5,123	Leak Extent	
6592025	142 GORDON RD	NEWTON	3	9/8/2015		Carried Forward	Pending		11/7/2023	5,040	Leak Extent	
270389	128 WOODWARD ST	NEWTON	3	4/27/2004		Carried Forward	Pending		7/18/2023	4,830	Leak Extent	
270681	131 COUNTRY CLUB RD	NEWTON	3	8/3/2004		Carried Forward	Pending		12/5/2023	4,560	Leak Extent	
5620596	832 DEDHAM ST	NEWTON	3	8/27/2015		Carried Forward	Pending		12/19/2023	4,550	Leak Extent	
7364122	STONELEIGH RD & DAVIS AVE	NEWTON	3	6/29/2020	2/16/2023	Carried Forward	Repaired		4/15/2022	4,503	Leak Extent	
7375100	7 AMHERST RD	NEWTON	3	4/5/2022	2/8/2023	Carried Forward	Repaired		4/5/2022	4,454	Leak Extent	
7355582	284 WOODWARD ST	NEWTON	3	8/19/2019		Carried Forward	Pending		3/9/2023	4,400	Leak Extent	
7356220	27 EVELYN RD	NEWTON	3	9/4/2019		Carried Forward	Pending		3/10/2023	4,200	Leak Extent	
7375169	78 FARLOW RD	NEWTON	3	6/1/2022	2/7/2023	Carried Forward	Repaired		6/1/2022	4,160	Leak Extent	
7383029	140 WINDERMERE RD	NEWTON	3	7/24/2023		Newly Identified	Pending		7/24/2023	4,050	Leak Extent	
7337028	100 CONCORD ST	NEWTON	3	8/1/2017		Carried Forward	Pending		11/14/2023	4,025	Leak Extent	
7380677	324 WINCHESTER ST	NEWTON	3	2/22/2023		Newly Identified	Pending		11/16/2023	3,875	Leak Extent	
7383027	26 PARKER ST	NEWTON	3	8/2/2023		Newly Identified	Pending		8/2/2023	3,750	Leak Extent	
7383508	HIGH ST & ELLIOT ST	NEWTON	3	8/14/2023		Newly Identified	Pending		8/14/2023	3,640	Leak Extent	
7360536	34 BEACON ST	NEWTON	3	5/29/2020	2/21/2023	Carried Forward	Repaired		4/11/2022	3,600	Leak Extent	
1363546	295 DUDLEY RD	NEWTON	3	9/19/2013		Carried Forward	Pending		12/19/2023	3,510	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
339664	33 TERRACE AVE	NEWTON	3	10/13/2015	11/13/2023	Carried Forward	Eliminated Otherwise		11/17/2023	3,456	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7326197	145 HIGHLAND ST	NEWTON	3	5/11/2016		Carried Forward	Pending		6/23/2023	3,420	Leak Extent	
7374855	23 FOREST AVE	NEWTON	3	5/12/2022	2/25/2023	Carried Forward	Repaired		5/12/2022	3,420	Leak Extent	
7326619	26 PARKER ST	NEWTON	3	6/10/2016	7/18/2023	Carried Forward	Eliminated Otherwise		7/18/2023	3,400	Leak Extent	NO READS
337228	DORSET RD & METACOMET R	NEWTON	3	8/19/2010		Carried Forward	Pending		11/16/2023	3,360	Leak Extent	
329877	39 HOLMAN RD	NEWTON	3	11/5/2009	2/9/2023	Carried Forward	Repaired		3/28/2022	3,201	Leak Extent	
7353513	23 HIGH ST	NEWTON	3	5/23/2019	3/9/2023	Carried Forward	Repaired		2/15/2023	3,168	Leak Extent	
7374850	145 WOODLAND RD	NEWTON	3	5/9/2022	2/10/2023	Carried Forward	Repaired		5/9/2022	3,150	Leak Extent	
7365084	DAVIS ST & HIGHLAND ST	NEWTON	3	9/23/2020	2/16/2023	Carried Forward	Repaired		7/27/2022	3,105	Leak Extent	
1282579	239 WOODLAND RD	NEWTON	3	6/28/2013		Carried Forward	Pending		3/9/2023	3,000	Leak Extent	
7374854	5 ANGIER CIR	NEWTON	3	5/11/2022		Carried Forward	Pending		12/20/2023	3,000	Leak Extent	
7378581	HAGAR ST & CONCORD ST	NEWTON	3	11/4/2022		Carried Forward	Pending		9/12/2023	2,750	Leak Extent	
7339371	110 AUSTIN ST	NEWTON	3	10/17/2017	2/15/2023	Carried Forward	Repaired		4/25/2022	2,700	Leak Extent	
7376707	200 DERBY ST	NEWTON	3	8/24/2022		Carried Forward	Pending		6/23/2023	2,550	Leak Extent	
7371382	212 CHESTNUT ST	NEWTON	3	10/9/2021		Carried Forward	Pending		6/23/2023	2,500	Leak Extent	
7375168	410 LEXINGTON ST	NEWTON	3	6/3/2022	9/28/2023	Carried Forward	Repaired		3/21/2023	2,500	Leak Extent	
7355432	65 SUFFOLK RD	NEWTON	3	7/24/2019	2/15/2023	Carried Forward	Repaired		1/22/2023	2,485	Leak Extent	
7375992	8 CLEARWATER RD	NEWTON	3	6/20/2022	2/7/2023	Carried Forward	Repaired		6/20/2022	2,420	Leak Extent	
7356438	741 SAWMILL BROOK PKY	NEWTON	3	9/26/2019		Carried Forward	Pending		4/25/2023	2,400	Leak Extent	
7375165	49 GROVE ST	NEWTON	3	5/27/2022		Carried Forward	Pending		3/21/2023	2,400	Leak Extent	
5338221	WABAN AVE & ANNAWAN RD	NEWTON	3	7/10/2015	2/15/2023	Carried Forward	Repaired		4/21/2022	2,250	Leak Extent	
1593092	1629 BEACON ST	NEWTON	3	2/19/2014		Carried Forward	Pending		12/19/2023	2,200	Leak Extent	
7356517	6 RESERVOIR AVE	NEWTON	3	9/12/2019	2/22/2023	Carried Forward	Repaired		4/28/2022	2,184	Leak Extent	
338429	30 ELLIS RD	NEWTON	3	10/13/2010		Carried Forward	Pending		11/17/2023	2,132	Leak Extent	
7327564	367 ALBEMARLE RD	NEWTON	3	6/24/2016	3/3/2023	Carried Forward	Eliminated by Replacemen		1/18/2023	2,100	Leak Extent	
7375163	303 HARTMAN RD	NEWTON	3	5/25/2022	3/6/2023	Carried Forward	Repaired		5/25/2022	2,058	Leak Extent	
7364131	28 WADE ST	NEWTON	3	7/16/2020	2/21/2023	Carried Forward	Repaired		4/21/2022	2,040	Leak Extent	
7379849	249 CYPRESS ST	NEWTON	3	2/16/2023		Newly Identified	Pending		11/13/2023	2,025	Leak Extent	
4339243	130 BEACON ST	NEWTON	3	6/4/2015		Carried Forward	Pending		12/19/2023	2,016	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location		Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificatio n)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name	Town/City							Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7323097	14 ROKEBY RD	NEWTON	3	1/14/2016		Carried Forward	Pending		11/13/2023	2,000	Leak Extent	
7343321	15 G ROADWAY	NEWTON	3	4/6/2018		Carried Forward	Pending		6/23/2023	2,000	Leak Extent	
7325803	640 GROVE ST	NEWTON	3	4/22/2016		Carried Forward	Pending		11/14/2023	1,922	Leak Extent	
7380675	MASSACHUSETTS TPKE & LOV	NEWTON	3	3/18/2023		Newly Identified	Pending		12/20/2023	1,840	Leak Extent	
7354944	942 BEACON ST	NEWTON	3	9/27/2022	12/5/2023	Carried Forward	Eliminated Otherwise		7/19/2023	1,820	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
303664	12 WOODBINE ST	NEWTON	3	4/18/2014	2/15/2023	Carried Forward	Repaired		2/14/2023	1,800	Leak Extent	
7336297	327 DEDHAM ST	NEWTON	3	7/12/2017		Carried Forward	Pending		11/17/2023	1,800	Leak Extent	
7371042	305 COMMONWEALTH AVE	NEWTON	3	10/6/2021		Carried Forward	Pending		6/23/2023	1,800	Leak Extent	
7324470	22 PURITAN RD	NEWTON	3	3/30/2016		Carried Forward	Pending		11/13/2023	1,750	Leak Extent	
7374848	299 WOODLAND RD	NEWTON	3	5/6/2022	12/4/2023	Carried Forward	Repaired		3/17/2023	1,750	Leak Extent	
1363304	321 HAMMOND ST	NEWTON	3	9/9/2013		Carried Forward	Pending		11/16/2023	1,739	Leak Extent	
7355561	117 NORTH ST	NEWTON	3	8/19/2019		Carried Forward	Pending		12/13/2023	1,725	Leak Extent	
7375162	33 OAK HILL ST	NEWTON	3	5/19/2022		Carried Forward	Pending		3/20/2023	1,680	Leak Extent	
329373	320 NEEDHAM ST	NEWTON	3	10/11/2009		Carried Forward	Pending		7/18/2023	1,600	Leak Extent	
7355556	205 MILL ST	NEWTON	3	8/22/2019		Carried Forward	Pending		12/13/2023	1,600	Leak Extent	
7370879	983 CENTRE ST	NEWTON	3	9/8/2021	12/4/2023	Carried Forward	Repaired		6/1/2023	1,600	Leak Extent	
7365115	1364 WALNUT ST	NEWTON	3	10/9/2020		Carried Forward	Pending		6/20/2023	1,584	Leak Extent	
3900011	18 ALDEN ST	NEWTON	3	4/24/2015		Carried Forward	Pending		11/16/2023	1,530	Leak Extent	
7378477	LOWELL AVE & WASHINGTON	NEWTON	3	12/1/2022		Carried Forward	Pending		9/15/2023	1,520	Leak Extent	
7338745	67 OAKCLIFF RD	NEWTON	3	9/27/2017		Carried Forward	Pending		12/12/2023	1,500	Leak Extent	
7354547	443 WOLCOTT ST	NEWTON	3	7/9/2019		Carried Forward	Pending		11/16/2023	1,500	Leak Extent	
7356154	104 VINE ST	NEWTON	3	9/4/2019	12/6/2023	Carried Forward	Eliminated Otherwise		3/10/2023	1,500	Leak Extent	NO READS
7383021	146 ALBEMARLE RD	NEWTON	3	8/4/2023		Newly Identified	Pending		8/4/2023	1,500	Leak Extent	
7325491	604 WALNUT ST	NEWTON	3	4/19/2016		Carried Forward	Pending		11/14/2023	1,452	Leak Extent	
6722106	400 WARD ST	NEWTON	3	9/28/2015	6/27/2023	Carried Forward	Eliminated Otherwise		2/15/2023	1,440	Leak Extent	DUPLICATE LEAK
7356372	569 SAWMILL BROOK PKY	NEWTON	3	9/25/2019		Carried Forward	Pending		4/24/2023	1,428	Leak Extent	
796835	11 VIRGINIA RD	NEWTON	3	2/6/2012		Carried Forward	Pending		12/19/2023	1,426	Leak Extent	
7356134	105 OSBORNE PATH	NEWTON	3	9/3/2019		Carried Forward	Pending		3/9/2023	1,400	Leak Extent	
332435	30 K ROADWAY	NEWTON	3	4/13/2010		Carried Forward	Pending		11/17/2023	1,395	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificatio n)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
6980988	83 CARVER RD	NEWTON	3	5/28/2019		Carried Forward	Pending		11/7/2023	1,392	Leak Extent	
1362684	131 WINDSOR RD	NEWTON	3	9/30/2013		Carried Forward	Pending		11/17/2023	1,363	Leak Extent	
7356347	40 JANE RD	NEWTON	3	9/25/2019		Carried Forward	Pending		12/20/2023	1,360	Leak Extent	
7375160	64 HILLSIDE AVE	NEWTON	3	5/17/2022		Carried Forward	Pending		3/20/2023	1,350	Leak Extent	
1337088	4 GAY ST	NEWTON	3	8/20/2013		Carried Forward	Pending		11/17/2023	1,326	Leak Extent	
7365119	110 WOODWARD ST	NEWTON	3	9/24/2020	3/7/2023	Carried Forward	Repaired		7/27/2022	1,232	Leak Extent	
7376774	232 DERBY ST	NEWTON	3	8/24/2022		Carried Forward	Pending		6/23/2023	1,225	Leak Extent	
7364130	109 CABOT ST	NEWTON	3	7/15/2020		Carried Forward	Pending		12/13/2023	1,200	Leak Extent	
7365477	8 BACON RD	NEWTON	3	11/9/2020		Carried Forward	Pending		6/28/2023	1,200	Leak Extent	
7325705	79 CHARLEMONT ST	NEWTON	3	4/15/2016	5/16/2023	Carried Forward	Eliminated Otherwise		2/21/2023	1,188	Leak Extent	NO READS
7354551	30 BERWICK RD	NEWTON	3	7/9/2019	3/6/2023	Carried Forward	Repaired		3/3/2023	1,178	Leak Extent	
1337305	108 WINDSOR RD	NEWTON	3	8/21/2013		Carried Forward	Pending		4/24/2023	1,140	Leak Extent	
7379850	54 DUXBURY RD	NEWTON	3	2/7/2023		Newly Identified	Pending		11/17/2023	1,140	Leak Extent	
7376321	137 GARLAND RD	NEWTON	3	7/29/2022		Carried Forward	Pending		5/24/2023	1,104	Leak Extent	
7375135	341 CABOT ST	NEWTON	3	5/23/2022		Carried Forward	Pending		3/20/2023	1,092	Leak Extent	
7327750	OAKLAND ST & CHURCH ST	NEWTON	3	6/2/2016		Carried Forward	Pending		7/18/2023	1,073	Leak Extent	
307752	176 WABAN AVE	NEWTON	3	11/7/2007		Carried Forward	Pending		7/19/2023	1,064	Leak Extent	
270598	16-25 BROADLAWN DR	NEWTON	3	7/27/2004		Carried Forward	Pending		9/13/2023	1,050	Leak Extent	
338734	6 SUN HILL LN	NEWTON	3	10/21/2010		Carried Forward	Pending		3/9/2023	1,050	Leak Extent	
7345014	7 CURTIS ST	NEWTON	3	11/29/2018		Carried Forward	Pending		3/20/2023	1,050	Leak Extent	
7375161	262 OTIS ST	NEWTON	3	5/18/2022		Carried Forward	Pending		3/20/2023	1,050	Leak Extent	
7325813	32 MELVILLE AVE	NEWTON	3	4/29/2016		Carried Forward	Pending		11/14/2023	1,000	Leak Extent	
7326889	89 WALTHAM ST	NEWTON	3	6/15/2016		Carried Forward	Pending		7/18/2023	1,000	Leak Extent	
7365118	10 LOCKE RD	NEWTON	3	9/24/2020		Carried Forward	Pending		5/12/2023	1,000	Leak Extent	
7379883	228 HIGHLAND AVE	NEWTON	3	2/28/2023		Newly Identified	Pending		11/17/2023	1,000	Leak Extent	
7383501	34 BROOKSIDE AVE	NEWTON	3	8/17/2023		Newly Identified	Pending		8/17/2023	957	Leak Extent	
1338973	5 CHANNING RD	NEWTON	3	8/30/2013		Carried Forward	Pending		12/19/2023	945	Leak Extent	
304745	4 JANET RD	NEWTON	3	8/23/2007		Carried Forward	Pending		12/13/2023	900	Leak Extent	
7324254	70 OAKDALE RD	NEWTON	3	3/27/2016		Carried Forward	Pending		11/13/2023	900	Leak Extent	
7336460	1746 BEACON ST	NEWTON	3	7/19/2017		Carried Forward	Pending		11/6/2023	900	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7376812	36 NEWELL RD	NEWTON	3	8/19/2022		Carried Forward	Pending		6/23/2023	900	Leak Extent	
7379880	31 FOX HILL RD	NEWTON	3	2/18/2023		Newly Identified	Pending		11/13/2023	900	Leak Extent	
7326621	116 OXFORD RD	NEWTON	3	6/10/2016		Carried Forward	Pending		7/19/2023	884	Leak Extent	
7335500	35 LLEWELLYN RD	NEWTON	3	6/13/2017		Carried Forward	Pending		11/14/2023	860	Leak Extent	
7353517	26 LINDEN ST	NEWTON	3	5/29/2019	2/22/2023	Carried Forward	Repaired		2/14/2023	840	Leak Extent	
7379274	1607 CENTRE ST	NEWTON	3	12/28/2022		Carried Forward	Pending		9/26/2023	832	Leak Extent	
7379917	1010 BOYLSTON ST	NEWTON	3	2/15/2023		Newly Identified	Pending		11/28/2023	825	Leak Extent	
427378	692 COMMONWEALTH AVE	NEWTON	3	10/7/2011		Carried Forward	Pending		11/16/2023	816	Leak Extent	
7327022	74 HOMESTEAD ST	NEWTON	3	6/27/2016		Carried Forward	Pending		5/15/2023	800	Leak Extent	
7365406	48 PRINCE ST	NEWTON	3	12/19/2020		Carried Forward	Pending		6/28/2023	800	Leak Extent	
7371859	214 BEACON ST	NEWTON	3	11/10/2021		Carried Forward	Pending		7/18/2023	800	Leak Extent	
7375167	275 WAVERLY AVE	NEWTON	3	6/2/2022	9/28/2023	Carried Forward	Eliminated by Replacement		3/21/2023	800	Leak Extent	
7376041	14 HOMESTEAD ST	NEWTON	3	7/13/2022		Carried Forward	Pending		5/16/2023	800	Leak Extent	
270745	WALNUT ST & BACON RD	NEWTON	3	8/6/2004		Carried Forward	Pending		11/6/2023	750	Leak Extent	
304327	ALBEMARLE RD & WATERTOWN	NEWTON	3	8/15/2007		Carried Forward	Pending		9/13/2023	750	Leak Extent	
839499	220 WOODWARD ST	NEWTON	3	6/29/2016		Carried Forward	Pending		11/14/2023	750	Leak Extent	
7353121	95 PINE GROVE AVE	NEWTON	3	5/8/2019		Carried Forward	Pending		11/16/2023	750	Leak Extent	
7355549	200 COTTON ST	NEWTON	3	8/22/2019		Carried Forward	Pending		12/13/2023	750	Leak Extent	
7379082	9 NARDELL RD	NEWTON	3	1/5/2023		Newly Identified	Pending		11/7/2023	750	Leak Extent	
7379847	1818 BEACON ST	NEWTON	3	2/13/2023		Newly Identified	Pending		11/8/2023	750	Leak Extent	
7354555	11 OWAISA RD	NEWTON	3	6/10/2019		Carried Forward	Pending		11/14/2023	738	Leak Extent	
7373593	BOYLSTON ST (POLE 61) & HUNTINGTON	NEWTON	3	2/22/2022		Carried Forward	Pending		11/28/2023	720	Leak Extent	
596669	90 ROWENA RD	NEWTON	3	11/28/2011	6/20/2023	Carried Forward	Eliminated by Replacement		1/18/2023	700	Leak Extent	
6625370	27 CAMDEN RD	NEWTON	3	9/22/2015		Carried Forward	Pending		11/14/2023	700	Leak Extent	
7327021	20 HOLDEN RD	NEWTON	3	6/28/2016		Carried Forward	Pending		9/13/2023	700	Leak Extent	
7354554	81 CHURCH ST	NEWTON	3	7/9/2019		Carried Forward	Pending		11/9/2023	700	Leak Extent	
7335226	26 PAGE RD	NEWTON	3	5/31/2017	7/18/2023	Carried Forward	Eliminated by Replacement		10/7/2022	680	Leak Extent	
7349163	CYPRESS ST & PARKER ST	NEWTON	3	11/15/2018		Carried Forward	Pending		4/24/2023	672	Leak Extent	
7353118	207 AUBURN ST	NEWTON	3	5/17/2019		Carried Forward	Pending		11/16/2023	660	Leak Extent	
7375099	750 COMMONWEALTH AVE	NEWTON	3	4/26/2022		Carried Forward	Pending		3/13/2023	640	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
230055	1046 CHESTNUT ST	NEWTON	3	10/24/2017		Carried Forward	Pending		12/19/2023	630	Leak Extent	
7354890	33 THE LEDGES RD	NEWTON	3	7/24/2019		Carried Forward	Pending		11/9/2023	625	Leak Extent	
284375	59 WACHUSETT RD	NEWTON	3	1/25/2006		Carried Forward	Pending		11/8/2023	600	Leak Extent	
1286057	26 HOLMAN RD	NEWTON	3	6/12/2013		Carried Forward	Pending		11/7/2023	600	Leak Extent	
7347782	2044 BEACON ST	NEWTON	3	9/23/2018		Carried Forward	Pending		5/12/2023	600	Leak Extent	
7353084	3 AUSTIN ST	NEWTON	3	5/15/2019		Carried Forward	Pending		11/6/2023	600	Leak Extent	
7354697	72 ALGONQUIN RD	NEWTON	3	7/16/2019	10/17/2023	Carried Forward	Repaired		3/3/2023	600	Leak Extent	
7355431	1928 COMMONWEALTH AVE	NEWTON	3	8/5/2019		Carried Forward	Pending		12/13/2023	600	Leak Extent	
7355559	96 NORTH ST	NEWTON	3	8/19/2019		Carried Forward	Pending		12/13/2023	600	Leak Extent	
7355977	173 HIGHLAND ST	NEWTON	3	12/8/2020		Carried Forward	Pending		6/28/2023	600	Leak Extent	
7356426	5 NIGHTINGALE PATH	NEWTON	3	9/26/2019	11/30/2023	Carried Forward	Repaired		4/25/2023	600	Leak Extent	
7364831	5 PHILBRICK RD	NEWTON	3	8/17/2020		Carried Forward	Pending		5/4/2023	600	Leak Extent	
7378589	242 LEXINGTON ST	NEWTON	3	11/23/2022		Carried Forward	Pending		10/17/2023	600	Leak Extent	
7326638	89 WINDSOR RD	NEWTON	3	6/10/2016		Carried Forward	Pending		7/19/2023	580	Leak Extent	
7356355	146 HAMMOND ST	NEWTON	3	9/25/2019		Carried Forward	Pending		3/20/2023	570	Leak Extent	
7353516	43 HIGH ST	NEWTON	3	5/23/2019	3/16/2023	Carried Forward	Repaired		2/15/2023	560	Leak Extent	
7356225	105 HANSON RD	NEWTON	3	9/5/2019		Carried Forward	Pending		12/19/2023	528	Leak Extent	
304719	94 MARY ELLEN RD	NEWTON	3	8/29/2007	5/1/2023	Carried Forward	Eliminated by Replacement		7/26/2022	525	Leak Extent	
7379918	1088 BOYLSTON ST	NEWTON	3	2/15/2023		Newly Identified	Pending		11/28/2023	525	Leak Extent	
155801	KENDALL RD & WALNUT HILL	NEWTON	3	7/23/1999		Carried Forward	Pending		11/8/2023	500	Leak Extent	
258065	122 WARD ST	NEWTON	3	1/22/2004		Carried Forward	Pending		11/14/2023	500	Leak Extent	
307615	24 CENTRAL AVE	NEWTON	3	9/10/2007		Carried Forward	Pending		11/13/2023	500	Leak Extent	
329823	41 BERKELEY ST	NEWTON	3	12/4/2009		Carried Forward	Pending		9/12/2023	500	Leak Extent	
1283461	21 WALNUT ST	NEWTON	3	9/29/2014		Carried Forward	Pending		9/13/2023	500	Leak Extent	
1338980	66 COMMONWEALTH PIKE W	NEWTON	3	8/29/2013		Carried Forward	Pending		9/12/2023	500	Leak Extent	
7332282	NONANTUM RD & CHARLESB	NEWTON	3	2/1/2017		Carried Forward	Pending		5/12/2023	500	Leak Extent	
7336456	12 BERTRAND RD	NEWTON	3	7/18/2017		Carried Forward	Pending		11/6/2023	500	Leak Extent	
7337016	214 CONCORD ST	NEWTON	3	8/1/2017		Carried Forward	Pending		11/14/2023	500	Leak Extent	
7341653	457 WASHINGTON ST	NEWTON	3	1/28/2018		Carried Forward	Pending		5/12/2023	500	Leak Extent	
7342376	3 DANIEL ST	NEWTON	3	3/6/2018		Carried Forward	Pending		6/7/2023	500	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classifica tion)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7345717	85 COMMONWEALTH AVE	NEWTON	3	7/14/2018		Carried Forward	Pending		5/11/2023	500	Leak Extent	
7353522	8 WETHERELL ST	NEWTON	3	5/5/2019		Carried Forward	Pending		9/12/2023	500	Leak Extent	
7354542	190 TEMPLE ST	NEWTON	3	7/11/2019		Carried Forward	Pending		11/17/2023	500	Leak Extent	
7354716	16 KENYON ST	NEWTON	3	7/19/2019		Carried Forward	Pending		11/16/2023	500	Leak Extent	
7356420	24 OROURKE PATH	NEWTON	3	9/26/2019		Carried Forward	Pending		5/11/2023	500	Leak Extent	
7371044	178 PRINCE ST	NEWTON	3	9/27/2021		Carried Forward	Pending		7/11/2023	500	Leak Extent	
7376315	1013 BEACON ST	NEWTON	3	7/18/2022		Carried Forward	Pending		5/11/2023	500	Leak Extent	
7376813	32 NOBLE ST	NEWTON	3	8/24/2022		Carried Forward	Pending		6/26/2023	500	Leak Extent	
7379545	105 ANNAWAN RD	NEWTON	3	1/19/2023		Newly Identified	Pending		11/13/2023	500	Leak Extent	
304662	19 FENWICK RD	NEWTON	3	9/12/2007		Carried Forward	Pending		11/16/2023	480	Leak Extent	
7326329	121 DICKERMAN RD	NEWTON	3	6/1/2016		Carried Forward	Pending		7/19/2023	480	Leak Extent	
7355236	98 LEXINGTON ST	NEWTON	3	8/5/2019	3/9/2023	Carried Forward	Repaired		3/7/2023	480	Leak Extent	
42571	1418 COMMONWEALTH AV	NEWTON	3	7/7/1995		Carried Forward	Pending		3/9/2023	450	Leak Extent	
263170	207 WALTHAM ST	NEWTON	3	10/13/2004		Carried Forward	Pending		3/10/2023	450	Leak Extent	
271180	63 AVONDALE RD	NEWTON	3	2/1/2005		Carried Forward	Pending		11/8/2023	450	Leak Extent	
1206963	41 BRUSH HILL RD	NEWTON	3	4/25/2013		Carried Forward	Pending		11/13/2023	450	Leak Extent	
7326999	169 FULLER ST	NEWTON	3	6/23/2016		Carried Forward	Pending		7/31/2023	450	Leak Extent	
7335809	1319 CENTRE ST	NEWTON	3	6/23/2017		Carried Forward	Pending		11/6/2023	450	Leak Extent	
7353115	150 WOODLAND RD	NEWTON	3	5/8/2019		Carried Forward	Pending		11/16/2023	450	Leak Extent	
7356361	52 G ROADWAY	NEWTON	3	9/25/2019		Carried Forward	Pending		3/21/2023	450	Leak Extent	
7378586	8 EARLY PATH	NEWTON	3	11/15/2022		Carried Forward	Pending		10/17/2023	450	Leak Extent	
7379271	255 BOYLSTON ST	NEWTON	3	1/6/2023		Newly Identified	Pending		11/9/2023	450	Leak Extent	
4788513	22 AUBURN ST	NEWTON	3	7/9/2015		Carried Forward	Pending		7/18/2023	435	Leak Extent	
7379022	1499 WASHINGTON ST	NEWTON	3	12/13/2022		Carried Forward	Pending		9/26/2023	420	Leak Extent	
839999	115 ELLIOT ST	NEWTON	3	3/23/2012		Carried Forward	Pending		11/17/2023	410	Leak Extent	
338427	65 ELINOR RD	NEWTON	3	10/9/2010		Carried Forward	Pending		12/19/2023	407	Leak Extent	
42479	52 SEWALL ST	NEWTON	3	10/22/1990		Carried Forward	Pending		11/6/2023	400	Leak Extent	
303660	43 WALNUT ST	NEWTON	3	11/18/2014		Carried Forward	Pending		11/8/2023	400	Leak Extent	
304766	6 SUMNER ST	NEWTON	3	8/28/2007		Carried Forward	Pending		11/16/2023	400	Leak Extent	
337057	327 CHERRY ST	NEWTON	3	12/2/2020		Carried Forward	Pending		6/26/2023	400	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
854114	712 SAWMILL BROOK PKY	NEWTON	3	4/24/2012		Carried Forward	Pending		11/13/2023	400	Leak Extent	
1217681	206 CONCORD ST	NEWTON	3	5/6/2013		Carried Forward	Pending		11/13/2023	400	Leak Extent	
1338964	15 PHEASANT RD	NEWTON	3	9/3/2013	2/10/2023	Carried Forward	Repaired		1/27/2023	400	Leak Extent	
1363313	110 CEDAR ST	NEWTON	3	9/10/2013		Carried Forward	Pending		12/12/2023	400	Leak Extent	
7324469	16 SOMERSET RD	NEWTON	3	4/1/2016		Carried Forward	Pending		11/13/2023	400	Leak Extent	
7327002	1395 COMMONWEALTH AVE	NEWTON	3	6/23/2016		Carried Forward	Pending		7/31/2023	400	Leak Extent	
7336530	6 SAMOSET RD	NEWTON	3	7/21/2017		Carried Forward	Pending		11/16/2023	400	Leak Extent	
7353088	238 DORSET RD	NEWTON	3	5/6/2019		Carried Forward	Pending		11/13/2023	400	Leak Extent	
7354553	7 BUSWELL PIKE	NEWTON	3	7/9/2019		Carried Forward	Pending		11/9/2023	400	Leak Extent	
7354698	559 CENTRE ST	NEWTON	3	7/16/2019		Carried Forward	Pending		11/17/2023	400	Leak Extent	
7356850	HIGHLAND ST & DAVIS ST	NEWTON	3	10/15/2019		Carried Forward	Pending		5/16/2023	400	Leak Extent	
7364115	33 WARREN RD	NEWTON	3	5/24/2020		Carried Forward	Pending		11/17/2023	400	Leak Extent	
7371866	1292 WALNUT ST	NEWTON	3	11/9/2021		Carried Forward	Pending		7/12/2023	400	Leak Extent	
7376811	195 MORTON ST	NEWTON	3	8/26/2022		Carried Forward	Pending		6/28/2023	400	Leak Extent	
7376816	45 SHERIDAN ST	NEWTON	3	8/18/2022		Carried Forward	Pending		6/22/2023	400	Leak Extent	
7379290	25 OLD ENGLAND RD	NEWTON	3	1/4/2023		Newly Identified	Pending		11/7/2023	400	Leak Extent	
270388	50 DORSET RD	NEWTON	3	4/29/2004		Carried Forward	Pending		11/13/2023	375	Leak Extent	
302760	60 WHITE OAK RD	NEWTON	3	7/13/2007		Carried Forward	Pending		7/31/2023	375	Leak Extent	
7341496	COMMONWEALTH AVE & AULICK ST	NEWTON	3	1/12/2018		Carried Forward	Pending		5/12/2023	375	Leak Extent	
7348312	393 LOWELL AVE	NEWTON	3	10/13/2018		Carried Forward	Pending		5/11/2023	375	Leak Extent	
7348728	283 MELROSE ST	NEWTON	3	6/29/2018		Carried Forward	Pending		5/11/2023	375	Leak Extent	
7365082	35 WHITTIER RD	NEWTON	3	9/1/2020		Carried Forward	Pending		5/11/2023	375	Leak Extent	
7368736	1330 BOYLSTON ST	NEWTON	3	5/15/2021		Carried Forward	Pending		12/12/2023	375	Leak Extent	
7377629	39 MASON RD	NEWTON	3	9/13/2022	10/5/2023	Carried Forward	Eliminated Otherwise		7/12/2023	375	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7378202	904 BOYLSTON ST	NEWTON	3	11/16/2022		Carried Forward	Pending		9/15/2023	375	Leak Extent	
7378650	NONANTUM RD & MAPLE ST	NEWTON	3	11/7/2022		Carried Forward	Pending		10/17/2023	375	Leak Extent	
7379461	184 WINDSOR RD	NEWTON	3	1/10/2023		Newly Identified	Pending		11/7/2023	375	Leak Extent	
230386	LANGDON ST & BELLEVUE ST	NEWTON	3	2/26/2002		Carried Forward	Pending		11/8/2023	312	Leak Extent	
294276	64 PUTNAM ST	NEWTON	3	9/25/2006		Carried Forward	Pending		11/7/2023	300	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
296483	10 LANGLEY RD	NEWTON	3	12/7/2006		Carried Forward	Pending		11/6/2023	300	Leak Extent	
303110	40 CENTRAL TER	NEWTON	3	7/3/2007		Carried Forward	Pending		6/26/2023	300	Leak Extent	
303666	78 WOODBINE ST	NEWTON	3	8/1/2007		Carried Forward	Pending		11/8/2023	300	Leak Extent	
305519	50 CHESTNUT HILL RD	NEWTON	3	8/23/2007		Carried Forward	Pending		11/16/2023	300	Leak Extent	
307614	499 CRAFTS ST	NEWTON	3	9/4/2007		Carried Forward	Pending		11/9/2023	300	Leak Extent	
329984	216 WINSLOW RD	NEWTON	3	11/30/2009		Carried Forward	Pending		3/20/2023	300	Leak Extent	
949724	8 HAMMOND ST	NEWTON	3	8/1/2012		Carried Forward	Pending		11/13/2023	300	Leak Extent	
1230002	WALNUT ST & LAKEWOOD RD	NEWTON	3	5/17/2013		Carried Forward	Pending		3/21/2023	300	Leak Extent	
1338217	102 RIDGE AVE	NEWTON	3	8/20/2013		Carried Forward	Pending		3/9/2023	300	Leak Extent	
1362600	45 PARK LN	NEWTON	3	9/25/2013		Carried Forward	Pending		5/4/2023	300	Leak Extent	
7324253	15 JACKSON ST	NEWTON	3	3/23/2016		Carried Forward	Pending		11/13/2023	300	Leak Extent	
7325718	8 WHITE OAK RD	NEWTON	3	5/10/2016		Carried Forward	Pending		6/7/2023	300	Leak Extent	
7336302	42 ANNAWAN RD	NEWTON	3	7/1/2017		Carried Forward	Pending		11/6/2023	300	Leak Extent	
7348310	95 DORSET RD	NEWTON	3	10/11/2018		Carried Forward	Pending		5/11/2023	300	Leak Extent	
7354147	9 HIGH ST	NEWTON	3	6/27/2019		Carried Forward	Pending		11/16/2023	300	Leak Extent	
7354252	2 KINGSTON RD	NEWTON	3	6/27/2019		Carried Forward	Pending		11/16/2023	300	Leak Extent	
7354537	10 DAY ST	NEWTON	3	7/15/2019		Carried Forward	Pending		11/17/2023	300	Leak Extent	
7355545	11 ANTONELLIS CIR	NEWTON	3	8/22/2019		Carried Forward	Pending		12/13/2023	300	Leak Extent	
7355564	51 SHERBROOKE RD	NEWTON	3	8/21/2019		Carried Forward	Pending		12/13/2023	300	Leak Extent	
7356211	84 RACHEL RD	NEWTON	3	9/5/2019		Carried Forward	Pending		3/20/2023	300	Leak Extent	
7356212	500 DEDHAM ST	NEWTON	3	9/5/2019		Carried Forward	Pending		3/10/2023	300	Leak Extent	
7356428	37 TRUMAN RD	NEWTON	3	9/26/2019		Carried Forward	Pending		4/25/2023	300	Leak Extent	
7358412	LOS ANGELES ST & CALIFORNIA	NEWTON	3	12/26/2019		Carried Forward	Pending		6/1/2023	300	Leak Extent	
7364120	43 SHERBROOKE RD	NEWTON	3	6/15/2020		Carried Forward	Pending		11/17/2023	300	Leak Extent	
7364450	60 FAIRLEE RD	NEWTON	3	8/26/2020		Carried Forward	Pending		5/16/2023	300	Leak Extent	
7365526	36 METACOMET RD	NEWTON	3	11/20/2020		Carried Forward	Pending		6/28/2023	300	Leak Extent	
7369056	935 WASHINGTON ST	NEWTON	3	9/8/2021		Carried Forward	Pending		6/1/2023	300	Leak Extent	
7369059	415 LOWELL AVE	NEWTON	3	8/8/2021		Carried Forward	Pending		5/16/2023	300	Leak Extent	
7371864	465 CENTRE ST	NEWTON	3	10/23/2021		Carried Forward	Pending		7/11/2023	300	Leak Extent	
7371865	4 RANDOLPH ST	NEWTON	3	11/9/2021		Carried Forward	Pending		7/12/2023	300	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location		Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name	Town/City							Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7375136	15 ELMWOOD PIKE	NEWTON	3	5/24/2022		Carried Forward	Pending		3/20/2023	300	Leak Extent	
7375986	11 EDGE HILL RD	NEWTON	3	5/23/2022		Carried Forward	Pending		3/20/2023	300	Leak Extent	
7376632	227 CHERRY ST	NEWTON	3	8/25/2022		Carried Forward	Pending		6/28/2023	300	Leak Extent	
7378750	116 LEXINGTON ST	NEWTON	3	11/8/2022		Carried Forward	Pending		9/12/2023	300	Leak Extent	
7379295	416 NEWTONVILLE AVE	NEWTON	3	1/9/2023		Newly Identified	Pending		11/7/2023	300	Leak Extent	
7383022	74 BRIDGE ST	NEWTON	3	8/3/2023		Newly Identified	Pending		8/3/2023	300	Leak Extent	
7370900	11 CLOVELLY RD	NEWTON	3	9/20/2021		Carried Forward	Pending		6/20/2023	264	Leak Extent	
303659	470 CALIFORNIA ST	NEWTON	3	8/3/2007		Carried Forward	Pending		3/10/2023	250	Leak Extent	
304862	30 PEARL ST	NEWTON	3	8/14/2007		Carried Forward	Pending		11/13/2023	250	Leak Extent	
4497451	60 HIGHLAND AVE	NEWTON	3	3/4/2015		Carried Forward	Pending		12/12/2023	250	Leak Extent	
7325992	269 JACKSON ST	NEWTON	3	5/12/2016		Carried Forward	Pending		6/22/2023	250	Leak Extent	
7325996	1 NONANTUM ST	NEWTON	3	5/10/2016		Carried Forward	Pending		7/11/2023	250	Leak Extent	
7326997	21 LAUDHOLM RD	NEWTON	3	6/17/2016		Carried Forward	Pending		7/31/2023	250	Leak Extent	
7348100	63 OAKDALE RD	NEWTON	3	10/12/2018		Carried Forward	Pending		5/11/2023	250	Leak Extent	
7353089	65 GROVE ST	NEWTON	3	5/8/2019		Carried Forward	Pending		11/13/2023	250	Leak Extent	
7354263	1932 COMMONWEALTH AVE	NEWTON	3	6/24/2019		Carried Forward	Pending		11/16/2023	250	Leak Extent	
7354709	20 CLAREMONT ST	NEWTON	3	7/16/2019		Carried Forward	Pending		11/17/2023	250	Leak Extent	
7354711	86 COMMONWEALTH AVE	NEWTON	3	7/16/2019		Carried Forward	Pending		11/17/2023	250	Leak Extent	
7355422	1466 COMMONWEALTH AVE	NEWTON	3	7/24/2019		Carried Forward	Pending		11/16/2023	250	Leak Extent	
7356362	29 F ROADWAY	NEWTON	3	9/25/2019		Carried Forward	Pending		3/21/2023	250	Leak Extent	
7356450	10 SPIERS RD	NEWTON	3	9/27/2019		Carried Forward	Pending		5/4/2023	250	Leak Extent	
7356852	WATERTOWN ST & CRAFTS ST	NEWTON	3	10/15/2019		Carried Forward	Pending		6/28/2023	250	Leak Extent	
7376814	222 PLEASANT ST	NEWTON	3	8/25/2022		Carried Forward	Pending		6/29/2023	250	Leak Extent	
7377631	364 WOODWARD ST	NEWTON	3	9/12/2022		Carried Forward	Pending		7/12/2023	250	Leak Extent	
7379240	494 WATERTOWN ST	NEWTON	3	1/4/2023		Newly Identified	Pending		11/7/2023	250	Leak Extent	
7379277	234 CENTRAL ST	NEWTON	3	1/9/2023		Newly Identified	Pending		11/7/2023	250	Leak Extent	
7379456	34 WARE RD	NEWTON	3	2/1/2023		Newly Identified	Pending		11/16/2023	250	Leak Extent	
7381198	899 WALNUT ST	NEWTON	3	11/14/2023		Newly Identified	Pending	2	11/14/2023	250	Leak Extent	
335508	15 ROTHERWOOD RD	NEWTON	3	7/10/2010		Carried Forward	Pending		7/18/2023	225	Leak Extent	
7355430	32 SMITH AVE	NEWTON	3	7/25/2019		Carried Forward	Pending		12/12/2023	225	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classifica tion)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7355668	34 BROADLAWN DR	NEWTON	3	8/23/2019		Carried Forward	Pending		12/14/2023	225	Leak Extent	
7373592	11 ASHCROFT RD	NEWTON	3	2/22/2022		Carried Forward	Pending		11/15/2023	225	Leak Extent	
7374857	265 OTIS ST	NEWTON	3	5/15/2022		Carried Forward	Pending		12/20/2023	220	Leak Extent	
121969	CRAFTS ST & FESSENDEN RD	NEWTON	3	4/8/1998		Carried Forward	Pending		11/16/2023	200	Leak Extent	
270655	100 SUFFOLK RD	NEWTON	3	8/19/2004		Carried Forward	Pending		5/12/2023	200	Leak Extent	
278687	HAMMOND ST & MIDDLESEX	NEWTON	3	8/8/2005		Carried Forward	Pending		11/8/2023	200	Leak Extent	
305355	36 MAGNOLIA AVE	NEWTON	3	8/29/2007		Carried Forward	Pending		11/7/2023	200	Leak Extent	
329904	25 MORSE RD	NEWTON	3	12/8/2009		Carried Forward	Pending		11/15/2023	200	Leak Extent	
336992	881 DEDHAM ST	NEWTON	3	9/1/2010		Carried Forward	Pending		11/13/2023	200	Leak Extent	
343469	PARKER ST & BOYLSTON ST	NEWTON	3	2/1/2011		Carried Forward	Pending		6/1/2023	200	Leak Extent	
1230260	62 OLDEFIELD RD	NEWTON	3	5/7/2013		Carried Forward	Pending		11/14/2023	200	Leak Extent	
1363357	647 COMMONWEALTH AVE	NEWTON	3	9/12/2013		Carried Forward	Pending		9/12/2023	200	Leak Extent	
4788254	8 CENTRAL AVE	NEWTON	3	7/10/2015		Carried Forward	Pending		5/11/2023	200	Leak Extent	
6591350	22 OLDEFIELD RD	NEWTON	3	9/12/2015		Carried Forward	Pending		11/28/2023	200	Leak Extent	
6624524	14 SAMOSET RD	NEWTON	3	9/21/2015		Carried Forward	Pending		5/15/2023	200	Leak Extent	
7325430	9 KIRKSTALL RD	NEWTON	3	4/20/2016		Carried Forward	Pending		11/13/2023	200	Leak Extent	
7325711	5 AGAWAM RD	NEWTON	3	5/10/2016		Carried Forward	Pending		12/12/2023	200	Leak Extent	
7327326	91 ARNOLD RD	NEWTON	3	7/8/2016	11/8/2023	Carried Forward	Eliminated Otherwise		1/27/2023	200	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7327702	111 HOBART RD	NEWTON	3	7/7/2016		Carried Forward	Pending		11/6/2023	200	Leak Extent	
7353086	43 CENTRAL ST	NEWTON	3	5/8/2019		Carried Forward	Pending		11/13/2023	200	Leak Extent	
7353577	73 DEDHAM ST	NEWTON	3	5/24/2019		Carried Forward	Pending		11/8/2023	200	Leak Extent	
7354712	31 DEVONSHIRE RD	NEWTON	3	7/19/2019		Carried Forward	Pending		11/17/2023	200	Leak Extent	
7361466	109 PRINCE ST	NEWTON	3	6/9/2020		Carried Forward	Pending		11/9/2023	200	Leak Extent	
7365408	NORTH ST & ALBEMARLE RD	NEWTON	3	10/28/2020		Carried Forward	Pending		6/20/2023	200	Leak Extent	
7370901	38 BARNSTABLE RD	NEWTON	3	9/24/2021		Carried Forward	Pending		6/22/2023	200	Leak Extent	
7372371	28 MOODY ST	NEWTON	3	12/3/2021		Carried Forward	Pending		7/31/2023	200	Leak Extent	
7374831	75 ELMHURST RD	NEWTON	3	4/5/2022		Carried Forward	Pending		11/17/2023	200	Leak Extent	
7376827	120 CORNELL ST	NEWTON	3	4/5/2022		Carried Forward	Pending		11/17/2023	200	Leak Extent	
7378677	138 LEXINGTON ST	NEWTON	3	11/8/2022		Carried Forward	Pending		9/12/2023	200	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location		Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name	Town/City							Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7379906	35 KELVEDEN RD	NEWTON	3	3/1/2023		Newly Identified	Pending		11/9/2023	200	Leak Extent	
7379276	10 MOODY ST	NEWTON	3	12/22/2022		Carried Forward	Pending		9/26/2023	192	Leak Extent	
7339913	58 AUBURN ST	NEWTON	3	11/15/2017		Carried Forward	Pending		12/20/2023	180	Leak Extent	
6722656	69 PRINCE ST	NEWTON	3	9/29/2015		Carried Forward	Pending		11/13/2023	170	Leak Extent	
1237078	94 DEVONSHIRE RD	NEWTON	3	10/9/2015		Carried Forward	Pending		3/16/2023	168	Leak Extent	
7338634	6 VAUGHAN AVE	NEWTON	3	9/9/2017		Carried Forward	Pending		4/24/2023	160	Leak Extent	
7354257	254 WEBSTER ST	NEWTON	3	12/31/2019		Carried Forward	Pending		6/20/2023	160	Leak Extent	
7375133	46 BEMIS ST	NEWTON	3	5/17/2022		Carried Forward	Pending		12/20/2023	160	Leak Extent	
7375988	146 INTERVALE RD	NEWTON	3	6/16/2022		Carried Forward	Pending		4/24/2023	160	Leak Extent	
230384	41 LAKEVIEW AV	NEWTON	3	8/7/2000		Carried Forward	Pending		5/15/2023	150	Leak Extent	
258085	WABAN AV & VARICK RD	NEWTON	3	2/24/2004		Carried Forward	Pending		11/8/2023	150	Leak Extent	
270381	55 WINDSOR RD	NEWTON	3	4/29/2004		Carried Forward	Pending		11/8/2023	150	Leak Extent	
303661	315 CRAFTS ST	NEWTON	3	8/6/2007		Carried Forward	Pending		11/16/2023	150	Leak Extent	
2349834	109 ALLERTON RD	NEWTON	3	12/26/2014		Carried Forward	Pending		11/15/2023	150	Leak Extent	
3093950	43 SEWALL ST	NEWTON	3	2/9/2015		Carried Forward	Pending		5/16/2023	150	Leak Extent	
7322014	83 DEVONSHIRE RD	NEWTON	3	12/8/2015		Carried Forward	Pending		11/9/2023	150	Leak Extent	
7330385	75 SUMNER ST	NEWTON	3	11/16/2016		Carried Forward	Pending		5/15/2023	150	Leak Extent	
7340358	246 BEACON ST	NEWTON	3	12/12/2017		Carried Forward	Pending		5/11/2023	150	Leak Extent	
7350513	15 OAK ST	NEWTON	3	2/1/2019		Carried Forward	Pending		6/1/2023	150	Leak Extent	
7353083	1830 COMMONWEALTH AVE	NEWTON	3	5/13/2019		Carried Forward	Pending		11/14/2023	150	Leak Extent	
7355552	8 EXMOOR RD	NEWTON	3	8/21/2019		Carried Forward	Pending		12/13/2023	150	Leak Extent	
7356210	15 LEEWOOD RD	NEWTON	3	9/5/2019		Carried Forward	Pending		12/20/2023	150	Leak Extent	
7356357	12 WACHUSETT RD	NEWTON	3	9/25/2019		Carried Forward	Pending		3/21/2023	150	Leak Extent	
7357654	143 RIVER ST	NEWTON	3	10/16/2019		Carried Forward	Pending		5/16/2023	150	Leak Extent	
7375989	38 VERNDALE RD	NEWTON	3	6/17/2022		Carried Forward	Pending		4/25/2023	150	Leak Extent	
7376323	4 GRAY CLIFF RD	NEWTON	3	7/24/2022		Carried Forward	Pending		5/12/2023	150	Leak Extent	
7376829	126 EASTBOURNE RD	NEWTON	3	4/12/2022		Carried Forward	Pending		12/12/2023	150	Leak Extent	
7379278	280 CENTRAL ST	NEWTON	3	1/9/2023		Newly Identified	Pending		11/7/2023	150	Leak Extent	
347021	160 COMMONWEALTH AVE	NEWTON	3	5/25/2011		Carried Forward	Pending		3/16/2023	144	Leak Extent	
871400	23 FREDANA RD	NEWTON	3	5/4/2012		Carried Forward	Pending		11/17/2023	140	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classifica tion)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7326625	129 PARKER ST	NEWTON	3	6/10/2016		Carried Forward	Pending		7/19/2023	136	Leak Extent	
7355359	41 ORCHARD AVE	NEWTON	3	8/12/2019		Carried Forward	Pending		12/12/2023	125	Leak Extent	
332258	30 ROLAND ST	NEWTON	3	4/8/2010		Carried Forward	Pending		12/14/2023	120	Leak Extent	
5337636	330 CENTRAL ST	NEWTON	3	7/6/2015		Carried Forward	Pending		7/19/2023	120	Leak Extent	
7355547	85 BROOKSIDE AVE	NEWTON	3	8/20/2019		Carried Forward	Pending		4/24/2023	120	Leak Extent	
275900	544 QUINOBEQUIN RD	NEWTON	3	6/8/2005		Carried Forward	Pending		11/7/2023	100	Leak Extent	
303702	9 T ROADWAY	NEWTON	3	8/6/2007		Carried Forward	Pending		5/15/2023	100	Leak Extent	
304860	167 PARKER ST	NEWTON	3	8/14/2007		Carried Forward	Pending		11/15/2023	100	Leak Extent	
316528	64 FULLER ST	NEWTON	3	9/8/2008		Carried Forward	Pending		11/15/2023	100	Leak Extent	
332674	15 HARTMAN RD	NEWTON	3	12/20/2010		Carried Forward	Pending		11/16/2023	100	Leak Extent	
343629	37 SHAW ST	NEWTON	3	2/15/2011		Carried Forward	Pending		11/14/2023	100	Leak Extent	
693516	1 QUINOBEQUIN RD	NEWTON	3	12/15/2011		Carried Forward	Pending		11/14/2023	100	Leak Extent	
1217964	68 WYOMING RD	NEWTON	3	4/30/2013		Carried Forward	Pending		11/14/2023	100	Leak Extent	
1229009	WALNUT ST & HOMER ST	NEWTON	3	5/17/2013		Carried Forward	Pending		11/16/2023	100	Leak Extent	
5321355	124 WINCHESTER ST	NEWTON	3	6/23/2009	11/8/2023	Carried Forward	Eliminated Otherwise		6/28/2023	100	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7321944	120 FARWELL ST	NEWTON	3	12/4/2015		Carried Forward	Pending		7/19/2023	100	Leak Extent	
7323096	11 RIDGEWAY TER	NEWTON	3	1/21/2016		Carried Forward	Pending		11/13/2023	100	Leak Extent	
7325806	4 PEMBROKE ST	NEWTON	3	4/22/2016		Carried Forward	Pending		11/14/2023	100	Leak Extent	
7326186	1267 CENTRE ST	NEWTON	3	5/20/2016	3/1/2023	Carried Forward	Eliminated Otherwise		8/30/2022	100	Leak Extent	NO READS
7326630	39 COURT ST	NEWTON	3	6/9/2016		Carried Forward	Pending		7/18/2023	100	Leak Extent	
7341526	224 JACKSON ST	NEWTON	3	2/27/2018		Carried Forward	Pending		5/12/2023	100	Leak Extent	
7347783	69 EVELYN RD	NEWTON	3	9/16/2018		Carried Forward	Pending		5/12/2023	100	Leak Extent	
7347784	12 NONANTUM ST	NEWTON	3	9/15/2018		Carried Forward	Pending		5/12/2023	100	Leak Extent	
7353079	1870 COMMONWEALTH AVE	NEWTON	3	5/13/2019		Carried Forward	Pending		11/14/2023	100	Leak Extent	
7354021	25 HAYNES RD	NEWTON	3	6/4/2019		Carried Forward	Pending		11/13/2023	100	Leak Extent	
7354041	66 NEEDHAM ST	NEWTON	3	10/20/2021		Carried Forward	Pending		6/28/2023	100	Leak Extent	
7355351	57 COOK ST	NEWTON	3	8/12/2019		Carried Forward	Pending		12/12/2023	100	Leak Extent	
7355555	68 LITTLEFIELD RD	NEWTON	3	8/19/2019		Carried Forward	Pending		12/13/2023	100	Leak Extent	
7355569	300 WARD ST	NEWTON	3	8/21/2019	10/3/2023	Carried Forward	Eliminated by Replacemen		3/8/2023	100	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7356133	151 VALENTINE ST	NEWTON	3	8/6/2019		Carried Forward	Pending		12/13/2023	100	Leak Extent	
7356371	80 HANSON RD	NEWTON	3	9/25/2019		Carried Forward	Pending		4/24/2023	100	Leak Extent	
7364409	170 OTIS ST	NEWTON	3	7/15/2020		Carried Forward	Pending		3/8/2023	100	Leak Extent	
7365113	110 ADELINE RD	NEWTON	3	10/9/2020		Carried Forward	Pending		6/1/2023	100	Leak Extent	
7365478	50 MANEMET RD	NEWTON	3	11/14/2020		Carried Forward	Pending		6/28/2023	100	Leak Extent	
7367241	46 CEDAR ST	NEWTON	3	3/1/2021		Carried Forward	Pending		7/31/2023	100	Leak Extent	
7368505	87 ATWOOD AVE	NEWTON	3	5/4/2021		Carried Forward	Pending		11/17/2023	100	Leak Extent	
7371048	212 TEMPLE ST	NEWTON	3	9/27/2021	11/29/2023	Carried Forward	Repaired		7/11/2023	100	Leak Extent	
7374830	21 MARSHFIELD RD	NEWTON	3	3/15/2022		Carried Forward	Pending		11/8/2023	100	Leak Extent	
7374843	1994 BEACON ST	NEWTON	3	5/29/2022		Carried Forward	Pending		3/21/2023	100	Leak Extent	
7374856	1750 COMMONWEALTH AVE	NEWTON	3	5/14/2022		Carried Forward	Pending		3/17/2023	100	Leak Extent	
7378794	1370 WALNUT ST	NEWTON	3	11/10/2022		Carried Forward	Pending		9/13/2023	100	Leak Extent	
7379021	9 FOREST ST	NEWTON	3	8/9/2022		Carried Forward	Pending		6/7/2023	100	Leak Extent	
7379023	HIGHLAND ST & DAVIS ST	NEWTON	3	12/18/2022		Carried Forward	Pending		9/26/2023	100	Leak Extent	
7379298	64 PROSPECT AVE	NEWTON	3	1/10/2023		Newly Identified	Pending		11/7/2023	100	Leak Extent	
7379909	152 UPLAND RD	NEWTON	3	2/1/2023		Newly Identified	Pending		11/15/2023	100	Leak Extent	
7376046	11 EDGEFIELD RD	NEWTON	3	6/23/2022	2/23/2023	Carried Forward	Eliminated Otherwise		6/23/2022	90	Leak Extent	DUPLICATE LEAK
1337093	40 WINDSOR RD	NEWTON	3	8/19/2013		Carried Forward	Pending		11/13/2023	80	Leak Extent	
305109	32 WESSEX RD	NEWTON	3	8/28/2007		Carried Forward	Pending		11/13/2023	75	Leak Extent	
2725982	BEACON ST & RESERVOIR AVE	NEWTON	3	12/4/2014		Carried Forward	Pending		3/20/2023	75	Leak Extent	
7356142	26 HARWICH RD	NEWTON	3	9/4/2019		Carried Forward	Pending		3/10/2023	75	Leak Extent	
7335811	78 NONANTUM ST	NEWTON	3	6/10/2017		Carried Forward	Pending		7/19/2023	72	Leak Extent	
303390	167 MELROSE ST	NEWTON	3	7/31/2007		Carried Forward	Pending		11/7/2023	64	Leak Extent	
304763	8 LANCASTER RD	NEWTON	3	6/21/2016		Carried Forward	Pending		11/7/2023	64	Leak Extent	
7377628	23 LONGMEADOW RD	NEWTON	3	9/28/2022		Carried Forward	Pending		7/19/2023	64	Leak Extent	
7380691	43 KING ST	NEWTON	3	11/8/2023	11/29/2023	Newly Identified	Repaired	2	11/8/2023	64	Leak Extent	
7325492	135 BIGELOW RD	NEWTON	3	4/21/2016		Carried Forward	Pending		11/13/2023	50	Leak Extent	
7379279	1438 COMMONWEALTH AVE	NEWTON	3	1/11/2023		Newly Identified	Pending		11/8/2023	50	Leak Extent	
7375134	380 WINCHESTER ST	NEWTON	3	5/16/2022		Carried Forward	Pending		12/20/2023	49	Leak Extent	
7383497	2084 BEACON ST	NEWTON	3	8/27/2023		Newly Identified	Pending		8/27/2023	48	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificatio n)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7349893	240 VALENTINE ST	NEWTON	3	12/17/2018		Carried Forward	Pending		4/24/2023	45	Leak Extent	
42522	3 COLUMBUS ST	NEWTON	3	5/21/1993		Carried Forward	Pending		11/13/2023	25	Leak Extent	
42649	CLAREMONT ST & LOMBARD	NEWTON	3	3/3/1993	12/5/2023	Carried Forward	Eliminated Otherwise		11/8/2023	25	Leak Extent	NO READS
270390	PLYMOUTH RD & WOODWAR	NEWTON	3	4/27/2004		Carried Forward	Pending		11/8/2023	25	Leak Extent	
270413	1812 COMMONWEALTH AV	NEWTON	3	5/18/2004		Carried Forward	Pending		11/8/2023	25	Leak Extent	
270538	522 COMMONWEALTH AV	NEWTON	3	6/29/2004		Carried Forward	Pending		4/25/2023	25	Leak Extent	
270653	HAMMOND ST & RESERVOIR	NEWTON	3	8/20/2004		Carried Forward	Pending		11/14/2023	25	Leak Extent	
303097	82 CONCORD ST	NEWTON	3	7/3/2007	12/5/2023	Carried Forward	Eliminated Otherwise		11/8/2023	25	Leak Extent	NO READS
335126	79 KENWOOD AVE	NEWTON	3	7/2/2010	12/5/2023	Carried Forward	Eliminated by Replacemen		11/7/2023	25	Leak Extent	
338426	61 CENTRAL ST	NEWTON	3	9/17/2015		Carried Forward	Pending		11/8/2023	25	Leak Extent	
340420	167 NEHOIDEN RD	NEWTON	3	12/25/2010		Carried Forward	Pending		5/15/2023	25	Leak Extent	
1246024	242 WABAN AVE	NEWTON	3	7/31/2017		Carried Forward	Pending		11/13/2023	25	Leak Extent	
1363562	102 MCCARTHY RD	NEWTON	3	9/18/2013	12/18/2023	Carried Forward	Eliminated Otherwise		11/14/2023	25	Leak Extent	NO READS
2720300	61 SHARPE RD	NEWTON	3	1/23/2015		Carried Forward	Pending		11/13/2023	25	Leak Extent	
2834933	2401 COMMONWEALTH AVE	NEWTON	3	11/7/2014		Carried Forward	Pending		11/16/2023	25	Leak Extent	
3205205	60 HIGHLAND ST	NEWTON	3	3/4/2015		Carried Forward	Pending		12/12/2023	25	Leak Extent	
4787400	300 ADAMS ST	NEWTON	3	7/7/2015		Carried Forward	Pending		3/10/2023	25	Leak Extent	
6722810	75 GROVE HILL AVE	NEWTON	3	9/29/2015		Carried Forward	Pending		11/13/2023	25	Leak Extent	
7325494	4 MARLBORO ST	NEWTON	3	4/21/2016		Carried Forward	Pending		11/14/2023	25	Leak Extent	
7327103	19 RICHARDSON RD	NEWTON	3	6/30/2016	10/3/2023	Carried Forward	Eliminated by Replacemen		9/13/2023	25	Leak Extent	
7327360	A ROADWAY & SPIERS RD	NEWTON	3	6/14/2017		Carried Forward	Pending		9/13/2023	25	Leak Extent	
7329507	263 HAMMOND ST	NEWTON	3	11/7/2016		Carried Forward	Pending		5/16/2023	25	Leak Extent	
7329882	BEACON ST & HAMMOND ST	NEWTON	3	10/28/2016		Carried Forward	Pending		11/16/2023	25	Leak Extent	
7331474	71 COMMONWEALTH AVE	NEWTON	3	1/3/2017		Carried Forward	Pending		11/16/2023	25	Leak Extent	
7331915	150 SPIERS RD	NEWTON	3	2/2/2017		Carried Forward	Pending		11/16/2023	25	Leak Extent	
7332762	ISLINGTON RD & KINGSWOOD	NEWTON	3	3/21/2017		Carried Forward	Pending		12/12/2023	25	Leak Extent	
7336232	566 SAWMILL BROOK PKY	NEWTON	3	7/14/2017		Carried Forward	Pending		11/6/2023	25	Leak Extent	
7336365	23 DAVIS ST	NEWTON	3	7/15/2017		Carried Forward	Pending		11/17/2023	25	Leak Extent	
7336764	CENTRAL AVE & WASHINGTON	NEWTON	3	7/26/2017		Carried Forward	Pending		11/9/2023	25	Leak Extent	
7343320	30 E ROADWAY	NEWTON	3	4/6/2018		Carried Forward	Pending		6/23/2023	25	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location		Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name	Town/City							Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7345915	COMMONWEALTH AVE & HO	NEWTON	3	2/4/2019	3/8/2023	Carried Forward	Repaired		8/3/2022	25	Leak Extent	
7351646	20 SUN HILL LN	NEWTON	3	3/8/2019		Carried Forward	Pending		6/23/2023	25	Leak Extent	
7353074	70 WINDERMERE RD	NEWTON	3	5/13/2019	12/18/2023	Carried Forward	Eliminated Otherwise		11/14/2023	25	Leak Extent	NO READS
7353562	401 WINCHESTER ST	NEWTON	3	5/22/2019		Carried Forward	Pending		11/7/2023	25	Leak Extent	
7354042	130 NEEDHAM ST	NEWTON	3	6/21/2019		Carried Forward	Pending		11/16/2023	25	Leak Extent	
7354258	369 LEXINGTON ST	NEWTON	3	6/24/2019		Carried Forward	Pending		11/16/2023	25	Leak Extent	
7354269	62 WALNUT PIKE	NEWTON	3	6/26/2019		Carried Forward	Pending		11/16/2023	25	Leak Extent	
7355411	47 ESTY FARM RD	NEWTON	3	8/2/2019		Carried Forward	Pending		11/9/2023	25	Leak Extent	
7357139	48 LANTERN LN	NEWTON	3	10/25/2019		Carried Forward	Pending		5/12/2023	25	Leak Extent	
7364121	34 FENNO RD	NEWTON	3	6/17/2020		Carried Forward	Pending		12/12/2023	25	Leak Extent	
7368124	650 CENTRE ST	NEWTON	3	4/22/2021		Carried Forward	Pending		11/16/2023	25	Leak Extent	
7368508	97 ATWOOD AVE	NEWTON	3	4/26/2021		Carried Forward	Pending		11/16/2023	25	Leak Extent	
7371043	34 EMERSON ST	NEWTON	3	10/7/2021		Carried Forward	Pending		6/23/2023	25	Leak Extent	
7374842	6 LINCOLN ST	NEWTON	3	4/22/2022		Carried Forward	Pending		12/19/2023	25	Leak Extent	
7374845	2055 WASHINGTON ST	NEWTON	3	4/27/2022		Carried Forward	Pending		12/19/2023	25	Leak Extent	
7375164	8 BALDPATE HILL RD	NEWTON	3	4/26/2022		Carried Forward	Pending		12/19/2023	25	Leak Extent	
7375985	66 PELHAM ST	NEWTON	3	5/28/2022		Carried Forward	Pending		3/21/2023	25	Leak Extent	
7376631	224 ADAMS AVE	NEWTON	3	8/22/2022		Carried Forward	Pending		6/23/2023	25	Leak Extent	
7376820	96 WESTLAND AVE	NEWTON	3	8/19/2022		Carried Forward	Pending		6/23/2023	25	Leak Extent	
7376828	216 PLEASANT ST	NEWTON	3	4/3/2022		Carried Forward	Pending		11/16/2023	25	Leak Extent	
7378752	271 CYPRESS ST	NEWTON	3	11/9/2022		Carried Forward	Pending		9/12/2023	25	Leak Extent	
7379280	17 FAYETTE ST	NEWTON	3	1/11/2023	12/5/2023	Newly Identified	Eliminated Otherwise		11/8/2023	25	Leak Extent	NO READS
7379459	839 WASHINGTON ST	NEWTON	3	1/11/2023		Newly Identified	Pending		11/8/2023	25	Leak Extent	
345666	1234 COMMONWEALTH AVE	NEWTON	3	4/14/2011		Carried Forward	Pending		5/4/2023	16	Leak Extent	
7365094	160 PARKER ST	NEWTON	3	10/15/2020		Carried Forward	Pending		6/20/2023	9	Leak Extent	
270652	55 JEFFERSON ST	NEWTON	3	8/13/2004		Carried Forward	Pending		4/25/2023	4	Leak Extent	
1065965	32 RICHARDSON ST	NEWTON	3	11/29/2012		Carried Forward	Pending		4/25/2023	4	Leak Extent	
1428283	191 GROVE ST	NEWTON	3	10/8/2013		Carried Forward	Pending		5/16/2023	4	Leak Extent	
7325267	130 RACHEL RD	NEWTON	3	4/14/2016	3/16/2023	Carried Forward	Eliminated Otherwise		7/12/2022	4	Leak Extent	UPGRADE
7347786	DEDHAM ST & MEADOWBRO	NEWTON	3	9/29/2018		Carried Forward	Pending		5/16/2023	4	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificatio n)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7368732	1304 BOYLSTON ST	NEWTON	3	5/30/2021	1/9/2023	Carried Forward	Repaired		4/20/2022	4	Leak Extent	
7375170	275 AUBURN ST	NEWTON	3	6/3/2022		Carried Forward	Pending		3/21/2023	4	Leak Extent	
7356214	471 DEDHAM ST	NEWTON	3	9/5/2019		Carried Forward	Pending		3/10/2023	1	Leak Extent	
7364116	1774 COMMONWEALTH AVE	NEWTON	3	6/29/2020	8/14/2023	Carried Forward	Eliminated Otherwise		3/7/2023	1	Leak Extent	DUPLICATE LEAK
7374851	24 LESLIE RD	NEWTON	3	5/11/2022		Carried Forward	Pending		12/20/2023	1	Leak Extent	
232986	174 LEXINGTON ST	NEWTON	3	7/10/2002	3/3/2023	Carried Forward	Eliminated Otherwise		2/15/2023	-	No CGI reading	SYSTEM ISSUE
258079	2004 BEACON ST	NEWTON	3	3/2/2004		Carried Forward	Pending		11/16/2023	-	No CGI reading	
270391	WOODWARD ST & UPLAND R	NEWTON	3	4/22/2004	9/6/2023	Carried Forward	Repaired		7/31/2023	-	No CGI reading	
270497	WARD ST & ASHFORD RD	NEWTON	3	6/18/2004	12/5/2023	Carried Forward	Eliminated Otherwise		11/8/2023	-	No CGI reading	NO READS
270560	9 STRATFORD RD	NEWTON	3	7/1/2004		Carried Forward	Pending		11/16/2023	-	No CGI reading	
270590	35-45 MCCARTHY RD	NEWTON	3	7/22/2004		Carried Forward	Pending		11/6/2023	-	No CGI reading	
271927	NESHOBE RD & WASHINGTON	NEWTON	3	2/14/2005		Carried Forward	Pending		11/17/2023	-	No CGI reading	
284000	48 INDIANA TER	NEWTON	3	12/10/2005	11/8/2023	Carried Forward	Eliminated Otherwise		11/6/2023	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
290176	38 LOCKSLEY RD	NEWTON	3	12/6/2006		Carried Forward	Pending		7/12/2023	-	No CGI reading	
304740	275 MILL ST	NEWTON	3	8/31/2007	1/26/2023	Carried Forward	Repaired		8/23/2022	-	No CGI reading	
317344	116 RIDGE AVE	NEWTON	3	12/12/2008		Carried Forward	Pending		3/9/2023	-	No CGI reading	
321189	4 GARRISON ST	NEWTON	3	1/27/2009	7/27/2023	Carried Forward	Eliminated Otherwise		5/15/2023	-	No CGI reading	NO READS
341416	144 HANCOCK ST	NEWTON	3	1/28/2011	11/27/2023	Carried Forward	Repaired		11/16/2023	-	No CGI reading	
341457	71 WEBSTER PIKE	NEWTON	3	1/28/2011	7/27/2023	Carried Forward	Eliminated Otherwise		3/21/2023	-	No CGI reading	NO READS

Table L5 Newton Leak Report Dec 31, 2023														
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>									
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations		
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]			
349458	HIGHLAND ST & TEMPLE ST	NEWTON	3	8/14/2011	7/10/2023	Carried Forward	Eliminated Otherwise		5/16/2023	-	No CGI reading	NO READS		
693370	230 MOUNT VERNON ST	NEWTON	3	12/23/2011	7/10/2023	Carried Forward	Eliminated Otherwise		5/16/2023	-	No CGI reading	NO READS		
1018521	12 VINEYARD RD	NEWTON	3	10/12/2012		Carried Forward	Pending		11/17/2023	-	No CGI reading			
1150031	1957 BEACON ST	NEWTON	3	2/13/2013		Carried Forward	Pending		3/9/2023	-	No CGI reading			
1317702	91 PICKWICK RD	NEWTON	3	8/16/2013		Carried Forward	Pending		4/25/2023	-	No CGI reading			
1337372	229 CYPRESS ST	NEWTON	3	8/21/2013	11/29/2023	Carried Forward	Eliminated Otherwise		11/9/2023	-	No CGI reading	NO READS		
1363297	284 CHESTNUT ST	NEWTON	3	9/6/2013	3/24/2023	Carried Forward	Repaired		3/7/2023	-	No CGI reading			
1594140	43 GRAY CLIFF RD	NEWTON	3	1/16/2014	9/28/2023	Carried Forward	Repaired		2/10/2023	-	No CGI reading			
3023506	COMMONWEALTH AVE & CO	NEWTON	3	11/6/2014		Carried Forward	Pending		11/9/2023	-	No CGI reading			
3190426	5 MARY ELLEN RD	NEWTON	3	5/5/2015	5/1/2023	Carried Forward	Eliminated by Replacemen		5/4/2023	-	No CGI reading			
3869246	877 CHESTNUT ST	NEWTON	3	4/7/2015		Carried Forward	Pending		5/4/2023	-	No CGI reading			
3869342	212 GRANT AVE	NEWTON	3	4/9/2015		Carried Forward	Pending		11/16/2023	-	No CGI reading			
4105417	23 COLLEGE RD	NEWTON	3	3/22/2019	7/17/2023	Carried Forward	Eliminated Otherwise		7/11/2023	-	No CGI reading	NO READS		
4118969	141 RANDLETT PIKE	NEWTON	3	3/15/2015	7/27/2023	Carried Forward	Eliminated Otherwise		5/4/2023	-	No CGI reading	NO READS		
5217418	499 WINCHESTER ST	NEWTON	3	6/16/2015		Carried Forward	Pending		7/18/2023	-	No CGI reading			
5620468	121 PARKER AVE	NEWTON	3	8/27/2015		Carried Forward	Pending		11/13/2023	-	No CGI reading			

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classifica tion)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7322667	12 CHAMBERLAIN RD	NEWTON	3	1/12/2016	12/22/2023	Carried Forward	Eliminated Otherwise		11/13/2023	-	No CGI reading	NO READS
7322832	49 ASHMONT AVE	NEWTON	3	4/25/2016		Carried Forward	Pending		3/10/2023	-	No CGI reading	
7323095	21 TURNER TER	NEWTON	3	1/21/2016	12/22/2023	Carried Forward	Eliminated Otherwise		11/13/2023	-	No CGI reading	NO READS
7323736	35 BELLEVUE ST	NEWTON	3	2/2/2016		Carried Forward	Pending		3/10/2023	-	No CGI reading	
7323783	38 PUTNAM ST	NEWTON	3	2/1/2016		Carried Forward	Pending		4/25/2023	-	No CGI reading	
7325235	525 WALNUT ST	NEWTON	3	6/9/2016	5/1/2023	Carried Forward	Eliminated Otherwise		9/20/2022	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7326611	26 MAPLE ST	NEWTON	3	6/6/2016		Carried Forward	Pending		5/15/2023	-	No CGI reading	
7326995	3 LANGLEY RD	NEWTON	3	6/15/2016	7/10/2023	Carried Forward	Eliminated Otherwise		5/15/2023	-	No CGI reading	NO READS
7327024	118 MEADOWBROOK RD	NEWTON	3	6/22/2016	9/28/2023	Carried Forward	Eliminated by Replacemen		9/13/2023	-	No CGI reading	
7327405	DAVIS AVE & EDEN AVE	NEWTON	3	6/27/2016		Carried Forward	Pending		9/12/2023	-	No CGI reading	
7330111	28 CONSIDINE RD	NEWTON	3	11/3/2016		Carried Forward	Pending		12/12/2023	-	No CGI reading	
7331479	425 CENTRE ST	NEWTON	3	1/3/2017	12/28/2023	Carried Forward	Eliminated Otherwise		11/17/2023	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7332931	COMMONWEALTH AVE & BEA	NEWTON	3	3/23/2017		Carried Forward	Pending		11/9/2023	-	No CGI reading	
7336298	867 DEDHAM ST	NEWTON	3	7/10/2017	9/28/2023	Carried Forward	Eliminated by Replacemen		9/12/2023	-	No CGI reading	
7338743	50 FORDHAM RD	NEWTON	3	9/26/2017	7/27/2023	Carried Forward	Eliminated Otherwise		5/16/2023	-	No CGI reading	NO READS
7338876	47 FELLSMERE RD	NEWTON	3	9/27/2017	7/27/2023	Carried Forward	Eliminated Otherwise		4/25/2023	-	No CGI reading	NO READS

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7339363	4 EVERGREEN AVE	NEWTON	3	10/21/2017	7/6/2023	Carried Forward	Eliminated Otherwise		3/16/2023	-	No CGI reading	NO READS
7339900	57 WARREN RD	NEWTON	3	10/30/2017	7/27/2023	Carried Forward	Eliminated Otherwise		4/24/2023	-	No CGI reading	NO READS
7345718	DEDHAM ST & MEADOWBRO	NEWTON	3	7/13/2018		Carried Forward	Pending		5/12/2023	-	No CGI reading	
7348856	140 STANLEY RD	NEWTON	3	7/13/2018	7/27/2023	Carried Forward	Eliminated Otherwise		5/11/2023	-	No CGI reading	NO READS
7350045	400 WAVERLY AVE	NEWTON	3	12/26/2018	7/27/2023	Carried Forward	Eliminated Otherwise		4/25/2023	-	No CGI reading	NO READS
7352431	54 TEMPLE ST	NEWTON	3	3/28/2019		Carried Forward	Pending		7/18/2023	-	No CGI reading	
7353512	47 CHANDLER PL	NEWTON	3	5/23/2019		Carried Forward	Pending		11/13/2023	-	No CGI reading	
7354715	6 EDGEWOOD RD	NEWTON	3	7/19/2019		Carried Forward	Pending		11/16/2023	-	No CGI reading	
7355415	7 FREDETTE RD	NEWTON	3	8/2/2019	12/5/2023	Carried Forward	Eliminated Otherwise		11/9/2023	-	No CGI reading	NO READS
7355428	265 RIVER ST	NEWTON	3	7/25/2019	3/6/2023	Carried Forward	Repaired		3/3/2023	-	No CGI reading	
7355442	361 THORNTON ST	NEWTON	3	8/1/2019		Carried Forward	Pending		12/12/2023	-	No CGI reading	
7355674	188 DEDHAM ST	NEWTON	3	8/23/2019		Carried Forward	Pending		12/14/2023	-	No CGI reading	
7356139	344 BROOKLINE ST	NEWTON	3	9/3/2019		Carried Forward	Pending		3/9/2023	-	No CGI reading	
7356203	17 WAYNE RD	NEWTON	3	9/4/2019		Carried Forward	Pending		3/10/2023	-	No CGI reading	
7356207	36 WISWALL RD	NEWTON	3	9/5/2019		Carried Forward	Pending		3/10/2023	-	No CGI reading	
7356368	36 BONTEMPO RD	NEWTON	3	9/25/2019	7/6/2023	Carried Forward	Eliminated Otherwise		4/24/2023	-	No CGI reading	NO READS

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificatio n)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7356370	47 BONTEMPO RD	NEWTON	3	9/25/2019	9/28/2023	Carried Forward	Eliminated by Replacemen		4/24/2023	-	No CGI reading	
7356413	27 BONTEMPO RD	NEWTON	3	9/26/2019	7/6/2023	Carried Forward	Eliminated Otherwise		4/24/2023	-	No CGI reading	NO READS
7356514	25 TURNER TER	NEWTON	3	9/10/2019	7/6/2023	Carried Forward	Eliminated Otherwise		3/13/2023	-	No CGI reading	NO READS
7359597	8 WOODCHESTER DR	NEWTON	3	1/30/2020	1/11/2023	Carried Forward	Eliminated Otherwise		12/9/2022	-	No CGI reading	NO READS
7359897	26 COOK ST	NEWTON	3	3/30/2020		Carried Forward	Pending		9/13/2023	-	No CGI reading	
7359968	33 COLLINS RD	NEWTON	3	8/18/2020	7/27/2023	Carried Forward	Eliminated Otherwise		5/4/2023	-	No CGI reading	NO READS
7360337	44 MARY ELLEN RD	NEWTON	3	3/14/2020	5/1/2023	Carried Forward	Eliminated by Replacemen		11/28/2022	-	No CGI reading	
7364119	23 MAPLE ST	NEWTON	3	5/13/2020		Carried Forward	Pending		11/14/2023	-	No CGI reading	
7364449	20 STONEWOOD DR	NEWTON	3	8/9/2020	7/27/2023	Carried Forward	Eliminated Otherwise		3/16/2023	-	No CGI reading	NO READS
7364832	274 AUBURNDALE AVE	NEWTON	3	8/14/2020	7/6/2023	Carried Forward	Eliminated Otherwise		4/25/2023	-	No CGI reading	NO READS
7365409	64 OBER RD	NEWTON	3	12/21/2020	7/17/2023	Carried Forward	Eliminated Otherwise		7/11/2023	-	No CGI reading	NO READS
7368733	17 COCHITUATE RD	NEWTON	3	5/19/2021		Carried Forward	Pending		12/13/2023	-	No CGI reading	
7370883	389 CENTRAL ST	NEWTON	3	9/14/2021	6/1/2023	Carried Forward	Eliminated Otherwise		6/1/2023	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7370889	375 AUBURN ST	NEWTON	3	9/19/2021		Carried Forward	Pending		6/20/2023	-	No CGI reading	
7371857	26 PARK LN	NEWTON	3	11/21/2021	7/17/2023	Carried Forward	Eliminated Otherwise		7/12/2023	-	No CGI reading	NO READS
7371862	26 VAN ROOSEN RD	NEWTON	3	11/8/2021	7/17/2023	Carried Forward	Eliminated Otherwise		7/11/2023	-	No CGI reading	NO READS

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7373591	495 WATERTOWN ST	NEWTON	3	1/21/2022	9/13/2023	Carried Forward	Eliminated Otherwise		9/12/2023	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7374799	1730 WASHINGTON ST	NEWTON	3	4/5/2023		Carried Forward	Pending	2	2/13/2023	-	No CGI reading	
7374835	138 WARREN ST	NEWTON	3	4/8/2022	3/2/2023	Carried Forward	Eliminated Otherwise		3/1/2023	-	No CGI reading	WRONG ADDRESS
7374838	64 OAK ST	NEWTON	3	4/13/2022	11/29/2023	Carried Forward	Repaired		9/26/2023	-	No CGI reading	
7376318	39 BILLINGS PIKE	NEWTON	3	8/3/2022		Carried Forward	Pending		6/1/2023	-	No CGI reading	
7376320	CARLTON RD & WABAN AVE	NEWTON	3	8/2/2022	5/16/2023	Carried Forward	Eliminated Otherwise			-		REPAIRED UNDER OTHER LEAK REPAIR
7376329	1595 WASHINGTON ST	NEWTON	3	7/28/2022		Carried Forward	Pending		9/15/2023	-	No CGI reading	
7376817	115 SHERIDAN ST	NEWTON	3	8/18/2022	8/3/2023	Carried Forward	Repaired		6/22/2023	-	No CGI reading	
7376826	12 COPLEY ST	NEWTON	3	4/15/2022		Carried Forward	Pending		3/8/2023	-	No CGI reading	
7377815	2096 WASHINGTON ST	NEWTON	3	8/13/2022		Carried Forward	Pending		6/22/2023	-	No CGI reading	
7377817	21 IVANHOE ST	NEWTON	3	9/2/2022	7/17/2023	Carried Forward	Eliminated Otherwise		7/12/2023	-	No CGI reading	NO READS
7377831	155 WOODWARD ST	NEWTON	3	8/1/2022	11/27/2023	Carried Forward	Repaired		9/15/2023	-	No CGI reading	
7377997	216 LOWELL AVE	NEWTON	3	10/3/2022	7/21/2023	Carried Forward	Eliminated Otherwise		7/19/2023	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7378483	15 SHERIDAN ST	NEWTON	3	11/4/2022	3/2/2023	Carried Forward	Eliminated Otherwise		1/27/2023	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7378587	8 EARLY PATH	NEWTON	3	11/15/2022	2/23/2023	Carried Forward	Eliminated Otherwise			-		DUPLICATE LEAK
7378751	2 KINGSTON RD	NEWTON	3	11/7/2022	2/23/2023	Carried Forward	Eliminated Otherwise			-		DUPLICATE LEAK
7378796	960 WALNUT ST	NEWTON	3	11/10/2022	5/1/2023	Carried Forward	Eliminated Otherwise			-		REPAIRED UNDER OTHER LEAK REPAIR

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7378999	1 OAK AVE	NEWTON	3	11/3/2022	5/10/2023	Carried Forward	Eliminated Otherwise		11/3/2022	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7379081	497 BOYLSTON ST	NEWTON	3	1/4/2023		Newly Identified	Pending		11/7/2023	-	No CGI reading	
7379116	151 WINCHESTER ST	NEWTON	3	1/4/2023	12/20/2023	Newly Identified	Repaired		11/7/2023	-	No CGI reading	
7379171	74 FAIRMONT AVE	NEWTON	3	6/13/2023		Newly Identified	Pending	2	5/15/2023	-	No CGI reading	
7379289	89 MONTROSE ST	NEWTON	3	12/21/2022	1/24/2023	Carried Forward	Repaired		1/26/2023	-	No CGI reading	
7379296	25 OLD ENGLAND RD	NEWTON	3	1/11/2023	2/23/2023	Newly Identified	Eliminated Otherwise			-		DUPLICATE LEAK
7379848	457 WAVERLY AVE	NEWTON	3	2/13/2023	12/5/2023	Newly Identified	Eliminated Otherwise		11/8/2023	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7379881	63 GARLAND RD	NEWTON	3	2/2/2023	12/18/2023	Newly Identified	Eliminated Otherwise		11/15/2023	-	No CGI reading	NO READS
7379907	85 MONTVALE RD	NEWTON	3	1/27/2023	6/29/2023	Newly Identified	Repaired			-		
7379908	100 OLDEFIELD RD	NEWTON	3	2/12/2023	8/9/2023	Newly Identified	Eliminated Otherwise			-		REPAIRED UNDER OTHER LEAK REPAIR
7379912	692 BOYLSTON ST	NEWTON	3	1/30/2023	6/27/2023	Newly Identified	Repaired			-		
7379914	750 BOYLSTON ST	NEWTON	3	2/25/2023		Newly Identified	Pending		12/5/2023	-	No CGI reading	
7379915	760 BOYLSTON ST	NEWTON	3	1/30/2023		Newly Identified	Pending		11/7/2023	-	No CGI reading	
7380668	10 ANNAWAN RD	NEWTON	3	3/27/2023		Newly Identified	Pending			-	Survey to be provided	
7380669	1880 BEACON ST	NEWTON	3	3/27/2023		Newly Identified	Pending			-	Survey to be provided	
7380670	122 CARVER RD	NEWTON	3	4/13/2023		Newly Identified	Pending			-	Survey to be provided	
7380671	118 EVELYN RD	NEWTON	3	3/30/2023	5/1/2023	Newly Identified	Eliminated by Replacement			-		
7380672	31 GARDNER ST	NEWTON	3	3/23/2023		Newly Identified	Pending			-	Survey to be provided	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7380673	205 HOMER ST	NEWTON	3	4/11/2023		Newly Identified	Pending			-	Survey to be provided	
7380674	10 LOWELL AVE	NEWTON	3	2/24/2023		Newly Identified	Pending		11/16/2023	-	No CGI reading	
7380676	923 WALNUT ST	NEWTON	3	4/6/2023		Newly Identified	Pending			-	Survey to be provided	
7380678	183 WINCHESTER ST	NEWTON	3	3/31/2023	5/1/2023	Newly Identified	Eliminated Otherwise			-		DUPLICATE LEAK
7381364	376 HOMER ST	NEWTON	3	5/11/2023	9/15/2023	Newly Identified	Eliminated by Replacement			-		
7382267	78 FARLOW RD	NEWTON	3	6/21/2023		Newly Identified	Pending			-	Survey to be provided	
7382268	243 ISLINGTON RD	NEWTON	3	6/20/2023		Newly Identified	Pending			-	Survey to be provided	
7382270	53 HIGH ST	NEWTON	3	6/7/2023		Newly Identified	Pending			-	Survey to be provided	
7382271	2322 WASHINGTON ST	NEWTON	3	6/20/2023		Newly Identified	Pending			-	Survey to be provided	
7382336	24 PHILBRICK RD	NEWTON	3	6/26/2023		Newly Identified	Pending			-	Survey to be provided	
7382337	264 WINCHESTER ST	NEWTON	3	6/9/2023		Newly Identified	Pending			-	Survey to be provided	
7382533	43 COTTON ST	NEWTON	3	9/22/2023	10/10/2023	Newly Identified	Repaired	2		-		
7382778	45 WATERSTON RD	NEWTON	3	8/4/2023	8/4/2023	Newly Identified	Repaired			-		
7382898	160 BOYLSTON ST	NEWTON	3	7/1/2023		Newly Identified	Pending			-	Survey to be provided	
7382899	298 CYPRESS ST	NEWTON	3	7/8/2023		Newly Identified	Pending			-	Survey to be provided	
7382908	100 OLDEFIELD RD	NEWTON	3	7/14/2023		Newly Identified	Pending			-	Survey to be provided	
7383023	1261 CENTRE ST	NEWTON	3	8/4/2023		Newly Identified	Pending		8/4/2023	-	No CGI reading	
7383025	DAVIS ST & HIGHLAND ST	NEWTON	3	7/26/2023		Newly Identified	Pending			-	Survey to be provided	
7383298	20 STAR RD	NEWTON	3	9/1/2023	9/1/2023	Newly Identified	Repaired			-		

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023 Name of Operator: <i>Boston Gas Company</i>										
Leak ID (if applicable)	Location		Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name	Town/City							Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7383506	CALIFORNIA ST & BRIDGE ST	NEWTON	3	8/30/2023		Newly Identified	Pending		8/30/2023	-	No CGI reading	
7383509	118 LANGLEY RD	NEWTON	3	8/15/2023		Newly Identified	Pending		8/15/2023	-	No CGI reading	
7383510	43 PHILBRICK RD	NEWTON	3	9/5/2023		Newly Identified	Pending		9/5/2023	-	No CGI reading	
7383512	5 SHELDON RD	NEWTON	3	8/29/2023		Newly Identified	Pending		8/29/2023	-	No CGI reading	
7383831	250 ALBEMARLE RD	NEWTON	3	9/17/2023		Newly Identified	Pending			-	Survey to be provided	
7383832	59 PONTIAC RD	NEWTON	3	9/21/2023		Newly Identified	Pending			-	Survey to be provided	
7383833	WASHINGTON ST & CENTRE S	NEWTON	3	9/13/2023		Newly Identified	Pending			-	Survey to be provided	
7384346	45 HOLMAN RD	NEWTON	3	9/28/2023		Newly Identified	Pending			-	Survey to be provided	
7384348	38 MORELAND AVE	NEWTON	3	9/28/2023		Newly Identified	Pending			-	Survey to be provided	
7384585	22 BERWICK RD	NEWTON	3	10/15/2023		Newly Identified	Pending			-	Survey to be provided	
7384586	80 WOODCHESTER DR	NEWTON	3	10/12/2023		Newly Identified	Pending			-	Survey to be provided	
7384691	320 WASHINGTON ST	NEWTON	3	11/15/2023		Newly Identified	Pending			-	Survey to be provided	
7384931	BROOKSIDE AVE & ALBEMARLE	NEWTON	3	11/10/2023		Newly Identified	Pending			-	Survey to be provided	
7385305	937 DEDHAM ST	NEWTON	3	12/9/2023		Newly Identified	Pending			-	Survey to be provided	
7385308	55 FOREST AVE	NEWTON	3	12/9/2023		Newly Identified	Pending			-	Survey to be provided	
7385309	20 GREENLAWN AVE	NEWTON	3	12/20/2023		Newly Identified	Pending			-	Survey to be provided	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificatio n)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7385311	23 DAVIS ST	NEWTON	3	12/19/2023		Newly Identified	Pending			-	Survey to be provided	
100193	9 CARTER ST	NEWTON	2	1/20/2023	2/9/2023	Carried Forward	Repaired					
293593	12 PLEASANT ST	NEWTON	2	2/13/2023	3/1/2023	Carried Forward	Repaired					
307227	210 COTTON ST	NEWTON	2	1/19/2023	2/2/2023	Carried Forward	Repaired					
333022	WASHBURN AVE & AUBURN D	NEWTON	2	2/9/2023	3/20/2023	Carried Forward	Repaired					
591420	342 BEACON ST	NEWTON	2	2/22/2023	3/18/2023	Carried Forward	Repaired					
1215753	52 ELLIOT ST	NEWTON	2	2/15/2023		Carried Forward	Pending					
1217730	10 OAK TER	NEWTON	2	5/12/2023	7/21/2023	Carried Forward	Repaired	3				
1286045	12 MURRAY RD	NEWTON	2	1/27/2023	2/9/2023	Carried Forward	Repaired					
1286053	LEXINGTON ST & SCRIBNER PI	NEWTON	2	1/27/2023	2/10/2023	Carried Forward	Repaired					
1336115	156 OAK ST	NEWTON	2	4/17/2020		Carried Forward	Pending					
1363327	36 ROSLYN RD	NEWTON	2	1/27/2023	2/9/2023	Carried Forward	Repaired					
2835044	1766 COMMONWEALTH AVE	NEWTON	2	7/21/2023	10/26/2023	Carried Forward	Eliminated O	3				REPAIRED UNDER OTHER LEAK REPAIR
7332283	76 WALDEN ST	NEWTON	2	9/12/2023	10/3/2023	Carried Forward	Repaired	3				
7336761	425 WATERTOWN ST	NEWTON	2	2/14/2023		Carried Forward	Pending					
7351330	34 COLLINS RD	NEWTON	2	6/23/2023	7/27/2023	Carried Forward	Eliminated O	3				NO READS
7353077	8 HOPE ST	NEWTON	2	9/30/2023	11/28/2023	Carried Forward	Repaired	3				
7353689	454 WALNUT ST	NEWTON	2	5/24/2022	2/15/2023	Carried Forward	Eliminated Otherwise					UPGRADE
7353695	90 HIGHLAND AVE	NEWTON	2	6/1/2023	6/21/2023	Carried Forward	Eliminated O	3				NO READS
7354043	170 NEEDHAM ST	NEWTON	2	5/21/2020		Carried Forward	Pending					
7354148	238 TREMONT ST	NEWTON	2	2/21/2023	3/16/2023	Carried Forward	Eliminated Otherwise					NO READS
7354261	MELROSE AVE & MELROSE ST	NEWTON	2	11/16/2023		Carried Forward	Pending	3				
7354538	5 MARSHALL ST	NEWTON	2	11/16/2023		Carried Forward	Pending	3				
7354888	624 BEACON ST	NEWTON	2	6/17/2020		Carried Forward	Pending					
7355426	7 KILBURN RD	NEWTON	2	10/11/2023	11/27/2023	Carried Forward	Repaired	3				
7356367	350 WINCHESTER ST	NEWTON	2	12/4/2023		Carried Forward	Pending	3				
7356436	317 PARKER ST	NEWTON	2	7/27/2021		Carried Forward	Pending					
7365827	5 OLDEFIELD RD	NEWTON	2	1/19/2021		Carried Forward	Pending					

Table L5 Newton Leak Report Dec 31, 2023													
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations	
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]		
7366850	176 BOYLSTON ST	NEWTON	1	3/24/2021		Carried Forward	Pending						
7370687	1129 WALNUT ST	NEWTON	2	5/11/2023	5/24/2023	Carried Forward	Repaired	3					
7373055	56 CRESCENT AVE	NEWTON	2	1/25/2022	1/17/2023	Carried Forward	Repaired						
7374403	963 BOYLSTON ST	NEWTON	2	4/22/2022	5/2/2023	Carried Forward	Repaired						
7374797	1675 WASHINGTON ST	NEWTON	2	5/10/2022	4/6/2023	Carried Forward	Eliminated Otherwise					NO READS	
7374815	211 HIGHLAND AVE	NEWTON	2	5/12/2022	9/13/2023	Carried Forward	Eliminated Otherwise					NO READS	
7374816	951 WALNUT ST	NEWTON	2	4/2/2022	1/11/2023	Carried Forward	Eliminated Otherwise					NO READS	
7374832	366 ELLIOT ST	NEWTON	2	12/20/2023		Carried Forward	Pending	3					
7374846	90 ELM ST	NEWTON	2	3/16/2023	4/21/2023	Carried Forward	Repaired						
7375091	21 CHANDLER PL	NEWTON	2	6/10/2022	7/11/2023	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR	
7375092	88 ESSEX RD	NEWTON	2	5/12/2022		Carried Forward	Pending						
7375098	1149 WASHINGTON ST	NEWTON	2	5/16/2022	4/6/2023	Carried Forward	Eliminated Otherwise					NO READS	
7375346	61 HUNTINGTON RD	NEWTON	2	6/1/2022	11/20/2023	Carried Forward	Eliminated Otherwise					NO READS	
7375721	100 BOYLSTON ST	NEWTON	2	6/2/2022	11/13/2023	Carried Forward	Repaired						
7376043	737 DEDHAM ST	NEWTON	2	5/23/2022	12/4/2023	Carried Forward	Repaired						
7376438	281 HOMER ST	NEWTON	2	7/29/2022		Carried Forward	Pending						
7376441	1650 WASHINGTON ST	NEWTON	2	7/28/2022	4/6/2023	Carried Forward	Eliminated Otherwise					NO READS	
7376565	290 DERBY ST	NEWTON	2	8/24/2022	11/28/2023	Carried Forward	Repaired						
7376582	245 RIVER ST	NEWTON	2	8/19/2022	11/29/2023	Carried Forward	Repaired						
7377314	249 DERBY ST	NEWTON	2	9/2/2022	2/9/2023	Carried Forward	Eliminated Otherwise					WRONG ADDRESS	
7377316	787 WASHINGTON ST	NEWTON	2	1/12/2023	7/20/2023	Carried Forward	Eliminated Otherwise					NO READS	
7377627	12 FERNCROFT RD	NEWTON	2	3/24/2023	5/18/2023	Carried Forward	Eliminated O	3				REPAIRED UNDER OTHER LEAK REPAIR	
7377630	545 PARKER ST	NEWTON	2	10/7/2022	11/27/2023	Carried Forward	Repaired						
7377830	37 GLENWOOD AVE	NEWTON	2	7/12/2023	8/24/2023	Carried Forward	Repaired	3					
7378110	599 COMMONWEALTH AVE	NEWTON	2	10/28/2022	11/30/2023	Carried Forward	Repaired						
7378159	640 BOYLSTON ST	NEWTON	2	11/8/2022	6/22/2023	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR	
7378163	371 WASHINGTON ST	NEWTON	2	11/8/2022	8/1/2023	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR	

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7378190	250 ALBEMARLE RD	NEWTON	2	11/9/2022	4/27/2023	Carried Forward	Repaired					
7378193	4 JUDITH RD	NEWTON	2	11/8/2022		Carried Forward	Pending					
7378467	316 CENTRAL ST	NEWTON	2	8/21/2023		Carried Forward	Pending	3				
7378649	53 VAN ROOSEN RD	NEWTON	2	3/28/2023	7/13/2023	Carried Forward	Repaired	3				
7378798	126 NONANTUM RD	NEWTON	2	10/19/2022	8/29/2023	Carried Forward	Eliminated by Replacement					
7378966	719 WATERTOWN ST	NEWTON	1	1/4/2023	1/4/2023	Newly Identified	Repaired					
7378969	1190 BOYLSTON ST	NEWTON	1	1/4/2023	1/14/2023	Newly Identified	Repaired					
7379010	315 HIGHLAND AVE	NEWTON	2	12/27/2022	1/17/2023	Carried Forward	Eliminated Otherwise					NO READS
7379035	525 WALNUT ST	NEWTON	1	1/9/2023	1/9/2023	Newly Identified	Repaired					
7379036	2311 WASHINGTON ST	NEWTON	1	1/9/2023	1/10/2023	Newly Identified	Repaired					
7379078	336 LEXINGTON ST	NEWTON	2	1/6/2023	1/25/2023	Newly Identified	Repaired					
7379079	30 KILBURN RD	NEWTON	2	1/9/2023	1/24/2023	Newly Identified	Repaired					
7379088	104 AUSTIN ST	NEWTON	1	1/11/2023	1/11/2023	Newly Identified	Repaired					
7379129	54 LORNA RD	NEWTON	1	1/12/2023	1/12/2023	Newly Identified	Repaired					
7379149	19 PELHAM ST	NEWTON	1	1/13/2023	1/13/2023	Newly Identified	Repaired					
7379169	13 ASHMONT AVE	NEWTON	2	1/10/2023	1/25/2023	Newly Identified	Repaired					
7379170	41 AUBURN ST	NEWTON	2	1/11/2023	1/24/2023	Newly Identified	Repaired					
7379172	250 FULLER ST	NEWTON	2	1/11/2023	1/24/2023	Newly Identified	Repaired					
7379173	46 GARDNER ST	NEWTON	2	1/10/2023	1/26/2023	Newly Identified	Repaired					
7379207	43 WYOMING RD	NEWTON	1	1/18/2023	1/18/2023	Newly Identified	Repaired					
7379236	853 WASHINGTON ST	NEWTON	2	1/10/2023	1/4/2023	Newly Identified	Repaired					
7379237	152 LEXINGTON ST	NEWTON	2	1/7/2023	2/6/2023	Newly Identified	Repaired					
7379281	544 GROVE ST	NEWTON	2	11/7/2023	12/19/2023	Newly Identified	Repaired	3				
7379321	614 DEDHAM ST	NEWTON	2	1/5/2023	2/2/2023	Newly Identified	Repaired					
7379421	43 WYOMING RD	NEWTON	1	1/30/2023	1/30/2023	Newly Identified	Repaired					
7379428	414 WALTHAM ST	NEWTON	1	1/31/2023	1/31/2023	Newly Identified	Repaired					
7379457	575 WASHINGTON ST	NEWTON	2	7/12/2023	11/17/2023	Newly Identified	Eliminated O	3				NO READS
7379482	94 REDWOOD RD	NEWTON	1	2/2/2023	2/2/2023	Newly Identified	Repaired					
7379489	55 MURRAY RD	NEWTON	1	2/2/2023	2/2/2023	Newly Identified	Repaired					
7379564	25 CORNELL ST	NEWTON	1	2/9/2023	2/9/2023	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2023													
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location		Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks				
	Street Number and Name								Town/City	Survey Designatio n Date	Leak Extent or Barhole Reading		Method Used [Leak Extent/ Barhole]
7379566	GREENLAWN AVE & HOMER ST	NEWTON	2	1/30/2023	3/1/2023	Newly Identified	Repaired						
7379608	1385 WALNUT ST	NEWTON	1	2/10/2023	2/10/2023	Newly Identified	Repaired						
7379613	142 WALNUT HILL RD	NEWTON	1	2/10/2023	2/10/2023	Newly Identified	Repaired						
7379638	66 PLEASANT ST	NEWTON	1	2/13/2023	2/13/2022	Newly Identified	Repaired					Date error: WO closed 2/17/2023	
7379641	454 WALNUT ST	NEWTON	1	2/13/2023	2/13/2023	Newly Identified	Repaired						
7379677	317 WASHINGTON ST	NEWTON	1	2/14/2023	2/22/2023	Newly Identified	Eliminated Otherwise					CALLED OFF BY SUPERVISOR	
7379706	1224 BOYLSTON ST	NEWTON	1	2/15/2023	2/22/2023	Newly Identified	Repaired						
7379741	925 CHESTNUT ST	NEWTON	1	2/16/2023	2/18/2023	Newly Identified	Repaired						
7379748	384 BOYLSTON ST	NEWTON	2	2/7/2023	6/22/2023	Newly Identified	Repaired						
7379781	25 COPLEY ST	NEWTON	1	2/21/2023	2/21/2023	Newly Identified	Repaired						
7379859	18 MURRAY TER	NEWTON	1	2/25/2023	2/26/2023	Newly Identified	Repaired						
7379866	93 CARVER RD	NEWTON	2	2/12/2023	2/27/2023	Newly Identified	Repaired						
7379904	15 SHERIDAN ST	NEWTON	1	2/28/2023	3/1/2023	Newly Identified	Repaired						
7379911	616 BOYLSTON ST	NEWTON	2	6/20/2023	7/18/2023	Newly Identified	Eliminated O	3				REPAIRED UNDER OTHER LEAK REPAIR	
7379926	15 BROADLAWN DR	NEWTON	1	3/1/2023	3/1/2023	Newly Identified	Repaired						
7379930	702 BOYLSTON ST	NEWTON	2	2/15/2023	6/22/2023	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR	
7379946	20 WHITLOWE RD	NEWTON	1	3/2/2023	3/2/2023	Newly Identified	Repaired						
7379954	255 PARKER ST	NEWTON	1	3/3/2023	3/6/2023	Newly Identified	Eliminated Otherwise					CALLED OFF BY SUPERVISOR	
7379962	174 LEXINGTON ST	NEWTON	2	2/15/2023	3/10/2023	Newly Identified	Repaired						
7379991	16 DERBY ST	NEWTON	1	3/7/2023	3/7/2023	Newly Identified	Repaired						
7380058	31 ASHEVILLE RD	NEWTON	2	2/9/2023	3/22/2023	Newly Identified	Repaired						
7380059	92 CHERRY ST	NEWTON	2	2/13/2023	3/24/2023	Newly Identified	Repaired						
7380098	130 RACHEL RD	NEWTON	1	3/15/2023	3/15/2023	Newly Identified	Repaired						
7380104	65 BERNARD ST	NEWTON	1	3/15/2023	3/15/2023	Newly Identified	Repaired						
7380116	74 RACHEL RD	NEWTON	1	3/16/2023	3/16/2023	Newly Identified	Repaired						
7380137	255 PARKER ST	NEWTON	1	3/18/2023	3/22/2023	Newly Identified	Repaired						

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7380201	ALBEMARLE RD & WATERTOWN	NEWTON	2	3/5/2023	3/24/2023	Newly Identified	Repaired					
7380202	66 LANGDON ST	NEWTON	1	3/24/2023	3/24/2023	Newly Identified	Repaired					
7380205	13 HENSHAW TER	NEWTON	1	3/24/2023	3/24/2023	Newly Identified	Repaired					
7380214	17 FERNCROFT RD	NEWTON	1	3/26/2023	3/27/2023	Newly Identified	Repaired					
7380222	66 LANGDON ST	NEWTON	1	3/27/2023	3/27/2023	Newly Identified	Repaired					
7380231	31 CORNELL ST	NEWTON	1	3/27/2023	3/28/2023	Newly Identified	Repaired					
7380286	491 DUDLEY RD	NEWTON	1	3/31/2023	3/31/2023	Newly Identified	Repaired					
7380293	770 CENTRE ST	NEWTON	1	3/31/2023	3/31/2023	Newly Identified	Repaired					
7380299	491 DUDLEY RD	NEWTON	1	4/1/2023	4/1/2023	Newly Identified	Repaired					
7380332	90 ELM ST	NEWTON	2	3/16/2023	4/5/2023	Newly Identified	Eliminated Otherwise					SYSTEM ISSUE
7380368	32 WASHBURN ST	NEWTON	1	4/6/2023	4/6/2023	Newly Identified	Eliminated Otherwise					WRONG ADDRESS
7380375	297 LOWELL AVE	NEWTON	1	4/6/2023	4/6/2023	Newly Identified	Repaired					
7380433	61 MONTVALE RD	NEWTON	1	4/10/2023	4/10/2023	Newly Identified	Repaired					
7380465	494 WATERTOWN ST	NEWTON	1	4/12/2023	4/13/2023	Newly Identified	Repaired					
7380505	961 WALNUT ST	NEWTON	1	4/14/2023	4/16/2023	Newly Identified	Repaired					
7380508	956 WALNUT ST	NEWTON	1	4/16/2023	4/16/2023	Newly Identified	Repaired					
7380544	961 WALNUT ST	NEWTON	1	4/18/2023	4/18/2023	Newly Identified	Repaired					
7380568	512 DEDHAM ST	NEWTON	1	4/19/2023	4/20/2023	Newly Identified	Repaired					
7380664	126 EVELYN RD	NEWTON	2	4/17/2023	5/1/2023	Newly Identified	Eliminated by Replacement					
7380666	32 ELIZABETH CIR	NEWTON	2	4/11/2023	5/1/2023	Newly Identified	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7380701	1033 WALNUT ST	NEWTON	2	4/16/2023	5/11/2023	Newly Identified	Repaired					
7380704	2390 COMMONWEALTH AVE	NEWTON	1	4/26/2023	4/28/2023	Newly Identified	Repaired					
7380707	183 WINCHESTER ST	NEWTON	2	5/31/2023	6/27/2023	Newly Identified	Repaired	3				
7380760	985 BEACON ST	NEWTON	1	4/29/2023	4/29/2023	Newly Identified	Repaired					
7380780	27 BOYLSTON ST	NEWTON	1	5/1/2023	5/1/2023	Newly Identified	Repaired					
7380844	961 WALNUT ST	NEWTON	1	5/2/2023	5/2/2023	Newly Identified	Repaired					
7380872	1000 COMMONWEALTH AVE	NEWTON	1	5/3/2023	5/4/2023	Newly Identified	Repaired					
7380874	282 WATERTOWN ST	NEWTON	1	5/4/2023	5/4/2023	Newly Identified	Repaired					
7380907	20 MANET RD	NEWTON	1	5/5/2023	5/5/2023	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7380928	961 WALNUT ST	NEWTON	1	5/6/2023	5/6/2023	Newly Identified	Repaired					
7380934	20 AUBURNDALE AVE	NEWTON	1	5/7/2023	5/9/2023	Newly Identified	Repaired					
7380935	79 CHARLEMONT ST	NEWTON	1	5/7/2023	5/8/2023	Newly Identified	Repaired					
7380997	KERRY CT & PINE ST	NEWTON	1	5/10/2023	5/10/2023	Newly Identified	Repaired					
7381003	9 WILLIAM ST	NEWTON	1	5/10/2023	5/10/2023	Newly Identified	Repaired					
7381021	15 BEAUMONT AVE	NEWTON	1	5/11/2023	5/11/2023	Newly Identified	Repaired					
7381065	46 COCHITUATE RD	NEWTON	1	5/13/2023	5/14/2023	Newly Identified	Repaired					
7381080	46 COCHITUATE RD	NEWTON	1	5/15/2023	5/15/2023	Newly Identified	Repaired					
7381137	93 CARLTON RD	NEWTON	2	5/10/2023	5/23/2023	Newly Identified	Repaired					
7381138	100 OLDEFIELD RD	NEWTON	2	5/8/2023	5/26/2023	Newly Identified	Repaired					
7381200	121 VALENTINE ST	NEWTON	2	4/12/2023	6/1/2023	Newly Identified	Repaired					
7381201	25 CLEMENTS RD	NEWTON	1	5/18/2023	5/18/2023	Newly Identified	Repaired					
7381314	19 ADELLA AVE	NEWTON	1	5/24/2023	5/24/2023	Newly Identified	Repaired					
7381511	389 CENTRAL ST	NEWTON	1	6/1/2023	6/1/2023	Newly Identified	Repaired					
7381530	22 SHAW ST	NEWTON	1	6/1/2023	6/1/2023	Newly Identified	Repaired					
7381578	1169 WASHINGTON ST	NEWTON	1	6/4/2023	6/6/2023	Newly Identified	Repaired					
7381585	51 OAKWOOD RD	NEWTON	1	6/5/2023	6/5/2023	Newly Identified	Repaired					
7381598	43 CHINIAN PATH	NEWTON	1	6/6/2023	6/6/2023	Newly Identified	Repaired					
7381628	20 BEACON ST	NEWTON	2	5/21/2023	7/19/2023	Newly Identified	Eliminated Otherwise					SYSTEM ISSUE
7381630	18 PINE CREST RD	NEWTON	1	6/7/2023	6/7/2023	Newly Identified	Repaired					
7381647	33 BOYLSTON ST	NEWTON	1	6/7/2023	6/8/2023	Newly Identified	Repaired					
7381742	6 LOWELL AVE	NEWTON	1	6/12/2023	6/13/2023	Newly Identified	Repaired					
7381808	22 NARDELL RD	NEWTON	1	6/14/2023	6/15/2023	Newly Identified	Repaired					
7381812	52 RANDLETT PIKE	NEWTON	1	6/14/2023	6/14/2023	Newly Identified	Repaired					
7381822	1224 BOYLSTON ST	NEWTON	1	6/14/2023	6/20/2023	Newly Identified	Repaired					
7381828	85 CLEMENTS RD	NEWTON	1	6/7/2023	6/14/2023	Newly Identified	Repaired					
7381910	384 BOYLSTON ST	NEWTON	1	6/20/2023	6/21/2023	Newly Identified	Repaired					
7381928	336 BOYLSTON ST	NEWTON	1	6/20/2023	7/18/2023	Newly Identified	Repaired					
7381940	1 ELIOT AVE	NEWTON	2	5/16/2023	7/19/2023	Newly Identified	Eliminated Otherwise					NO READS
7381950	PAULSON RD & FERNCROFT R	NEWTON	1	6/21/2023	6/21/2023	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7381973	2096 WASHINGTON ST	NEWTON	1	6/22/2023	6/22/2023	Newly Identified	Repaired					
7382027	18 PINE ST	NEWTON	1	6/24/2023	6/24/2023	Newly Identified	Repaired					
7382052	287 AUBURN ST	NEWTON	1	6/26/2023	6/27/2023	Newly Identified	Repaired					
7382072	244 UPLAND AVE	NEWTON	1	6/27/2023	6/27/2023	Newly Identified	Repaired					
7382087	399 WASHINGTON ST	NEWTON	1	6/27/2023	6/28/2023	Newly Identified	Repaired					
7382110	74 COUNTRY CLUB RD	NEWTON	1	6/29/2023	6/29/2023	Newly Identified	Repaired					
7382121	38 WETHERELL ST	NEWTON	2	6/7/2023	8/7/2023	Newly Identified	Repaired					
7382122	207 WASHINGTON ST	NEWTON	2	6/6/2023		Newly Identified	Pending					
7382161	14 HIGHLAND AVE	NEWTON	1	7/3/2023	7/3/2023	Newly Identified	Repaired					
7382175	14 HIGHLAND PIKE	NEWTON	1	7/5/2023	7/12/2023	Newly Identified	Eliminated Otherwise					WRONG ADDRESS
7382207	671 SAWMILL BROOK PKY	NEWTON	1	7/6/2023	7/7/2023	Newly Identified	Repaired					
7382245	21 CHANDLER PL	NEWTON	1	7/9/2023	7/10/2023	Newly Identified	Repaired					
7382248	394 HOMER ST	NEWTON	1	7/9/2023	7/9/2023	Newly Identified	Repaired					
7382269	1175 CENTRE ST	NEWTON	1	7/11/2023	7/11/2023	Newly Identified	Repaired					
7382273	115 RANDLETT PIKE	NEWTON	1	7/11/2023	7/11/2023	Newly Identified	Repaired					
7382319	1191 CENTRE ST	NEWTON	1	7/13/2023	7/14/2023	Newly Identified	Repaired					
7382364	16 JUNE LN	NEWTON	1	7/14/2023	7/14/2023	Newly Identified	Repaired					
7382370	MEREDITH AVE & BOYLSTON	NEWTON	1	7/15/2023	7/16/2023	Newly Identified	Repaired					
7382389	616 BOYLSTON ST	NEWTON	1	7/17/2023	7/18/2023	Newly Identified	Repaired					
7382443	46 GARDNER ST	NEWTON	1	7/19/2023	7/19/2023	Newly Identified	Repaired					
7382457	216 LOWELL AVE	NEWTON	1	7/19/2023	7/20/2023	Newly Identified	Repaired					
7382517	389 CENTRAL ST	NEWTON	1	7/21/2023	7/21/2023	Newly Identified	Repaired					
7382529	997 BEACON ST	NEWTON	1	7/24/2023	7/24/2023	Newly Identified	Repaired					
7382536	74 EDDY ST	NEWTON	2	6/29/2023		Newly Identified	Pending					
7382540	33 TERRACE AVE	NEWTON	1	7/24/2023	7/24/2023	Newly Identified	Repaired					
7382574	1875 BEACON ST	NEWTON	1	7/25/2023	7/25/2023	Newly Identified	Repaired					
7382593	385 WARD ST	NEWTON	2	6/25/2023	8/31/2023	Newly Identified	Repaired					
7382660	1084 BOYLSTON ST	NEWTON	1	7/29/2023	7/30/2023	Newly Identified	Repaired					
7382671	268 NEWTONVILLE AVE	NEWTON	1	7/31/2023	7/31/2023	Newly Identified	Repaired					
7382683	371 WASHINGTON ST	NEWTON	1	7/30/2023	8/2/2023	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7382686	525 WALNUT ST	NEWTON	1	7/31/2023	8/1/2023	Newly Identified	Repaired					
7382729	1057 WALNUT ST	NEWTON	1	8/2/2023	8/3/2023	Newly Identified	Repaired					
7382741	263 HAMMOND ST	NEWTON	1	8/3/2023		Newly Identified	Pending					
7382775	40 NEEDHAM ST	NEWTON	1	8/4/2023	8/5/2023	Newly Identified	Repaired					
7382781	82 CARVER RD	NEWTON	1	8/4/2023	8/4/2023	Newly Identified	Repaired					
7382792	583 WATERTOWN ST	NEWTON	1	8/5/2023	8/5/2023	Newly Identified	Repaired					
7382795	187 MOFFAT RD	NEWTON	1	8/5/2023	8/5/2023	Newly Identified	Repaired					
7382837	118 LANGLEY RD	NEWTON	1	8/8/2023	8/8/2023	Newly Identified	Repaired					
7382839	302 CYPRESS ST	NEWTON	1	8/8/2023	8/9/2023	Newly Identified	Repaired					
7382850	187 MOFFAT RD	NEWTON	1	8/9/2023	8/10/2023	Newly Identified	Repaired					
7382874	268 NEWTONVILLE AVE	NEWTON	1	8/10/2023	8/11/2023	Newly Identified	Repaired					
7382891	118 LANGLEY RD	NEWTON	1	8/10/2023	8/11/2023	Newly Identified	Repaired					
7382903	106 FAIR OAKS AVE	NEWTON	1	8/11/2023	8/11/2023	Newly Identified	Repaired					
7382935	14 EMERALD ST	NEWTON	1	8/12/2023	8/12/2023	Newly Identified	Repaired					
7382936	116 CHURCH ST	NEWTON	1	8/12/2023	8/12/2023	Newly Identified	Repaired					
7382940	628 BOYLSTON ST	NEWTON	1	8/13/2023	8/14/2023	Newly Identified	Repaired					
7382941	4 MEREDITH AVE	NEWTON	1	8/13/2023	8/15/2023	Newly Identified	Repaired					
7382946	69 WALDORF RD	NEWTON	2	6/27/2023	9/11/2023	Newly Identified	Repaired					
7383058	28 WARWICK RD	NEWTON	1	8/18/2023	8/19/2023	Newly Identified	Repaired					
7383061	118 LANGLEY RD	NEWTON	1	8/19/2023	8/19/2023	Newly Identified	Repaired					
7383066	743 WASHINGTON ST	NEWTON	1	8/20/2023	8/21/2023	Newly Identified	Repaired					
7383078	851 WATERTOWN ST	NEWTON	1	8/21/2023	8/21/2023	Newly Identified	Repaired					
7383149	193 WINCHESTER ST	NEWTON	2	9/1/2023	11/29/2023	Newly Identified	Repaired					
7383171	WALNUT ST & WATERTOWN ST	NEWTON	1	8/26/2023	9/30/2023	Newly Identified	Repaired					
7383172	19 WEBSTER PL	NEWTON	1	8/26/2023	8/26/2023	Newly Identified	Repaired					
7383193	17 SUFFOLK RD	NEWTON	1	8/28/2023	8/29/2023	Newly Identified	Repaired					
7383225	45 PARK AVE	NEWTON	1	8/29/2023	8/29/2023	Newly Identified	Repaired					
7383272	325 BEACON ST	NEWTON	1	8/31/2023	9/1/2023	Newly Identified	Repaired					
7383368	292 FRANKLIN ST	NEWTON	1	9/7/2023	9/7/2023	Newly Identified	Repaired					
7383391	128 OTIS ST	NEWTON	1	9/8/2023	9/8/2023	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023		Name of Operator: <i>Boston Gas Company</i>								
Leak ID (if applicable)	Location Street Number and Name	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
									Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7383437	233 NAHANTON ST	NEWTON	1	9/11/2023	9/11/2023	Newly Identified	Repaired					
7383475	495 WATERTOWN ST	NEWTON	1	9/12/2023	9/13/2023	Newly Identified	Repaired					
7383538	107 TRUMAN RD	NEWTON	1	9/14/2023	9/14/2023	Newly Identified	Repaired					
7383539	209 COUNTRY CLUB RD	NEWTON	2	8/11/2023	10/11/2023	Newly Identified	Repaired					
7383616	FERNCROFT RD & BEACON ST	NEWTON	1	9/19/2023	9/19/2023	Newly Identified	Repaired					
7383823	999 CHESTNUT ST	NEWTON	2	9/16/2023	11/27/2023	Newly Identified	Repaired					
7383839	39 MASON RD	NEWTON	1	10/2/2023	10/2/2023	Newly Identified	Repaired					
7383883	64 CARL ST	NEWTON	1	10/3/2023	10/3/2023	Newly Identified	Repaired					
7383905	34 WATERSTON RD	NEWTON	1	10/4/2023	10/4/2023	Newly Identified	Repaired					
7383988	1 ELIOT AVE	NEWTON	2	10/10/2023	10/21/2023	Newly Identified	Repaired					
7383995	46 VISTA AVE	NEWTON	1	10/11/2023	10/12/2023	Newly Identified	Repaired					
7384027	29 HUNTER ST	NEWTON	1	10/13/2023	10/13/2023	Newly Identified	Repaired					
7384033	131 BRANDEIS RD	NEWTON	1	10/13/2023	10/13/2023	Newly Identified	Repaired					
7384099	31 HOLLY RD	NEWTON	1	10/17/2023	10/17/2023	Newly Identified	Repaired					
7384217	1268 BOYLSTON ST	NEWTON	1	10/23/2023	10/23/2023	Newly Identified	Repaired					
7384257	1766 COMMONWEALTH AVE	NEWTON	1	10/25/2023	10/27/2023	Newly Identified	Repaired					
7384283	20 CARL ST	NEWTON	1	10/26/2023	10/26/2023	Newly Identified	Repaired					
7384330	181 CALIFORNIA ST	NEWTON	1	10/27/2023	10/27/2023	Newly Identified	Repaired					
7384401	93 BEAUMONT AVE	NEWTON	1	11/2/2023	11/2/2023	Newly Identified	Repaired					
7384437	38 MECHANIC ST	NEWTON	1	11/5/2023	11/5/2023	Newly Identified	Repaired					
7384443	62 BEACON ST	NEWTON	2	11/2/2023	12/4/2023	Newly Identified	Eliminated Otherwise					NO READS
7384460	91 ARNOLD RD	NEWTON	1	11/6/2023	11/6/2023	Newly Identified	Repaired					
7384464	48 INDIANA TER	NEWTON	1	11/6/2023	11/6/2023	Newly Identified	Repaired					
7384465	112 WINCHESTER ST	NEWTON	1	11/6/2023	11/7/2023	Newly Identified	Repaired					
7384549	643 WATERTOWN ST	NEWTON	1	11/11/2023	11/15/2023	Newly Identified	Repaired					
7384625	275 NEVADA ST	NEWTON	1	11/15/2023	11/15/2023	Newly Identified	Repaired					
7384626	42 PLAINFIELD ST	NEWTON	1	11/15/2023	11/15/2023	Newly Identified	Repaired					
7384637	41 JOHN ST	NEWTON	1	11/16/2023	11/16/2023	Newly Identified	Repaired					
7384664	11 THORNTON ST	NEWTON	1	11/18/2023	11/21/2023	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7384682	11 THORNTON ST	NEWTON	1	11/18/2023	11/20/2023	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2023												
Detailed Quarterly Information		QUARTER 4 - 2023			Name of Operator: <i>Boston Gas Company</i>							
Leak ID (if applicable)	Location	Town/City	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name								Survey Designatio n Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7384705	LOWELL AVE & WASHINGTON	NEWTON	1	11/22/2023	11/22/2023	Newly Identified	Repaired					
7384726	934 BEACON ST	NEWTON	1	11/27/2023	11/27/2023	Newly Identified	Repaired					
7384775	628 BOYLSTON ST	NEWTON	2	10/24/2023		Newly Identified	Pending					
7384797	318 BOYLSTON ST	NEWTON	1	11/30/2023	12/1/2023	Newly Identified	Repaired					
7384926	55 MURRAY RD	NEWTON	1	12/10/2023		Newly Identified	Pending					
7384927	55 MURRAY RD	NEWTON	1	12/10/2023	12/12/2023	Newly Identified	Repaired					
7385003	13 WOODROW AVE	NEWTON	1	12/14/2023	12/14/2023	Newly Identified	Repaired					
7385038	168 RIVER ST	NEWTON	2	12/16/2023	12/17/2023	Newly Identified	Repaired					
7385073	48 WARWICK RD	NEWTON	1	12/20/2023	12/20/2023	Newly Identified	Repaired					
7385091	142 CHURCH ST	NEWTON	1	12/22/2023	12/22/2023	Newly Identified	Repaired					
7385092	437 CENTRE ST	NEWTON	1	12/22/2023	12/23/2023	Newly Identified	Repaired					
7385096	68 WOODBINE ST	NEWTON	1	12/22/2023	12/22/2023	Newly Identified	Repaired					
7385123	437 CENTRE ST	NEWTON	1	12/26/2023	12/26/2023	Newly Identified	Repaired					
7385129	90 ALLEN AVE	NEWTON	1	12/26/2023	12/27/2023	Newly Identified	Repaired					
7385159	15 BEECH ST	NEWTON	1	12/27/2023	12/27/2023	Newly Identified	Repaired					
7385304	35 LEXINGTON ST	NEWTON	2	12/24/2023		Newly Identified	Pending					
7385348	17 WARE RD	NEWTON	2	12/22/2023		Newly Identified	Pending					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5866391	HAMMOND ST & COLLEGE RD	3	12/14/2015	8/6/2024	Carried Forward	Eliminated Otherwise		12/5/2023	25,000	Leak Extent	NO READS
7382271	2322 WASHINGTON ST	3	6/20/2023	10/28/2024	Carried Forward	Repaired		4/23/2024	14,400	Leak Extent	
7377815	2096 WASHINGTON ST	3	8/13/2022	11/7/2024	Carried Forward	Repaired		4/25/2024	12,600	Leak Extent	
7325996	1 NONANTUM ST	3	5/10/2016		Carried Forward	Pending		5/6/2024	12,000	Leak Extent	
7374844	1974 WASHINGTON ST	3	4/27/2022	2/20/2024	Carried Forward	Repaired		12/19/2023	11,016	Leak Extent	
7375162	33 OAK HILL ST	3	5/19/2022		Carried Forward	Pending		10/11/2024	8,000	Leak Extent	
1065939	53 CHARLESBANK RD	3	8/30/2012	1/20/2024	Carried Forward	Eliminated Otherwise		8/31/2023	7,500	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7387162	546 PARKER ST	3	4/10/2024		Newly Identified	Pending		11/20/2024	6,600	Leak Extent	
7383506	CALIFORNIA ST & BRIDGE ST	3	8/30/2023		Carried Forward	Pending		6/26/2024	6,400	Leak Extent	
7391375	1802 BEACON ST	3	12/22/2024		Newly Identified	Pending		12/22/2024	5,610	Leak Extent	
7382337	264 WINCHESTER ST	3	6/9/2023		Carried Forward	Pending		4/23/2024	5,500	Leak Extent	
7353121	95 PINE GROVE AVE	3	5/8/2019		Carried Forward	Pending		8/28/2024	5,075	Leak Extent	
6592025	142 GORDON RD	3	9/8/2015	3/6/2024	Carried Forward	Repaired		11/7/2023	5,040	Leak Extent	
5620596	832 DEDHAM ST	3	8/27/2015	9/12/2024	Carried Forward	Eliminated Otherwise		12/19/2023	4,550	Leak Extent	NO READS
7387878	103 COLLINS RD	3	5/13/2024	8/15/2024	Newly Identified	Eliminated by Replacement		5/13/2024	4,320	Leak Extent	
278687	HAMMOND ST & MIDDLESEX RD	3	8/8/2005	10/8/2024	Carried Forward	Repaired		8/8/2024	4,200	Leak Extent	
270745	WALNUT ST & BACON RD	3	8/6/2004	10/3/2024	Carried Forward	Repaired		7/29/2024	4,000	Leak Extent	
343469	PARKER ST & BOYLSTON ST	3	11/19/2024		Carried Forward	Pending		11/19/2024	4,000	Leak Extent	
6980988	83 CARVER RD	3	5/28/2019		Carried Forward	Pending		8/5/2024	3,800	Leak Extent	
693516	1 QUINOBEQUIN RD	3	12/15/2011		Carried Forward	Pending		8/20/2024	3,750	Leak Extent	
7383027	26 PARKER ST	3	8/2/2023	8/14/2024	Carried Forward	Repaired		5/21/2024	3,750	Leak Extent	
7355422	1466 COMMONWEALTH AVE	3	7/24/2019	10/1/2024	Carried Forward	Repaired		8/28/2024	3,500	Leak Extent	
337228	DORSET RD & METACOMET RD	3	8/19/2010	7/26/2024	Carried Forward	Repaired		11/16/2023	3,360	Leak Extent	
7324254	70 OAKDALE RD	3	3/27/2016		Carried Forward	Pending		8/14/2024	3,000	Leak Extent	
7335809	1319 CENTRE ST	3	6/23/2017		Carried Forward	Pending		7/29/2024	3,000	Leak Extent	
7365477	8 BACON RD	3	11/9/2020		Carried Forward	Pending		5/6/2024	3,000	Leak Extent	
6722656	69 PRINCE ST	3	9/29/2015		Carried Forward	Pending		8/13/2024	2,750	Leak Extent	
1217681	206 CONCORD ST	3	5/6/2013		Carried Forward	Pending		8/13/2024	2,720	Leak Extent	
316528	64 FULLER ST	3	9/8/2008		Carried Forward	Pending		8/22/2024	2,550	Leak Extent	
839499	220 WOODWARD ST	3	6/29/2016		Carried Forward	Pending		8/20/2024	2,520	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7378581	HAGAR ST & CONCORD ST	3	11/4/2022		Carried Forward	Pending		6/26/2024	2,500	Leak Extent	
7336365	23 DAVIS ST	3	7/15/2017		Carried Forward	Pending		11/20/2024	2,400	Leak Extent	
7383025	DAVIS ST & HIGHLAND ST	3	7/26/2023		Carried Forward	Pending		5/21/2024	2,400	Leak Extent	
7336297	327 DEDHAM ST	3	7/12/2017		Carried Forward	Pending		9/3/2024	2,310	Leak Extent	
7376816	45 SHERIDAN ST	3	8/18/2022		Carried Forward	Pending		4/25/2024	2,310	Leak Extent	
7354554	81 CHURCH ST	3	7/9/2019		Carried Forward	Pending		8/9/2024	2,280	Leak Extent	
7379847	1818 BEACON ST	3	2/13/2023		Carried Forward	Pending		8/8/2024	2,250	Leak Extent	
1593092	1629 BEACON ST	3	2/19/2014	4/1/2024	Carried Forward	Repaired		12/19/2023	2,200	Leak Extent	
7354553	7 BUSWELL PIKE	3	7/9/2019	12/18/2024	Carried Forward	Repaired		8/9/2024	2,200	Leak Extent	
7382908	100 OLDEFIELD RD	3	7/14/2023		Carried Forward	Pending		5/7/2024	2,200	Leak Extent	
338429	30 ELLIS RD	3	10/13/2010	8/7/2024	Carried Forward	Repaired		11/17/2023	2,132	Leak Extent	
4339243	130 BEACON ST	3	6/4/2015	7/30/2024	Carried Forward	Repaired		12/19/2023	2,016	Leak Extent	
7388306	1119 WALNUT ST	3	6/13/2024		Newly Identified	Pending		6/13/2024	1,968	Leak Extent	
1337093	40 WINDSOR RD	3	8/19/2013		Carried Forward	Pending		8/13/2024	1,950	Leak Extent	
7325718	8 WHITE OAK RD	3	5/10/2016	4/17/2024	Carried Forward	Repaired		3/21/2024	1,914	Leak Extent	
304662	19 FENWICK RD	3	9/12/2007		Carried Forward	Pending		8/27/2024	1,870	Leak Extent	
7388906	212 TEMPLE ST	3	7/24/2024		Newly Identified	Pending		7/24/2024	1,863	Leak Extent	
7376632	227 CHERRY ST	3	8/25/2022		Carried Forward	Pending		5/6/2024	1,850	Leak Extent	
7364130	109 CABOT ST	3	7/15/2020		Carried Forward	Pending		9/23/2024	1,802	Leak Extent	
296483	10 LANGLEY RD	3	12/7/2006		Carried Forward	Pending		7/29/2024	1,800	Leak Extent	
7356438	741 SAWMILL BROOK PKY	3	9/26/2019	8/28/2024	Carried Forward	Repaired		2/16/2024	1,800	Leak Extent	
7371042	305 COMMONWEALTH AVE	3	10/6/2021	2/17/2024	Carried Forward	Repaired		6/23/2023	1,800	Leak Extent	
7381198	899 WALNUT ST	3	11/14/2023		Carried Forward	Pending		8/21/2024	1,800	Leak Extent	
7383501	34 BROOKSIDE AVE	3	8/17/2023		Carried Forward	Pending		5/29/2024	1,800	Leak Extent	
7387351	29 LINDEN ST	3	4/18/2024		Newly Identified	Pending		11/19/2024	1,760	Leak Extent	
294276	64 PUTNAM ST	3	9/25/2006		Carried Forward	Pending		8/5/2024	1,750	Leak Extent	
304766	6 SUMNER ST	3	8/28/2007		Carried Forward	Pending		8/27/2024	1,750	Leak Extent	
7325803	640 GROVE ST	3	4/22/2016	10/24/2024	Carried Forward	Eliminated Otherwise		8/20/2024	1,750	Leak Extent	DUPLICATE LEAK
7355556	205 MILL ST	3	8/22/2019		Carried Forward	Pending		9/23/2024	1,750	Leak Extent	
7379909	152 UPLAND RD	3	2/1/2023		Carried Forward	Pending		8/22/2024	1,750	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7382270	53 HIGH ST	3	6/7/2023		Carried Forward	Pending		4/23/2024	1,675	Leak Extent	
7386489	620 GROVE ST	3	2/21/2024		Newly Identified	Pending		11/6/2024	1,650	Leak Extent	
7353084	3 AUSTIN ST	3	5/15/2019		Carried Forward	Pending		7/29/2024	1,620	Leak Extent	
1230260	62 OLDEFIELD RD	3	5/7/2013		Carried Forward	Pending		8/20/2024	1,600	Leak Extent	
7356372	569 SAWMILL BROOK PKY	3	9/25/2019	10/24/2024	Carried Forward	Eliminated Otherwise		2/16/2024	1,600	Leak Extent	DUPLICATE LEAK
7383029	140 WINDERMERE RD	3	7/24/2023	12/17/2024	Carried Forward	Repaired		11/22/2024	1,600	Leak Extent	
7386827	65 WILDE RD	3	4/1/2024		Newly Identified	Pending		11/20/2024	1,596	Leak Extent	
7354269	62 WALNUT PIKE	3	6/26/2019		Carried Forward	Pending		8/28/2024	1,540	Leak Extent	
7354716	16 KENYON ST	3	7/19/2019		Carried Forward	Pending		8/28/2024	1,536	Leak Extent	
7382267	78 FARLOW RD	3	6/21/2023		Carried Forward	Pending		4/25/2024	1,536	Leak Extent	
3900011	18 ALDEN ST	3	4/24/2015	8/6/2024	Carried Forward	Repaired		11/16/2023	1,530	Leak Extent	
7390654	391 DEDHAM ST	3	10/28/2024		Newly Identified	Pending		10/28/2024	1,505	Leak Extent	
7324469	16 SOMERSET RD	3	4/1/2016		Carried Forward	Pending		8/14/2024	1,500	Leak Extent	
1337088	4 GAY ST	3	8/20/2013		Carried Forward	Pending		9/3/2024	1,488	Leak Extent	
305109	32 WESSEX RD	3	8/28/2007		Carried Forward	Pending		8/13/2024	1,485	Leak Extent	
7376828	216 PLEASANT ST	3	4/3/2022		Carried Forward	Pending		8/28/2024	1,472	Leak Extent	
7335500	35 LLEWELLYN RD	3	6/13/2017		Carried Forward	Pending		8/21/2024	1,440	Leak Extent	
7353088	238 DORSET RD	3	5/6/2019		Carried Forward	Pending		8/14/2024	1,440	Leak Extent	
7379545	105 ANNAWAN RD	3	1/19/2023	12/19/2024	Carried Forward	Repaired		8/20/2024	1,440	Leak Extent	
796835	11 VIRGINIA RD	3	2/6/2012	6/27/2024	Carried Forward	Eliminated Otherwise		12/19/2023	1,426	Leak Extent	NO READS
3869342	212 GRANT AVE	3	4/9/2015		Carried Forward	Pending		8/27/2024	1,410	Leak Extent	
275900	544 QUINOBEQUIN RD	3	6/8/2005	11/12/2024	Carried Forward	Repaired		8/5/2024	1,400	Leak Extent	
7324470	22 PURITAN RD	3	3/30/2016		Carried Forward	Pending		8/14/2024	1,400	Leak Extent	
7327702	111 HOBART RD	3	7/7/2016		Carried Forward	Pending		7/29/2024	1,400	Leak Extent	
7336530	6 SAMOSET RD	3	7/21/2017		Carried Forward	Pending		11/20/2024	1,400	Leak Extent	
7376631	224 ADAMS AVE	3	8/22/2022		Carried Forward	Pending		4/30/2024	1,400	Leak Extent	
7354709	20 CLAREMONT ST	3	7/16/2019		Carried Forward	Pending		9/4/2024	1,380	Leak Extent	
7354252	2 KINGSTON RD	3	6/27/2019		Carried Forward	Pending		8/28/2024	1,350	Leak Extent	
7388305	ELLIOT ST & RIVER AVE	3	6/13/2024		Newly Identified	Pending		6/13/2024	1,350	Leak Extent	
7355545	11 ANTONELLIS CIR	3	8/22/2019	12/17/2024	Carried Forward	Repaired		9/27/2024	1,332	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7379278	280 CENTRAL ST	3	1/9/2023		Carried Forward	Pending		8/5/2024	1,330	Leak Extent	
7379914	750 BOYLSTON ST	3	2/25/2023		Carried Forward	Pending		11/12/2024	1,330	Leak Extent	
7338745	67 OAKCLIFF RD	3	9/27/2017		Carried Forward	Pending		9/27/2024	1,320	Leak Extent	
7354547	443 WOLCOTT ST	3	7/9/2019		Carried Forward	Pending		8/28/2024	1,316	Leak Extent	
6722810	75 GROVE HILL AVE	3	9/29/2015		Carried Forward	Pending		8/13/2024	1,302	Leak Extent	
307752	176 WABAN AVE	3	11/7/2007		Carried Forward	Pending		5/15/2024	1,292	Leak Extent	
7376829	126 EASTBOURNE RD	3	4/12/2022		Carried Forward	Pending		9/27/2024	1,280	Leak Extent	
7355431	1928 COMMONWEALTH AVE	3	8/5/2019		Carried Forward	Pending		9/27/2024	1,276	Leak Extent	
270681	131 COUNTRY CLUB RD	3	8/3/2004		Carried Forward	Pending		9/12/2024	1,260	Leak Extent	
7376774	232 DERBY ST	3	8/24/2022		Carried Forward	Pending		4/30/2024	1,260	Leak Extent	
7354542	190 TEMPLE ST	3	7/11/2019		Carried Forward	Pending		9/3/2024	1,250	Leak Extent	
7367241	46 CEDAR ST	3	3/1/2021	7/1/2024	Carried Forward	Eliminated Otherwise		5/21/2024	1,250	Leak Extent	NO READS
7376321	137 GARLAND RD	3	7/29/2022		Carried Forward	Pending		11/20/2024	1,248	Leak Extent	
7355564	51 SHERBROOKE RD	3	8/21/2019		Carried Forward	Pending		9/23/2024	1,230	Leak Extent	
304745	4 JANET RD	3	8/23/2007		Carried Forward	Pending		9/27/2024	1,216	Leak Extent	
7326621	116 OXFORD RD	3	6/10/2016		Carried Forward	Pending		5/15/2024	1,216	Leak Extent	
7387599	405 WOLCOTT ST	3	4/21/2024		Newly Identified	Pending		11/19/2024	1,209	Leak Extent	
1206963	41 BRUSH HILL RD	3	4/25/2013	12/16/2024	Carried Forward	Repaired		8/13/2024	1,200	Leak Extent	
7326197	145 HIGHLAND ST	3	5/11/2016	9/3/2024	Carried Forward	Repaired		4/25/2024	1,200	Leak Extent	
7336456	12 BERTRAND RD	3	7/18/2017		Carried Forward	Pending		7/29/2024	1,200	Leak Extent	
7337016	214 CONCORD ST	3	8/1/2017		Carried Forward	Pending		9/3/2024	1,200	Leak Extent	
7377631	364 WOODWARD ST	3	9/12/2022		Carried Forward	Pending		5/7/2024	1,200	Leak Extent	
7379906	35 KELVEDEN RD	3	3/1/2023		Carried Forward	Pending		8/9/2024	1,200	Leak Extent	
7383510	43 PHILBRICK RD	3	9/5/2023		Carried Forward	Pending		6/26/2024	1,200	Leak Extent	
7385305	937 DEDHAM ST	3	12/9/2023		Carried Forward	Pending		9/12/2024	1,200	Leak Extent	
7355549	200 COTTON ST	3	8/22/2019		Carried Forward	Pending		9/27/2024	1,116	Leak Extent	
3205205	60 HIGHLAND ST	3	3/4/2015		Carried Forward	Pending		9/12/2024	1,104	Leak Extent	
1246024	242 WABAN AVE	3	7/31/2017		Carried Forward	Pending		8/13/2024	1,092	Leak Extent	
303110	40 CENTRAL TER	3	7/3/2007		Carried Forward	Pending		4/30/2024	1,080	Leak Extent	
7336302	42 ANNAWAN RD	3	7/1/2017		Carried Forward	Pending		7/29/2024	1,080	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7376707	200 DERBY ST	3	8/24/2022		Carried Forward	Pending		4/30/2024	1,080	Leak Extent	
7376812	36 NEWELL RD	3	8/19/2022		Carried Forward	Pending		4/30/2024	1,080	Leak Extent	
7356850	HIGHLAND ST & DAVIS ST	3	10/15/2019		Carried Forward	Pending		11/7/2024	1,073	Leak Extent	
1286057	26 HOLMAN RD	3	6/12/2013		Carried Forward	Pending		8/5/2024	1,050	Leak Extent	
1362684	131 WINDSOR RD	3	9/30/2013		Carried Forward	Pending		9/3/2024	1,050	Leak Extent	
7330111	28 CONSIDINE RD	3	11/3/2016	10/12/2024	Carried Forward	Eliminated Otherwise		9/12/2024	1,050	Leak Extent	NO READS
7379082	9 NARDELL RD	3	1/5/2023		Carried Forward	Pending		8/5/2024	1,050	Leak Extent	
270655	100 SUFFOLK RD	3	8/19/2004		Carried Forward	Pending		11/4/2024	1,000	Leak Extent	
304763	8 LANCASTER RD	3	6/21/2016		Carried Forward	Pending		11/19/2024	1,000	Leak Extent	
5217418	499 WINCHESTER ST	3	6/16/2015	7/1/2024	Carried Forward	Eliminated Otherwise		5/7/2024	1,000	Leak Extent	NO READS
7371044	178 PRINCE ST	3	9/27/2021		Carried Forward	Pending		5/6/2024	1,000	Leak Extent	
7374851	24 LESLIE RD	3	5/11/2022		Carried Forward	Pending		9/30/2024	990	Leak Extent	
7380677	324 WINCHESTER ST	3	2/22/2023		Carried Forward	Pending		8/28/2024	960	Leak Extent	
42522	3 COLUMBUS ST	3	5/21/1993		Carried Forward	Pending		8/9/2024	952	Leak Extent	
307614	499 CRAFTS ST	3	9/4/2007		Carried Forward	Pending		8/8/2024	952	Leak Extent	
7389638	379 HAMMOND ST	3	9/16/2024		Newly Identified	Pending		9/16/2024	952	Leak Extent	
7387164	91 CARL ST	3	4/11/2024		Newly Identified	Pending		11/20/2024	950	Leak Extent	
1363304	321 HAMMOND ST	3	9/9/2013		Carried Forward	Pending		8/27/2024	945	Leak Extent	
854114	712 SAWMILL BROOK PKY	3	4/24/2012		Carried Forward	Pending		8/13/2024	912	Leak Extent	
230386	LANGDON ST & BELLEVUE ST	3	2/26/2002		Carried Forward	Pending		8/7/2024	900	Leak Extent	
270390	PLYMOUTH RD & WOODWARD	3	4/27/2004		Carried Forward	Pending		8/7/2024	900	Leak Extent	
1282579	239 WOODLAND RD	3	6/28/2013	8/20/2024	Carried Forward	Repaired		1/11/2024	900	Leak Extent	
7336460	1746 BEACON ST	3	7/19/2017	10/10/2024	Carried Forward	Eliminated by Replacement		11/6/2023	900	Leak Extent	
7345717	85 COMMONWEALTH AVE	3	7/14/2018	8/7/2024	Carried Forward	Repaired		2/21/2024	900	Leak Extent	
7355582	284 WOODWARD ST	3	8/19/2019	8/27/2024	Carried Forward	Repaired		1/11/2024	900	Leak Extent	
7376813	32 NOBLE ST	3	8/24/2022		Carried Forward	Pending		4/30/2024	900	Leak Extent	
7379298	64 PROSPECT AVE	3	1/10/2023		Carried Forward	Pending		8/7/2024	900	Leak Extent	
7379880	31 FOX HILL RD	3	2/18/2023	5/29/2024	Carried Forward	Eliminated by Replacement		11/13/2023	900	Leak Extent	
7383512	5 SHELTON RD	3	8/29/2023	11/27/2024	Carried Forward	Eliminated Otherwise		6/26/2024	900	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7385309	20 GREENLAWN AVE	3	12/20/2023		Carried Forward	Pending		11/12/2024	900	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
6624524	14 SAMOSET RD	3	9/21/2015	6/27/2024	Carried Forward	Eliminated Otherwise		3/20/2024	875	Leak Extent	NO READS
7378467	316 CENTRAL ST	3	5/15/2024		Carried Forward	Pending	2	11/14/2023	875	Leak Extent	
1363546	295 DUDLEY RD	3	9/19/2013		Carried Forward	Pending		9/30/2024	860	Leak Extent	
304862	30 PEARL ST	3	8/14/2007		Carried Forward	Pending		8/9/2024	840	Leak Extent	
7326999	169 FULLER ST	3	6/23/2016		Carried Forward	Pending		5/21/2024	800	Leak Extent	
7378477	LOWELL AVE & WASHINGTON ST	3	12/1/2022		Carried Forward	Pending		7/11/2024	800	Leak Extent	
7379917	1010 BOYLSTON ST	3	2/15/2023		Carried Forward	Pending		9/9/2024	780	Leak Extent	
7361466	109 PRINCE ST	3	6/9/2020		Carried Forward	Pending		8/9/2024	760	Leak Extent	
1363313	110 CEDAR ST	3	9/10/2013		Carried Forward	Pending		9/12/2024	750	Leak Extent	
7353089	65 GROVE ST	3	5/8/2019		Carried Forward	Pending		8/14/2024	750	Leak Extent	
7355430	32 SMITH AVE	3	7/25/2019		Carried Forward	Pending		9/27/2024	750	Leak Extent	
7356220	27 EVELYN RD	3	9/4/2019	8/28/2024	Carried Forward	Repaired		1/4/2024	750	Leak Extent	
7386043	19 COLUMBUS ST	3	1/31/2024		Newly Identified	Pending		10/30/2024	750	Leak Extent	
7365113	110 ADELINE RD	3	10/9/2020	8/12/2024	Carried Forward	Repaired		3/21/2024	748	Leak Extent	
1217964	68 WYOMING RD	3	4/30/2013		Carried Forward	Pending		8/20/2024	720	Leak Extent	
7371382	212 CHESTNUT ST	3	10/9/2021		Carried Forward	Pending		4/30/2024	720	Leak Extent	
7387598	56 UPLAND RD	3	4/17/2024		Newly Identified	Pending		11/19/2024	684	Leak Extent	
284375	59 WACHUSETT RD	3	1/25/2006		Carried Forward	Pending		8/8/2024	680	Leak Extent	
7375170	275 AUBURN ST	3	6/3/2022		Carried Forward	Pending		10/30/2024	680	Leak Extent	
7372371	28 MOODY ST	3	12/3/2021		Carried Forward	Pending		5/21/2024	675	Leak Extent	
7325711	5 AGAWAM RD	3	5/10/2016	12/17/2024	Carried Forward	Repaired		9/12/2024	660	Leak Extent	
7374854	5 ANGLIER CIR	3	5/11/2022	12/18/2024	Carried Forward	Repaired		9/30/2024	660	Leak Extent	
7379918	1088 BOYLSTON ST	3	2/15/2023		Carried Forward	Pending		9/9/2024	660	Leak Extent	
7345718	DEDHAM ST & MEADOWBROOK	3	7/13/2018		Carried Forward	Pending		11/6/2024	650	Leak Extent	
7355359	41 ORCHARD AVE	3	8/12/2019		Carried Forward	Pending		9/27/2024	620	Leak Extent	
121969	CRAFTS ST & FESSENDEN RD	3	4/8/1998		Carried Forward	Pending		8/22/2024	600	Leak Extent	
347021	160 COMMONWEALTH AVE	3	5/25/2011	7/25/2024	Carried Forward	Repaired		1/11/2024	600	Leak Extent	
2349834	109 ALLERTON RD	3	12/26/2014	12/16/2024	Carried Forward	Repaired		8/22/2024	600	Leak Extent	
7342376	3 DANIEL ST	3	3/6/2018		Carried Forward	Pending		11/20/2024	600	Leak Extent	
7347782	2044 BEACON ST	3	9/23/2018	3/27/2024	Carried Forward	Repaired		5/12/2023	600	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7356355	146 HAMMOND ST	3	9/25/2019		Carried Forward	Pending		10/11/2024	600	Leak Extent	
7356450	10 SPIERS RD	3	9/27/2019	9/12/2024	Carried Forward	Eliminated Otherwise		2/21/2024	600	Leak Extent	NO READS
7364409	170 OTIS ST	3	7/15/2020		Carried Forward	Pending		10/9/2024	600	Leak Extent	
7375165	49 GROVE ST	3	5/27/2022	8/29/2024	Carried Forward	Repaired		1/12/2024	600	Leak Extent	
7380675	MASSACHUSETTS TPKE & LOWE	3	3/18/2023		Carried Forward	Pending		10/1/2024	580	Leak Extent	
7325492	135 BIGELOW RD	3	4/21/2016	8/19/2024	Carried Forward	Eliminated Otherwise		8/14/2024	560	Leak Extent	NO READS
7391265	300 BOYLSTON ST	3	12/5/2024		Newly Identified	Pending		12/5/2024	560	Leak Extent	
7355552	8 EXMOOR RD	3	8/21/2019		Carried Forward	Pending		9/27/2024	550	Leak Extent	
7356134	105 OSBORNE PATH	3	9/3/2019		Carried Forward	Pending		10/11/2024	550	Leak Extent	
305355	36 MAGNOLIA AVE	3	8/29/2007	8/15/2024	Carried Forward	Repaired		8/5/2024	540	Leak Extent	
7382268	243 ISLINGTON RD	3	6/20/2023		Carried Forward	Pending		4/23/2024	540	Leak Extent	
1283461	21 WALNUT ST	3	9/29/2014	6/25/2024	Carried Forward	Repaired		9/13/2023	500	Leak Extent	
1338973	5 CHANNING RD	3	8/30/2013		Carried Forward	Pending		9/30/2024	500	Leak Extent	
1362600	45 PARK LN	3	9/25/2013		Carried Forward	Pending		11/6/2024	500	Leak Extent	
2725982	BEACON ST & RESERVOIR AVE	3	12/4/2014		Carried Forward	Pending		10/9/2024	500	Leak Extent	
4788254	8 CENTRAL AVE	3	7/10/2015		Carried Forward	Pending		11/6/2024	500	Leak Extent	
7378794	1370 WALNUT ST	3	11/10/2022		Carried Forward	Pending		7/11/2024	500	Leak Extent	
7383023	1261 CENTRE ST	3	8/4/2023		Carried Forward	Pending		5/21/2024	500	Leak Extent	
7383509	118 LANGLEY RD	3	8/15/2023		Carried Forward	Pending		5/29/2024	500	Leak Extent	
7387880	24 OAKCLIFF RD	3	5/14/2024		Newly Identified	Pending		5/14/2024	500	Leak Extent	
7355351	57 COOK ST	3	8/12/2019		Carried Forward	Pending		9/27/2024	484	Leak Extent	
258079	2004 BEACON ST	3	3/2/2004		Carried Forward	Pending		8/22/2024	480	Leak Extent	
7386041	37 CHAPIN RD	3	2/1/2024		Newly Identified	Pending		10/30/2024	480	Leak Extent	
7386487	43 ELM ST	3	2/15/2024		Newly Identified	Pending		11/1/2024	470	Leak Extent	
7356225	105 HANSON RD	3	9/5/2019		Carried Forward	Pending		9/30/2024	460	Leak Extent	
7375134	380 WINCHESTER ST	3	5/16/2022		Carried Forward	Pending		10/1/2024	460	Leak Extent	
230055	1046 CHESTNUT ST	3	10/24/2017		Carried Forward	Pending		9/30/2024	450	Leak Extent	
7379271	255 BOYLSTON ST	3	1/6/2023		Carried Forward	Pending		11/9/2023	450	Leak Extent	
7379279	1438 COMMONWEALTH AVE	3	1/11/2023	9/26/2024	Carried Forward	Repaired		8/8/2024	450	Leak Extent	
7390711	168 RIVER ST	3	11/2/2024		Newly Identified	Pending		11/2/2024	450	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7356420	24 OROURKE PATH	3	9/26/2019		Carried Forward	Pending		11/4/2024	420	Leak Extent	
7386037	249 ADAMS ST	3	1/30/2024	12/19/2024	Newly Identified	Repaired		10/30/2024	420	Leak Extent	
7386490	12 MURRAY RD	3	2/15/2024		Newly Identified	Pending		11/1/2024	420	Leak Extent	
7327002	1395 COMMONWEALTH AVE	3	6/23/2016	2/21/2024	Carried Forward	Eliminated Otherwise		7/31/2023	400	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7356347	40 JANE RD	3	9/25/2019		Carried Forward	Pending		9/30/2024	400	Leak Extent	
7369309	129 DORSET RD	3	6/11/2021	7/11/2024	Carried Forward	Eliminated Otherwise		1/11/2024	400	Leak Extent	DUPLICATE LEAK
7371866	1292 WALNUT ST	3	11/9/2021	1/3/2024	Carried Forward	Repaired		7/12/2023	400	Leak Extent	
7378202	904 BOYLSTON ST	3	11/16/2022		Carried Forward	Pending		8/12/2024	400	Leak Extent	
7378650	NONANTUM RD & MAPLE ST	3	11/7/2022		Carried Forward	Pending		7/25/2024	400	Leak Extent	
7379000	BEACON ST & OWAISA RD	3	12/17/2022	8/5/2024	Carried Forward	Repaired		7/25/2024	400	Leak Extent	
7379081	497 BOYLSTON ST	3	1/4/2023		Carried Forward	Pending		2/7/2024	400	Leak Extent	
7379274	1607 CENTRE ST	3	12/28/2022		Carried Forward	Pending		7/25/2024	400	Leak Extent	
7379461	184 WINDSOR RD	3	1/10/2023		Carried Forward	Pending		8/7/2024	400	Leak Extent	
7380670	122 CARVER RD	3	4/13/2023	2/26/2024	Carried Forward	Repaired		4/13/2023	400	Leak Extent	
7383832	59 PONTIAC RD	3	9/21/2023		Carried Forward	Pending		7/11/2024	400	Leak Extent	
7326638	89 WINDSOR RD	3	6/10/2016		Carried Forward	Pending		5/15/2024	390	Leak Extent	
7355442	361 THORNTON ST	3	8/1/2019		Carried Forward	Pending		9/27/2024	390	Leak Extent	
7374843	1994 BEACON ST	3	5/29/2022		Carried Forward	Pending		10/30/2024	380	Leak Extent	
302760	60 WHITE OAK RD	3	7/13/2007	4/18/2024	Carried Forward	Repaired		7/31/2023	375	Leak Extent	
303666	78 WOODBINE ST	3	8/1/2007		Carried Forward	Pending		11/19/2024	375	Leak Extent	
7323096	11 RIDGEWAY TER	3	1/21/2016		Carried Forward	Pending		8/14/2024	375	Leak Extent	
7326997	21 LAUDHOLM RD	3	6/17/2016		Carried Forward	Pending		5/21/2024	375	Leak Extent	
7325813	32 MELVILLE AVE	3	4/29/2016		Carried Forward	Pending		8/21/2024	360	Leak Extent	
7386044	112 EXETER ST	3	1/30/2024		Newly Identified	Pending		10/30/2024	360	Leak Extent	
270413	1812 COMMONWEALTH AV	3	5/18/2004		Carried Forward	Pending		8/7/2024	350	Leak Extent	
1150031	1957 BEACON ST	3	2/13/2013		Carried Forward	Pending		10/9/2024	350	Leak Extent	
7348312	393 LOWELL AVE	3	10/13/2018		Carried Forward	Pending		11/4/2024	350	Leak Extent	
7356212	500 DEDHAM ST	3	9/5/2019		Carried Forward	Pending		10/9/2024	350	Leak Extent	
7356357	12 WACHUSETT RD	3	9/25/2019		Carried Forward	Pending		10/11/2024	340	Leak Extent	
7386040	141 CEDAR ST	3	2/1/2024		Newly Identified	Pending		10/30/2024	340	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7375135	341 CABOT ST	3	5/23/2022		Carried Forward	Pending		10/11/2024	320	Leak Extent	
270381	55 WINDSOR RD	3	4/29/2004	10/18/2024	Carried Forward	Eliminated Otherwise		8/7/2024	300	Leak Extent	NO READS
303661	315 CRAFTS ST	3	8/6/2007		Carried Forward	Pending		8/22/2024	300	Leak Extent	
335508	15 ROTHERWOOD RD	3	7/10/2010		Carried Forward	Pending		5/7/2024	300	Leak Extent	
427378	692 COMMONWEALTH AVE	3	10/7/2011		Carried Forward	Pending		11/19/2024	300	Leak Extent	
1065965	32 RICHARDSON ST	3	11/29/2012		Carried Forward	Pending		11/4/2024	300	Leak Extent	
1337305	108 WINDSOR RD	3	8/21/2013		Carried Forward	Pending		11/1/2024	300	Leak Extent	
5337636	330 CENTRAL ST	3	7/6/2015		Carried Forward	Pending		5/15/2024	300	Leak Extent	
7326329	121 DICKERMAN RD	3	6/1/2016		Carried Forward	Pending		11/19/2024	300	Leak Extent	
7338634	6 VAUGHAN AVE	3	9/9/2017	12/3/2024	Carried Forward	Eliminated Otherwise		11/1/2024	300	Leak Extent	NO READS
7355559	96 NORTH ST	3	8/19/2019		Carried Forward	Pending		9/23/2024	300	Leak Extent	
7356214	471 DEDHAM ST	3	9/5/2019		Carried Forward	Pending		10/9/2024	300	Leak Extent	
7378589	242 LEXINGTON ST	3	11/23/2022		Carried Forward	Pending		7/25/2024	300	Leak Extent	
7383021	146 ALBEMARLE RD	3	8/4/2023		Carried Forward	Pending		11/22/2024	300	Leak Extent	
7384348	38 MORELAND AVE	3	9/28/2023		Carried Forward	Pending		7/25/2024	300	Leak Extent	
7384585	22 BERWICK RD	3	10/15/2023		Carried Forward	Pending		7/25/2024	300	Leak Extent	
7326625	129 PARKER ST	3	6/10/2016		Carried Forward	Pending		5/15/2024	280	Leak Extent	
303702	9 T ROADWAY	3	8/6/2007		Carried Forward	Pending		11/6/2024	275	Leak Extent	
7369056	935 WASHINGTON ST	3	9/8/2021		Carried Forward	Pending		11/12/2024	275	Leak Extent	
7387912	1042 BOYLSTON ST	3	11/6/2024		Newly Identified	Pending	2	11/6/2024	270	Leak Extent	
7390821	569 SAWMILL BROOK PKY	3	11/17/2024		Newly Identified	Pending		11/17/2024	270	Leak Extent	
304860	167 PARKER ST	3	8/14/2007		Carried Forward	Pending		8/22/2024	264	Leak Extent	
7370900	11 CLOVELLY RD	3	9/20/2021	1/19/2024	Carried Forward	Repaired		6/20/2023	264	Leak Extent	
329904	25 MORSE RD	3	12/8/2009		Carried Forward	Pending		11/19/2024	250	Leak Extent	
1363357	647 COMMONWEALTH AVE	3	9/12/2013	10/16/2024	Carried Forward	Eliminated by Replacement		6/26/2024	250	Leak Extent	
7325430	9 KIRKSTALL RD	3	4/20/2016		Carried Forward	Pending		8/14/2024	250	Leak Extent	
7348100	63 OAKDALE RD	3	10/12/2018		Carried Forward	Pending		11/6/2024	250	Leak Extent	
7350513	15 OAK ST	3	2/1/2019		Carried Forward	Pending		11/12/2024	250	Leak Extent	
7375988	146 INTERVALE RD	3	6/16/2022		Carried Forward	Pending		11/4/2024	250	Leak Extent	
7376814	222 PLEASANT ST	3	8/25/2022		Carried Forward	Pending		5/6/2024	250	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7379240	494 WATERTOWN ST	3	1/4/2023	8/13/2024	Carried Forward	Eliminated Otherwise		11/7/2023	250	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7379456	34 WARE RD	3	2/1/2023	7/11/2024	Carried Forward	Repaired		11/16/2023	250	Leak Extent	
7388309	6 WESSEX RD	3	6/17/2023	7/2/2024	Carried Forward	Eliminated Otherwise		6/17/2023	250	Leak Extent	SYSTEM ISSUE
7343321	15 G ROADWAY	3	4/6/2018		Carried Forward	Pending		9/17/2024	240	Leak Extent	
7364831	5 PHILBRICK RD	3	8/17/2020		Carried Forward	Pending		11/6/2024	240	Leak Extent	
7365526	36 METACOMET RD	3	11/20/2020		Carried Forward	Pending		5/6/2024	240	Leak Extent	
7375161	262 OTIS ST	3	5/18/2022	10/24/2024	Carried Forward	Eliminated Otherwise		10/11/2024	230	Leak Extent	DUPLICATE LEAK
7323097	14 ROKEBY RD	3	1/14/2016	8/21/2024	Carried Forward	Repaired		8/14/2024	225	Leak Extent	
7327750	OAKLAND ST & CHURCH ST	3	6/2/2016	7/1/2024	Carried Forward	Eliminated Otherwise		5/7/2024	225	Leak Extent	NO READS
7349163	CYPRESS ST & PARKER ST	3	11/15/2018		Carried Forward	Pending		11/1/2024	225	Leak Extent	
7370901	38 BARNSTABLE RD	3	9/24/2021		Carried Forward	Pending		4/25/2024	225	Leak Extent	
7375099	750 COMMONWEALTH AVE	3	4/26/2022	7/22/2024	Carried Forward	Repaired		1/11/2024	225	Leak Extent	
7379021	9 FOREST ST	3	8/9/2022		Carried Forward	Pending		4/23/2024	225	Leak Extent	
7380669	1880 BEACON ST	3	3/27/2023		Carried Forward	Pending		11/1/2024	225	Leak Extent	
7386038	138 CEDAR ST	3	2/1/2024		Newly Identified	Pending		10/30/2024	225	Leak Extent	
7386050	20 WOODSIDE RD	3	2/1/2024		Newly Identified	Pending		11/1/2024	225	Leak Extent	
338426	61 CENTRAL ST	3	9/17/2015		Carried Forward	Pending		8/8/2024	220	Leak Extent	
42571	1418 COMMONWEALTH AV	3	7/7/1995	9/23/2024	Carried Forward	Repaired		1/11/2024	200	Leak Extent	
270598	16-25 BROADLAWN DR	3	7/27/2004		Carried Forward	Pending		7/11/2024	200	Leak Extent	
271180	63 AVONDALE RD	3	2/1/2005		Carried Forward	Pending		8/7/2024	200	Leak Extent	
303660	43 WALNUT ST	3	11/18/2014		Carried Forward	Pending		8/8/2024	200	Leak Extent	
304327	ALBEMARLE RD & WATERTOWN	3	8/15/2007		Carried Forward	Pending		7/11/2024	200	Leak Extent	
4788513	22 AUBURN ST	3	7/9/2015	10/17/2024	Carried Forward	Eliminated Otherwise		5/7/2024	200	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7327021	20 HOLDEN RD	3	6/28/2016		Carried Forward	Pending		11/19/2024	200	Leak Extent	
7365118	10 LOCKE RD	3	9/24/2020		Carried Forward	Pending		11/12/2024	200	Leak Extent	
7376315	1013 BEACON ST	3	7/18/2022		Carried Forward	Pending		11/4/2024	200	Leak Extent	
7378750	116 LEXINGTON ST	3	11/8/2022		Carried Forward	Pending		6/26/2024	200	Leak Extent	
7379022	1499 WASHINGTON ST	3	12/13/2022		Carried Forward	Pending		7/25/2024	200	Leak Extent	
7379295	416 NEWTONVILLE AVE	3	1/9/2023		Carried Forward	Pending		8/7/2024	200	Leak Extent	
7379915	760 BOYLSTON ST	3	1/30/2023		Carried Forward	Pending		8/7/2024	200	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
338734	6 SUN HILL LN	3	10/21/2010		Carried Forward	Pending		10/9/2024	190	Leak Extent	
7356361	52 G ROADWAY	3	9/25/2019		Carried Forward	Pending		10/9/2024	190	Leak Extent	
7386142	315 TREMONT ST	3	2/7/2024		Newly Identified	Pending		11/1/2024	190	Leak Extent	
317344	116 RIDGE AVE	3	12/12/2008		Carried Forward	Pending		10/9/2024	180	Leak Extent	
6625370	27 CAMDEN RD	3	9/22/2015		Carried Forward	Pending		8/20/2024	175	Leak Extent	
7369059	415 LOWELL AVE	3	8/8/2021		Carried Forward	Pending		11/12/2024	175	Leak Extent	
7371865	4 RANDOLPH ST	3	11/9/2021		Carried Forward	Pending		5/7/2024	170	Leak Extent	
7390551	DALTON RD & BEACON ST	3	10/9/2024		Newly Identified	Pending		10/9/2024	168	Leak Extent	
270652	55 JEFFERSON ST	3	8/13/2004		Carried Forward	Pending		11/1/2024	165	Leak Extent	
270388	50 DORSET RD	3	4/29/2004		Carried Forward	Pending		8/9/2024	160	Leak Extent	
303659	470 CALIFORNIA ST	3	8/3/2007		Carried Forward	Pending		10/11/2024	160	Leak Extent	
7375133	46 BEMIS ST	3	5/17/2022	5/9/2024	Carried Forward	Repaired		12/20/2023	160	Leak Extent	
7380673	205 HOMER ST	3	4/11/2023		Carried Forward	Pending		11/1/2024	160	Leak Extent	
7322014	83 DEVONSHIRE RD	3	12/8/2015	7/1/2024	Carried Forward	Eliminated Otherwise		11/9/2023	150	Leak Extent	NO READS
7356210	15 LEEWOOD RD	3	9/5/2019	4/17/2024	Carried Forward	Repaired		12/20/2023	150	Leak Extent	
7357654	143 RIVER ST	3	10/16/2019	1/29/2024	Carried Forward	Repaired		5/16/2023	150	Leak Extent	
7383022	74 BRIDGE ST	3	8/3/2023		Carried Forward	Pending		5/21/2024	150	Leak Extent	
7376041	14 HOMESTEAD ST	3	7/13/2022		Carried Forward	Pending		11/12/2024	125	Leak Extent	
7358412	LOS ANGELES ST & CALIFORNIA	3	12/26/2019		Carried Forward	Pending		11/12/2024	115	Leak Extent	
270560	9 STRATFORD RD	3	7/1/2004		Carried Forward	Pending		8/22/2024	112	Leak Extent	
7353577	73 DEDHAM ST	3	5/24/2019	9/16/2024	Carried Forward	Eliminated Otherwise		8/8/2024	112	Leak Extent	NO READS
7384931	BROOKSIDE AVE & ALBEMARLE	3	11/10/2023		Carried Forward	Pending		8/9/2024	112	Leak Extent	
258085	WABAN AV & VARICK RD	3	2/24/2004		Carried Forward	Pending		8/7/2024	100	Leak Extent	
329373	320 NEEDHAM ST	3	10/11/2009	9/12/2024	Carried Forward	Eliminated Otherwise		5/7/2024	100	Leak Extent	NO READS
329823	41 BERKELEY ST	3	12/4/2009		Carried Forward	Pending		6/26/2024	100	Leak Extent	
1338980	66 COMMONWEALTH PIKE W	3	8/29/2013	10/14/2024	Carried Forward	Repaired		6/26/2024	100	Leak Extent	
7326889	89 WALTHAM ST	3	6/15/2016		Carried Forward	Pending		5/7/2024	100	Leak Extent	
7327405	DAVIS AVE & EDEN AVE	3	6/27/2016	10/19/2024	Carried Forward	Eliminated Otherwise		6/26/2024	100	Leak Extent	NO READS
7354257	254 WEBSTER ST	3	12/31/2019		Carried Forward	Pending		4/23/2024	100	Leak Extent	
7356133	151 VALENTINE ST	3	8/6/2019	8/8/2024	Carried Forward	Eliminated by Replacement		12/13/2023	100	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7359897	26 COOK ST	3	3/30/2020		Carried Forward	Pending		7/11/2024	100	Leak Extent	
7365115	1364 WALNUT ST	3	10/9/2020		Carried Forward	Pending		4/23/2024	100	Leak Extent	
7365406	48 PRINCE ST	3	12/19/2020		Carried Forward	Pending		5/6/2024	100	Leak Extent	
7365408	NORTH ST & ALBEMARLE RD	3	10/28/2020		Carried Forward	Pending		4/23/2024	100	Leak Extent	
7365478	50 MANEMET RD	3	11/14/2020	6/27/2024	Carried Forward	Eliminated Otherwise		5/6/2024	100	Leak Extent	NO READS
7373592	11 ASHCROFT RD	3	2/22/2022	12/18/2024	Carried Forward	Repaired		8/22/2024	100	Leak Extent	
7378586	8 EARLY PATH	3	11/15/2022		Carried Forward	Pending		7/25/2024	100	Leak Extent	
7378677	138 LEXINGTON ST	3	11/8/2022		Carried Forward	Pending		6/26/2024	100	Leak Extent	
7379023	HIGHLAND ST & DAVIS ST	3	12/18/2022	1/17/2024	Carried Forward	Eliminated Otherwise		9/26/2023	100	Leak Extent	DUPLICATE LEAK
7383833	WASHINGTON ST & CENTRE ST	3	9/13/2023		Carried Forward	Pending		7/11/2024	100	Leak Extent	
7384586	80 WOODCHESTER DR	3	10/12/2023	8/9/2024	Carried Forward	Repaired		7/25/2024	100	Leak Extent	
7388304	1216 CHESTNUT ST	3	6/11/2024	7/19/2024	Newly Identified	Repaired		6/11/2024	100	Leak Extent	
7335811	78 NONANTUM ST	3	6/10/2017	7/1/2024	Carried Forward	Eliminated Otherwise		5/15/2024	84	Leak Extent	NO READS
7353086	43 CENTRAL ST	3	5/8/2019		Carried Forward	Pending		8/14/2024	80	Leak Extent	
7385311	23 DAVIS ST	3	12/19/2023	1/24/2024	Carried Forward	Eliminated Otherwise		12/19/2023	80	Leak Extent	DUPLICATE LEAK
7354890	33 THE LEDGES RD	3	7/24/2019		Carried Forward	Pending		8/9/2024	70	Leak Extent	
7343320	30 E ROADWAY	3	4/6/2018		Carried Forward	Pending		4/25/2024	64	Leak Extent	
7324253	15 JACKSON ST	3	3/23/2016	9/12/2024	Carried Forward	Eliminated Otherwise		8/14/2024	50	Leak Extent	NO READS
7356428	37 TRUMAN RD	3	9/26/2019	4/18/2024	Carried Forward	Repaired		2/16/2024	50	Leak Extent	
7332931	COMMONWEALTH AVE & BEAU	3	3/23/2017		Carried Forward	Pending		8/8/2024	49	Leak Extent	
7374842	6 LINCOLN ST	3	4/22/2022		Carried Forward	Pending		9/30/2024	41	Leak Extent	
270653	HAMMOND ST & RESERVOIR AV	3	8/20/2004	1/2/2024	Carried Forward	Eliminated Otherwise		11/14/2023	25	Leak Extent	NO READS
340420	167 NEHOLDEN RD	3	12/25/2010	7/1/2024	Carried Forward	Eliminated Otherwise		3/20/2024	25	Leak Extent	NO READS
7326611	26 MAPLE ST	3	6/6/2016	7/1/2024	Carried Forward	Eliminated Otherwise		3/20/2024	25	Leak Extent	NO READS
7329882	BEACON ST & HAMMOND ST	3	10/28/2016	1/4/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7331915	150 SPIERS RD	3	2/2/2017	1/2/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7354042	130 NEEDHAM ST	3	6/21/2019	1/2/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7354258	369 LEXINGTON ST	3	6/24/2019	1/4/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7368124	650 CENTRE ST	3	4/22/2021	1/4/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7368508	97 ATWOOD AVE	3	4/26/2021	1/4/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7373593	BOYLSTON ST & HURLEY PL	3	2/22/2022		Carried Forward	Pending		9/9/2024	25	Leak Extent	
7375164	8 BALDPATE HILL RD	3	4/26/2022	8/5/2024	Carried Forward	Eliminated Otherwise		12/19/2023	25	Leak Extent	NO READS
7377628	23 LONGMEADOW RD	3	9/28/2022		Carried Forward	Pending		5/15/2024	25	Leak Extent	
7379276	10 MOODY ST	3	12/22/2022		Carried Forward	Pending		7/25/2024	25	Leak Extent	
7384346	45 HOLMAN RD	3	9/28/2023		Carried Forward	Pending		7/25/2024	25	Leak Extent	
7336764	CENTRAL AVE & WASHINGTON S	3	7/26/2017		Carried Forward	Pending		8/9/2024	24	Leak Extent	
258065	122 WARD ST	3	1/22/2004		Carried Forward	Pending		8/20/2024	9	Leak Extent	
343629	37 SHAW ST	3	2/15/2011		Carried Forward	Pending		8/20/2024	9	Leak Extent	
7325491	604 WALNUT ST	3	4/19/2016		Carried Forward	Pending		8/20/2024	9	Leak Extent	
7351646	20 SUN HILL LN	3	3/8/2019	6/27/2024	Carried Forward	Eliminated Otherwise		4/30/2024	9	Leak Extent	NO READS
7354555	11 OWAISA RD	3	6/10/2019		Carried Forward	Pending		8/21/2024	9	Leak Extent	
7382336	24 PHILBRICK RD	3	6/26/2023		Carried Forward	Pending		4/30/2024	9	Leak Extent	
7386865	991 BOYLSTON ST	3	6/13/2024		Newly Identified	Pending		6/13/2024	9	Leak Extent	
7353562	401 WINCHESTER ST	3	5/22/2019		Carried Forward	Pending		8/5/2024	4	Leak Extent	
7364119	23 MAPLE ST	3	5/13/2020		Carried Forward	Pending		8/21/2024	4	Leak Extent	
7376820	96 WESTLAND AVE	3	8/19/2022		Carried Forward	Pending		4/30/2024	4	Leak Extent	
7379849	249 CYPRESS ST	3	2/16/2023		Carried Forward	Pending		8/20/2024	4	Leak Extent	
7321944	120 FARWELL ST	3	12/4/2015		Carried Forward	Pending		5/15/2024	1	Leak Extent	
7327360	A ROADWAY & SPIERS RD	3	6/14/2017		Carried Forward	Pending		7/11/2024	1	Leak Extent	
7336232	566 SAWMILL BROOK PKY	3	7/14/2017		Carried Forward	Pending		11/19/2024	1	Leak Extent	
7354021	25 HAYNES RD	3	6/4/2019		Carried Forward	Pending		8/14/2024	1	Leak Extent	
7355411	47 ESTY FARM RD	3	8/2/2019		Carried Forward	Pending		8/9/2024	1	Leak Extent	
7364121	34 FENNO RD	3	6/17/2020	10/19/2024	Carried Forward	Eliminated Otherwise		9/27/2024	1	Leak Extent	NO READS
7376323	4 GRAY CLIFF RD	3	7/24/2022		Carried Forward	Pending		11/7/2024	1	Leak Extent	
7378752	271 CYPRESS ST	3	11/9/2022	7/30/2024	Carried Forward	Eliminated by Replacement		6/26/2024	1	Leak Extent	
7387349	57 DEVONSHIRE RD	3	4/18/2024		Newly Identified	Pending		11/19/2024	1	Leak Extent	
230384	41 LAKEVIEW AV	3	8/7/2000	11/27/2024	Carried Forward	Eliminated Otherwise		11/6/2024	-	No CGI reading	NO READS
263170	207 WALTHAM ST	3	10/13/2004		Carried Forward	Pending		10/11/2024	-	No CGI reading	
270389	128 WOODWARD ST	3	4/27/2004		Carried Forward	Pending		5/7/2024	-	No CGI reading	
270538	522 COMMONWEALTH AV	3	6/29/2004	6/12/2024	Carried Forward	Repaired		2/16/2024	-	No CGI reading	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
270590	35-45 MCCARTHY RD	3	7/22/2004	6/27/2024	Carried Forward	Eliminated Otherwise		11/6/2023	-	No CGI reading	NO READS
271927	NESHOBE RD & WASHINGTON S	3	2/14/2005		Carried Forward	Pending		8/28/2024	-	No CGI reading	
290176	38 LOCKSLEY RD	3	12/6/2006		Carried Forward	Pending		5/7/2024	-	No CGI reading	
303390	167 MELROSE ST	3	7/31/2007		Carried Forward	Pending		11/19/2024	-	No CGI reading	
305519	50 CHESTNUT HILL RD	3	8/23/2007		Carried Forward	Pending		8/27/2024	-	No CGI reading	
307615	24 CENTRAL AVE	3	9/10/2007	12/2/2024	Carried Forward	Eliminated Otherwise		8/13/2024	-	No CGI reading	NO READS
329984	216 WINSLOW RD	3	11/30/2009		Carried Forward	Pending		10/1/2024	-	No CGI reading	
332258	30 ROLAND ST	3	4/8/2010		Carried Forward	Pending		9/23/2024	-	No CGI reading	
332435	30 K ROADWAY	3	4/13/2010	10/12/2024	Carried Forward	Eliminated Otherwise		9/3/2024	-	No CGI reading	NO READS
332674	15 HARTMAN RD	3	12/20/2010		Carried Forward	Pending		8/27/2024	-	No CGI reading	
336992	881 DEDHAM ST	3	9/1/2010	10/19/2024	Carried Forward	Eliminated Otherwise		8/13/2024	-	No CGI reading	NO READS
338427	65 ELINOR RD	3	10/9/2010	10/8/2024	Carried Forward	Eliminated by Replacement		9/30/2024	-	No CGI reading	
345666	1234 COMMONWEALTH AVE	3	4/14/2011	7/30/2024	Carried Forward	Eliminated Otherwise		2/21/2024	-	No CGI reading	NO READS
839999	115 ELLIOT ST	3	3/23/2012		Carried Forward	Pending		9/3/2024	-	No CGI reading	
871400	23 FREDANA RD	3	5/4/2012		Carried Forward	Pending		9/3/2024	-	No CGI reading	
949724	8 HAMMOND ST	3	8/1/2012	9/12/2024	Carried Forward	Eliminated Otherwise		8/13/2024	-	No CGI reading	NO READS
1018521	12 VINEYARD RD	3	10/12/2012	9/12/2024	Carried Forward	Eliminated Otherwise		9/3/2024	-	No CGI reading	NO READS
1229009	WALNUT ST & HOMER ST	3	5/17/2013		Carried Forward	Pending		8/27/2024	-	No CGI reading	
1230002	WALNUT ST & LAKEWOOD RD	3	5/17/2013		Carried Forward	Pending		10/1/2024	-	No CGI reading	
1237078	94 DEVONSHIRE RD	3	10/9/2015	10/19/2024	Carried Forward	Eliminated Otherwise		10/9/2024	-	No CGI reading	NO READS
1317702	91 PICKWICK RD	3	8/16/2013	6/27/2024	Carried Forward	Eliminated Otherwise		2/16/2024	-	No CGI reading	NO READS
1338217	102 RIDGE AVE	3	8/20/2013		Carried Forward	Pending		10/9/2024	-	No CGI reading	
1428283	191 GROVE ST	3	10/8/2013	11/27/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
2720300	61 SHARPE RD	3	1/23/2015		Carried Forward	Pending		8/13/2024	-	No CGI reading	
2834933	2401 COMMONWEALTH AVE	3	11/7/2014		Carried Forward	Pending		8/27/2024	-	No CGI reading	
3023506	COMMONWEALTH AVE & COMM	3	11/6/2014	7/1/2024	Carried Forward	Eliminated Otherwise		11/9/2023	-	No CGI reading	NO READS
3093950	43 SEWALL ST	3	2/9/2015	11/27/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
3869246	877 CHESTNUT ST	3	4/7/2015	7/1/2024	Carried Forward	Eliminated Otherwise		2/21/2024	-	No CGI reading	NO READS
4497451	60 HIGHLAND AVE	3	3/4/2015		Carried Forward	Pending		9/12/2024	-	No CGI reading	
4787400	300 ADAMS ST	3	7/7/2015	7/1/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5620468	121 PARKER AVE	3	8/27/2015	1/2/2024	Carried Forward	Eliminated Otherwise		11/13/2023	-	No CGI reading	NO READS
6591350	22 OLDEFIELD RD	3	9/12/2015	12/2/2024	Carried Forward	Eliminated Otherwise		9/9/2024	-	No CGI reading	NO READS
7322832	49 ASHMONT AVE	3	4/25/2016	8/5/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
7323736	35 BELLEVUE ST	3	2/2/2016	7/2/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
7323783	38 PUTNAM ST	3	2/1/2016	4/12/2024	Carried Forward	Eliminated Otherwise		2/16/2024	-	No CGI reading	NO READS
7325806	4 PEMBROKE ST	3	4/22/2016	12/3/2024	Carried Forward	Eliminated Otherwise		11/19/2024	-	No CGI reading	NO READS
7325992	269 JACKSON ST	3	5/12/2016	9/12/2024	Carried Forward	Eliminated Otherwise		4/25/2024	-	No CGI reading	NO READS
7326630	39 COURT ST	3	6/9/2016	10/12/2024	Carried Forward	Eliminated Otherwise		5/7/2024	-	No CGI reading	NO READS
7326636	NORTH ST & ALBEMARLE RD	3	6/13/2016	10/24/2024	Carried Forward	Eliminated Otherwise		5/7/2024	-	No CGI reading	DUPLICATE LEAK
7329507	263 HAMMOND ST	3	11/7/2016	11/27/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
7330385	75 SUMNER ST	3	11/16/2016	12/9/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
7331474	71 COMMONWEALTH AVE	3	1/3/2017		Carried Forward	Pending		11/19/2024	-	No CGI reading	
7332282	NONANTUM RD & CHARLESBAN	3	2/1/2017		Carried Forward	Pending		11/4/2024	-	No CGI reading	
7332762	ISLINGTON RD & KINGSWOOD R	3	3/21/2017		Carried Forward	Pending		9/12/2024	-	No CGI reading	
7337028	100 CONCORD ST	3	8/1/2017		Carried Forward	Pending		9/3/2024	-	No CGI reading	
7339913	58 AUBURN ST	3	11/15/2017	12/3/2024	Carried Forward	Eliminated by Replacement		9/30/2024	-	No CGI reading	
7340358	246 BEACON ST	3	12/12/2017		Carried Forward	Pending		11/6/2024	-	No CGI reading	
7341496	COMMONWEALTH AVE & AUBU	3	1/12/2018		Carried Forward	Pending		11/4/2024	-	No CGI reading	
7341526	224 JACKSON ST	3	2/27/2018	9/12/2024	Carried Forward	Eliminated Otherwise		2/20/2024	-	No CGI reading	NO READS
7341653	457 WASHINGTON ST	3	1/28/2018	12/3/2024	Carried Forward	Eliminated Otherwise		11/6/2024	-	No CGI reading	NO READS
7347783	69 EVELYN RD	3	9/16/2018	12/7/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
7347784	12 NONANTUM ST	3	9/15/2018		Carried Forward	Pending		11/7/2024	-	No CGI reading	
7347786	DEDHAM ST & MEADOWBROOK	3	9/29/2018		Carried Forward	Pending		11/7/2024	-	No CGI reading	
7348310	95 DORSET RD	3	10/11/2018	11/22/2024	Carried Forward	Eliminated Otherwise		11/20/2024	-	No CGI reading	NO READS
7348728	283 MELROSE ST	3	6/29/2018	12/3/2024	Carried Forward	Eliminated Otherwise		11/4/2024	-	No CGI reading	NO READS
7349893	240 VALENTINE ST	3	12/17/2018	8/8/2024	Carried Forward	Eliminated by Replacement		2/5/2024	-	No CGI reading	
7353079	1870 COMMONWEALTH AVE	3	5/13/2019	10/12/2024	Carried Forward	Eliminated Otherwise		8/21/2024	-	No CGI reading	NO READS
7353083	1830 COMMONWEALTH AVE	3	5/13/2019	9/21/2024	Carried Forward	Eliminated Otherwise		8/21/2024	-	No CGI reading	NO READS
7353115	150 WOODLAND RD	3	5/8/2019		Carried Forward	Pending		8/27/2024	-	No CGI reading	
7353118	207 AUBURN ST	3	5/17/2019		Carried Forward	Pending		8/27/2024	-	No CGI reading	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7353512	47 CHANDLER PL	3	5/23/2019	1/4/2024	Carried Forward	Eliminated Otherwise		11/13/2023	-	No CGI reading	NO READS
7354041	66 NEEDHAM ST	3	10/20/2021		Carried Forward	Pending		11/20/2024	-	No CGI reading	
7354147	9 HIGH ST	3	6/27/2019		Carried Forward	Pending		8/28/2024	-	No CGI reading	
7354263	1932 COMMONWEALTH AVE	3	6/24/2019		Carried Forward	Pending		8/28/2024	-	No CGI reading	
7354537	10 DAY ST	3	7/15/2019		Carried Forward	Pending		9/3/2024	-	No CGI reading	
7354698	559 CENTRE ST	3	7/16/2019		Carried Forward	Pending		9/4/2024	-	No CGI reading	
7354711	86 COMMONWEALTH AVE	3	7/16/2019	11/15/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7354712	31 DEVONSHIRE RD	3	7/19/2019	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7354715	6 EDGEWOOD RD	3	7/19/2019	8/19/2024	Carried Forward	Eliminated Otherwise		11/16/2023	-	No CGI reading	NO READS
7355547	85 BROOKSIDE AVE	3	8/20/2019	11/27/2024	Carried Forward	Eliminated Otherwise		11/1/2024	-	No CGI reading	NO READS
7355555	68 LITTLEFIELD RD	3	8/19/2019		Carried Forward	Pending		9/23/2024	-	No CGI reading	
7355561	117 NORTH ST	3	8/19/2019		Carried Forward	Pending		9/23/2024	-	No CGI reading	
7355668	34 BROADLAWN DR	3	8/23/2019		Carried Forward	Pending		9/23/2024	-	No CGI reading	
7355674	188 DEDHAM ST	3	8/23/2019	1/4/2024	Carried Forward	Eliminated Otherwise		12/14/2023	-	No CGI reading	NO READS
7356139	344 BROOKLINE ST	3	9/3/2019	8/5/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
7356142	26 HARWICH RD	3	9/4/2019		Carried Forward	Pending		10/9/2024	-	No CGI reading	
7356203	17 WAYNE RD	3	9/4/2019	6/27/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
7356207	36 WISWALL RD	3	9/5/2019	6/27/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
7356211	84 RACHEL RD	3	9/5/2019		Carried Forward	Pending		10/11/2024	-	No CGI reading	
7356362	29 F ROADWAY	3	9/25/2019	11/27/2024	Carried Forward	Eliminated Otherwise		10/30/2024	-	No CGI reading	NO READS
7356371	80 HANSON RD	3	9/25/2019	12/3/2024	Carried Forward	Eliminated Otherwise		11/4/2024	-	No CGI reading	NO READS
7356852	WATERTOWN ST & CRAFTS ST	3	10/15/2019		Carried Forward	Pending		5/6/2024	-	No CGI reading	
7357139	48 LANTERN LN	3	10/25/2019	12/3/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
7364115	33 WARREN RD	3	5/24/2020	12/9/2024	Carried Forward	Eliminated Otherwise		11/20/2024	-	No CGI reading	NO READS
7364120	43 SHERBROOKE RD	3	6/15/2020	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7364450	60 FAIRLEE RD	3	8/26/2020	11/27/2024	Carried Forward	Eliminated Otherwise		11/12/2024	-	No CGI reading	NO READS
7365082	35 WHITTIER RD	3	9/1/2020	7/11/2024	Carried Forward	Eliminated Otherwise		2/20/2024	-	No CGI reading	NO READS
7365094	160 PARKER ST	3	10/15/2020	10/19/2024	Carried Forward	Eliminated Otherwise		4/23/2024	-	No CGI reading	NO READS
7368505	87 ATWOOD AVE	3	5/4/2021	12/19/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7368733	17 COCHITUATE RD	3	5/19/2021		Carried Forward	Pending		9/23/2024	-	No CGI reading	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7370889	375 AUBURN ST	3	9/19/2021	12/3/2024	Carried Forward	Eliminated Otherwise		11/20/2024	-	No CGI reading	NO READS
7371043	34 EMERSON ST	3	10/7/2021	8/19/2024	Carried Forward	Eliminated Otherwise		4/30/2024	-	No CGI reading	NO READS
7371864	465 CENTRE ST	3	10/23/2021		Carried Forward	Pending		5/6/2024	-	No CGI reading	
7374830	21 MARSHFIELD RD	3	3/15/2022	9/12/2024	Carried Forward	Eliminated Otherwise		8/8/2024	-	No CGI reading	NO READS
7374831	75 ELMHURST RD	3	4/5/2022	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7374857	265 OTIS ST	3	5/15/2022		Carried Forward	Pending		9/30/2024	-	No CGI reading	
7375136	15 ELMWOOD PIKE	3	5/24/2022	11/27/2024	Carried Forward	Eliminated Otherwise		10/11/2024	-	No CGI reading	NO READS
7375986	11 EDGE HILL RD	3	5/23/2022		Carried Forward	Pending		10/11/2024	-	No CGI reading	
7375989	38 VERNDAL RD	3	6/17/2022	12/3/2024	Carried Forward	Eliminated Otherwise		11/6/2024	-	No CGI reading	NO READS
7376318	39 BILLINGS PIKE	3	8/3/2022	12/7/2024	Carried Forward	Eliminated Otherwise		11/12/2024	-	No CGI reading	NO READS
7376811	195 MORTON ST	3	8/26/2022		Carried Forward	Pending		5/6/2024	-	No CGI reading	
7376826	12 COPLEY ST	3	4/15/2022	8/19/2024	Carried Forward	Eliminated Otherwise		1/11/2024	-	No CGI reading	NO READS
7379850	54 DUXBURY RD	3	2/7/2023	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7379883	228 HIGHLAND AVE	3	2/28/2023	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7380672	31 GARDNER ST	3	3/23/2023	8/19/2024	Carried Forward	Eliminated Otherwise		1/12/2024	-	No CGI reading	NO READS
7380674	10 LOWELL AVE	3	2/24/2023	9/12/2024	Carried Forward	Eliminated Otherwise		8/28/2024	-	No CGI reading	NO READS
7382899	298 CYPRESS ST	3	7/8/2023	8/19/2024	Carried Forward	Eliminated Otherwise		5/6/2024	-	No CGI reading	NO READS
7384691	320 WASHINGTON ST	3	11/15/2023	6/27/2024	Carried Forward	Eliminated Otherwise		2/13/2024	-	No CGI reading	NO READS
7385308	55 FOREST AVE	3	12/9/2023		Carried Forward	Pending		9/12/2024	-	No CGI reading	
7385843	299 WOODLAND RD	3	1/11/2024		Newly Identified	Pending		10/9/2024	-	No CGI reading	
7385972	5 MARSHALL ST	3	2/1/2024	12/3/2024	Newly Identified	Eliminated Otherwise		10/30/2024	-	No CGI reading	NO READS
7386046	17 CHESTER ST	3	1/31/2024		Newly Identified	Pending		10/30/2024	-	No CGI reading	
7386138	11 CANTERBURY RD	3	2/11/2024	11/27/2024	Newly Identified	Eliminated Otherwise		11/1/2024	-	No CGI reading	NO READS
7390988	22 TRAVERSE ST	3	11/22/2024		Newly Identified	Pending		11/22/2024	-	No CGI reading	
7391266	46 CEDAR ST	3	12/11/2024		Newly Identified	Pending		12/11/2024	-	No CGI reading	
7391275	54 BALLARD ST	3	12/9/2024		Newly Identified	Pending		12/9/2024	-	No CGI reading	
7382741	263 HAMMOND ST	1	8/3/2023	3/21/2024	Carried Forward	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7384926	55 MURRAY RD	1	12/10/2023	3/21/2024	Carried Forward	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7385225	12 WASHBURN ST	1	1/2/2024	1/2/2024	Newly Identified	Repaired					
7385254	898 CHESTNUT ST	1	1/4/2024	1/4/2024	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7385256	45 SEWALL ST	1	1/4/2024	1/4/2024	Newly Identified	Repaired					
7385276	228 HIGHLAND AVE	1	1/5/2024	1/5/2024	Newly Identified	Repaired					
7385351	178 NEHOIDEN RD	1	1/11/2024	1/11/2024	Newly Identified	Repaired					
7385364	206 WINSLOW RD	1	1/11/2024	1/11/2024	Newly Identified	Repaired					
7385367	19 WOODBINE ST	1	1/11/2024	1/11/2024	Newly Identified	Repaired					
7385393	37 MONTROSE ST	1	1/14/2024	1/15/2024	Newly Identified	Repaired					
7385398	12 ELLIOT PL	1	1/15/2024	1/15/2024	Newly Identified	Repaired					
7385399	21 JASSET ST	1	1/15/2024	1/16/2024	Newly Identified	Repaired					
7385407	101 VERNON ST	1	1/16/2024	1/16/2024	Newly Identified	Repaired					
7385408	55 WETHERELL ST	1	1/16/2024	1/17/2024	Newly Identified	Repaired					
7385426	24 LEE RD	1	1/17/2024	1/18/2024	Newly Identified	Repaired					
7385427	12 BROADLAWN DR	1	1/17/2024	1/17/2024	Newly Identified	Repaired					
7385462	28 ISLINGTON RD	1	1/19/2024	1/19/2024	Newly Identified	Repaired					
7385463	350 WOODWARD ST	1	1/20/2024	1/20/2024	Newly Identified	Repaired					
7385487	458 LOWELL AVE	1	1/22/2024	1/22/2024	Newly Identified	Repaired					
7385518	256 WATERTOWN ST	1	1/23/2024	1/23/2024	Newly Identified	Repaired					
7385527	28 GEORGE ST	1	1/23/2024	2/6/2024	Newly Identified	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7385528	28 GEORGE ST	1	1/23/2024	1/24/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7385532	263 PEARL ST	1	1/24/2024	1/25/2024	Newly Identified	Repaired					
7385551	213 NAHANTON ST	1	1/24/2024	1/25/2024	Newly Identified	Repaired					
7385614	95 ALLEN AVE	1	1/28/2024	1/28/2024	Newly Identified	Repaired					
7385615	215 NAHANTON ST	1	1/28/2024	1/28/2024	Newly Identified	Repaired					
7385616	215 NAHANTON ST	1	1/28/2024	1/28/2024	Newly Identified	Repaired					
7385638	2014 WASHINGTON ST	1	1/29/2024	1/29/2024	Newly Identified	Repaired					
7385654	139 CALIFORNIA ST	1	1/30/2024	1/30/2024	Newly Identified	Repaired					
7385663	25 AVALON RD	1	1/31/2024	1/31/2024	Newly Identified	Repaired					
7385671	616 BOYLSTON ST	1	1/31/2024	2/2/2024	Newly Identified	Repaired					
7385703	204 NORTH ST	1	2/1/2024	2/2/2024	Newly Identified	Repaired					
7385814	18 PRISCILLA RD	1	2/6/2024	2/6/2024	Newly Identified	Repaired					
7385821	103 WABAN AVE	1	2/6/2024	2/7/2024	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7385872	28 HIBBARD RD	1	2/8/2024	2/8/2024	Newly Identified	Repaired					
7385874	22 FAIRWAY DR	1	2/8/2024	2/9/2024	Newly Identified	Repaired					
7385884	109 ADAMS ST	1	2/9/2024	2/9/2024	Newly Identified	Repaired					
7385888	384 NEWTONVILLE AVE	1	2/9/2024	2/9/2024	Newly Identified	Repaired					
7385944	1395 COMMONWEALTH AVE	1	2/14/2024	2/14/2024	Newly Identified	Repaired					
7385971	305 COMMONWEALTH AVE	1	2/15/2024	2/15/2024	Newly Identified	Repaired					
7385979	14 MARGARET RD	1	2/15/2024	2/16/2024	Newly Identified	Repaired					
7386005	14 PARK PL	1	2/17/2024	2/19/2024	Newly Identified	Repaired					
7386010	5 MARSHALL ST	1	2/17/2024	2/17/2024	Newly Identified	Repaired					
7386154	160 NEEDHAM ST	1	2/27/2024	2/27/2024	Newly Identified	Repaired					
7386159	69 LOS ANGELES ST	1	2/28/2024	2/28/2024	Newly Identified	Repaired					
7386202	53 CRESCENT AVE	1	3/3/2024	3/3/2024	Newly Identified	Repaired					
7386313	1888 COMMONWEALTH AVE	1	3/11/2024	3/13/2024	Newly Identified	Repaired					
7386320	40 THE LEDGES RD	1	3/12/2024	3/13/2024	Newly Identified	Repaired					
7386330	380 WABAN AVE	1	3/12/2024	3/13/2024	Newly Identified	Repaired					
7386372	50 QUINCY RD	1	3/14/2024	3/15/2024	Newly Identified	Repaired					
7386381	21 CHANDLER PL	1	3/15/2024	3/15/2024	Newly Identified	Repaired					
7386395	19 SYLVESTER RD	1	3/16/2024	3/16/2024	Newly Identified	Repaired					
7386433	4 MEREDITH AVE	1	3/19/2024	3/20/2024	Newly Identified	Eliminated Otherwise					CALLLED OFF BY SUPERVISOR
7386453	1251 WASHINGTON ST	1	3/20/2024	3/21/2024	Newly Identified	Repaired					
7386555	427 LEXINGTON ST	1	3/28/2024	3/29/2024	Newly Identified	Repaired					
7386569	427 LEXINGTON ST	1	3/28/2024	3/29/2024	Newly Identified	Repaired					
7386609	23 RESERVOIR AVE	1	4/2/2024	4/2/2024	Newly Identified	Repaired					
7386617	826 WATERTOWN ST	1	4/2/2024	4/3/2024	Newly Identified	Repaired					
7386630	51 WILDWOOD AVE	1	4/3/2024	4/4/2024	Newly Identified	Repaired					
7386656	320 WASHINGTON ST	1	4/5/2024	4/7/2024	Newly Identified	Repaired					
7386658	21 CLOELIA TER	1	4/5/2024	4/6/2024	Newly Identified	Repaired					
7386671	15 WOODCLIFF RD	1	4/8/2024	4/8/2024	Newly Identified	Repaired					
7386912	1224 BOYLSTON ST	1	4/18/2024	5/1/2024	Newly Identified	Repaired					
7386949	1197 CENTRE ST	1	4/20/2024	4/22/2024	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7386979	461 WOLCOTT ST	1	4/22/2024	4/22/2024	Newly Identified	Repaired					
7387022	137 PINE RIDGE RD	1	4/23/2024	4/23/2024	Newly Identified	Repaired					
7387036	1564 BEACON ST	1	4/24/2024	4/25/2024	Newly Identified	Repaired					
7387052	300 PRINCE ST	1	4/24/2024	4/24/2024	Newly Identified	Repaired					
7387082	105 TOLMAN ST	1	4/25/2024	4/25/2024	Newly Identified	Repaired					
7387122	8 SHELDON RD	1	4/28/2024	5/2/2024	Newly Identified	Repaired					
7387128	420 WALTHAM ST	1	4/29/2024	4/29/2024	Newly Identified	Repaired					
7387168	320 WASHINGTON ST	1	4/30/2024	6/3/2024	Newly Identified	Repaired					
7387171	1310 CENTRE ST	1	4/30/2024	4/30/2024	Newly Identified	Repaired					
7387201	77 HALCYON RD	1	5/1/2024	5/1/2024	Newly Identified	Repaired					
7387243	2240 COMMONWEALTH AVE	1	5/3/2024	5/6/2024	Newly Identified	Repaired					
7387253	665 WATERTOWN ST	1	5/4/2024	5/8/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7387254	665 WATERTOWN ST	1	5/4/2024	5/4/2024	Newly Identified	Repaired					
7387260	90 HIGHLAND AVE	1	5/5/2024	5/6/2024	Newly Identified	Repaired					
7387299	51 GORDON RD	1	5/7/2024	5/7/2024	Newly Identified	Repaired					
7387303	3 CARL ST	1	5/7/2024	5/7/2024	Newly Identified	Repaired					
7387326	5 MARGARET RD	1	5/7/2024	5/10/2024	Newly Identified	Repaired					
7387337	9 MARGARET RD	1	5/7/2024	5/7/2024	Newly Identified	Repaired					
7387339	84 HAMMONDSWOOD RD	1	5/7/2024	5/7/2024	Newly Identified	Repaired					
7387378	60 DWHINDA RD	1	5/9/2024	5/9/2024	Newly Identified	Repaired					
7387407	112 AUBURNDAL AVE	1	5/10/2024	5/10/2024	Newly Identified	Repaired					
7387464	61 WINTHROP ST	1	5/13/2024	5/13/2024	Newly Identified	Repaired					
7387484	528 BOYLSTON ST	1	5/14/2024	5/21/2024	Newly Identified	Repaired					
7387504	WINDERMERE RD & WOODLAN	1	5/15/2024	5/15/2024	Newly Identified	Repaired					
7387664	176 BOYLSTON ST	1	5/22/2024	5/22/2024	Newly Identified	Repaired					
7387665	176 BOYLSTON ST	1	5/23/2024	12/30/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7387982	12 GEORGE ST	1	6/7/2024	6/7/2024	Newly Identified	Repaired					
7388022	22 WALSH RD	1	6/11/2024	6/12/2024	Newly Identified	Repaired					
7388114	728 WALNUT ST	1	6/17/2024	6/17/2024	Newly Identified	Repaired					
7388177	300 HAMMOND ST	1	6/22/2024	6/22/2024	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7388276	432 WATERTOWN ST	1	6/27/2024	6/27/2024	Newly Identified	Repaired					
7388323	1009 BOYLSTON ST	1	7/1/2024	7/1/2024	Newly Identified	Repaired					
7388359	146 LINCOLN ST	1	7/2/2024	7/3/2024	Newly Identified	Repaired					
7388489	22 BONMAR CIR	1	7/12/2024	7/12/2024	Newly Identified	Repaired					
7388530	1 RIDGE RD	1	7/16/2024	7/16/2024	Newly Identified	Repaired					
7388577	GILBERT ST & AUBURN ST	1	7/19/2024	7/19/2024	Newly Identified	Repaired					
7388623	11 CLEARWATER RD	1	7/22/2024	7/22/2024	Newly Identified	Repaired					
7388654	500 DUDLEY RD	1	7/24/2024	7/24/2024	Newly Identified	Repaired					
7388809	494 WATERTOWN ST	1	8/5/2024		Newly Identified	Pending					
7388841	83 MORRILL ST	1	8/6/2024	8/6/2024	Newly Identified	Repaired					
7388879	100 WOODCHESTER DR	1	8/8/2024	8/8/2024	Newly Identified	Repaired					
7388951	628 BOYLSTON ST	1	8/12/2024	8/16/2024	Newly Identified	Repaired					
7388988	78 WALKER ST	1	8/13/2024	8/13/2024	Newly Identified	Repaired					
7389106	866 BEACON ST	1	8/12/2024	8/19/2024	Newly Identified	Repaired					
7389107	7 WADE ST	1	8/19/2024	8/19/2024	Newly Identified	Repaired					
7389135	567 WALNUT ST	1	8/20/2024	8/21/2024	Newly Identified	Repaired					
7389156	1042 BOYLSTON ST	1	8/21/2024	8/23/2024	Newly Identified	Repaired					
7389172	WESTBOURNE RD & EASTBOURNE ST	1	8/21/2024	8/21/2024	Newly Identified	Repaired					
7389264	949 CENTRE ST	1	8/27/2024	8/27/2024	Newly Identified	Repaired					
7389409	202 AUBURNDAL AVE	1	9/6/2024	9/6/2024	Newly Identified	Repaired					
7389575	14 SHORNECLIFFE RD	1	9/13/2024	9/13/2024	Newly Identified	Repaired					
7389682	1039 WALNUT ST	1	9/19/2024	9/19/2024	Newly Identified	Repaired					
7389705	989 CENTRE ST	1	9/20/2024	9/20/2024	Newly Identified	Repaired					
7389793	CURVE ST & AUBURN ST	1	9/25/2024	9/25/2024	Newly Identified	Repaired					
7389801	796 CHESTNUT ST	1	9/25/2024	9/25/2024	Newly Identified	Repaired					
7389806	98 ANNAWAN RD	1	9/26/2024	9/26/2024	Newly Identified	Repaired					
7389938	961 WALNUT ST	1	10/4/2024	10/4/2024	Newly Identified	Repaired					
7390136	6 DORCAR RD	1	10/17/2024	10/17/2024	Newly Identified	Repaired					
7390261	1011 CENTRE ST	1	10/18/2024	10/24/2024	Newly Identified	Repaired					
7390304	60 ELLIOT ST	1	10/22/2024	10/22/2024	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7390630	27 METACOMET RD	1	11/5/2024	11/6/2024	Newly Identified	Repaired					
7390704	6 ALBAN RD	1	11/12/2024	11/12/2024	Newly Identified	Repaired					
7390779	49 MILLER RD	1	11/17/2024	11/18/2024	Newly Identified	Repaired					
7390783	16 MANEMET RD	1	11/18/2024	11/18/2024	Newly Identified	Repaired					
7390797	933 CENTRE ST	1	11/18/2024	11/18/2024	Newly Identified	Repaired					
7390874	5 SHELDON RD	1	11/22/2024	11/26/2024	Newly Identified	Repaired					
7390876	116 FAIRWAY DR	1	11/22/2024	11/25/2024	Newly Identified	Repaired					
7390889	35 DRUMLIN RD	1	11/24/2024	11/24/2024	Newly Identified	Repaired					
7391093	74 WALKER ST	1	12/5/2024	12/5/2024	Newly Identified	Repaired					
7391098	955 CENTRE ST	1	12/5/2024	12/5/2024	Newly Identified	Repaired					
7391104	15 SIMPSON ST	1	12/5/2024		Newly Identified	Pending					
7391215	123 SPIERS RD	1	12/17/2024		Newly Identified	Pending					
7391282	494 WARD ST	1	12/24/2024	12/27/2024	Newly Identified	Repaired					
7391286	268 DORSET RD	1	12/26/2024	12/26/2024	Newly Identified	Repaired					
7391330	OAK ST & CHESTNUT ST	1	12/29/2024	12/30/2024	Newly Identified	Repaired					
7391334	865 BEACON ST	1	12/29/2024	12/30/2024	Newly Identified	Repaired					
42479	52 SEWALL ST	2	7/25/2024	8/30/2024	Carried Forward	Repaired	3				
155801	KENDALL RD & WALNUT HILL RD	2	6/27/2024	9/4/2024	Carried Forward	Repaired	3				
337057	327 CHERRY ST	2	4/30/2024		Carried Forward	Pending	3				
1215753	52 ELLIOT ST	2	2/15/2023	9/24/2024	Carried Forward	Repaired					
1336115	156 OAK ST	2	4/17/2020	10/30/2024	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7325494	4 MARLBORO ST	2	9/6/2024	9/18/2024	Carried Forward	Repaired	3				
7327022	74 HOMESTEAD ST	2	6/26/2024	8/19/2024	Carried Forward	Eliminated Other	3				NO READS
7336761	425 WATERTOWN ST	2	2/14/2023	2/14/2024	Carried Forward	Repaired					
7345014	7 CURTIS ST	2	11/20/2024		Carried Forward	Pending	3				
7352431	54 TEMPLE ST	2	2/14/2024	3/14/2024	Carried Forward	Repaired	3				
7353522	8 WETHERELL ST	2	6/26/2024	8/23/2024	Carried Forward	Repaired	3				
7354043	170 NEEDHAM ST	2	5/21/2020	11/20/2020	Carried Forward	Eliminated by Replacement					
7354261	MELROSE AVE & MELROSE ST	2	11/16/2023	1/11/2024	Carried Forward	Repaired					
7354538	5 MARSHALL ST	2	11/16/2023	1/9/2024	Carried Forward	Repaired					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7354888	624 BEACON ST	2	6/17/2020	10/1/2024	Carried Forward	Repaired					
7355977	173 HIGHLAND ST	2	9/18/2024	9/30/2024	Carried Forward	Repaired	3				
7356367	350 WINCHESTER ST	2	12/4/2023	1/2/2024	Carried Forward	Repaired					
7356436	317 PARKER ST	2	7/27/2021	9/25/2024	Carried Forward	Repaired					
7368736	1330 BOYLSTON ST	2	11/20/2024		Carried Forward	Pending	3				
7371859	214 BEACON ST	2	5/15/2024	6/14/2024	Carried Forward	Eliminated Other	3				SYSTEM ISSUE
7374832	366 ELLIOT ST	2	12/20/2023	1/12/2024	Carried Forward	Repaired					
7374845	2055 WASHINGTON ST	2	1/21/2024	4/23/2024	Carried Forward	Eliminated Other	3				NO READS
7374856	1750 COMMONWEALTH AVE	2	2/15/2024	3/11/2024	Carried Forward	Repaired	3				
7375160	64 HILLSIDE AVE	2	6/26/2024	10/1/2024	Carried Forward	Eliminated by Re	3				
7375985	66 PELHAM ST	2	7/6/2024	8/28/2024	Carried Forward	Repaired	3				
7376438	281 HOMER ST	2	7/29/2022	9/26/2024	Carried Forward	Repaired					
7376827	120 CORNELL ST	2	11/22/2024	12/6/2024	Carried Forward	Repaired	3				
7378193	4 JUDITH RD	2	11/8/2022	9/10/2024	Carried Forward	Repaired					
7379171	74 FAIRMONT AVE	2	11/22/2024	12/12/2024	Carried Forward	Repaired	3				
7379277	234 CENTRAL ST	2	8/5/2024	9/11/2024	Carried Forward	Repaired	3				
7379290	25 OLD ENGLAND RD	2	10/6/2024	11/4/2024	Carried Forward	Repaired	3				
7379459	839 WASHINGTON ST	2	7/26/2024	8/29/2024	Carried Forward	Repaired	3				
7380676	923 WALNUT ST	2	1/29/2024	3/11/2024	Carried Forward	Repaired	3				
7382122	207 WASHINGTON ST	2	6/6/2023	6/6/2024	Carried Forward	Repaired					
7382536	74 EDDY ST	2	6/29/2023	7/25/2024	Carried Forward	Eliminated Otherwise					NO READS
7382898	160 BOYLSTON ST	2	5/6/2024		Carried Forward	Pending	3				
7383497	2084 BEACON ST	2	5/24/2024	7/25/2024	Carried Forward	Repaired	3				
7383508	HIGH ST & ELLIOT ST	2	11/22/2024	12/13/2024	Carried Forward	Repaired	3				
7383831	250 ALBEMARLE RD	2	7/11/2024	9/6/2024	Carried Forward	Repaired	3				
7384775	628 BOYLSTON ST	2	10/24/2023	2/6/2024	Carried Forward	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7385304	35 LEXINGTON ST	2	12/24/2023	2/14/2024	Carried Forward	Repaired					
7385348	17 WARE RD	2	12/22/2023	1/31/2024	Carried Forward	Repaired					
7385438	72 ALLEN AVE	2	1/2/2024	1/30/2024	Newly Identified	Repaired					
7385439	384 LINWOOD AVE	2	1/3/2024	2/21/2024	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7385512	86 ALLEN AVE	2	12/31/2023	1/30/2024	Carried Forward	Repaired					
7385629	4 CAPITAL ST	2	1/22/2024	3/25/2024	Newly Identified	Repaired					
7385715	15 HICKORY CLIFF RD	2	1/23/2024	6/3/2024	Newly Identified	Eliminated by Replacement					
7385716	30 KILBURN RD	2	1/25/2024	3/20/2024	Newly Identified	Repaired					
7385717	12 PLEASANT ST	2	1/25/2024	3/20/2024	Newly Identified	Repaired					
7385809	580 WASHINGTON ST	2	12/20/2023	2/22/2024	Carried Forward	Repaired					
7385861	67 CHERRY ST	2	1/30/2024	2/21/2024	Newly Identified	Repaired					
7385862	53 CRESCENT ST	2	1/31/2024	2/26/2024	Newly Identified	Repaired					
7385864	48 NATHAN RD	2	2/1/2024	2/22/2024	Newly Identified	Repaired					
7385940	346 WINCHESTER ST	2	2/6/2024	2/16/2024	Newly Identified	Repaired					
7385941	87 ALLEN AVE	2	2/6/2024	2/15/2024	Newly Identified	Repaired					
7385960	CYPRESS ST & PARKER ST	2	2/6/2024	2/29/2024	Newly Identified	Repaired					
7385961	20 MALIA TER	2	2/4/2024	4/24/2024	Newly Identified	Repaired					
7386019	5 SWAN AVE	2	2/6/2024	3/6/2024	Newly Identified	Repaired					
7386051	316 WOODWARD ST	2	4/8/2024	7/1/2024	Newly Identified	Repaired	3				
7386104	228 WEBSTER ST	2	2/15/2024	4/24/2024	Newly Identified	Repaired					
7386106	56 MILLER RD	2	10/9/2024	10/25/2024	Newly Identified	Repaired	3				
7386383	1730 WASHINGTON ST	2	2/7/2024	5/16/2024	Newly Identified	Repaired					
7386420	138 COTTON ST	2	3/6/2024	4/1/2024	Newly Identified	Repaired					
7386423	5 OLDEFIELD RD	2	3/6/2024	4/10/2024	Newly Identified	Repaired					
7386574	528 BOYLSTON ST	2	3/3/2024	5/16/2024	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7386863	47 WINCHESTER RD	2	4/18/2024	5/1/2024	Newly Identified	Repaired					
7387138	1774 COMMONWEALTH AVE	2	12/2/2024		Newly Identified	Pending	3				
7387188	28 ARAPAHOE RD	2	3/18/2024	6/14/2024	Newly Identified	Repaired					
7387447	115 ALLEN AVE	2	4/22/2024	10/2/2024	Newly Identified	Repaired					
7387449	208 LEXINGTON ST	2	4/29/2024	8/20/2024	Newly Identified	Repaired					
7387451	26 NOBLE ST	2	4/30/2024	6/14/2024	Newly Identified	Repaired					
7387453	122 CARVER RD	2	4/22/2024	6/13/2024	Newly Identified	Repaired					
7387519	477 GROVE ST	2	4/19/2024		Newly Identified	Pending					
7387874	100 VALENTINE ST	2	5/3/2024	7/24/2024	Newly Identified	Eliminated by Replacement					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7387884	336 BOYLSTON ST	2	5/16/2024		Newly Identified	Pending					
7387910	1026 BOYLSTON ST	2	5/13/2024		Newly Identified	Pending					
7387914	1310 CENTRE ST	2	5/13/2024	9/10/2024	Newly Identified	Repaired					
7387916	3 CHANDLER ST	2	5/13/2024	7/25/2024	Newly Identified	Repaired					
7387919	169 CYPRESS ST	2	5/28/2024	7/18/2024	Newly Identified	Repaired					
7387922	2096 WASHINGTON ST	2	5/24/2024		Newly Identified	Pending					
7387994	300 HAMMOND ST	2	5/31/2024	6/24/2024	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7388266	8 BROWNING RD	2	5/30/2024	7/11/2024	Newly Identified	Repaired					
7388349	6 WESSEX RD	2	10/13/2024	10/30/2024	Newly Identified	Repaired	3				
7388430	7 WADE ST	2	5/14/2024	8/22/2024	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7388519	368 BOYLSTON ST	2	6/12/2024		Newly Identified	Pending					
7388683	195 NORTH ST	2	7/7/2024	10/9/2024	Newly Identified	Repaired					
7388831	440 LEXINGTON ST	2	7/23/2024		Newly Identified	Pending					
7388903	1185 WALNUT ST	2	7/25/2024	10/23/2024	Newly Identified	Repaired					
7388975	449 NEWTONVILLE AVE	2	7/26/2024	8/30/2024	Newly Identified	Repaired					
7389123	100 BOYLSTON ST	2	8/14/2024		Newly Identified	Pending					
7389152	44 WAVERLY AVE	2	8/18/2024	9/10/2024	Newly Identified	Repaired					
7389267	33 ORIENT AVE	2	8/26/2024		Newly Identified	Pending					
7389363	10 WINDSOR RD	2	8/27/2024	9/11/2024	Newly Identified	Repaired					
7389498	275 MILL ST	2	9/6/2024	9/24/2024	Newly Identified	Repaired					
7389504	109 CABOT ST	2	9/5/2024	9/17/2024	Newly Identified	Repaired					
7389508	427 LEXINGTON ST	2	9/4/2024	10/2/2024	Newly Identified	Repaired					
7389974	11 CLEARWATER RD	2	9/30/2024	10/16/2024	Newly Identified	Repaired					
7389975	1097 CENTRE ST	2	9/23/2024	10/16/2024	Newly Identified	Repaired					
7389976	64 BISHOPSGATE RD	2	10/1/2024	10/23/2024	Newly Identified	Repaired					
7390003	85 MONTVALE RD	2	10/4/2024	10/28/2024	Newly Identified	Repaired					
7390093	835 WASHINGTON ST	2	10/13/2024	11/4/2024	Newly Identified	Repaired					
7390373	961 WALNUT ST	2	10/17/2024	10/23/2024	Newly Identified	Repaired					
7390421	111 PARKER AVE	2	10/23/2024	11/12/2024	Newly Identified	Repaired					
7390652	1197 CENTRE ST	2	10/9/2024	11/21/2024	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7390710	75 WALKER ST	2	11/2/2024	12/4/2024	Newly Identified	Repaired					
7390737	38 PRINCE ST	2	11/2/2024	12/2/2024	Newly Identified	Repaired					
7390899	7 CURTIS ST	2	11/20/2024	12/4/2024	Newly Identified	Repaired					
7391075	3 NARDONE RD	2	11/24/2024	12/16/2024	Newly Identified	Repaired					
7391374	26 BEACON ST	2	12/12/2024		Newly Identified	Pending					
7391505	15 LARCHMONT AVE	2	12/31/2024		Newly Identified	Pending					
7374799	1730 WASHINGTON ST	3	4/5/2023	3/15/2024	Carried Forward	Eliminated Otherwise					SYSTEM ISSUE
7376329	1595 WASHINGTON ST	3	7/28/2022	6/5/2024	Carried Forward	Repaired					
7380668	10 ANNAWAN RD	3	3/27/2023	2/22/2024	Carried Forward	Repaired					
7385845	200 JACKSON RD	3	1/18/2024	7/29/2024	Newly Identified	Repaired					
7386000	83 FAXON ST	3	2/16/2024	2/16/2024	Newly Identified	Repaired					
7386047	25 GREENLAWN AVE	3	2/1/2024	10/24/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7386471	100 VARICK RD	3	3/21/2024	3/21/2024	Newly Identified	Repaired					
7386559	933 CENTRE ST	3	3/12/2024	11/14/2024	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7387353	77 WOOD END RD	3	4/22/2024		Newly Identified	Pending				Survey to be provided	
7387493	1750 COMMONWEALTH AVE	3	5/8/2024	11/20/2024	Newly Identified	Repaired					
7387593	40 CHASKE AVE	3	4/22/2024		Newly Identified	Pending				Survey to be provided	
7387594	40 CHASKE AVE	3	4/22/2024	5/30/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7387597	9 ELLIOT ST	3	4/29/2024		Newly Identified	Pending				Survey to be provided	
7387765	156 OAK ST	3	5/14/2024		Newly Identified	Pending				Survey to be provided	
7387777	82 ALBEMARLE RD	3	5/2/2024		Newly Identified	Pending				Survey to be provided	
7387779	20 BEAUMONT AVE	3	5/6/2024		Newly Identified	Pending				Survey to be provided	
7387993	AUBURNDALE AVE & HAROLD T	3	5/31/2024	7/23/2024	Newly Identified	Eliminated by Replacement					
7388450	320 WASHINGTON ST	3	6/25/2024		Newly Identified	Pending				Survey to be provided	
7388454	74 ERIE AVE	3	7/2/2024		Newly Identified	Pending				Survey to be provided	
7388455	318 CABOT ST	3	6/25/2024		Newly Identified	Pending				Survey to be provided	
7388521	255 PARKER ST	3	10/1/2024	9/25/2024	Newly Identified	Repaired	2				
7388900	425 WARD ST	3	7/23/2024	8/15/2024	Newly Identified	Repaired					
7389125	32 SUFFOLK RD	3	8/13/2024		Newly Identified	Pending				Survey to be provided	
7389144	39 NEHOIDEN RD	3	8/17/2024		Newly Identified	Pending				Survey to be provided	

Table L6 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)

QUARTER 4 - 2024

Name of Operator: *Boston & Colonial Gas Company*

Leak ID (if applicable)	Street Number and Name	Grade [1, 2, 3]	Classification Date	Repair Dates (during quarter)	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7389263	269 HIGHLAND ST	3	8/21/2024		Newly Identified	Pending				Survey to be provided	
7389268	15 UPLAND RD	3	8/25/2024		Newly Identified	Pending				Survey to be provided	
7389395	92 WALKER ST	3	9/2/2024		Newly Identified	Pending				Survey to be provided	
7389589	7 WADE ST	3	9/11/2024	12/9/2024	Newly Identified	Repaired					
7389618	20 WOODCHESTER DR	3	9/13/2024		Newly Identified	Pending				Survey to be provided	
7389619	15 LAWRENCE RD	3	9/15/2024		Newly Identified	Pending				Survey to be provided	
7389634	1297 WALNUT ST	3	9/12/2024		Newly Identified	Pending				Survey to be provided	
7389706	87 CHARLEMONT ST	3	9/18/2024		Newly Identified	Pending				Survey to be provided	
7389707	1063 COMMONWEALTH AVE	3	9/17/2024		Newly Identified	Pending				Survey to be provided	
7389759	130 NONANTUM RD	3	9/24/2024	9/25/2024	Newly Identified	Repaired					
7389765	23 HIGH ST	3	8/12/2024		Newly Identified	Pending				Survey to be provided	
7389987	37 CLARK ST	3	9/12/2024		Newly Identified	Pending				Survey to be provided	
7389989	40 ROYCE RD	3	9/23/2024		Newly Identified	Pending				Survey to be provided	
7390129	573 WASHINGTON ST	3	10/16/2024	10/16/2024	Newly Identified	Repaired					
7390404	1669 CENTRE ST	3	10/23/2024		Newly Identified	Pending				Survey to be provided	
7390407	160 PARKER ST	3	10/23/2024		Newly Identified	Pending				Survey to be provided	
7391223	6 ANGIER CIR	3	12/17/2024	12/18/2024	Newly Identified	Repaired					
7391274	54 BALLARD ST	3	12/9/2024		Newly Identified	Pending				Survey to be provided	

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7385884	109 ADAMS ST	1	2024-02-09	2024-02-09	Newly Identified	Repaired					
7386037	249 ADAMS ST	3	2024-01-30	2024-12-19	Newly Identified	Repaired		2024-10-30	420	Leak Extent	
4787400	300 ADAMS ST	3	2015-07-07	2024-07-01	Carried Forward	Eliminated Otherwise		2024-01-04	0	No CGI reading	NO READS
7365113	110 ADELINE RD	3	2020-10-09	2024-08-12	Carried Forward	Repaired		2024-03-21	748	Leak Extent	
7325711	5 AGAWAM RD	3	2016-05-10	2024-12-17	Carried Forward	Repaired		2024-09-12	660	Leak Extent	
7390704	6 ALBAN RD	1	2024-11-12	2024-11-12	Newly Identified	Repaired					
7383831	250 ALBEMARLE RD	2	2024-07-11	2024-09-06	Carried Forward	Repaired	3				
3900011	18 ALDEN ST	3	2015-04-24	2024-08-06	Carried Forward	Repaired		2023-11-16	1530	Leak Extent	
7385438	72 ALLEN AVE	2	2024-01-02	2024-01-30	Newly Identified	Repaired					
7385512	86 ALLEN AVE	2	2023-12-31	2024-01-30	Carried Forward	Repaired					
7385941	87 ALLEN AVE	2	2024-02-06	2024-02-15	Newly Identified	Repaired					
7385614	95 ALLEN AVE	1	2024-01-28	2024-01-28	Newly Identified	Repaired					
7387447	115 ALLEN AVE	2	2024-04-22	2024-10-02	Newly Identified	Repaired					
2349834	109 ALLERTON RD	3	2014-12-26	2024-12-16	Carried Forward	Repaired		2024-08-22	600	Leak Extent	
7374854	5 ANGIER CIR	3	2022-05-11	2024-12-18	Carried Forward	Repaired		2024-09-30	660	Leak Extent	
7391223	6 ANGIER CIR	3	2024-12-17	2024-12-18	Newly Identified	Repaired					
7380668	10 ANNAWAN RD	3	2023-03-27	2024-02-22	Carried Forward	Repaired					
7389806	98 ANNAWAN RD	1	2024-09-26	2024-09-26	Newly Identified	Repaired					
7379545	105 ANNAWAN RD	3	2023-01-19	2024-12-19	Carried Forward	Repaired		2024-08-20	1440	Leak Extent	
7355545	11 ANTONELLIS CIR	3	2019-08-22	2024-12-17	Carried Forward	Repaired		2024-09-27	1332	Leak Extent	
7387188	28 ARAPAHOE RD	2	2024-03-18	2024-06-14	Newly Identified	Repaired					
7373592	11 ASHCROFT RD	3	2022-02-22	2024-12-18	Carried Forward	Repaired		2024-08-22	100	Leak Extent	
7322832	49 ASHMONT AVE	3	2016-04-25	2024-08-05	Carried Forward	Eliminated Otherwise		2024-01-04	0	No CGI reading	NO READS
7368505	87 ATWOOD AVE	3	2021-05-04	2024-12-19	Carried Forward	Eliminated Otherwise		2024-09-04	0	No CGI reading	NO READS
7368508	97 ATWOOD AVE	3	2021-04-26	2024-01-04	Carried Forward	Eliminated Otherwise		2023-11-16	25	Leak Extent	NO READS
4788513	22 AUBURN ST	3	2015-07-09	2024-10-17	Carried Forward	Eliminated Otherwise		2024-05-07	200	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7339913	58 AUBURN ST	3	2017-11-15	2024-12-03	Carried Forward	Eliminated by Replacement		2024-09-30	0	No CGI reading	
7370889	375 AUBURN ST	3	2021-09-19	2024-12-03	Carried Forward	Eliminated Otherwise		2024-11-20	0	No CGI reading	NO READS
7387993	AUBURNDALE AVE & HAROLD TER	3	2024-05-31	2024-07-23	Newly Identified	Eliminated by Replacement					
7387407	112 AUBURNDALE AVE	1	2024-05-10	2024-05-10	Newly Identified	Repaired					
7389409	202 AUBURNDALE AVE	1	2024-09-06	2024-09-06	Newly Identified	Repaired					
7385663	25 AVALON RD	1	2024-01-31	2024-01-31	Newly Identified	Repaired					
7375164	8 BALDPATE HILL RD	3	2022-04-26	2024-08-05	Carried Forward	Eliminated Otherwise		2023-12-19	25	Leak Extent	NO READS
7329882	BEACON ST & HAMMOND ST	3	2016-10-28	2024-01-04	Carried Forward	Eliminated Otherwise		2023-11-16	25	Leak Extent	NO READS
7379000	BEACON ST & OWAISA RD	3	2022-12-17	2024-08-05	Carried Forward	Repaired		2024-07-25	400	Leak Extent	
4339243	130 BEACON ST	3	2015-06-04	2024-07-30	Carried Forward	Repaired		2023-12-19	2016	Leak Extent	
7371859	214 BEACON ST	2	2024-05-15	2024-06-14	Carried Forward	Eliminated Otherwi	3				SYSTEM ISSUE
7354888	624 BEACON ST	2	2020-06-17	2024-10-01	Carried Forward	Repaired					
7391334	865 BEACON ST	1	2024-12-29	2024-12-30	Newly Identified	Repaired					

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7389106	866 BEACON ST	1	2024-08-12	2024-08-19	Newly Identified	Repaired					
7387036	1564 BEACON ST	1	2024-04-24	2024-04-25	Newly Identified	Repaired					
1593092	1629 BEACON ST	3	2014-02-19	2024-04-01	Carried Forward	Repaired		2023-12-19	2200	Leak Extent	
7336460	1746 BEACON ST	3	2017-07-19	2024-10-10	Carried Forward	Eliminated by Replacemen		2023-11-06	900	Leak Extent	
7347782	2044 BEACON ST	3	2018-09-23	2024-03-27	Carried Forward	Repaired		2023-05-12	600	Leak Extent	
7383497	2084 BEACON ST	2	2024-05-24	2024-07-25	Carried Forward	Repaired	3				
7323736	35 BELLEVUE ST	3	2016-02-02	2024-07-02	Carried Forward	Eliminated Otherwise		2024-01-04	0	No CGI reading	NO READS
7375133	46 BEMIS ST	3	2022-05-17	2024-05-09	Carried Forward	Repaired		2023-12-20	160	Leak Extent	
7325492	135 BIGELOW RD	3	2016-04-21	2024-08-19	Carried Forward	Eliminated Otherwise		2024-08-14	560	Leak Extent	NO READS
7376318	39 BILLINGS PIKE	3	2022-08-03	2024-12-07	Carried Forward	Eliminated Otherwise		2024-11-12	0	No CGI reading	NO READS
7389976	64 BISHOPSGATE RD	2	2024-10-01	2024-10-23	Newly Identified	Repaired					
7388489	22 BONMAR CIR	1	2024-07-12	2024-07-12	Newly Identified	Repaired					
7387664	176 BOYLSTON ST	1	2024-05-22	2024-05-22	Newly Identified	Repaired					
7387665	176 BOYLSTON ST	1	2024-05-23	2024-12-30	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7386574	528 BOYLSTON ST	2	2024-03-03	2024-05-16	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7387484	528 BOYLSTON ST	1	2024-05-14	2024-05-21	Newly Identified	Repaired					
7385671	616 BOYLSTON ST	1	2024-01-31	2024-02-02	Newly Identified	Repaired					
7384775	628 BOYLSTON ST	2	2023-10-24	2024-02-06	Carried Forward	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7388951	628 BOYLSTON ST	1	2024-08-12	2024-08-16	Newly Identified	Repaired					
7388323	1009 BOYLSTON ST	1	2024-07-01	2024-07-01	Newly Identified	Repaired					
7389156	1042 BOYLSTON ST	1	2024-08-21	2024-08-23	Newly Identified	Repaired					
7386912	1224 BOYLSTON ST	1	2024-04-18	2024-05-01	Newly Identified	Repaired					
7385427	12 BROADLAWN DR	1	2024-01-17	2024-01-17	Newly Identified	Repaired					
7356139	344 BROOKLINE ST	3	2019-09-03	2024-08-05	Carried Forward	Eliminated Otherwise		2024-01-04	0	No CGI reading	NO READS
7355547	85 BROOKSIDE AVE	3	2019-08-20	2024-11-27	Carried Forward	Eliminated Otherwise		2024-11-01	0	No CGI reading	NO READS
7388266	8 BROWNING RD	2	2024-05-30	2024-07-11	Newly Identified	Repaired					
1206963	41 BRUSH HILL RD	3	2013-04-25	2024-12-16	Carried Forward	Repaired		2024-08-13	1200	Leak Extent	
7354553	7 BUSWELL PIKE	3	2019-07-09	2024-12-18	Carried Forward	Repaired		2024-08-09	2200	Leak Extent	
7389504	109 CABOT ST	2	2024-09-05	2024-09-17	Newly Identified	Repaired					
7385654	139 CALIFORNIA ST	1	2024-01-30	2024-01-30	Newly Identified	Repaired					
7386138	11 CANTERBURY RD	3	2024-02-11	2024-11-27	Newly Identified	Eliminated Otherwise		2024-11-01	0	No CGI reading	NO READS
7385629	4 CAPITAL ST	2	2024-01-22	2024-03-25	Newly Identified	Repaired					
7387303	3 CARL ST	1	2024-05-07	2024-05-07	Newly Identified	Repaired					
7380670	122 CARVER RD	3	2023-04-13	2024-02-26	Carried Forward	Repaired		2023-04-13	400	Leak Extent	
7387453	122 CARVER RD	2	2024-04-22	2024-06-13	Newly Identified	Repaired					
7367241	46 CEDAR ST	3	2021-03-01	2024-07-01	Carried Forward	Eliminated Otherwise		2024-05-21	1250	Leak Extent	NO READS
307615	24 CENTRAL AVE	3	2007-09-10	2024-12-02	Carried Forward	Eliminated Otherwise		2024-08-13	0	No CGI reading	NO READS
7379277	234 CENTRAL ST	2	2024-08-05	2024-09-11	Carried Forward	Repaired	3				
7368124	650 CENTRE ST	3	2021-04-22	2024-01-04	Carried Forward	Eliminated Otherwise		2023-11-16	25	Leak Extent	NO READS

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7386559	933 CENTRE ST	3	2024-03-12	2024-11-14	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7390797	933 CENTRE ST	1	2024-11-18	2024-11-18	Newly Identified	Repaired					
7389264	949 CENTRE ST	1	2024-08-27	2024-08-27	Newly Identified	Repaired					
7391098	955 CENTRE ST	1	2024-12-05	2024-12-05	Newly Identified	Repaired					
7389705	989 CENTRE ST	1	2024-09-20	2024-09-20	Newly Identified	Repaired					
7390261	1011 CENTRE ST	1	2024-10-18	2024-10-24	Newly Identified	Repaired					
7389975	1097 CENTRE ST	2	2024-09-23	2024-10-16	Newly Identified	Repaired					
7386949	1197 CENTRE ST	1	2024-04-20	2024-04-22	Newly Identified	Repaired					
7390652	1197 CENTRE ST	2	2024-10-09	2024-11-21	Newly Identified	Repaired					
7387171	1310 CENTRE ST	1	2024-04-30	2024-04-30	Newly Identified	Repaired					
7387914	1310 CENTRE ST	2	2024-05-13	2024-09-10	Newly Identified	Repaired					
7386381	21 CHANDLER PL	1	2024-03-15	2024-03-15	Newly Identified	Repaired					
7353512	47 CHANDLER PL	3	2019-05-23	2024-01-04	Carried Forward	Eliminated Otherwise		2023-11-13	0	No CGI reading	NO READS
7387916	3 CHANDLER ST	2	2024-05-13	2024-07-25	Newly Identified	Repaired					
1065939	53 CHARLESBANK RD	3	2012-08-30	2024-01-20	Carried Forward	Eliminated Otherwise		2023-08-31	7500	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7387594	40 CHASKE AVE	3	2024-04-22	2024-05-30	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7385861	67 CHERRY ST	2	2024-01-30	2024-02-21	Newly Identified	Repaired					
7389801	796 CHESTNUT ST	1	2024-09-25	2024-09-25	Newly Identified	Repaired					
3869246	877 CHESTNUT ST	3	2015-04-07	2024-07-01	Carried Forward	Eliminated Otherwise		2024-02-21	0	No CGI reading	NO READS
7385254	898 CHESTNUT ST	1	2024-01-04	2024-01-04	Newly Identified	Repaired					
7388304	1216 CHESTNUT ST	3	2024-06-11	2024-07-19	Newly Identified	Repaired		2024-06-11	100	Leak Extent	
7388623	11 CLEARWATER RD	1	2024-07-22	2024-07-22	Newly Identified	Repaired					
7389974	11 CLEARWATER RD	2	2024-09-30	2024-10-16	Newly Identified	Repaired					
7386658	21 CLOELIA TER	1	2024-04-05	2024-04-06	Newly Identified	Repaired					
7370900	11 CLOVELLY RD	3	2021-09-20	2024-01-19	Carried Forward	Repaired		2023-06-20	264	Leak Extent	
7387878	103 COLLINS RD	3	2024-05-13	2024-08-15	Newly Identified	Eliminated by Replacemen		2024-05-13	4320	Leak Extent	
3023506	COMMONWEALTH AVE & COMMONWE	3	2014-11-06	2024-07-01	Carried Forward	Eliminated Otherwise		2023-11-09	0	No CGI reading	NO READS
7345717	85 COMMONWEALTH AVE	3	2018-07-14	2024-08-07	Carried Forward	Repaired		2024-02-21	900	Leak Extent	
7354711	86 COMMONWEALTH AVE	3	2019-07-16	2024-11-15	Carried Forward	Eliminated Otherwise		2024-09-04	0	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
347021	160 COMMONWEALTH AVE	3	2011-05-25	2024-07-25	Carried Forward	Repaired		2024-01-11	600	Leak Extent	
7371042	305 COMMONWEALTH AVE	3	2021-10-06	2024-02-17	Carried Forward	Repaired		2023-06-23	1800	Leak Extent	
7385971	305 COMMONWEALTH AVE	1	2024-02-15	2024-02-15	Newly Identified	Repaired					
270538	522 COMMONWEALTH AV	3	2004-06-29	2024-06-12	Carried Forward	Repaired		2024-02-16	0	No CGI reading	
1363357	647 COMMONWEALTH AVE	3	2013-09-12	2024-10-16	Carried Forward	Eliminated by Replacemen		2024-06-26	250	Leak Extent	
7375099	750 COMMONWEALTH AVE	3	2022-04-26	2024-07-22	Carried Forward	Repaired		2024-01-11	225	Leak Extent	
345666	1234 COMMONWEALTH AVE	3	2011-04-14	2024-07-30	Carried Forward	Eliminated Otherwise		2024-02-21	0	No CGI reading	NO READS
7327002	1395 COMMONWEALTH AVE	3	2016-06-23	2024-02-21	Carried Forward	Eliminated Otherwise		2023-07-31	400	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7385944	1395 COMMONWEALTH AVE	1	2024-02-14	2024-02-14	Newly Identified	Repaired					
42571	1418 COMMONWEALTH AV	3	1995-07-07	2024-09-23	Carried Forward	Repaired		2024-01-11	200	Leak Extent	

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7379279	1438 COMMONWEALTH AVE	3	2023-01-11	2024-09-26	Carried Forward	Repaired		2024-08-08	450	Leak Extent	
7355422	1466 COMMONWEALTH AVE	3	2019-07-24	2024-10-01	Carried Forward	Repaired		2024-08-28	3500	Leak Extent	
7374856	1750 COMMONWEALTH AVE	2	2024-02-15	2024-03-11	Carried Forward	Repaired	3				
7387493	1750 COMMONWEALTH AVE	3	2024-05-08	2024-11-20	Newly Identified	Repaired					
7353083	1830 COMMONWEALTH AVE	3	2019-05-13	2024-09-21	Carried Forward	Eliminated Otherwise		2024-08-21	0	No CGI reading	NO READS
7353079	1870 COMMONWEALTH AVE	3	2019-05-13	2024-10-12	Carried Forward	Eliminated Otherwise		2024-08-21	0	No CGI reading	NO READS
7386313	1888 COMMONWEALTH AVE	1	2024-03-11	2024-03-13	Newly Identified	Repaired					
7387243	2240 COMMONWEALTH AVE	1	2024-05-03	2024-05-06	Newly Identified	Repaired					
1338980	66 COMMONWEALTH PIKE W	3	2013-08-29	2024-10-14	Carried Forward	Repaired		2024-06-26	100	Leak Extent	
7330111	28 CONSIDINE RD	3	2016-11-03	2024-10-12	Carried Forward	Eliminated Otherwise		2024-09-12	1050	Leak Extent	NO READS
7376826	12 COPLEY ST	3	2022-04-15	2024-08-19	Carried Forward	Eliminated Otherwise		2024-01-11	0	No CGI reading	NO READS
7376827	120 CORNELL ST	2	2024-11-22	2024-12-06	Carried Forward	Repaired	3				
7386420	138 COTTON ST	2	2024-03-06	2024-04-01	Newly Identified	Repaired					
7326630	39 COURT ST	3	2016-06-09	2024-10-12	Carried Forward	Eliminated Otherwise		2024-05-07	0	No CGI reading	NO READS
7386202	53 CRESCENT AVE	1	2024-03-03	2024-03-03	Newly Identified	Repaired					
7385862	53 CRESCENT ST	2	2024-01-31	2024-02-26	Newly Identified	Repaired					
7390899	7 CURTIS ST	2	2024-11-20	2024-12-04	Newly Identified	Repaired					
7389793	CURVE ST & AUBURN ST	1	2024-09-25	2024-09-25	Newly Identified	Repaired					
7385960	CYPRESS ST & PARKER ST	2	2024-02-06	2024-02-29	Newly Identified	Repaired					
7387919	169 CYPRESS ST	2	2024-05-28	2024-07-18	Newly Identified	Repaired					
7378752	271 CYPRESS ST	3	2022-11-09	2024-07-30	Carried Forward	Eliminated by Replacemen		2024-06-26	1	Leak Extent	
7382899	298 CYPRESS ST	3	2023-07-08	2024-08-19	Carried Forward	Eliminated Otherwise		2024-05-06	0	No CGI reading	NO READS
7327405	DAVIS AVE & EDEN AVE	3	2016-06-27	2024-10-19	Carried Forward	Eliminated Otherwise		2024-06-26	100	Leak Extent	NO READS
7385311	23 DAVIS ST	3	2023-12-19	2024-01-24	Carried Forward	Eliminated Otherwise		2023-12-19	80	Leak Extent	DUPLICATE LEAK
7353577	73 DEDHAM ST	3	2019-05-24	2024-09-16	Carried Forward	Eliminated Otherwise		2024-08-08	112	Leak Extent	NO READS
7355674	188 DEDHAM ST	3	2019-08-23	2024-01-04	Carried Forward	Eliminated Otherwise		2023-12-14	0	No CGI reading	NO READS
5620596	832 DEDHAM ST	3	2015-08-27	2024-09-12	Carried Forward	Eliminated Otherwise		2023-12-19	4550	Leak Extent	NO READS
336992	881 DEDHAM ST	3	2010-09-01	2024-10-19	Carried Forward	Eliminated Otherwise		2024-08-13	0	No CGI reading	NO READS
7354712	31 DEVONSHIRE RD	3	2019-07-19	2024-09-12	Carried Forward	Eliminated Otherwise		2024-09-04	0	No CGI reading	NO READS
7322014	83 DEVONSHIRE RD	3	2015-12-08	2024-07-01	Carried Forward	Eliminated Otherwise		2023-11-09	150	Leak Extent	NO READS
1237078	94 DEVONSHIRE RD	3	2015-10-09	2024-10-19	Carried Forward	Eliminated Otherwise		2024-10-09	0	No CGI reading	NO READS
7390136	6 DORCAR RD	1	2024-10-17	2024-10-17	Newly Identified	Repaired					
337228	DORSET RD & METACOMET RD	3	2010-08-19	2024-07-26	Carried Forward	Repaired		2023-11-16	3360	Leak Extent	
7348310	95 DORSET RD	3	2018-10-11	2024-11-22	Carried Forward	Eliminated Otherwise		2024-11-20	0	No CGI reading	NO READS
7369309	129 DORSET RD	3	2021-06-11	2024-07-11	Carried Forward	Eliminated Otherwise		2024-01-11	400	Leak Extent	DUPLICATE LEAK
7391286	268 DORSET RD	1	2024-12-26	2024-12-26	Newly Identified	Repaired					
7390889	35 DRUMLIN RD	1	2024-11-24	2024-11-24	Newly Identified	Repaired					
7388654	500 DUDLEY RD	1	2024-07-24	2024-07-24	Newly Identified	Repaired					
7379850	54 DUXBURY RD	3	2023-02-07	2024-09-12	Carried Forward	Eliminated Otherwise		2024-09-04	0	No CGI reading	NO READS

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7387378	60 DWHINDA RD	1	2024-05-09	2024-05-09	Newly Identified	Repaired					
7382536	74 EDDY ST	2	2023-06-29	2024-07-25	Carried Forward	Eliminated Otherwise					NO READS
7354715	6 EDGEWOOD RD	3	2019-07-19	2024-08-19	Carried Forward	Eliminated Otherwise		2023-11-16	0	No CGI reading	NO READS
338427	65 ELINOR RD	3	2010-10-09	2024-10-08	Carried Forward	Eliminated by Replacemen		2024-09-30	0	No CGI reading	
7385398	12 ELLIOT PL	1	2024-01-15	2024-01-15	Newly Identified	Repaired					
1215753	52 ELLIOT ST	2	2023-02-15	2024-09-24	Carried Forward	Repaired					
7390304	60 ELLIOT ST	1	2024-10-22	2024-10-22	Newly Identified	Repaired					
7374832	366 ELLIOT ST	2	2023-12-20	2024-01-12	Carried Forward	Repaired					
338429	30 ELLIS RD	3	2010-10-13	2024-08-07	Carried Forward	Repaired		2023-11-17	2132	Leak Extent	
7374831	75 ELMHURST RD	3	2022-04-05	2024-09-12	Carried Forward	Eliminated Otherwise		2024-09-04	0	No CGI reading	NO READS
7375136	15 ELMWOOD PIKE	3	2022-05-24	2024-11-27	Carried Forward	Eliminated Otherwise		2024-10-11	0	No CGI reading	NO READS
7371043	34 EMERSON ST	3	2021-10-07	2024-08-19	Carried Forward	Eliminated Otherwise		2024-04-30	0	No CGI reading	NO READS
7356220	27 EVELYN RD	3	2019-09-04	2024-08-28	Carried Forward	Repaired		2024-01-04	750	Leak Extent	
7347783	69 EVELYN RD	3	2018-09-16	2024-12-07	Carried Forward	Eliminated Otherwise		2024-11-07	0	No CGI reading	NO READS
7356362	29 F ROADWAY	3	2019-09-25	2024-11-27	Carried Forward	Eliminated Otherwise		2024-10-30	0	No CGI reading	NO READS
7364450	60 FAIRLEE RD	3	2020-08-26	2024-11-27	Carried Forward	Eliminated Otherwise		2024-11-12	0	No CGI reading	NO READS
7379171	74 FAIRMONT AVE	2	2024-11-22	2024-12-12	Carried Forward	Repaired	3				
7385874	22 FAIRWAY DR	1	2024-02-08	2024-02-09	Newly Identified	Repaired					
7390876	116 FAIRWAY DR	1	2024-11-22	2024-11-25	Newly Identified	Repaired					
7386000	83 FAXON ST	3	2024-02-16	2024-02-16	Newly Identified	Repaired					
7364121	34 FENNO RD	3	2020-06-17	2024-10-19	Carried Forward	Eliminated Otherwise		2024-09-27	1	Leak Extent	NO READS
7379880	31 FOX HILL RD	3	2023-02-18	2024-05-29	Carried Forward	Eliminated by Replacemen		2023-11-13	900	Leak Extent	
7380672	31 GARDNER ST	3	2023-03-23	2024-08-19	Carried Forward	Eliminated Otherwise		2024-01-12	0	No CGI reading	NO READS
7387982	12 GEORGE ST	1	2024-06-07	2024-06-07	Newly Identified	Repaired					
7385527	28 GEORGE ST	1	2024-01-23	2024-02-06	Newly Identified	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7385528	28 GEORGE ST	1	2024-01-23	2024-01-24	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7388577	GILBERT ST & AUBURN ST	1	2024-07-19	2024-07-19	Newly Identified	Repaired					
7387299	51 GORDON RD	1	2024-05-07	2024-05-07	Newly Identified	Repaired					
6592025	142 GORDON RD	3	2015-09-08	2024-03-06	Carried Forward	Repaired		2023-11-07	5040	Leak Extent	
7386047	25 GREENLAWN AVE	3	2024-02-01	2024-10-24	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7375165	49 GROVE ST	3	2022-05-27	2024-08-29	Carried Forward	Repaired		2024-01-12	600	Leak Extent	
1428283	191 GROVE ST	3	2013-10-08	2024-11-27	Carried Forward	Eliminated Otherwise		2024-11-07	0	No CGI reading	NO READS
7325803	640 GROVE ST	3	2016-04-22	2024-10-24	Carried Forward	Eliminated Otherwise		2024-08-20	1750	Leak Extent	DUPLICATE LEAK
7387201	77 HALCYON RD	1	2024-05-01	2024-05-01	Newly Identified	Repaired					
270653	HAMMOND ST & RESERVOIR AV	3	2004-08-20	2024-01-02	Carried Forward	Eliminated Otherwise		2023-11-14	25	Leak Extent	NO READS
278687	HAMMOND ST & MIDDLESEX RD	3	2005-08-08	2024-10-08	Carried Forward	Repaired		2024-08-08	4200	Leak Extent	
5866391	HAMMOND ST & COLLEGE RD	3	2015-12-14	2024-08-06	Carried Forward	Eliminated Otherwise		2023-12-05	25000	Leak Extent	NO READS
949724	8 HAMMOND ST	3	2012-08-01	2024-09-12	Carried Forward	Eliminated Otherwise		2024-08-13	0	No CGI reading	NO READS
7329507	263 HAMMOND ST	3	2016-11-07	2024-11-27	Carried Forward	Eliminated Otherwise		2024-11-07	0	No CGI reading	NO READS

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7382741	263 HAMMOND ST	1	2023-08-03	2024-03-21	Carried Forward	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7387994	300 HAMMOND ST	2	2024-05-31	2024-06-24	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7388177	300 HAMMOND ST	1	2024-06-22	2024-06-22	Newly Identified	Repaired					
7387339	84 HAMMONDSWOOD RD	1	2024-05-07	2024-05-07	Newly Identified	Repaired					
7356371	80 HANSON RD	3	2019-09-25	2024-12-03	Carried Forward	Eliminated Otherwise		2024-11-04	0	No CGI reading	NO READS
7385872	28 HIBBARD RD	1	2024-02-08	2024-02-08	Newly Identified	Repaired					
7385715	15 HICKORY CLIFF RD	2	2024-01-23	2024-06-03	Newly Identified	Eliminated by Replacement					
7383508	HIGH ST & ELLIOT ST	2	2024-11-22	2024-12-13	Carried Forward	Repaired	3				
7387260	90 HIGHLAND AVE	1	2024-05-05	2024-05-06	Newly Identified	Repaired					
7379883	228 HIGHLAND AVE	3	2023-02-28	2024-09-12	Carried Forward	Eliminated Otherwise		2024-09-04	0	No CGI reading	NO READS
7385276	228 HIGHLAND AVE	1	2024-01-05	2024-01-05	Newly Identified	Repaired					
7379023	HIGHLAND ST & DAVIS ST	3	2022-12-18	2024-01-17	Carried Forward	Eliminated Otherwise		2023-09-26	100	Leak Extent	DUPLICATE LEAK
7326197	145 HIGHLAND ST	3	2016-05-11	2024-09-03	Carried Forward	Repaired		2024-04-25	1200	Leak Extent	
7355977	173 HIGHLAND ST	2	2024-09-18	2024-09-30	Carried Forward	Repaired	3				
7375160	64 HILLSIDE AVE	2	2024-06-26	2024-10-01	Carried Forward	Eliminated by Repl	3				
7376438	281 HOMER ST	2	2022-07-29	2024-09-26	Carried Forward	Repaired					
7327022	74 HOMESTEAD ST	2	2024-06-26	2024-08-19	Carried Forward	Eliminated Otherwi	3				NO READS
7385462	28 ISLINGTON RD	1	2024-01-19	2024-01-19	Newly Identified	Repaired					
7385845	200 JACKSON RD	3	2024-01-18	2024-07-29	Newly Identified	Repaired					
7324253	15 JACKSON ST	3	2016-03-23	2024-09-12	Carried Forward	Eliminated Otherwise		2024-08-14	50	Leak Extent	NO READS
7341526	224 JACKSON ST	3	2018-02-27	2024-09-12	Carried Forward	Eliminated Otherwise		2024-02-20	0	No CGI reading	NO READS
7325992	269 JACKSON ST	3	2016-05-12	2024-09-12	Carried Forward	Eliminated Otherwise		2024-04-25	0	No CGI reading	NO READS
7385399	21 JASSET ST	1	2024-01-15	2024-01-16	Newly Identified	Repaired					
7378193	4 JUDITH RD	2	2022-11-08	2024-09-10	Carried Forward	Repaired					
332435	30 K ROADWAY	3	2010-04-13	2024-10-12	Carried Forward	Eliminated Otherwise		2024-09-03	0	No CGI reading	NO READS
155801	KENDALL RD & WALNUT HILL RD	2	2024-06-27	2024-09-04	Carried Forward	Repaired	3				
7385716	30 KILBURN RD	2	2024-01-25	2024-03-20	Newly Identified	Repaired					
230384	41 LAKEVIEW AV	3	2000-08-07	2024-11-27	Carried Forward	Eliminated Otherwise		2024-11-06	0	No CGI reading	NO READS
7357139	48 LANTERN LN	3	2019-10-25	2024-12-03	Carried Forward	Eliminated Otherwise		2024-11-07	0	No CGI reading	NO READS
7385426	24 LEE RD	1	2024-01-17	2024-01-18	Newly Identified	Repaired					
7356210	15 LEEWOOD RD	3	2019-09-05	2024-04-17	Carried Forward	Repaired		2023-12-20	150	Leak Extent	
7385304	35 LEXINGTON ST	2	2023-12-24	2024-02-14	Carried Forward	Repaired					
7387449	208 LEXINGTON ST	2	2024-04-29	2024-08-20	Newly Identified	Repaired					
7354258	369 LEXINGTON ST	3	2019-06-24	2024-01-04	Carried Forward	Eliminated Otherwise		2023-11-16	25	Leak Extent	NO READS
7386555	427 LEXINGTON ST	1	2024-03-28	2024-03-29	Newly Identified	Repaired					
7386569	427 LEXINGTON ST	1	2024-03-28	2024-03-29	Newly Identified	Repaired					
7389508	427 LEXINGTON ST	2	2024-09-04	2024-10-02	Newly Identified	Repaired					
7388359	146 LINCOLN ST	1	2024-07-02	2024-07-03	Newly Identified	Repaired					
7385439	384 LINWOOD AVE	2	2024-01-03	2024-02-21	Newly Identified	Repaired					

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7386159	69 LOS ANGELES ST	1	2024-02-28	2024-02-28	Newly Identified	Repaired					
7380674	10 LOWELL AVE	3	2023-02-24	2024-09-12	Carried Forward	Eliminated Otherwise		2024-08-28	0	No CGI reading	NO READS
7385487	458 LOWELL AVE	1	2024-01-22	2024-01-22	Newly Identified	Repaired					
305355	36 MAGNOLIA AVE	3	2007-08-29	2024-08-15	Carried Forward	Repaired		2024-08-05	540	Leak Extent	
7385961	20 MALIA TER	2	2024-02-04	2024-04-24	Newly Identified	Repaired					
7390783	16 MANEMET RD	1	2024-11-18	2024-11-18	Newly Identified	Repaired					
7365478	50 MANEMET RD	3	2020-11-14	2024-06-27	Carried Forward	Eliminated Otherwise		2024-05-06	100	Leak Extent	NO READS
7326611	26 MAPLE ST	3	2016-06-06	2024-07-01	Carried Forward	Eliminated Otherwise		2024-03-20	25	Leak Extent	NO READS
7387326	5 MARGARET RD	1	2024-05-07	2024-05-10	Newly Identified	Repaired					
7387337	9 MARGARET RD	1	2024-05-07	2024-05-07	Newly Identified	Repaired					
7385979	14 MARGARET RD	1	2024-02-15	2024-02-16	Newly Identified	Repaired					
7325494	4 MARLBORO ST	2	2024-09-06	2024-09-18	Carried Forward	Repaired	3				
7354538	5 MARSHALL ST	2	2023-11-16	2024-01-09	Carried Forward	Repaired					
7385972	5 MARSHALL ST	3	2024-02-01	2024-12-03	Newly Identified	Eliminated Otherwise		2024-10-30	0	No CGI reading	NO READS
7386010	5 MARSHALL ST	1	2024-02-17	2024-02-17	Newly Identified	Repaired					
7374830	21 MARSHFIELD RD	3	2022-03-15	2024-09-12	Carried Forward	Eliminated Otherwise		2024-08-08	0	No CGI reading	NO READS
270590	35-45 MCCARTHY RD	3	2004-07-22	2024-06-27	Carried Forward	Eliminated Otherwise		2023-11-06	0	No CGI reading	NO READS
7354261	MELROSE AVE & MELROSE ST	2	2023-11-16	2024-01-11	Carried Forward	Repaired					
7348728	283 MELROSE ST	3	2018-06-29	2024-12-03	Carried Forward	Eliminated Otherwise		2024-11-04	0	No CGI reading	NO READS
7386433	4 MEREDITH AVE	1	2024-03-19	2024-03-20	Newly Identified	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7390630	27 METACOMET RD	1	2024-11-05	2024-11-06	Newly Identified	Repaired					
7389498	275 MILL ST	2	2024-09-06	2024-09-24	Newly Identified	Repaired					
7390779	49 MILLER RD	1	2024-11-17	2024-11-18	Newly Identified	Repaired					
7386106	56 MILLER RD	2	2024-10-09	2024-10-25	Newly Identified	Repaired	3				
7385393	37 MONTROSE ST	1	2024-01-14	2024-01-15	Newly Identified	Repaired					
7390003	85 MONTVALE RD	2	2024-10-04	2024-10-28	Newly Identified	Repaired					
7388841	83 MORRILL ST	1	2024-08-06	2024-08-06	Newly Identified	Repaired					
7384926	55 MURRAY RD	1	2023-12-10	2024-03-21	Carried Forward	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7385551	213 NAHANTON ST	1	2024-01-24	2024-01-25	Newly Identified	Repaired					
7385615	215 NAHANTON ST	1	2024-01-28	2024-01-28	Newly Identified	Repaired					
7385616	215 NAHANTON ST	1	2024-01-28	2024-01-28	Newly Identified	Repaired					
7391075	3 NARDONE RD	2	2024-11-24	2024-12-16	Newly Identified	Repaired					
7385864	48 NATHAN RD	2	2024-02-01	2024-02-22	Newly Identified	Repaired					
7354042	130 NEEDHAM ST	3	2019-06-21	2024-01-02	Carried Forward	Eliminated Otherwise		2023-11-16	25	Leak Extent	NO READS
7386154	160 NEEDHAM ST	1	2024-02-27	2024-02-27	Newly Identified	Repaired					
7354043	170 NEEDHAM ST	2	2020-05-21	2020-11-20	Carried Forward	Eliminated by Replacement					
329373	320 NEEDHAM ST	3	2009-10-11	2024-09-12	Carried Forward	Eliminated Otherwise		2024-05-07	100	Leak Extent	NO READS
340420	167 NEHOIDEN RD	3	2010-12-25	2024-07-01	Carried Forward	Eliminated Otherwise		2024-03-20	25	Leak Extent	NO READS
7385351	178 NEHOIDEN RD	1	2024-01-11	2024-01-11	Newly Identified	Repaired					

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7385888	384 NEWTONVILLE AVE	1	2024-02-09	2024-02-09	Newly Identified	Repaired					
7388975	449 NEWTONVILLE AVE	2	2024-07-26	2024-08-30	Newly Identified	Repaired					
7387451	26 NOBLE ST	2	2024-04-30	2024-06-14	Newly Identified	Repaired					
7389759	130 NONANTUM RD	3	2024-09-24	2024-09-25	Newly Identified	Repaired					
7335811	78 NONANTUM ST	3	2017-06-10	2024-07-01	Carried Forward	Eliminated Otherwise		2024-05-15	84	Leak Extent	NO READS
7326636	NORTH ST & ALBEMARLE RD	3	2016-06-13	2024-10-24	Carried Forward	Eliminated Otherwise		2024-05-07	0	No CGI reading	DUPLICATE LEAK
7388683	195 NORTH ST	2	2024-07-07	2024-10-09	Newly Identified	Repaired					
7385703	204 NORTH ST	1	2024-02-01	2024-02-02	Newly Identified	Repaired					
7391330	OAK ST & CHESTNUT ST	1	2024-12-29	2024-12-30	Newly Identified	Repaired					
1336115	156 OAK ST	2	2020-04-17	2024-10-30	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7327750	OAKLAND ST & CHURCH ST	3	2016-06-02	2024-07-01	Carried Forward	Eliminated Otherwise		2024-05-07	225	Leak Extent	NO READS
7379290	25 OLD ENGLAND RD	2	2024-10-06	2024-11-04	Carried Forward	Repaired	3				
7386423	5 OLDEFIELD RD	2	2024-03-06	2024-04-10	Newly Identified	Repaired					
6591350	22 OLDEFIELD RD	3	2015-09-12	2024-12-02	Carried Forward	Eliminated Otherwise		2024-09-09	0	No CGI reading	NO READS
7375161	262 OTIS ST	3	2022-05-18	2024-10-24	Carried Forward	Eliminated Otherwise		2024-10-11	230	Leak Extent	DUPLICATE LEAK
7386005	14 PARK PL	1	2024-02-17	2024-02-19	Newly Identified	Repaired					
7390421	111 PARKER AVE	2	2024-10-23	2024-11-12	Newly Identified	Repaired					
5620468	121 PARKER AVE	3	2015-08-27	2024-01-02	Carried Forward	Eliminated Otherwise		2023-11-13	0	No CGI reading	NO READS
7383027	26 PARKER ST	3	2023-08-02	2024-08-14	Carried Forward	Repaired		2024-05-21	3750	Leak Extent	
7365094	160 PARKER ST	3	2020-10-15	2024-10-19	Carried Forward	Eliminated Otherwise		2024-04-23	0	No CGI reading	NO READS
7388521	255 PARKER ST	3	2024-10-01	2024-09-25	Newly Identified	Repaired	2				
7356436	317 PARKER ST	2	2021-07-27	2024-09-25	Carried Forward	Repaired					
7385532	263 PEARL ST	1	2024-01-24	2024-01-25	Newly Identified	Repaired					
7375985	66 PELHAM ST	2	2024-07-06	2024-08-28	Carried Forward	Repaired	3				
7325806	4 PEMBROKE ST	3	2016-04-22	2024-12-03	Carried Forward	Eliminated Otherwise		2024-11-19	0	No CGI reading	NO READS
1317702	91 PICKWICK RD	3	2013-08-16	2024-06-27	Carried Forward	Eliminated Otherwise		2024-02-16	0	No CGI reading	NO READS
7387022	137 PINE RIDGE RD	1	2024-04-23	2024-04-23	Newly Identified	Repaired					
7385717	12 PLEASANT ST	2	2024-01-25	2024-03-20	Newly Identified	Repaired					
7390737	38 PRINCE ST	2	2024-11-02	2024-12-02	Newly Identified	Repaired					
7387052	300 PRINCE ST	1	2024-04-24	2024-04-24	Newly Identified	Repaired					
7385814	18 PRISCILLA RD	1	2024-02-06	2024-02-06	Newly Identified	Repaired					
7323783	38 PUTNAM ST	3	2016-02-01	2024-04-12	Carried Forward	Eliminated Otherwise		2024-02-16	0	No CGI reading	NO READS
7386372	50 QUINCY RD	1	2024-03-14	2024-03-15	Newly Identified	Repaired					
275900	544 QUINOBEQUIN RD	3	2005-06-08	2024-11-12	Carried Forward	Repaired		2024-08-05	1400	Leak Extent	
7386609	23 RESERVOIR AVE	1	2024-04-02	2024-04-02	Newly Identified	Repaired					
7388530	1 RIDGE RD	1	2024-07-16	2024-07-16	Newly Identified	Repaired					
7357654	143 RIVER ST	3	2019-10-16	2024-01-29	Carried Forward	Repaired		2023-05-16	150	Leak Extent	
7323097	14 ROKEBY RD	3	2016-01-14	2024-08-21	Carried Forward	Repaired		2024-08-14	225	Leak Extent	
6624524	14 SAMOSET RD	3	2015-09-21	2024-06-27	Carried Forward	Eliminated Otherwise		2024-03-20	875	Leak Extent	NO READS

Table L7 All eliminated Newton leaks in 2024

	Listed alphabetically by street										
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7356372	569 SAWMILL BROOK PKY	3	2019-09-25	2024-10-24	Carried Forward	Eliminated Otherwise		2024-02-16	1600	Leak Extent	DUPLICATE LEAK
7356438	741 SAWMILL BROOK PKY	3	2019-09-26	2024-08-28	Carried Forward	Repaired		2024-02-16	1800	Leak Extent	
3093950	43 SEWALL ST	3	2015-02-09	2024-11-27	Carried Forward	Eliminated Otherwise		2024-11-07	0	No CGI reading	NO READS
7385256	45 SEWALL ST	1	2024-01-04	2024-01-04	Newly Identified	Repaired					
42479	52 SEWALL ST	2	2024-07-25	2024-08-30	Carried Forward	Repaired	3				
7383512	5 SHELDON RD	3	2023-08-29	2024-11-27	Carried Forward	Eliminated Otherwise		2024-06-26	900	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7390874	5 SHELDON RD	1	2024-11-22	2024-11-26	Newly Identified	Repaired					
7387122	8 SHELDON RD	1	2024-04-28	2024-05-02	Newly Identified	Repaired					
7364120	43 SHERBROOKE RD	3	2020-06-15	2024-09-12	Carried Forward	Eliminated Otherwise		2024-09-04	0	No CGI reading	NO READS
7389575	14 SHORNECLIFFE RD	1	2024-09-13	2024-09-13	Newly Identified	Repaired					
7356450	10 SPIERS RD	3	2019-09-27	2024-09-12	Carried Forward	Eliminated Otherwise		2024-02-21	600	Leak Extent	NO READS
7331915	150 SPIERS RD	3	2017-02-02	2024-01-02	Carried Forward	Eliminated Otherwise		2023-11-16	25	Leak Extent	NO READS
7330385	75 SUMNER ST	3	2016-11-16	2024-12-09	Carried Forward	Eliminated Otherwise		2024-11-07	0	No CGI reading	NO READS
7351646	20 SUN HILL LN	3	2019-03-08	2024-06-27	Carried Forward	Eliminated Otherwise		2024-04-30	9	Leak Extent	NO READS
7386019	5 SWAN AVE	2	2024-02-06	2024-03-06	Newly Identified	Repaired					
7386395	19 SYLVESTER RD	1	2024-03-16	2024-03-16	Newly Identified	Repaired					
7352431	54 TEMPLE ST	2	2024-02-14	2024-03-14	Carried Forward	Repaired	3				
7386320	40 THE LEDGES RD	1	2024-03-12	2024-03-13	Newly Identified	Repaired					
7387082	105 TOLMAN ST	1	2024-04-25	2024-04-25	Newly Identified	Repaired					
7356428	37 TRUMAN RD	3	2019-09-26	2024-04-18	Carried Forward	Repaired		2024-02-16	50	Leak Extent	
7387874	100 VALENTINE ST	2	2024-05-03	2024-07-24	Newly Identified	Eliminated by Replacement					
7356133	151 VALENTINE ST	3	2019-08-06	2024-08-08	Carried Forward	Eliminated by Replacemen		2023-12-13	100	Leak Extent	
7349893	240 VALENTINE ST	3	2018-12-17	2024-08-08	Carried Forward	Eliminated by Replacemen		2024-02-05	0	No CGI reading	
7386471	100 VARICK RD	3	2024-03-21	2024-03-21	Newly Identified	Repaired					
7338634	6 VAUGHAN AVE	3	2017-09-09	2024-12-03	Carried Forward	Eliminated Otherwise		2024-11-01	300	Leak Extent	NO READS
7375989	38 VERNDAL RD	3	2022-06-17	2024-12-03	Carried Forward	Eliminated Otherwise		2024-11-06	0	No CGI reading	NO READS
7385407	101 VERNON ST	1	2024-01-16	2024-01-16	Newly Identified	Repaired					
1018521	12 VINEYARD RD	3	2012-10-12	2024-09-12	Carried Forward	Eliminated Otherwise		2024-09-03	0	No CGI reading	NO READS
796835	11 VIRGINIA RD	3	2012-02-06	2024-06-27	Carried Forward	Eliminated Otherwise		2023-12-19	1426	Leak Extent	NO READS
7385821	103 WABAN AVE	1	2024-02-06	2024-02-07	Newly Identified	Repaired					
7386330	380 WABAN AVE	1	2024-03-12	2024-03-13	Newly Identified	Repaired					
7388430	7 WADE ST	2	2024-05-14	2024-08-22	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7389107	7 WADE ST	1	2024-08-19	2024-08-19	Newly Identified	Repaired					
7389589	7 WADE ST	3	2024-09-11	2024-12-09	Newly Identified	Repaired					
7391093	74 WALKER ST	1	2024-12-05	2024-12-05	Newly Identified	Repaired					
7390710	75 WALKER ST	2	2024-11-02	2024-12-04	Newly Identified	Repaired					
7388988	78 WALKER ST	1	2024-08-13	2024-08-13	Newly Identified	Repaired					
270745	WALNUT ST & BACON RD	3	2004-08-06	2024-10-03	Carried Forward	Repaired		2024-07-29	4000	Leak Extent	
1283461	21 WALNUT ST	3	2014-09-29	2024-06-25	Carried Forward	Repaired		2023-09-13	500	Leak Extent	

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7389135	567 WALNUT ST	1	2024-08-20	2024-08-21	Newly Identified	Repaired					
7388114	728 WALNUT ST	1	2024-06-17	2024-06-17	Newly Identified	Repaired					
7380676	923 WALNUT ST	2	2024-01-29	2024-03-11	Carried Forward	Repaired	3				
7389938	961 WALNUT ST	1	2024-10-04	2024-10-04	Newly Identified	Repaired					
7390373	961 WALNUT ST	2	2024-10-17	2024-10-23	Newly Identified	Repaired					
7389682	1039 WALNUT ST	1	2024-09-19	2024-09-19	Newly Identified	Repaired					
7388903	1185 WALNUT ST	2	2024-07-25	2024-10-23	Newly Identified	Repaired					
7371866	1292 WALNUT ST	3	2021-11-09	2024-01-03	Carried Forward	Repaired		2023-07-12	400	Leak Extent	
7388022	22 WALSH RD	1	2024-06-11	2024-06-12	Newly Identified	Repaired					
7387128	420 WALTHAM ST	1	2024-04-29	2024-04-29	Newly Identified	Repaired					
7388900	425 WARD ST	3	2024-07-23	2024-08-15	Newly Identified	Repaired					
7391282	494 WARD ST	1	2024-12-24	2024-12-27	Newly Identified	Repaired					
7385348	17 WARE RD	2	2023-12-22	2024-01-31	Carried Forward	Repaired					
7379456	34 WARE RD	3	2023-02-01	2024-07-11	Carried Forward	Repaired		2023-11-16	250	Leak Extent	
7364115	33 WARREN RD	3	2020-05-24	2024-12-09	Carried Forward	Eliminated Otherwise		2024-11-20	0	No CGI reading	NO READS
7385225	12 WASHBURN ST	1	2024-01-02	2024-01-02	Newly Identified	Repaired					
7382122	207 WASHINGTON ST	2	2023-06-06	2024-06-06	Carried Forward	Repaired					
7384691	320 WASHINGTON ST	3	2023-11-15	2024-06-27	Carried Forward	Eliminated Otherwise		2024-02-13	0	No CGI reading	NO READS
7386656	320 WASHINGTON ST	1	2024-04-05	2024-04-07	Newly Identified	Repaired					
7387168	320 WASHINGTON ST	1	2024-04-30	2024-06-03	Newly Identified	Repaired					
7341653	457 WASHINGTON ST	3	2018-01-28	2024-12-03	Carried Forward	Eliminated Otherwise		2024-11-06	0	No CGI reading	NO READS
7390129	573 WASHINGTON ST	3	2024-10-16	2024-10-16	Newly Identified	Repaired					
7385809	580 WASHINGTON ST	2	2023-12-20	2024-02-22	Carried Forward	Repaired					
7390093	835 WASHINGTON ST	2	2024-10-13	2024-11-04	Newly Identified	Repaired					
7379459	839 WASHINGTON ST	2	2024-07-26	2024-08-29	Carried Forward	Repaired	3				
7386453	1251 WASHINGTON ST	1	2024-03-20	2024-03-21	Newly Identified	Repaired					
7376329	1595 WASHINGTON ST	3	2022-07-28	2024-06-05	Carried Forward	Repaired					
7374799	1730 WASHINGTON ST	3	2023-04-05	2024-03-15	Carried Forward	Eliminated Otherwise					SYSTEM ISSUE
7386383	1730 WASHINGTON ST	2	2024-02-07	2024-05-16	Newly Identified	Repaired					
7374844	1974 WASHINGTON ST	3	2022-04-27	2024-02-20	Carried Forward	Repaired		2023-12-19	11016	Leak Extent	
7385638	2014 WASHINGTON ST	1	2024-01-29	2024-01-29	Newly Identified	Repaired					
7374845	2055 WASHINGTON ST	2	2024-01-21	2024-04-23	Carried Forward	Eliminated Otherwi	3				NO READS
7377815	2096 WASHINGTON ST	3	2022-08-13	2024-11-07	Carried Forward	Repaired		2024-04-25	12600	Leak Extent	
7382271	2322 WASHINGTON ST	3	2023-06-20	2024-10-28	Carried Forward	Repaired		2024-04-23	14400	Leak Extent	
7385518	256 WATERTOWN ST	1	2024-01-23	2024-01-23	Newly Identified	Repaired					
7336761	425 WATERTOWN ST	2	2023-02-14	2024-02-14	Carried Forward	Repaired					
7388276	432 WATERTOWN ST	1	2024-06-27	2024-06-27	Newly Identified	Repaired					
7379240	494 WATERTOWN ST	3	2023-01-04	2024-08-13	Carried Forward	Eliminated Otherwise		2023-11-07	250	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7387253	665 WATERTOWN ST	1	2024-05-04	2024-05-08	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK

Table L7 All eliminated Newton leaks in 2024

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7387254	665 WATERTOWN ST	1	2024-05-04	2024-05-04	Newly Identified	Repaired					
7386617	826 WATERTOWN ST	1	2024-04-02	2024-04-03	Newly Identified	Repaired					
7389152	44 WAVERLY AVE	2	2024-08-18	2024-09-10	Newly Identified	Repaired					
7356203	17 WAYNE RD	3	2019-09-04	2024-06-27	Carried Forward	Eliminated Otherwise		2024-01-04	0	No CGI reading	NO READS
7386104	228 WEBSTER ST	2	2024-02-15	2024-04-24	Newly Identified	Repaired					
7388309	6 WESSEX RD	3	2023-06-17	2024-07-02	Carried Forward	Eliminated Otherwise		2023-06-17	250	Leak Extent	SYSTEM ISSUE
7388349	6 WESSEX RD	2	2024-10-13	2024-10-30	Newly Identified	Repaired	3				
7389172	WESTBOURNE RD & EASTBOURNE RD	1	2024-08-21	2024-08-21	Newly Identified	Repaired					
7353522	8 WETHERELL ST	2	2024-06-26	2024-08-23	Carried Forward	Repaired	3				
7385408	55 WETHERELL ST	1	2024-01-16	2024-01-17	Newly Identified	Repaired					
7325718	8 WHITE OAK RD	3	2016-05-10	2024-04-17	Carried Forward	Repaired		2024-03-21	1914	Leak Extent	
302760	60 WHITE OAK RD	3	2007-07-13	2024-04-18	Carried Forward	Repaired		2023-07-31	375	Leak Extent	
7365082	35 WHITTIER RD	3	2020-09-01	2024-07-11	Carried Forward	Eliminated Otherwise		2024-02-20	0	No CGI reading	NO READS
7386630	51 WILDWOOD AVE	1	2024-04-03	2024-04-04	Newly Identified	Repaired					
7386863	47 WINCHESTER RD	2	2024-04-18	2024-05-01	Newly Identified	Repaired					
7385940	346 WINCHESTER ST	2	2024-02-06	2024-02-16	Newly Identified	Repaired					
7356367	350 WINCHESTER ST	2	2023-12-04	2024-01-02	Carried Forward	Repaired					
5217418	499 WINCHESTER ST	3	2015-06-16	2024-07-01	Carried Forward	Eliminated Otherwise		2024-05-07	1000	Leak Extent	NO READS
7387504	WINDERMERE RD & WOODLAND RD	1	2024-05-15	2024-05-15	Newly Identified	Repaired					
7383029	140 WINDERMERE RD	3	2023-07-24	2024-12-17	Carried Forward	Repaired		2024-11-22	1600	Leak Extent	
7389363	10 WINDSOR RD	2	2024-08-27	2024-09-11	Newly Identified	Repaired					
270381	55 WINDSOR RD	3	2004-04-29	2024-10-18	Carried Forward	Eliminated Otherwise		2024-08-07	300	Leak Extent	NO READS
7385364	206 WINSLOW RD	1	2024-01-11	2024-01-11	Newly Identified	Repaired					
7387464	61 WINTHROP ST	1	2024-05-13	2024-05-13	Newly Identified	Repaired					
7356207	36 WISWALL RD	3	2019-09-05	2024-06-27	Carried Forward	Eliminated Otherwise		2024-01-04	0	No CGI reading	NO READS
7386979	461 WOLCOTT ST	1	2024-04-22	2024-04-22	Newly Identified	Repaired					
7385367	19 WOODBINE ST	1	2024-01-11	2024-01-11	Newly Identified	Repaired					
7384586	80 WOODCHESTER DR	3	2023-10-12	2024-08-09	Carried Forward	Repaired		2024-07-25	100	Leak Extent	
7388879	100 WOODCHESTER DR	1	2024-08-08	2024-08-08	Newly Identified	Repaired					
7386671	15 WOODCLIFF RD	1	2024-04-08	2024-04-08	Newly Identified	Repaired					
1282579	239 WOODLAND RD	3	2013-06-28	2024-08-20	Carried Forward	Repaired		2024-01-11	900	Leak Extent	
7355582	284 WOODWARD ST	3	2019-08-19	2024-08-27	Carried Forward	Repaired		2024-01-11	900	Leak Extent	
7386051	316 WOODWARD ST	2	2024-04-08	2024-07-01	Newly Identified	Repaired	3				
7385463	350 WOODWARD ST	1	2024-01-20	2024-01-20	Newly Identified	Repaired					

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
42479	52 SEWALL ST		22-Oct-90	30-Aug-24	2		
42571	1418 COMMONWEALTH A	DARTMOUTH ST	7-Jul-95	23-Sep-24	3	200	Non-G3SEI
155801	KENDALL RD	WALNUT HILL RD	23-Jul-99	4-Sep-24	2		
270538	522 COMMONWEALTH AV		29-Jun-04	12-Jun-24	3	0	Non-G3SEI
270745	WALNUT ST	BACON RD	6-Aug-04	3-Oct-24	3	4000	G3SEI
275900	544 QUINOBEQUIN RD		8-Jun-05	12-Nov-24	3	1400	Non-G3SEI
278687	HAMMOND ST	MIDDLESEX RD	8-Aug-05	8-Oct-24	3	4200	G3SEI
302760	60 WHITE OAK RD	NESHOBE RD	13-Jul-07	18-Apr-24	3	375	Non-G3SEI
305355	36 MAGNOLIA AVE	ELIOT MEMORIAL RD	29-Aug-07	15-Aug-24	3	540	Non-G3SEI
337228	DORSET RD	METACOMET RD	19-Aug-10	26-Jul-24	3	3360	G3SEI
338429	30 ELLIS RD	WAUWINET RD	13-Oct-10	7-Aug-24	3	2132	G3SEI
347021	160 COMMONWEALTH AV	COLLEGE RD	25-May-11	25-Jul-24	3	600	Non-G3SEI
1206963	41 BRUSH HILL RD	DANE HILL RD	25-Apr-13	16-Dec-24	3	1200	Non-G3SEI
1215753	52 ELLIOT ST	FRANCES ST	5-May-13	24-Sep-24	2		
1282579	239 WOODLAND RD	CHESWICK RD	28-Jun-13	20-Aug-24	3	900	Non-G3SEI
1283461	21 WALNUT ST	FLORENCE CT	15-Jul-13	25-Jun-24	3	500	Non-G3SEI
1338980	66 COMMONWEALTH PIK	COMMONWEALTH AVE	29-Aug-13	14-Oct-24	3	100	Non-G3SEI
1593092	1629 BEACON ST	WINDSOR RD	19-Feb-14	1-Apr-24	3	2200	G3SEI
2349834	109 ALLERTON RD	CENTRE ST	26-Dec-14	16-Dec-24	3	600	Non-G3SEI
3900011	18 ALDEN ST	CENTRE ST	24-Apr-15	6-Aug-24	3	1530	Non-G3SEI
4339243	130 BEACON ST	RESERVOIR AVE	4-Jun-15	30-Jul-24	3	2016	G3SEI
6592025	142 GORDON RD	BEACON ST	8-Sep-15	6-Mar-24	3	5040	G3SEI
7323097	14 ROKEBY RD	PONTIAC RD	14-Jan-16	21-Aug-24	3	225	Non-G3SEI
7325494	4 MARLBORO ST	TREMONT ST	21-Apr-16	18-Sep-24	2		
7325711	5 AGAWAM RD	BEACON ST	10-May-16	17-Dec-24	3	660	Non-G3SEI
7325718	8 WHITE OAK RD	BEACON ST	10-May-16	17-Apr-24	3	1914	Non-G3SEI
7326197	145 HIGHLAND ST	ASCENTA TER	11-May-16	3-Sep-24	3	1200	Non-G3SEI

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7336761	425 WATERTOWN ST	HAWTHORN ST	28-Jul-17	14-Feb-24	2		
7345717	85 COMMONWEALTH AVE	ALGONQUIN RD	14-Jul-18	7-Aug-24	3	900	Non-G3SEI
7347782	2044 BEACON ST	WASHINGTON ST	23-Sep-18	27-Mar-24	3	600	Non-G3SEI
7352431	54 TEMPLE ST	PRINCE ST	28-Mar-19	14-Mar-24	2		
7353522	8 WETHERELL ST	ELLIOT ST	5-May-19	23-Aug-24	2		
7354261	MELROSE AVE	MELROSE ST	24-Jun-19	11-Jan-24	2		
7354538	5 MARSHALL ST	GRANT AVE	8-Jul-19	9-Jan-24	2		
7354553	7 BUSWELL PIKE	CENTRE ST	9-Jul-19	18-Dec-24	3	2200	G3SEI
7354888	624 BEACON ST	GLEN AVE	24-Jul-19	1-Oct-24	2		
7355422	1466 COMMONWEALTH AVE	DARTMOUTH ST	24-Jul-19	1-Oct-24	3	3500	G3SEI
7355545	11 ANTONELLIS CIR	SPIERS RD	22-Aug-19	17-Dec-24	3	1332	Non-G3SEI
7355582	284 WOODWARD ST	FAIRLEE RD	19-Aug-19	27-Aug-24	3	900	Non-G3SEI
7355977	173 HIGHLAND ST	CHESTNUT ST	16-Aug-19	30-Sep-24	2		
7356210	15 LEEWOOD RD	BOUND BROOK RD	5-Sep-19	17-Apr-24	3	150	Non-G3SEI
7356220	27 EVELYN RD	BEACON ST	4-Sep-19	28-Aug-24	3	750	Non-G3SEI
7356367	350 WINCHESTER ST	SUTCLIFFE PIKE	25-Sep-19	2-Jan-24	2		
7356428	37 TRUMAN RD	MILDRED RD	26-Sep-19	18-Apr-24	3	50	Non-G3SEI
7356436	317 PARKER ST	KENDALL RD	26-Sep-19	25-Sep-24	2		
7356438	741 SAWMILL BROOK PKY	TIMSON PATH	26-Sep-19	28-Aug-24	3	1800	Non-G3SEI
7357654	143 RIVER ST	ALDEN PL	16-Oct-19	29-Jan-24	3	150	Non-G3SEI
7365113	110 ADELINE RD	BRANDEIS RD	9-Oct-20	12-Aug-24	3	748	Non-G3SEI
7370900	11 CLOVELLY RD	SUFFOLK RD	20-Sep-21	19-Jan-24	3	264	Non-G3SEI
7371042	305 COMMONWEALTH AVE	HAMMOND ST	6-Oct-21	17-Feb-24	3	1800	Non-G3SEI
7371866	1292 WALNUT ST	ASHCROFT RD	9-Nov-21	3-Jan-24	3	400	Non-G3SEI
7373592	11 ASHCROFT RD	WALNUT ST	22-Feb-22	18-Dec-24	3	100	Non-G3SEI
7374832	366 ELLIOT ST	CHESTNUT ST	6-May-22	12-Jan-24	2		
7374844	1974 WASHINGTON ST	LONGFELLOW RD	27-Apr-22	20-Feb-24	3	11016	G3SEI-LVL

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7374854	5 ANGIER CIR	WASHINGTON ST	11-May-22	18-Dec-24	3	660	Non-G3SEI
7374856	1750 COMMONWEALTH A	WASHINGTON ST	14-May-22	11-Mar-24	2		
7375099	750 COMMONWEALTH AV	MASON RD	26-Apr-22	22-Jul-24	3	225	Non-G3SEI
7375133	46 BEMIS ST	NEVADA ST	17-May-22	9-May-24	3	160	Non-G3SEI
7375165	49 GROVE ST	GROVELAND ST	27-May-22	29-Aug-24	3	600	Non-G3SEI
7375985	66 PELHAM ST	CRESCENT AVE	28-May-22	28-Aug-24	2		
7376329	1595 WASHINGTON ST	GREENOUGH ST	28-Jul-22	5-Jun-24	3		
7376438	281 HOMER ST	GARLAND RD	29-Jul-22	26-Sep-24	2		
7376827	120 CORNELL ST	GROVE ST	5-Apr-22	6-Dec-24	2		
7377815	2096 WASHINGTON ST	NESHOBE RD	13-Aug-22	7-Nov-24	3	12600	G3SEI-LVL
7378193	4 JUDITH RD	WALNUT ST	8-Nov-22	10-Sep-24	2		
7379000	BEACON ST	OWAISA RD	17-Dec-22	5-Aug-24	3	400	Non-G3SEI
7379171	74 FAIRMONT AVE	CLAREMONT ST	10-Jan-23	12-Dec-24	2		
7379277	234 CENTRAL ST	HANCOCK ST	9-Jan-23	11-Sep-24	2		
7379279	1438 COMMONWEALTH A	DARTMOUTH ST	11-Jan-23	26-Sep-24	3	450	Non-G3SEI
7379290	25 OLD ENGLAND RD	WOODMAN RD	4-Jan-23	4-Nov-24	2		
7379456	34 WARE RD	REGINA RD	1-Feb-23	11-Jul-24	3	250	Non-G3SEI
7379459	839 WASHINGTON ST	WALNUT ST	11-Jan-23	29-Aug-24	2		
7379545	105 ANNAWAN RD	EDGEFIELD RD	19-Jan-23	19-Dec-24	3	1440	Non-G3SEI
7380668	10 ANNAWAN RD	WABAN AVE	27-Mar-23	22-Feb-24	3		
7380670	122 CARVER RD	DICKERMAN RD	13-Apr-23	26-Feb-24	3	400	Non-G3SEI
7380676	923 WALNUT ST	CARTHAY CIR	6-Apr-23	11-Mar-24	2		
7382122	207 WASHINGTON ST	NONANTUM PL	6-Jun-23	6-Jun-24	2		
7382271	2322 WASHINGTON ST	GROVE ST	20-Jun-23	28-Oct-24	3	14400	G3SEI-LVL
7383027	26 PARKER ST	CYPRESS ST	2-Aug-23	14-Aug-24	3	3750	G3SEI
7383029	140 WINDERMERE RD	WOODLAND RD	24-Jul-23	17-Dec-24	3	1600	Non-G3SEI
7383497	2084 BEACON ST	WASHINGTON ST	27-Aug-23	25-Jul-24	2		

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7383508	HIGH ST	ELLIOT ST	14-Aug-23	13-Dec-24	2		
7383831	250 ALBEMARLE RD	ACCESS RD	17-Sep-23	6-Sep-24	2		
7384586	80 WOODCHESTER DR	WOODLAWN DR	12-Oct-23	9-Aug-24	3	100	Non-G3SEI
7385225	12 WASHBURN ST	WATERTOWN ST	2-Jan-24	2-Jan-24	1		
7385254	898 CHESTNUT ST	ANITA CIR	4-Jan-24	4-Jan-24	1		
7385256	45 SEWALL ST	STERLING ST	4-Jan-24	4-Jan-24	1		
7385276	228 HIGHLAND AVE	FOREST AVE	5-Jan-24	5-Jan-24	1		
7385304	35 LEXINGTON ST	WHITLOWE RD	24-Dec-23	14-Feb-24	2		
7385348	17 WARE RD	OWATONA ST	22-Dec-23	31-Jan-24	2		
7385351	178 NEHOLDEN RD	ALBAN RD	11-Jan-24	11-Jan-24	1		
7385364	206 WINSLOW RD	SELDEN ST	11-Jan-24	11-Jan-24	1		
7385367	19 WOODBINE ST	AUBURN ST	11-Jan-24	11-Jan-24	1		
7385393	37 MONTROSE ST	IVANHOE ST	14-Jan-24	15-Jan-24	1		
7385398	12 ELLIOT PL	ELLIOT ST	15-Jan-24	15-Jan-24	1		
7385399	21 JASSET ST	BEECH ST	15-Jan-24	16-Jan-24	1		
7385407	101 VERNON ST	BALDWIN ST	16-Jan-24	16-Jan-24	1		
7385408	55 WETHERELL ST	MECHANIC ST	16-Jan-24	17-Jan-24	1		
7385426	24 LEE RD	ACACIA AVE	17-Jan-24	18-Jan-24	1		
7385427	12 BROADLAWN DR	BROADLAWN PIKE	17-Jan-24	17-Jan-24	1		
7385438	72 ALLEN AVE	WOODHAVEN RD	2-Jan-24	30-Jan-24	2		
7385439	384 LINWOOD AVE	WATERTOWN ST	3-Jan-24	21-Feb-24	2		
7385462	28 ISLINGTON RD	RIDER TER	19-Jan-24	19-Jan-24	1		
7385463	350 WOODWARD ST	HOMESTEAD ST	20-Jan-24	20-Jan-24	1		
7385487	458 LOWELL AVE	CRAIGIE TER	22-Jan-24	22-Jan-24	1		
7385512	86 ALLEN AVE	WOODHAVEN RD	31-Dec-23	30-Jan-24	2		
7385518	256 WATERTOWN ST	PEARL ST	23-Jan-24	23-Jan-24	1		
7385532	263 PEARL ST	WATERTOWN ST	24-Jan-24	25-Jan-24	1		

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7385551	213 NAHANTON ST	DEDHAM ST	24-Jan-24	25-Jan-24	1		
7385614	95 ALLEN AVE	PINE RIDGE RD	28-Jan-24	28-Jan-24	1		
7385615	215 NAHANTON ST	DEDHAM ST	28-Jan-24	28-Jan-24	1		
7385616	215 NAHANTON ST	DEDHAM ST	28-Jan-24	28-Jan-24	1		
7385629	4 CAPITAL ST	WATERTOWN ST	21-Jan-24	25-Mar-24	2		
7385638	2014 WASHINGTON ST	LONGFELLOW RD	29-Jan-24	29-Jan-24	1		
7385654	139 CALIFORNIA ST	CALIFORNIA PIKE	30-Jan-24	30-Jan-24	1		
7385663	25 AVALON RD	UPLAND RD	31-Jan-24	31-Jan-24	1		
7385671	616 BOYLSTON ST	PARKER ST	31-Jan-24	2-Feb-24	1		
7385703	204 NORTH ST	FARWELL ST	1-Feb-24	2-Feb-24	1		
7385716	30 KILBURN RD	S GATE PIKE	25-Jan-24	20-Mar-24	2		
7385717	12 PLEASANT ST	CENTRE ST	25-Jan-24	20-Mar-24	2		
7385809	580 WASHINGTON ST	LENGLEN RD	20-Dec-23	22-Feb-24	2		
7385814	18 PRISCILLA RD	MAYFLOWER RD	6-Feb-24	6-Feb-24	1		
7385821	103 WABAN AVE	CROFTON RD	6-Feb-24	7-Feb-24	1		
7385845	200 JACKSON RD	JACKSON TER	18-Jan-24	29-Jul-24	3		
7385861	67 CHERRY ST	SYLVESTER RD	30-Jan-24	21-Feb-24	2		
7385862	53 CRESCENT ST	ROBINHOOD ST	31-Jan-24	26-Feb-24	2		
7385864	48 NATHAN RD	RANSOM RD	1-Feb-24	22-Feb-24	2		
7385872	28 HIBBARD RD	TREMONT ST	8-Feb-24	8-Feb-24	1		
7385874	22 FAIRWAY DR	WATERTOWN ST	8-Feb-24	9-Feb-24	1		
7385884	109 ADAMS ST	WATERTOWN ST	9-Feb-24	9-Feb-24	1		
7385888	384 NEWTONVILLE AVE	HARVARD ST	9-Feb-24	9-Feb-24	1		
7385940	346 WINCHESTER ST	SUTCLIFFE PIKE	6-Feb-24	16-Feb-24	2		
7385941	87 ALLEN AVE	WOODHAVEN RD	6-Feb-24	15-Feb-24	2		
7385944	1395 COMMONWEALTH A	CHESTNUT ST	14-Feb-24	14-Feb-24	1		
7385960	CYPRESS ST	PARKER ST	6-Feb-24	29-Feb-24	2		

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7385961	20 MALIA TER	BEACON ST	4-Feb-24	24-Apr-24	2		
7385971	305 COMMONWEALTH AV	HAMMOND ST	15-Feb-24	15-Feb-24	1		
7385979	14 MARGARET RD	SUBAN PL	15-Feb-24	16-Feb-24	1		
7386000	83 FAXON ST	JASSET ST	16-Feb-24	16-Feb-24	3		
7386005	14 PARK PL	WASHINGTON PIKE	17-Feb-24	19-Feb-24	1		
7386010	5 MARSHALL ST	GRANT AVE	17-Feb-24	17-Feb-24	1		
7386019	5 SWAN AVE	HARDING ST	6-Feb-24	6-Mar-24	2		
7386037	249 ADAMS ST	ADAMS TER	30-Jan-24	19-Dec-24	3	420	Non-G3SEI
7386051	316 WOODWARD ST	UPLAND RD	31-Jan-24	1-Jul-24	2		
7386104	228 WEBSTER ST	CRESCENT ST	15-Feb-24	24-Apr-24	2		
7386106	56 MILLER RD	CENTRE ST	30-Jan-24	25-Oct-24	2		
7386154	160 NEEDHAM ST	JACONNET ST	27-Feb-24	27-Feb-24	1		
7386159	69 LOS ANGELES ST	CALIFORNIA ST	28-Feb-24	28-Feb-24	1		
7386202	53 CRESCENT AVE	NORWOOD AVE	3-Mar-24	3-Mar-24	1		
7386313	1888 COMMONWEALTH A	AUBURN ST	11-Mar-24	13-Mar-24	1		
7386320	40 THE LEDGES RD	BISHOPSGATE RD	12-Mar-24	13-Mar-24	1		
7386330	380 WABAN AVE	PALMER RD	12-Mar-24	13-Mar-24	1		
7386372	50 QUINCY RD	OLD COLONY RD	14-Mar-24	15-Mar-24	1		
7386381	21 CHANDLER PL	ELLIOT TER	15-Mar-24	15-Mar-24	1		
7386383	1730 WASHINGTON ST	WOODLAND RD	7-Feb-24	16-May-24	2		
7386395	19 SYLVESTER RD	RUSSELL RD	16-Mar-24	16-Mar-24	1		
7386420	138 COTTON ST	SUNSET RD	6-Mar-24	1-Apr-24	2		
7386423	5 OLDEFIELD RD	BOYLSTON ST	6-Mar-24	10-Apr-24	2		
7386453	1251 WASHINGTON ST	DAVIS CT	20-Mar-24	21-Mar-24	1		
7386471	100 VARICK RD	WABAN AVE	21-Mar-24	21-Mar-24	3		
7386555	427 LEXINGTON ST	COMMONWEALTH AVE	28-Mar-24	29-Mar-24	1		
7386569	427 LEXINGTON ST	MELROSE AVE	28-Mar-24	29-Mar-24	1		

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7386609	23 RESERVOIR AVE	NANCY RD	2-Apr-24	2-Apr-24	1		
7386617	826 WATERTOWN ST	PARSONS ST	2-Apr-24	3-Apr-24	1		
7386630	51 WILDWOOD AVE	WATERTOWN ST	3-Apr-24	4-Apr-24	1		
7386656	320 WASHINGTON ST	PEABODY ST	5-Apr-24	7-Apr-24	1		
7386658	21 CLOELIA TER	CABOT ST	5-Apr-24	6-Apr-24	1		
7386671	15 WOODCLIFF RD	ROCKLEDGE RD	8-Apr-24	8-Apr-24	1		
7386863	47 WINCHESTER RD	E SIDE PKY	18-Apr-24	1-May-24	2		
7386912	1224 BOYLSTON ST	WORCESTER TPKE	18-Apr-24	1-May-24	1		
7386949	1197 CENTRE ST	PLEASANT ST	20-Apr-24	22-Apr-24	1		
7386979	461 WOLCOTT ST	IONIA ST	22-Apr-24	22-Apr-24	1		
7387022	137 PINE RIDGE RD	CHESTNUT ST	23-Apr-24	23-Apr-24	1		
7387036	1564 BEACON ST	MONTCLAIR RD	24-Apr-24	25-Apr-24	1		
7387052	300 PRINCE ST	BONAD RD	24-Apr-24	24-Apr-24	1		
7387082	105 TOLMAN ST	DERBY ST	25-Apr-24	25-Apr-24	1		
7387122	8 SHELDON RD	BOYLSTON ST	28-Apr-24	2-May-24	1		
7387128	420 WALTHAM ST	ORCHARD AVE	29-Apr-24	29-Apr-24	1		
7387168	320 WASHINGTON ST	PEABODY ST	30-Apr-24	3-Jun-24	1		
7387171	1310 CENTRE ST	RIPLEY TER	30-Apr-24	30-Apr-24	1		
7387188	28 ARAPAHOE RD	GREENOUGH ST	18-Mar-24	14-Jun-24	2		
7387201	77 HALCYON RD	CLARK ST	1-May-24	1-May-24	1		
7387243	2240 COMMONWEALTH A	ISLINGTON RD	3-May-24	6-May-24	1		
7387254	665 WATERTOWN ST	EDINBORO ST	4-May-24	4-May-24	1		
7387260	90 HIGHLAND AVE	ELMWOOD PIKE	5-May-24	6-May-24	1		
7387299	51 GORDON RD	PAULSON RD	7-May-24	7-May-24	1		
7387303	3 CARL ST	CHARLEMONT ST	7-May-24	7-May-24	1		
7387326	5 MARGARET RD	BOYLSTON ST	7-May-24	10-May-24	1		
7387337	9 MARGARET RD	BOYLSTON ST	7-May-24	7-May-24	1		

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7387339	84 HAMMONDSWOOD RD	EDGE HILL RD	7-May-24	7-May-24	1		
7387378	60 DWHINDA RD	QUINOBEQUIN RD	9-May-24	9-May-24	1		
7387407	112 AUBURNDALE AVE	EDGEWOOD RD	10-May-24	10-May-24	1		
7387447	115 ALLEN AVE	PINE RIDGE RD	22-Apr-24	2-Oct-24	2		
7387449	208 LEXINGTON ST	STANIFORD ST	29-Apr-24	20-Aug-24	2		
7387451	26 NOBLE ST	WASHINGTON AVE	30-Apr-24	14-Jun-24	2		
7387453	122 CARVER RD	DICKERMAN RD	22-Apr-24	13-Jun-24	2		
7387464	61 WINTHROP ST	PERKINS ST	13-May-24	13-May-24	1		
7387484	528 BOYLSTON ST	OLDEFIELD RD	14-May-24	21-May-24	1		
7387493	1750 COMMONWEALTH A	WASHINGTON ST	8-May-24	20-Nov-24	3		
7387504	WINDERMERE RD	WOODLAND RD	15-May-24	15-May-24	1		
7387664	176 BOYLSTON ST	HAMMOND POND PKY	22-May-24	22-May-24	1		
7387914	1310 CENTRE ST	RIPLEY TER	13-May-24	10-Sep-24	2		
7387916	3 CHANDLER ST	BRIDGE ST	13-May-24	25-Jul-24	2		
7387919	169 CYPRESS ST	PARKER ST	28-May-24	18-Jul-24	2		
7387982	12 GEORGE ST	HYDE AVE	7-Jun-24	7-Jun-24	1		
7388022	22 WALSH RD	WISWALL RD	11-Jun-24	12-Jun-24	1		
7388114	728 WALNUT ST	HOMER ST	17-Jun-24	17-Jun-24	1		
7388177	300 HAMMOND ST	WOODMAN RD	22-Jun-24	22-Jun-24	1		
7388266	8 BROWNING RD	OXFORD RD	30-May-24	11-Jul-24	2		
7388276	432 WATERTOWN ST	HAWTHORN ST	27-Jun-24	27-Jun-24	1		
7388304	1216 CHESTNUT ST	OAK ST	11-Jun-24	19-Jul-24	3	100	Non-G3SEI
7388323	1009 BOYLSTON ST	WOODWARD ST	1-Jul-24	1-Jul-24	1		
7388349	6 WESSEX RD	WARD ST	17-Jun-24	30-Oct-24	2		
7388359	146 LINCOLN ST	MOUNTFORT RD	2-Jul-24	3-Jul-24	1		
7388489	22 BONMAR CIR	WASHINGTON ST	12-Jul-24	12-Jul-24	1		
7388521	255 PARKER ST	OAKDALE RD	22-Jun-24	25-Sep-24	3		

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7388530	1 RIDGE RD	VARICK RD	16-Jul-24	16-Jul-24	1		
7388577	GILBERT ST	AUBURN ST	19-Jul-24	19-Jul-24	1		
7388623	11 CLEARWATER RD	SHERRIN RD	22-Jul-24	22-Jul-24	1		
7388654	500 DUDLEY RD	BALDPATE HILL RD	24-Jul-24	24-Jul-24	1		
7388683	195 NORTH ST	DECATUR ST	7-Jul-24	9-Oct-24	2		
7388841	83 MORRILL ST	PRATT DR	6-Aug-24	6-Aug-24	1		
7388879	100 WOODCHESTER DR	WOODLAWN DR	8-Aug-24	8-Aug-24	1		
7388900	425 WARD ST	BALLARD ST	23-Jul-24	15-Aug-24	3		
7388903	1185 WALNUT ST	FLORAL ST	25-Jul-24	23-Oct-24	2		
7388951	628 BOYLSTON ST	PARKER ST	12-Aug-24	16-Aug-24	1		
7388975	449 NEWTONVILLE AVE	WALNUT ST	26-Jul-24	30-Aug-24	2		
7388988	78 WALKER ST	ROBERTS AVE	13-Aug-24	13-Aug-24	1		
7389106	866 BEACON ST	CRESCENT AVE	12-Aug-24	19-Aug-24	1		
7389107	7 WADE ST	BOYLSTON ST	19-Aug-24	19-Aug-24	1		
7389135	567 WALNUT ST	PROSPECT AVE	20-Aug-24	21-Aug-24	1		
7389152	44 WAVERLY AVE	TREMONT ST	18-Aug-24	10-Sep-24	2		
7389156	1042 BOYLSTON ST	DICKERMAN RD	21-Aug-24	23-Aug-24	1		
7389172	WESTBOURNE RD	EASTBOURNE RD	21-Aug-24	21-Aug-24	1		
7389264	949 CENTRE ST	BALLARD ST	27-Aug-24	27-Aug-24	1		
7389363	10 WINDSOR RD	KINMONTH RD	27-Aug-24	11-Sep-24	2		
7389409	202 AUBURNDALE AVE	PRAIRIE AVE	6-Sep-24	6-Sep-24	1		
7389498	275 MILL ST	WOODSIDE RD	6-Sep-24	24-Sep-24	2		
7389504	109 CABOT ST	LAUDHOLM RD	5-Sep-24	17-Sep-24	2		
7389508	427 LEXINGTON ST	COMMONWEALTH AVE	4-Sep-24	2-Oct-24	2		
7389575	14 SHORNECLIFFE RD	ARLINGTON ST	13-Sep-24	13-Sep-24	1		
7389589	7 WADE ST	BOYLSTON ST	11-Sep-24	9-Dec-24	3		
7389682	1039 WALNUT ST	HYDE ST	19-Sep-24	19-Sep-24	1		

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7389705	989 CENTRE ST	WARD ST	20-Sep-24	20-Sep-24	1		
7389759	130 NONANTUM RD	MAPLE ST	24-Sep-24	25-Sep-24	3		
7389793	CURVE ST	AUBURN ST	25-Sep-24	25-Sep-24	1		
7389801	796 CHESTNUT ST	FENWICK RD	25-Sep-24	25-Sep-24	1		
7389806	98 ANNAWAN RD	EDGEFIELD RD	26-Sep-24	26-Sep-24	1		
7389938	961 WALNUT ST	KINGMAN RD	4-Oct-24	4-Oct-24	1		
7389974	11 CLEARWATER RD	SHERRIN RD	30-Sep-24	16-Oct-24	2		
7389975	1097 CENTRE ST	TRINITY TER	23-Sep-24	16-Oct-24	2		
7389976	64 BISHOPSGATE RD	CROFTDALE RD	1-Oct-24	23-Oct-24	2		
7390003	85 MONTVALE RD	MONTVALE CIR	4-Oct-24	28-Oct-24	2		
7390093	835 WASHINGTON ST	WALNUT ST	13-Oct-24	4-Nov-24	2		
7390129	573 WASHINGTON ST	LENGLEN RD	16-Oct-24	16-Oct-24	3		
7390136	6 DORCAR RD	VINE ST	17-Oct-24	17-Oct-24	1		
7390261	1011 CENTRE ST	ALDEN ST	18-Oct-24	24-Oct-24	1		
7390304	60 ELLIOT ST	FRANCES ST	22-Oct-24	22-Oct-24	1		
7390373	961 WALNUT ST	KINGMAN RD	17-Oct-24	23-Oct-24	2		
7390421	111 PARKER AVE	WOODCLIFF RD	23-Oct-24	12-Nov-24	2		
7390630	27 METACOMET RD	QUIDNIC RD	5-Nov-24	6-Nov-24	1		
7390652	1197 CENTRE ST	PLEASANT ST	9-Oct-24	21-Nov-24	2		
7390704	6 ALBAN RD	NEHOIDEN RD	12-Nov-24	12-Nov-24	1		
7390710	75 WALKER ST	ROBERTS AVE	2-Nov-24	4-Dec-24	2		
7390737	38 PRINCE ST	SEWALL ST	2-Nov-24	2-Dec-24	2		
7390779	49 MILLER RD	CENTRE ST	17-Nov-24	18-Nov-24	1		
7390783	16 MANEMET RD	BOTHFIELD RD	18-Nov-24	18-Nov-24	1		
7390797	933 CENTRE ST	ALDERWOOD RD	18-Nov-24	18-Nov-24	1		
7390874	5 SHELDON RD	BOYLSTON ST	22-Nov-24	26-Nov-24	1		
7390876	116 FAIRWAY DR	BUNKER LN	22-Nov-24	25-Nov-24	1		

	Table L8 Newton Leaks Eliminated by Repair - Detail						
Source:	National Grid Service Quality Report 25-SQ-05						
Leak #	Reported Address	Cross Street	Reported Date	Repaired Date	Leak Grade	24-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7390889	35 DRUMLIN RD	DUDLEY RD	24-Nov-24	24-Nov-24	1		
7390899	7 CURTIS ST	RAMSDELL ST	20-Nov-24	4-Dec-24	2		
7391075	3 NARDONE RD	OLDEFIELD RD	24-Nov-24	16-Dec-24	2		
7391093	74 WALKER ST	ROBERTS AVE	5-Dec-24	5-Dec-24	1		
7391098	955 CENTRE ST	BALLARD ST	5-Dec-24	5-Dec-24	1		
7391223	6 ANGIER CIR	WASHINGTON ST	17-Dec-24	18-Dec-24	3		
7391282	494 WARD ST	ELMORE ST	24-Dec-24	27-Dec-24	1		
7391286	268 DORSET RD	LORRAINE CIR	26-Dec-24	26-Dec-24	1		
7391330	OAK ST	CHESTNUT ST	29-Dec-24	30-Dec-24	1		
7391334	865 BEACON ST	CRESCENT AVE	29-Dec-24	30-Dec-24	1		

Table L9 leaks eliminated by pipe replacement

Leak ID	Street Address	Grade	First Report Date	Latest Classification Date	Repair Date	Carried Forward or Newly Identified	Prior Grade (if any)	Survey Date	Leak Extent	Method	Appeared in GREC inventory	Repaired on and by end of work order	Note
7339913	58 AUBURN ST	3	2017-11-15	2017-11-15	2024-12-03	Carried Forward		2024-09-30	0	No CGI reading	No	1421288	
7387993	AUBURNDALE AVE & HAROLD TER	3		2024-05-31	2024-07-23	Newly Identified					No		Classified two weeks after completion of w.o. #1421113, and repaired almost two months later
7336460	1746 BEACON ST	3	2017-07-19	2017-07-19	2024-10-10	Carried Forward		2023-11-06	900	Leak Extent	Yes (CY 2021)	1454321	
7387878	103 COLLINS RD	3		2024-05-13	2024-08-15	Newly Identified		2024-05-13	4320	Leak Extent	Yes	1596797	
1363357	647 COMMONWEALTH AVE	3	2013-09-12	2013-09-12	2024-10-16	Carried Forward		2024-06-26	250	Leak Extent	No		
7378752	271 CYPRESS ST	3	2022-11-09	2022-11-09	2024-07-30	Carried Forward		2024-06-26	1	Leak Extent	No		
338427	65 ELINOR RD	3	2010-10-09	2010-10-09	2024-10-08	Carried Forward		2024-09-30	0	No CGI reading	No	1512179	
7379880	31 FOX HILL RD	3	2023-02-18	2023-02-18	2024-05-29	Carried Forward		2023-11-13	900	Leak Extent	No		
7385715	15 HICKORY CLIFF RD	2		2024-01-23	2024-06-03	Newly Identified					No		
7375160	64 HILLSIDE AVE	2	2022-05-17	2024-06-26	2024-10-01	Carried Forward	3				No	1476454	
7354043	170 NEEDHAM ST	2	2019-06-21	2020-05-21	2020-11-20	Carried Forward					No		
7387874	100 VALENTINE ST	2		2024-05-03	2024-07-24	Newly Identified					No	1483734	
7356133	151 VALENTINE ST	3	2019-08-06	2019-08-06	2024-08-08	Carried Forward		2023-12-13	100	Leak Extent	No	1483734	
7349893	240 VALENTINE ST	3	2018-12-17	2018-12-17	2024-08-08	Carried Forward		2024-02-05	0	No CGI reading	No	1483734	

Table L10 Newton leaks eliminated otherwise

Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
230384	41 LAKEVIEW AV	3	2000-08-07	2024-11-27	Carried Forward		2024-11-06	0	No CGI reading	NO READS
270381	55 WINDSOR RD	3	2004-04-29	2024-10-18	Carried Forward		2024-08-07	300	Leak Extent	NO READS
270590	35-45 MCCARTHY RD	3	2004-07-22	2024-06-27	Carried Forward		2023-11-06	0	No CGI reading	NO READS
270653	HAMMOND ST & RESERVC	3	2004-08-20	2024-01-02	Carried Forward		2023-11-14	25	Leak Extent	NO READS
307615	24 CENTRAL AVE	3	2007-09-10	2024-12-02	Carried Forward		2024-08-13	0	No CGI reading	NO READS
329373	320 NEEDHAM ST	3	2009-10-11	2024-09-12	Carried Forward		2024-05-07	100	Leak Extent	NO READS
332435	30 K ROADWAY	3	2010-04-13	2024-10-12	Carried Forward		2024-09-03	0	No CGI reading	NO READS
336992	881 DEDHAM ST	3	2010-09-01	2024-10-19	Carried Forward		2024-08-13	0	No CGI reading	NO READS
340420	167 NEHOIDEN RD	3	2010-12-25	2024-07-01	Carried Forward		2024-03-20	25	Leak Extent	NO READS
345666	1234 COMMONWEALTH AV	3	2011-04-14	2024-07-30	Carried Forward		2024-02-21	0	No CGI reading	NO READS
796835	11 VIRGINIA RD	3	2012-02-06	2024-06-27	Carried Forward		2023-12-19	1426	Leak Extent	NO READS
949724	8 HAMMOND ST	3	2012-08-01	2024-09-12	Carried Forward		2024-08-13	0	No CGI reading	NO READS
1065939	53 CHARLESBANK RD	3	2012-08-30	2024-01-20	Carried Forward		2023-08-31	7500	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
1018521	12 VINEYARD RD	3	2012-10-12	2024-09-12	Carried Forward		2024-09-03	0	No CGI reading	NO READS
1317702	91 PICKWICK RD	3	2013-08-16	2024-06-27	Carried Forward		2024-02-16	0	No CGI reading	NO READS
1428283	191 GROVE ST	3	2013-10-08	2024-11-27	Carried Forward		2024-11-07	0	No CGI reading	NO READS
3023506	COMMONWEALTH AVE & C	3	2014-11-06	2024-07-01	Carried Forward		2023-11-09	0	No CGI reading	NO READS
3093950	43 SEWALL ST	3	2015-02-09	2024-11-27	Carried Forward		2024-11-07	0	No CGI reading	NO READS
3869246	877 CHESTNUT ST	3	2015-04-07	2024-07-01	Carried Forward		2024-02-21	0	No CGI reading	NO READS
5217418	499 WINCHESTER ST	3	2015-06-16	2024-07-01	Carried Forward		2024-05-07	1000	Leak Extent	NO READS
4787400	300 ADAMS ST	3	2015-07-07	2024-07-01	Carried Forward		2024-01-04	0	No CGI reading	NO READS
4788513	22 AUBURN ST	3	2015-07-09	2024-10-17	Carried Forward		2024-05-07	200	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
5620596	832 DEDHAM ST	3	2015-08-27	2024-09-12	Carried Forward		2023-12-19	4550	Leak Extent	NO READS
5620468	121 PARKER AVE	3	2015-08-27	2024-01-02	Carried Forward		2023-11-13	0	No CGI reading	NO READS
6591350	22 OLDEFIELD RD	3	2015-09-12	2024-12-02	Carried Forward		2024-09-09	0	No CGI reading	NO READS
6624524	14 SAMOSET RD	3	2015-09-21	2024-06-27	Carried Forward		2024-03-20	875	Leak Extent	NO READS
1237078	94 DEVONSHIRE RD	3	2015-10-09	2024-10-19	Carried Forward		2024-10-09	0	No CGI reading	NO READS
7322014	83 DEVONSHIRE RD	3	2015-12-08	2024-07-01	Carried Forward		2023-11-09	150	Leak Extent	NO READS
5866391	HAMMOND ST & COLLEGE	3	2015-12-14	2024-08-06	Carried Forward		2023-12-05	25000	Leak Extent	NO READS
7323783	38 PUTNAM ST	3	2016-02-01	2024-04-12	Carried Forward		2024-02-16	0	No CGI reading	NO READS
7323736	35 BELLEVUE ST	3	2016-02-02	2024-07-02	Carried Forward		2024-01-04	0	No CGI reading	NO READS
7324253	15 JACKSON ST	3	2016-03-23	2024-09-12	Carried Forward		2024-08-14	50	Leak Extent	NO READS
7325492	135 BIGELOW RD	3	2016-04-21	2024-08-19	Carried Forward		2024-08-14	560	Leak Extent	NO READS
7325803	640 GROVE ST	3	2016-04-22	2024-10-24	Carried Forward		2024-08-20	1750	Leak Extent	DUPLICATE LEAK
7325806	4 PEMBROKE ST	3	2016-04-22	2024-12-03	Carried Forward		2024-11-19	0	No CGI reading	NO READS

Table L10 Newton leaks eliminated otherwise

Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7322832	49 ASHMONT AVE	3	2016-04-25	2024-08-05	Carried Forward		2024-01-04	0	No CGI reading	NO READS
7325992	269 JACKSON ST	3	2016-05-12	2024-09-12	Carried Forward		2024-04-25	0	No CGI reading	NO READS
7327750	OAKLAND ST & CHURCH S	3	2016-06-02	2024-07-01	Carried Forward		2024-05-07	225	Leak Extent	NO READS
7326611	26 MAPLE ST	3	2016-06-06	2024-07-01	Carried Forward		2024-03-20	25	Leak Extent	NO READS
7326630	39 COURT ST	3	2016-06-09	2024-10-12	Carried Forward		2024-05-07	0	No CGI reading	NO READS
7326636	NORTH ST & ALBEMARLE I	3	2016-06-13	2024-10-24	Carried Forward		2024-05-07	0	No CGI reading	DUPLICATE LEAK
7327002	1395 COMMONWEALTH AV	3	2016-06-23	2024-02-21	Carried Forward		2023-07-31	400	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7327405	DAVIS AVE & EDEN AVE	3	2016-06-27	2024-10-19	Carried Forward		2024-06-26	100	Leak Extent	NO READS
7329882	BEACON ST & HAMMOND S	3	2016-10-28	2024-01-04	Carried Forward		2023-11-16	25	Leak Extent	NO READS
7330111	28 CONSIDINE RD	3	2016-11-03	2024-10-12	Carried Forward		2024-09-12	1050	Leak Extent	NO READS
7329507	263 HAMMOND ST	3	2016-11-07	2024-11-27	Carried Forward		2024-11-07	0	No CGI reading	NO READS
7330385	75 SUMNER ST	3	2016-11-16	2024-12-09	Carried Forward		2024-11-07	0	No CGI reading	NO READS
7331915	150 SPIERS RD	3	2017-02-02	2024-01-02	Carried Forward		2023-11-16	25	Leak Extent	NO READS
7335811	78 NONANTUM ST	3	2017-06-10	2024-07-01	Carried Forward		2024-05-15	84	Leak Extent	NO READS
7338634	6 VAUGHAN AVE	3	2017-09-09	2024-12-03	Carried Forward		2024-11-01	300	Leak Extent	NO READS
7341653	457 WASHINGTON ST	3	2018-01-28	2024-12-03	Carried Forward		2024-11-06	0	No CGI reading	NO READS
7341526	224 JACKSON ST	3	2018-02-27	2024-09-12	Carried Forward		2024-02-20	0	No CGI reading	NO READS
7348728	283 MELROSE ST	3	2018-06-29	2024-12-03	Carried Forward		2024-11-04	0	No CGI reading	NO READS
7347783	69 EVELYN RD	3	2018-09-16	2024-12-07	Carried Forward		2024-11-07	0	No CGI reading	NO READS
7348310	95 DORSET RD	3	2018-10-11	2024-11-22	Carried Forward		2024-11-20	0	No CGI reading	NO READS
7351646	20 SUN HILL LN	3	2019-03-08	2024-06-27	Carried Forward		2024-04-30	9	Leak Extent	NO READS
7353083	1830 COMMONWEALTH AV	3	2019-05-13	2024-09-21	Carried Forward		2024-08-21	0	No CGI reading	NO READS
7353079	1870 COMMONWEALTH AV	3	2019-05-13	2024-10-12	Carried Forward		2024-08-21	0	No CGI reading	NO READS
7353512	47 CHANDLER PL	3	2019-05-23	2024-01-04	Carried Forward		2023-11-13	0	No CGI reading	NO READS
7353577	73 DEDHAM ST	3	2019-05-24	2024-09-16	Carried Forward		2024-08-08	112	Leak Extent	NO READS
7354042	130 NEEDHAM ST	3	2019-06-21	2024-01-02	Carried Forward		2023-11-16	25	Leak Extent	NO READS
7354258	369 LEXINGTON ST	3	2019-06-24	2024-01-04	Carried Forward		2023-11-16	25	Leak Extent	NO READS
7354711	86 COMMONWEALTH AVE	3	2019-07-16	2024-11-15	Carried Forward		2024-09-04	0	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7354712	31 DEVONSHIRE RD	3	2019-07-19	2024-09-12	Carried Forward		2024-09-04	0	No CGI reading	NO READS
7354715	6 EDGEWOOD RD	3	2019-07-19	2024-08-19	Carried Forward		2023-11-16	0	No CGI reading	NO READS
7355547	85 BROOKSIDE AVE	3	2019-08-20	2024-11-27	Carried Forward		2024-11-01	0	No CGI reading	NO READS
7355674	188 DEDHAM ST	3	2019-08-23	2024-01-04	Carried Forward		2023-12-14	0	No CGI reading	NO READS
7356139	344 BROOKLINE ST	3	2019-09-03	2024-08-05	Carried Forward		2024-01-04	0	No CGI reading	NO READS
7356203	17 WAYNE RD	3	2019-09-04	2024-06-27	Carried Forward		2024-01-04	0	No CGI reading	NO READS
7356207	36 WISWALL RD	3	2019-09-05	2024-06-27	Carried Forward		2024-01-04	0	No CGI reading	NO READS

Table L10 Newton leaks eliminated otherwise

Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7356362	29 F ROADWAY	3	2019-09-25	2024-11-27	Carried Forward		2024-10-30	0	No CGI reading	NO READS
7356371	80 HANSON RD	3	2019-09-25	2024-12-03	Carried Forward		2024-11-04	0	No CGI reading	NO READS
7356372	569 SAWMILL BROOK PKY	3	2019-09-25	2024-10-24	Carried Forward		2024-02-16	1600	Leak Extent	DUPLICATE LEAK
7356450	10 SPIERS RD	3	2019-09-27	2024-09-12	Carried Forward		2024-02-21	600	Leak Extent	NO READS
7357139	48 LANTERN LN	3	2019-10-25	2024-12-03	Carried Forward		2024-11-07	0	No CGI reading	NO READS
1336115	156 OAK ST	2	2020-04-17	2024-10-30	Carried Forward					REPAIRED UNDER OTHER LEAK REPAIR
7364115	33 WARREN RD	3	2020-05-24	2024-12-09	Carried Forward		2024-11-20	0	No CGI reading	NO READS
7364120	43 SHERBROOKE RD	3	2020-06-15	2024-09-12	Carried Forward		2024-09-04	0	No CGI reading	NO READS
7364121	34 FENNO RD	3	2020-06-17	2024-10-19	Carried Forward		2024-09-27	1	Leak Extent	NO READS
7364450	60 FAIRLEE RD	3	2020-08-26	2024-11-27	Carried Forward		2024-11-12	0	No CGI reading	NO READS
7365082	35 WHITTIER RD	3	2020-09-01	2024-07-11	Carried Forward		2024-02-20	0	No CGI reading	NO READS
7365094	160 PARKER ST	3	2020-10-15	2024-10-19	Carried Forward		2024-04-23	0	No CGI reading	NO READS
7365478	50 MANEMET RD	3	2020-11-14	2024-06-27	Carried Forward		2024-05-06	100	Leak Extent	NO READS
7367241	46 CEDAR ST	3	2021-03-01	2024-07-01	Carried Forward		2024-05-21	1250	Leak Extent	NO READS
7368124	650 CENTRE ST	3	2021-04-22	2024-01-04	Carried Forward		2023-11-16	25	Leak Extent	NO READS
7368508	97 ATWOOD AVE	3	2021-04-26	2024-01-04	Carried Forward		2023-11-16	25	Leak Extent	NO READS
7368505	87 ATWOOD AVE	3	2021-05-04	2024-12-19	Carried Forward		2024-09-04	0	No CGI reading	NO READS
7369309	129 DORSET RD	3	2021-06-11	2024-07-11	Carried Forward		2024-01-11	400	Leak Extent	DUPLICATE LEAK
7370889	375 AUBURN ST	3	2021-09-19	2024-12-03	Carried Forward		2024-11-20	0	No CGI reading	NO READS
7371043	34 EMERSON ST	3	2021-10-07	2024-08-19	Carried Forward		2024-04-30	0	No CGI reading	NO READS
7374830	21 MARSHFIELD RD	3	2022-03-15	2024-09-12	Carried Forward		2024-08-08	0	No CGI reading	NO READS
7374831	75 ELMHURST RD	3	2022-04-05	2024-09-12	Carried Forward		2024-09-04	0	No CGI reading	NO READS
7376826	12 COPLEY ST	3	2022-04-15	2024-08-19	Carried Forward		2024-01-11	0	No CGI reading	NO READS
7375164	8 BALDPATE HILL RD	3	2022-04-26	2024-08-05	Carried Forward		2023-12-19	25	Leak Extent	NO READS
7375161	262 OTIS ST	3	2022-05-18	2024-10-24	Carried Forward		2024-10-11	230	Leak Extent	DUPLICATE LEAK
7375136	15 ELMWOOD PIKE	3	2022-05-24	2024-11-27	Carried Forward		2024-10-11	0	No CGI reading	NO READS
7375989	38 VERNDAL RD	3	2022-06-17	2024-12-03	Carried Forward		2024-11-06	0	No CGI reading	NO READS
7376318	39 BILLINGS PIKE	3	2022-08-03	2024-12-07	Carried Forward		2024-11-12	0	No CGI reading	NO READS
7379023	HIGHLAND ST & DAVIS ST	3	2022-12-18	2024-01-17	Carried Forward		2023-09-26	100	Leak Extent	DUPLICATE LEAK
7379240	494 WATERTOWN ST	3	2023-01-04	2024-08-13	Carried Forward		2023-11-07	250	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7379850	54 DUXBURY RD	3	2023-02-07	2024-09-12	Carried Forward		2024-09-04	0	No CGI reading	NO READS
7380674	10 LOWELL AVE	3	2023-02-24	2024-09-12	Carried Forward		2024-08-28	0	No CGI reading	NO READS
7379883	228 HIGHLAND AVE	3	2023-02-28	2024-09-12	Carried Forward		2024-09-04	0	No CGI reading	NO READS
7380672	31 GARDNER ST	3	2023-03-23	2024-08-19	Carried Forward		2024-01-12	0	No CGI reading	NO READS
7374799	1730 WASHINGTON ST	3	2023-04-05	2024-03-15	Carried Forward					SYSTEM ISSUE

Table L10 Newton leaks eliminated otherwise

Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7388309	6 WESSEX RD	3	2023-06-17	2024-07-02	Carried Forward		2023-06-17	250	Leak Extent	SYSTEM ISSUE
7382536	74 EDDY ST	2	2023-06-29	2024-07-25	Carried Forward					NO READS
7382899	298 CYPRESS ST	3	2023-07-08	2024-08-19	Carried Forward		2024-05-06	0	No CGI reading	NO READS
7382741	263 HAMMOND ST	1	2023-08-03	2024-03-21	Carried Forward					CALLED OFF BY SUPERVISOR
7383512	5 SHELDON RD	3	2023-08-29	2024-11-27	Carried Forward		2024-06-26	900	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7384775	628 BOYLSTON ST	2	2023-10-24	2024-02-06	Carried Forward					CALLED OFF BY SUPERVISOR
7384691	320 WASHINGTON ST	3	2023-11-15	2024-06-27	Carried Forward		2024-02-13	0	No CGI reading	NO READS
7384926	55 MURRAY RD	1	2023-12-10	2024-03-21	Carried Forward					CALLED OFF BY SUPERVISOR
7385311	23 DAVIS ST	3	2023-12-19	2024-01-24	Carried Forward		2023-12-19	80	Leak Extent	DUPLICATE LEAK
7374845	2055 WASHINGTON ST	2	2024-01-21	2024-04-23	Carried Forward	3				NO READS
7385527	28 GEORGE ST	1	2024-01-23	2024-02-06	Newly Identified					CALLED OFF BY SUPERVISOR
7385528	28 GEORGE ST	1	2024-01-23	2024-01-24	Newly Identified					DUPLICATE LEAK
7386047	25 GREENLAWN AVE	3	2024-02-01	2024-10-24	Newly Identified					DUPLICATE LEAK
7385972	5 MARSHALL ST	3	2024-02-01	2024-12-03	Newly Identified		2024-10-30	0	No CGI reading	NO READS
7386138	11 CANTERBURY RD	3	2024-02-11	2024-11-27	Newly Identified		2024-11-01	0	No CGI reading	NO READS
7386574	528 BOYLSTON ST	2	2024-03-03	2024-05-16	Newly Identified					REPAIRED UNDER OTHER LEAK REPAIR
7386559	933 CENTRE ST	3	2024-03-12	2024-11-14	Newly Identified					REPAIRED UNDER OTHER LEAK REPAIR
7386433	4 MEREDITH AVE	1	2024-03-19	2024-03-20	Newly Identified					CALLED OFF BY SUPERVISOR
7387594	40 CHASKE AVE	3	2024-04-22	2024-05-30	Newly Identified					DUPLICATE LEAK
7387253	665 WATERTOWN ST	1	2024-05-04	2024-05-08	Newly Identified					DUPLICATE LEAK
7388430	7 WADE ST	2	2024-05-14	2024-08-22	Newly Identified					REPAIRED UNDER OTHER LEAK REPAIR
7371859	214 BEACON ST	2	2024-05-15	2024-06-14	Carried Forward	3				SYSTEM ISSUE
7387665	176 BOYLSTON ST	1	2024-05-23	2024-12-30	Newly Identified					DUPLICATE LEAK
7387994	300 HAMMOND ST	2	2024-05-31	2024-06-24	Newly Identified					REPAIRED UNDER OTHER LEAK REPAIR
7327022	74 HOMESTEAD ST	2	2024-06-26	2024-08-19	Carried Forward	3				NO READS

Table L11 Aggregation of Leaks Eliminated Otherwise		
How Eliminated	Count	Leak extent, sq. ft.
CALLED OFF BY SUPERVISOR	5	0
DUPLICATE LEAK	12	4,160
NO READS	99	38,092
REPAIRED UNDER OTHER LEAK REPAIR	11	9,250
SYSTEM ISSUE	3	250
UPGRADE	0	0
Total of leaks "eliminated otherwise"	130	51,752