

August 5, 2026

Memo to: Newton Energy Commission Chair Philip Hanser
From: Peter J. Barrer and Denise Freed
Re: GSEP in Newton 2025
Cc: Bob Persons, Ellie Goldberg, Nathan Phillips

Summary

The Newton Gas Pipes Team, a volunteer non-governmental group, has completed an investigation into National Grid's Gas System Enhancement Program (GSEP) plans and National Grid's pipeline replacement and leak repair projects in Newton for calendar year 2025. We are investigating to what degree National Grid's (NG) leak repair and pipeline replacement activities are in the interest of the City and its resident gas ratepayers.

As Newton residents work to reduce carbon emissions, the leaky gas distribution system will be phased out as it becomes obsolete. Under GSEP, however, National Grid's continued investments in the outdated gas pipe system will impose unnecessary costs on ratepayers and perhaps taxpayers.

This report follows similar investigations of GSEP in Newton for [2022](#), [2023](#) and [2024](#) as well as across all [National Grid territory for 2024](#).

We found that the work which National Grid is currently performing under GSEP does not serve the interests of Newton and does not align with the City's Climate Action Plan goal of eliminating fossil fuel carbon emissions by 2050.

The City's priorities have evolved since the implementation of GSEP in 2014. The City now recognizes that even leaks classified as non-hazardous can still pose significant risks to health and the environment and that the City needs a plan for retiring the gas system entirely.

National Grid replaces most of its pipes in Newton without obtaining specific approval from the City Council through a Grant of Location (GOL). Although National Grid submits its GSEP plans to the DPU, the plans lack details showing all the specific street segments; as a result, Newton elected officials have little information or control over gas pipe construction in Newton streets. Newton should alter its procedures to receive detailed GSEP street segment statements (which may require action by the DPU) and to require City Council GOL review for all non-emergency pipe replacement projects.

Gas leaks are a significant contributor to Newton's greenhouse gas emissions. However, "leak-prone" pipe replacement dominates current GSEP expenses, and this pipe replacement has been ineffective in reducing existing gas leaks. Leak repair is less expensive and more

effective for reducing leaks than pipe replacement. In coordination with National Grid, Newton should now prioritize repairing gas leaks as quickly as possible. To achieve this goal while minimizing ratepayer costs, the state needs to completely overhaul the GSEP program and align its priorities with the climate goal of eliminating gas by 2050.

Detailed Highlights

- \$27,071,209 was charged to GSEP for work in Newton in 2025.
- All of the eliminated leak extent (a measure of environmental harm attributable to a Grade 3 leak, the least hazardous class) was treated by lower-cost leak repair and not by pipe replacement.
- Repair of large leaks is far more cost-effective than pipe replacement at eliminating leaks in gas pipe.
- Over 75% of the total length of pipes installed and then charged to GSEP was not preceded by a Grant of Location approved by Newton's City Council
- Pipe replacement cost was \$759 per ft or \$4,004,903 per mile, a significant increase from \$658 per foot in 2024, and is becoming increasingly untenable in comparison to the cost-effectiveness of electrification and other non-pipeline alternatives.
- Some new leaks appeared on lengths of pipe (or the service lines connected to them) after the pipe had been replaced under GSEP.
- In the past year, measured gas leak extent has dramatically increased, which reverses the encouraging trend from the previous five years.

Introduction

The Newton Gas Pipes non-governmental volunteer team compiles publicly available data about the Newton gas distribution system operated by National Grid. We are working with public records of Gas System Enhancement Program (GSEP) plans, end-of-year accounting reports (GREC), end-of-year Service Quality reports (SQARs), and quarterly gas leak reports filed with the Mass. Department of Public Utilities (DPU), in addition to street surveys and other data from Newton public records.

The pipe replacement program requires National Grid to evaluate leak-prone pipe segments to prioritize replacing pipes that are at significant risk of developing high-impact leaks that could be explosive. It requires National Grid to repair the dangerous leaks, and permits accelerated cost recovery for replacing leak-prone pipes, with an allowance of accelerated cost recovery for pipes whose replacement can be coordinated with other public works jobs.

The Massachusetts legislature established GSEP in 2014 to increase the safety and reliability of the gas distribution system. This plan was made in the context of an aging system of pipes that would be used for the foreseeable future. GSEP provided a framework for classifying and repairing hazardous leaks, replacing leak-prone pipes, and expanding the gas infrastructure to replace what were considered more polluting energy sources.

However, even “non-hazardous” leaks pose health risks and can contribute significantly to greenhouse gas emissions and additional costs to consumers. To address the leak problem, the legislature in 2017 added the repair of high-volume methane leaks to the scope of GSEP. These leaks are classified as “non-hazardous” but still have a Significant Environmental Impact (SEI).

Massachusetts law and the DPU have defined various gas leak grades. Grade 1 leaks are hazardous and must be repaired immediately. Grade 2 leaks are non-hazardous, but could become hazardous in the near future and must be repaired within a year. Grade 3 leaks are non-hazardous and are expected to remain non-hazardous. Under the 2017 framework, Grade 3 leaks initially designated after January 1, 2018 are required to be repaired or eliminated within eight years. Grade 3 SEI leaks are those larger than 2,000 square feet, as measured by the leak extent method, and are required to be repaired within 1-3 years.

We are investigating the degree to which GSEP work is in the interest of the City and its resident gas ratepayers.

Methodology

Data for this investigation were compiled from National Grid’s filings submitted to the DPU. Most of these filings were downloaded from the DPU’s web-based “file room.”

Each October National Grid files GSEP plans for the coming year together with less-detailed GSEP plans (“lookaheads”¹) for the following four years. We focused on the 2025 GSEP plan. However, allowing for the possibility that a previous GSEP installation may have been delayed, we searched all GSEP plans back to 2019. Allowing for an unexpected acceleration of a GSEP installation, we also searched GSEP “lookaheads” covering the period 2020 through 2030. We compiled GSEP plans for 2019 through 2026 into a single table, which is linked as [Table L1](#). We compiled lookahead plans for 2020 to 2023, 2021 to 2024, 2022 to 2025, 2023 to 2026, 2024 to 2027, 2025 to 2028, 2026 to 2029 and 2027 to 2030 in linked [Table L2](#).

The cost data is sourced from various exhibits for the DPU’s CY 2025 GSEP reconciling mechanism which can be downloaded from the DPU file room (Docket 26-GREC-03). National Grid filed its Reconciliation “GREC” report for the 2025 GSEP expenses on May 1, 2025.

We obtained gas leak data from two largely overlapping sources: the NG Service Quality (SQ) Report for calendar year 2025, dated February 27, 2026 under DPU docket 26-SQ-05, and detailed leak reports produced for the DPU on a quarterly basis which can be obtained by public records request. The SQ report lists all reported leaks and identifies which ones were eliminated during the year, a summary of the quarterly snapshots. The quarterly reports provide

¹ Our use of the word “lookahead” refers to NGrid’s reports that anticipate pipe replacements four years out from the following calendar year, a total of five years, in compliance with regulations in 220 CMR 114.

a more complete chronology, allowing corroboration of leak conditions with dates of pipe replacement etc., but omit National Grid's assessments of both whether a given leak can be dealt with through a planned replacement, and whether or not the leak is G3SEI.

Regarding leak repair, GSEP provides incentivized cost recovery for the repair of Grade 3 Significant Environmental Impact (G3SEI) leaks in addition to supporting pipe replacement. We compiled and analyzed the GSEP plans for such repairs in 2025, as well as the actual 2025 costs in the GREC filing.

We extracted Newton data from National Grid GSEP and leak reports, analyzed the 2025 GREC filings to determine what kind of work in Newton the 2025 costs actually funded, and determined how Newton gas leaks were eliminated in 2025.

Results: GSEP cost summary for Newton in 2025

Table 1 below summarizes GSEP costs in Newton as reported in the National Grid GREC filing for 2025. GSEP reimburses both main replacements and service lines to individual buildings, in addition to leak repair. Note that this table does not include the expense of repairing grade 3 non-SEI (smaller) leaks, since such repair costs are not reimbursed through GSEP and are not reported. National Grid has stated that the annual repair cost for Grade 1, Grade 2, and smaller, non-SEI Grade 3 leaks, which are not reported in GSEP, is substantially greater than the annual cost to repair SEI Grade 3 leaks.

Table 1 2025 GSEP costs in Newton

GSEP costs for repairing large leaks	\$108,805.	\$0.4%
GSEP costs for pipe replacements	\$22,911,385	84.6%
CISBOT ²	\$2,015,671	7.4%
Lining ³	\$0	0.0%
GSEP costs for in-service projects ⁴	\$2,029,282	7.5%
GSEP costs for service replacements ⁵	\$6,066	.0.0%
Total	\$27,071,209	100%

² CISBOT is a robotic method of repairing a gas pipe without full excavation

³ Certain pipes can receive a protective lining which strengthens the pipe against leakage, obviating replacement. Such work was done in Newton as recently as 2022.

⁴ In-service projects are work on new replacement gas pipes that had been installed in recent years.

⁵ Service replacements connect the main in the street to the customer's building.

Results: Pipe replacement

Analysis of 2025 GSEP pipe replacement costs as displayed in the GREC filing

We separated the costs reported in the 2025 GREC into the following five categories of projects, displayed in Table 2.

- A. Projects that were anticipated in the GSEP plans for 2025.
- B. Projects that appeared in any other year's GSEPs or lookaheads.⁶
- C. Projects that did not appear in GSEP plans and were attributed to "encroachment" or water intrusion.
- D. Projects that did not appear in GSEP plans that were attributed to a leak in an abutment wall for a bridge. (Note – in 2021 lookahead there was a plan for a liner, not new Coated Steel main).
- E. Projects that were not in GSEP plans and were accomplished in accordance with Newton DPW coordination.

Table 2: 2025 GSEP pipe replacement costs compared to plans

Category	Number of projects	GSEP cost
A.	7	\$14,442,968
B.	6	\$3,948,739
C.	6	\$985,421
D.	1	\$3,505,720
E.	1	\$28,536
Total	21	\$22,911,384

Table 3 below consolidates results from Table 2.

⁶ Category B includes two projects that are attributed to "encroachment" and one public works project. None of these projects have a prioritization assessment (see [Table L3](#)).

Table 3 Consolidated analysis of 2025 GSEP pipe replacement costs

Description	GSEP cost	Pct.
All projects in a GSEP plan or lookahead (A plus B)	\$18,391,707	80.3%
Projects that were not in GSEP plans but addressed encroachment from other utilities or work on bridges(C plus D)	\$4,491,141	19.6%
Projects not in GSEP plans or lookaheads that were completed in coordination with Newton Public Works. (E)	\$28,536	0.1%
Total	\$22,911,384	100.0%

Unlike previous years when Public Works projects were a substantial part of the overall pipe replacement work, in 2025 very little pipe replacement work was done that was not in GSEP plans or in response to encroachment from other utility work.

Pipe replacement projects charged to GSEP in 2025 are shown in the linked [Table L3](#). The table lists each pipe replacement project. If the project appeared in a prior GSEP plan, the previous plan is also noted in the table.

We found that most of Newton’s GSEP work in 2025 was not preceded by a City Council vote for a Grant of Location (GOL). According to state law, a GOL must be approved by the city before any excavation of public roads. However, only 24% of the GSEP pipe length in 2025 was approved with a GOL, as shown in Table 4 below. At Newton’s Public Facilities Committee meeting on December 4, 2024, National Grid stated that it follows a “two-foot rule” that exempts the need for GOL approval. Newton Gas Pipes Team has yet to see written documentation of the rule; the Newton City Council has opened Docket #218-26 this year to look into changing it.

Table 4 Grants of Location preceding GSEP work

	Number of projects	Length of pipeline installed (ft.)	Pct. of length
Projects that had a GOL	5	7,205	24%
Projects that did not have a GOL	16	23,001	76%
Total	21	30,206	100%

Table 5 Cost effectiveness of GSEP leak elimination methods

	Number of leaks	Cost	Leak extent sf	Cost per leak
Large Leak Repair G3SEI	14	\$108,805	58,933	\$7,772
Pipe Replacement G3SEI	0	\$0.0	0	NA

GREC reported an expense of \$108,805 over the year to repair 14 G3SEI leaks with a combined extent of 58,933 sq. ft. according to the latest measurements reported in 2025. Because no G3SEI leaks were eliminated in 2025 by pipe replacement, we cannot compare the relative cost. In 2024, pipe replacement costs to eliminate were about 200 times the cost of pipe repair. Generally speaking, GSEP expenditures to reduce leak extent by leak repair are much more cost-effective than expenditures by pipe replacement.

Through pipe replacement, in 2025, GSEP did not address any G3SEI leaks. In other filings, National Grid reported that four non-G3SEI leaks were “eliminated by replacement” but the work was not part of GSEP and costs were not reported. (see Table 6), A more detailed review of all active leaks at the GSEP replacement sites just before each project started also revealed that these replacements did not lead to any elimination of leaks. (see [Table L4](#)). (There were only 5 distinct ongoing leaks at the time the projects were started, one Grade 2 leak and 4 non-SEI Grade 3 leaks. Three of them were reported to be eliminated by leak repair, and two are still pending.)

There were 17 Grade 1 leaks, two Grade 2 leaks, and four Grade 3 leaks that were first reported during the replacement period, which indicates that these pipes were in a fragile state. One of these leaks is a Grade 3 SEI leak which is still pending. At least nine leaks occurred after the replacements were completed, including two Grade 3 SEI leaks. These new leaks were all in the portions of the road where the work was done or very close to them. The new leaks could be in the service lines or other pipes at those locations. We conclude that replacing or repairing pipes does not prevent all new leaks, which illustrates the fragility of the whole gas distribution system.

Results - Leaks in Newton during 2025

We analyzed the National Grid Service Quality Report to collect information about how all Newton leaks were treated in 2025 regardless of whether the cost appeared in GSEP or outside of GSEP. Our analysis found the following:

- Total reported leaks as of Jan 1, 2025: 376 leaks comprising 266,103 sq. ft. leak extent [Table L5](#)
 - 3 Grade 1 leaks
 - 15 Grade 2 leaks

- 358 Grade 3 leaks comprising 266,103 sq. ft. leak extent⁷
- Total reported leaks as of Jan 1, 2026: 394 leaks comprising 441,434 sq. ft. leak extent
[Table L6](#)
 - 1 Grade 1 leak
 - 17 Grade 2 leaks
 - 376 Grade 3 leaks comprising 441,434 sq. ft. leak extent
- A total of 451 leaks were eliminated during 2025, including 158 Grade 3 leaks comprising 149,300 sq. ft. of leak extent.
- 76% of the eliminated leak extent for Grade 3 leaks was accomplished by leak repair. 0% of the eliminated leak extent for Grade 3 leaks was reported as accomplished by pipe replacement. The remainder, 24% of the eliminated leak extent, resulted from a variety of circumstances, including leaks that ceased to be observable, duplicate leak accounting, or other factors.
- Service Quality Reports showed that 476 new leaks were recorded during 2025. According to the quarterly reports, there were $469 = 394 + 451 - 376$ new leaks. The small discrepancy between 476 and 469 of 7 leaks is due to incomplete reporting in the National Grid quarterly leak reports.
 - 150 new Grade 1 leaks
 - 119 new Grade 2 leaks
 - 207 new Grade 3 leaks

This is a significant increase compared to 2024, when there were only 68 new Grade 2 leaks and 80 new Grade 3 leaks.

- 26 leaks that were non-hazardous in January 2025 were “upgraded” to a higher risk category during the year; only one leak was downgraded.
- 24 new leaks appeared on or near GSEP work during the pipe installation period. This indicates that pipe replacement projects initiated the observation of many new leaks or caused them to begin leaking.

[Table L7](#) lists all the leaks that were eliminated in 2025 along with the explanation for their elimination.

[Table L8](#) lists leaks that were eliminated by leak repair without being upgraded to a more hazardous category.

[Table L9](#) lists leaks eliminated by pipe replacement (GSEP and non-GSEP)

⁷ Combines information from SQ and quarterly leak reports

[Table L10](#) lists leaks “eliminated otherwise”, such as by being upgraded first, by repair of a nearby leak, or by some circumstance other than repair

[Table L11](#) aggregates National Grid’s statement of how leaks were “Eliminated Otherwise”

Table 6 aggregates how leaks were eliminated, according to National Grid categories.

Table 6 Leak Elimination in 2025

How eliminated	Count (All grades)	Count (Grade 3)	Leak extent sq. ft. (Grade 3)	% leak extent
Simple repair	372	114	110,200	74%
Pipe replacement	4	3	0	0%
Eliminated by the leak repair of other leaks or after being upgraded	6	3	3,070	2%
Eliminated by circumstances other than leak repair or pipe replacement	69	38	36,030	24%
Total	451	158	149,3000	100%

Much of the large leak extent that was eliminated by “circumstances other than leak repair or pipe replacement” in 2025 was explained by National Grid as correcting a recorded duplicate leak.

Results - Leak History in Newton starting 2020

Table 7 (next page) summarizes the status of reported gas leaks in Newton at the end of each quarter starting in 2020.

Table 7 Newton Reported Leak History since January 1, 2020

National Grid Report Date	Number of unrepaired leaks	Total leak extent of unrepaired leaks	Percentage reduction in total leak extent from previous quarter
03/31/2020	856	793,062	
06/30/2020	765	648,712	18%
09/30/2020	733	554,243	15%
12/31/2020	714	520,851	6%
03/31/2021	691	568,224	-9%
06/30/2021	678	567,029	0%
09/30/2021	672	565,074	0%
12/31/2021	639	601,857	-7%
03/31/2022	622	548,597	9%
06/30/2022	639	582,140	-6%
09/30/2022	619	529,339	9%
12/31/2022	588	477,736	10%
03/31/2023	573	364,170	24%
06/30/2023	566	328,240	10%
09/30/2023	545	319,140	3%
12/31/2023	507	287,317	10%
03/31/2024	496	286,502	0%
06/30/2024	505	311,616	-9%
09/30/2024	438	301,974	3%
12/31/2024	373	266,103	12%
03/31/2025	366	234,611	12%
06/30/2025	372	198,776	15%
09/30/2025	404	388,632	-96%
12/31/2025	394	441,434	-14%
03/31/2026	380	434,157	2%
06/30/2026	381	354,257	18%

Alarming, in the past year, gas leak impact in Newton has greatly increased. The leak extent has roughly doubled since June 30, 2025. In Newton, out of 381 total unrepaired leaks as of June 30, 2026, there were 125 unrepaired leaks which at any time in their history qualified as SEI. The sum of leak extent of these leaks is 247,791 sq. ft. which is 70% of the total leak extent in Newton (354,257 sq. ft.).

Although the number of leaks has not varied much in the past year, more new leaks appeared than in past years, and National Grid apparently increased the rate of repair.

Since 2020, National Grid has successfully reduced the number of leaks and leak extent in Newton, but the recent year has been a failure. National Grid now needs to prioritize eliminating leaks, especially SEI leaks, and through repair instead of generic replacement projects. Newton has a valuable opportunity to review its coordination with National Grid to do a better job of eliminating large leaks.

Conclusions and Recommendations

National Grid's pattern of expenses for replacing pipes and repairing leaks in 2025 was similar to previous years.

Gas leak repair is much more cost-effective for reducing gas leaks in the short term than replacing leak-prone pipes. Gas pipe work in Newton should heavily prioritize leak repair and pipe retirement; complete pipe replacement is an expensive choice and should be avoided wherever possible.

To achieve more input into and control over pipe replacement, and to foster non-fossil alternatives, Newton should alter its procedures to receive detailed GSEP street segment statements long before work begins (which may require action by the DPU) and to require City Council GOL review for all non-emergency pipe replacement projects. Newton should eliminate the "two-foot rule".

Newton prioritizes the immediate reduction and repair of gas leaks. National Grid needs to repair the most significant leaks as quickly as possible, because leaking methane is a significant local source of greenhouse gases. The plans and results for leak repair in Newton should be published quarterly for accountability.

Newton should formally urge State officials to eliminate or overhaul GSEP in support of Newton's Climate Action Plan goal of eliminating fossil gas emissions.

The original GSEP law envisioned the indefinite operation of the gas system. However, Newton and Massachusetts have climate goals that will require retirement of the gas distribution system. If GSEP is overhauled, it needs to provide a better balance among public safety, infrastructure cost, and speedy retirement of the gas system. If the GSEP program continues in its current

form, it should provide incentives to accelerate the retirement of the residential gas infrastructure. One way or another, GSEP should no longer serve as a broad excuse for the gas network to persist in spite of its damage to the environment.

Appreciations

Thank you to others on the Newton pipes team, including, in particular, Josh Nichols-Barrer.

APPENDIX

List of Tables

Num	Title	Page
1	GSEP costs in Newton 2025	4
2	2025 GSEP pipe replacement costs compared to plans	5
3	Consolidated aggregation of 2025 GSEP pipe replacement costs	6
4	Grant of Locations preceding GSEP work	6
5	Cost-effectiveness of leak elimination methods	7
6	Leak Elimination in 2025	9
7	Newton Leak History since January 1, 2020	10
	Linked Tables	
L1	GSEP plans in Newton for the Years 2019 through 2026	
L2	GSEP Lookahead plans for the Years 2020 through 2030	
L3	Pipe replacement projects charged to GSEP in 2025	
L4	Leaks at 2025 Pipe Replacement Sites	
L5	Reported leaks as of Dec. 31, 2024	
L6	Reported leaks as of Dec. 31, 2025	
L7	All leaks eliminated in 2025	
L8	Leaks eliminated by repair in 2025	
L9	Leaks eliminated by pipe replacement	
L10	Leaks “eliminated otherwise” detail	
L11	Aggregation of Leaks Eliminated Otherwise	

Appendix: Guide to GSEP program abbreviations for pipe replacement

Quoted from NGrid filing D.P.U. 26-GREC-03, Exhibit NG-GPP-1, May 1, 2026, Page 8

“There are fourteen types of programs included: (1) “BSMNRPL,” which indicates a bare steel main replacement project; (2) “CIMNRPL<10,” which is a cast iron main replacement project with pipe diameter less than 10 inches; (3) “CIRE101214,” which is a cast iron main replacement project with pipe diameter greater than 8” but less than or equal to 14”; (4) “ENCRCHMTPL,” which is a parallel main encroachment; (5) “PWNONREIM,” which is a public works non-reimbursable project; (6) “ENCRCHMTUM,” which is a main encroachment due to undermining of the existing facility; (7) “H2OINT,” a program that addresses recurring customer outages resulting from water intrusion into low-pressure distribution systems through the replacement of existing LPP; (8) “REANONLEAK,” a program used to replace main that, based on conditions found in the field, is immediately prioritized for replacement regardless of leak history; (9) “ALDYRPL,” a program to replace pre-1985 vintage Aldyl-A plastic pipe; (10) “GPLNG,” which are system reliability main replacements, (11) “BRIDGES”; (12) “CISBOTPRO”, which are proactive CISBOT projects; (13) “CIMNLINING” which are the large diameter pipe lining projects; and (14) “CISBOTREA” which are the reactive CISBOT projects.”

The following expanded definitions are quoted from DPU 26-GREC-03, Exhibit DPU-1-1, July 13, 2026⁸.

“Program Name	Definition	Prioritization
ENCRCHMTPL	Cast-iron pipes that are encroached due to a parallel excavation occurring adjacent to the gas facility	Reactive projects triggered by third party excavations and safety concerns rather than annual proactive risk- ranking This work is prioritized based on required replacement as stated in 220 CMR 113.

⁸ Responding to DPU information request 1-1 on June 29, 2026.

PWNONREIM	Pipe replacement in conjunction with municipal projects such as water, sewer, drain, and roadway restoration projects	Reactive municipal coordination projects, not part of the proactive risk- ranked project list because the timing in which projects are identified. This work is identified in the Company's GSEP plan filing (D.P.U. 24-GSEP-03, Exhibit NG-GPP-2, at 25).
ENCHRCHMTUM	Cast Iron Pipes that are encroached due to an undermine from a trench crossing excavation	Reactive projects triggered by third party excavations and safety concerns rather than annual proactive risk-ranking. This work is prioritized based on required replacement as stated in 220 CMR 113.
H2OINT	Projects targeted at addressing a problem with water intrusion into the gas distribution system	Generally prioritized on a reactive basis and identified based on customer loss of gas service. Projects approved under the H2OINT program are meant to solve problems with the loss of reliable customer service

Encroachment projects involve the exposure of enough cast iron pipe to increase the risk of failure based on the third-party excavation area and proximity to the cast iron main. Replacement of encroachment cast iron pipe is required per 220 CMR 113.

H2OINT projects are generally prioritized on a reactive basis and identified based on customer loss of gas service. Projects approved under the H2OINT program are meant to solve problems with the loss of reliable customer service.”

END

Table L1 Newton GSEP pipe replacement plans 2019 to 2026

Year	Work order number	Street address	Old pipe size (in)	GSEP footage (ft)	Cost estimate	Prioritization Factor	NPA Opportunity	Project Driver
2019	1210486	3-105 CENTRAL AV, NEW, & 15-87 PRESCOTT ST	8	4,500	\$1,712,259			
2019	1196349	5-124 MCCARTHY RD, NEW, 5-65 INDIAN RIDGE RD	8	6,620	\$2,187,841			
2020	1118346	9 - 85 CUMMINGS RD and 15 - 92 NORTH ST CTR	4	2,365	\$908,802			
2020	1196349	5 - 124 MCCARTHY RD and 5 - 65 INDIAN RIDGE RD	8	6,595	\$1,980,850			
2021	1312616	63 - 74 BOWEN ST	4	280	\$136,727			
2021	1350709	1063 - 1125 COMMONWEALTH AVE, LOWELL AVE from COMMONWEALTH AVE to WHITTIER RD and WHITTIER RD	8	1,975	\$1,110,625			
2021	1350723	374 - 430 HOMER ST and 1095 - 1125 COMMONWEALTH AVE	12	1,775	\$1,023,397			
2022	1199164	17 - 117 MOULTON ST and 1 - 15 COLGATE CIR	6	2,425	\$1,009,605			
2022	1325241	21 - 203 LAKE AVE CTR and LAKE TER	5	2,700	\$1,185,717			
2022	1343154	14 - 63 BOWDOIN ST and 60 - 93 FOREST ST	3	1,290	\$633,506			
2022	1384498	616 - 692 BOYLSTON ST and 5 - 16 WALNUT HILL RD	6	1,250	\$587,398			
2022	1384741	308 - 374 HOMER ST and WALNUT ST and HOMER ST	12	725	\$787,348			
2022	1395791	7 - 93 HANCOCK ST and 32 - 94 WOODLAND RD	3	2,045	\$899,139			
2022	1400142	388 - 450 LEXINGTON ST and 2060 - 2111 COMMONWEALTH AVE	12	2,105	\$2,128,966			
2023	1350723	374 - 430 HOMER ST and 1095 - 1125 COMMONWEALTH AVE	12	1,945	\$1,058,970			
2023	1400142	388 - 450 LEXINGTON ST and 2060 - 2111 COMMONWEALTH AVE	12	2,105	\$2,095,991			
2023	1421227	7 - 80 WADE ST	6	1,020	\$605,472			
2023	1421288	18 - 109 AUBURN ST and CURVE ST	12	1,355	\$916,102			
2023	1421438	1046 - 1267 CENTRE ST, PELHAM ST and LANGLEY RD from CENTRE ST to PELHAM ST	10	5,750	\$4,777,446			
2023	1457999	595 - 687 WATERTOWN ST	6	4,530	\$2,617,402			
2023	1458805	1549 - 1649 BEACON ST	12	4,140	\$3,576,325			
2024	1342783	15 - 56 MOODY ST and 250 HAMMOND POND PKWY	4	780	\$617,324			
2024	1421288	18 - 109 AUBURN ST and CURVE ST	12	1,355	\$1,020,896			
2024	1421438	1046 - 1267 CENTRE ST, PELHAM ST and LANGLEY RD from CENTRE ST to PELHAM ST	10	5,750	\$6,070,659			
2024	1441118	1080 - 1136 WALNUT ST and COLUMBUS ST	12	4,185	\$3,285,027			
2024	1444162	3 - 144 ELLIOT ST	10	2,315	\$1,616,987			
2024	1458805	1549 - 1649 BEACON ST	12	4,140	\$4,651,865			
2024	1463413	141 - 258 LINWOOD AVE	6	3,890	\$2,749,745			
2024	1476454	10 - 114 HILLSIDE AVE	6	1,045	\$705,700			
2024	1505036	1 - 109 ESSEX RD	6	3,465	\$2,011,358			
2025	1505036	1-109 ESSEX RD, NEW	6	3,465	\$2,204,601	27.5	Yes - Potential NPA, partial scope	
2025	1429616	1-113 GROVE ST, NEW	8	3,055	\$2,008,433	26.8	Yes - Potential NPA, partial scope	
2025	1554563	1-134 HANSON RD, NEW	4	3,900	\$2,629,098	24.1	Yes - Potential NPA, partial scope	
2025	1463413	141-258 LINWOOD AV, NEW	6	3,890	\$2,877,528	34.9	No - Impact to System Integration	
2025	1458805	1549-1649 BEACON ST, NEW	12	4,140	\$5,154,733	31.5	No - Impact to System Integration	
2025	1588181	1-85 CRESCENT AV, NEW	4	1,270	\$921,297	24.0	No - Impact to System Integration	

Table L1 Newton GSEP pipe replacement plans 2019 to 2026

Year	Work order number	Street address	Old pipe size (in)	GSEP footage (ft)	Cost estimate	Prioritization Factor	NPA Opportunity	Project Driver
2025	1384741	308-374 HOMER ST, NEW, & WALNUT ST	12	725	\$1,098,622	26.5	No - Impact to System Integration	
2025	1444162	3-144 ELLIOT ST, NEW	10	2,400	\$1,765,586	29.0	No - Impact to System Integration	
2025	1578640	574-687 GROVE ST, NEW, COLGATE RD & HAGAR ST	4	2,000	\$1,263,590	18.6	Yes - Potential NPA, partial scope	
2025	1384498	616-692 BOYLSTON ST, NEW, & 5-16 WALNUT HILL RD	6	1,250	\$789,362	32.8	No - Impact to System Integration	
2025	1426947	885-1055 CENTRE ST, NEW, WARD ST & NATHAN RD	12	4,655	\$4,608,350	13.7	No - Impact to System Integration	
2026	1421127	902-1038 BEACON ST, NEW	8	1,705	\$2,597,093	29.8	Yes - Potential NPA	Failed Hydraulic Testing
2026	1444162	48-144 ELLIOT ST, NEW	10	1,855	\$2,237,966	32.5	Yes - Potential NPA	Failed Hydraulic Testing
2026	1463413	141-258 LINWOOD AV, NEW	6	1,695	\$1,210,755	40.4	Yes - Potential NPA	Failed Hydraulic Testing
2026	9020129	107-230 WOODWARD ST, NEW & 73-93 CARVER RD	8	2,050	\$1,677,622	33.0	Yes - Potential NPA	Failed Hydraulic Testing
2026	13297486	700-757 CHESTNUT ST, NEW	8	920	\$664,805	38.5	Yes - Potential NPA	Failed Hydraulic Testing
2026	14215288	1-62 OAKWOOD RD, NEW, & VIRGINIA RD	4	880	\$731,068	28.4	Yes - Potential NPA	Cost Prohibitive
2026	15082759	167-367 ALBEMARLE RD, NEW	12	2,310	\$3,405,365	35.5	No-Critical main	Critical Main

Table L2 Newton GSEP plans					
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028, 2026-2029, and 2027-2030					
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity	Project Driver
2020 - 2023	BACON ST	3	378		
2020 - 2023	631-731 BEACON ST, NEW, & 11-15 COUSENS CIR	4	1,625		
2020 - 2023	BELLEVUE RD	3	254		
2020 - 2023	BELLEVUE ST	3	492		
2020 - 2023	BOWERS ST	3	617		
2020 - 2023	BOYD ST	3	214		
2020 - 2023	347-407 CENTRAL ST, NEW	6	730		
2020 - 2023	CHASE ST	3	876		
2020 - 2023	CHERRY ST	3	51		
2020 - 2023	CHESLEY AV	3	185		
2020 - 2023	CHESTER ST	3	405		
2020 - 2023	COLUMBUS ST	3	613		
2020 - 2023	COPLEY ST	3	482		
2020 - 2023	COURT ST	3	95		
2020 - 2023	CRESCENT AV	3	712		
2020 - 2023	CRYSTAL ST	3	344		
2020 - 2023	DUNCKLEE ST	3	255		
2020 - 2023	EDINBORO CIR	3	131		
2020 - 2023	ERIE AV	3	219		
2020 - 2023	FAIR OAKS AV	3	661		
2020 - 2023	FAIRMONT AV	3	571		
2020 - 2023	FOREST AV	3	95		
2020 - 2023	FOREST ST	3	795		
2020 - 2023	GRASMERE ST	3	204		
2020 - 2023	GREENWOOD AV	3	124		
2020 - 2023	141-192 GROVE ST, NEW, & MYRTLE AV	8	1,000		
2020 - 2023	HANCOCK ST	3	745		
2020 - 2023	HIGHLAND AV	3	435		
2020 - 2023	HIGHLAND PK	3	248		
2020 - 2023	HILLSIDE RD	3	31		
2020 - 2023	HOLLIS ST	3	257		
2020 - 2023	HUNTER ST	3	276		
2020 - 2023	HYDE ST	3	132		
2020 - 2023	4-49 JASSET ST, NEW	4	610		
2020 - 2023	JEWETT ST	3	229		
2020 - 2023	79-143 LANGDON ST, NEW, & 4-35 LAUDHOLM RD	4	2,065		
2020 - 2023	LENOX ST	3	631		
2020 - 2023	LOWELL AV	3	955		
2020 - 2023	LYMAN ST	3	340		
2020 - 2023	MELROSE ST	3	340		
2020 - 2023	MORELAND AV	3	225		
2020 - 2023	17-117 MOULTON ST, NEW, & 1-15 COLGATE CIR	6	1,930		
2020 - 2023	OLD ROGERS ST	3	275		
2020 - 2023	PAUL ST	3	508		
2020 - 2023	PEARL ST	3	369		
2020 - 2023	PERKINS ST	3	83		
2020 - 2023	PLEASANT ST	3	86		
2020 - 2023	PRESCOTT ST	3	275		
2020 - 2023	PROSPECT ST	3	818		
2020 - 2023	PUTNAM ST	3	697		
2020 - 2023	9-34 RICKER RD, NEW, & 11-20 RICKER TER	6	630		
2020 - 2023	RIVER ST	3	82		
2020 - 2023	42-51 ROCKLAND ST, NEW	8	245		
2020 - 2023	RUSSELL CT	3	310		
2020 - 2023	SHAW ST	3	457		
2020 - 2023	STANDISH ST	3	345		
2020 - 2023	STERLING ST	3	152		
2020 - 2023	SUMNER ST	3	419		
2020 - 2023	TEMPLE ST	3	184		
2020 - 2023	UNDERWOOD AV	3	234		
2020 - 2023	WABAN PK	3	1,140		
2020 - 2023	WABAN ST	3	873		

Table L2 Newton GSEP plans					
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028, 2026-2029, and 2027-2030					
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity	Project Driver
2020 - 2023	WALKER ST	3	576		
2020 - 2023	WALNUT PK	3	1,217		
2020 - 2023	406-506 WALNUT ST, NEW	12	1,440		
2020 - 2023	WASHINGTON PK	3	911		
2020 - 2023	WEBSTER CT	3	25		
2020 - 2023	WILLARD ST	3	186		
2020 - 2023	112-284 WINCHESTER ST, NEW	12	2,990		
2020 - 2023	WISWALL ST	3	215		
2020 - 2023	WOODBINE ST	3	508		
2021 - 2024	2-66 ALEXANDER RD, NEW, & 67-142 WATCH HILL RD	5	1,965		
2021 - 2024	BACON ST	3	378		
2021 - 2024	631-731 BEACON ST, NEW, & 11-15 COUSENS CIR	4	1,625		
2021 - 2024	BELLEVUE RD	3	254		
2021 - 2024	BELLEVUE ST	3	492		
2021 - 2024	BOWERS ST	3	617		
2021 - 2024	BOYD ST	3	214		
2021 - 2024	347-407 CENTRAL ST, NEW	6	730		
2021 - 2024	CHASE ST	3	876		
2021 - 2024	CHERRY ST	3	51		
2021 - 2024	CHESLEY AV	3	185		
2021 - 2024	CHESTER ST	3	405		
2021 - 2024	COLUMBUS ST	3	613		
2021 - 2024	COPLEY ST	3	482		
2021 - 2024	COURT ST	3	95		
2021 - 2024	CRESCENT AV	3	712		
2021 - 2024	CRYSTAL ST	3	344		
2021 - 2024	DUNCKLEE ST	3	255		
2021 - 2024	EDINBORO CIR	3	131		
2021 - 2024	ERIE AV	3	219		
2021 - 2024	FAIR OAKS AV	3	661		
2021 - 2024	FAIRMONT AV	3	571		
2021 - 2024	FOREST AV	3	95		
2021 - 2024	FOREST ST	3	795		
2021 - 2024	GRASMERE ST	3	204		
2021 - 2024	GREENWOOD AV	3	124		
2021 - 2024	HANCOCK ST	3	745		
2021 - 2024	HIGHLAND AV	3	435		
2021 - 2024	HIGHLAND PK	3	248		
2021 - 2024	HILLSIDE RD	3	31		
2021 - 2024	HOLLIS ST	3	257		
2021 - 2024	HUNTER ST	3	276		
2021 - 2024	HYDE ST	3	132		
2021 - 2024	4-49 JASSET ST, NEW	4	610		
2021 - 2024	JEWETT ST	3	229		
2021 - 2024	79-143 LANGDON ST, NEW, & 4-35 LAUDHOLM RD	4	2,065		
2021 - 2024	LENOX ST	3	631		
2021 - 2024	LOWELL AV	3	955		
2021 - 2024	LYMAN ST	3	340		
2021 - 2024	MELROSE ST	3	340		
2021 - 2024	MORELAND AV	3	225		
2021 - 2024	17-117 MOULTON ST, NEW, & 1-15 COLGATE CIR	6	1,930		
2021 - 2024	OLD ROGERS ST	3	275		
2021 - 2024	PAUL ST	3	508		
2021 - 2024	PEARL ST	3	369		
2021 - 2024	PERKINS ST	3	83		
2021 - 2024	PLEASANT ST	3	86		
2021 - 2024	PRESCOTT ST	3	275		
2021 - 2024	PROSPECT ST	3	818		
2021 - 2024	PUTNAM ST	3	697		
2021 - 2024	9-34 RICKER RD, NEW, & 11-20 RICKER TER	6	630		
2021 - 2024	RIVER ST	3	82		
2021 - 2024	42-51 ROCKLAND ST, NEW	8	245		

Table L2 Newton GSEP plans					
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028, 2026-2029, and 2027-2030					
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity	Project Driver
2021 - 2024	RUSSELL CT	3	310		
2021 - 2024	SHAW ST	3	457		
2021 - 2024	STANDISH ST	3	345		
2021 - 2024	STERLING ST	3	152		
2021 - 2024	SUMNER ST	3	419		
2021 - 2024	TEMPLE ST	3	184		
2021 - 2024	UNDERWOOD AV	3	234		
2021 - 2024	WABAN PK	3	1,140		
2021 - 2024	WABAN ST	3	873		
2021 - 2024	WALKER ST	3	576		
2021 - 2024	WALNUT PK	3	1,217		
2021 - 2024	406-506 WALNUT ST, NEW	12	1,440		
2021 - 2024	WASHINGTON PK	3	911		
2021 - 2024	337-647 WASHINGTON ST, NEW	10	3,300		
2021 - 2024	WEBSTER CT	3	25		
2021 - 2024	WILLARD ST	3	186		
2021 - 2024	112-284 WINCHESTER ST, NEW	12	2,990		
2021 - 2024	WISWALL ST	3	215		
2021 - 2024	WOODBINE ST	3	508		
2022 - 2025	ALDEN ST	4	288		
2022 - 2025	2 - 66 ALEXANDER RD and 67 - 142 WALNUT HILL RD	5	1,965		
2022 - 2025	9 - 28 ARDMORE RD and 7 - 14 ARDMORE TER	4	630		
2022 - 2025	631 - 731 BEACON ST and 11 - 15 COUSENS CIR	4	1,625		
2022 - 2025	14 - 63 BOWDOIN ST and 60 - 93 FOREST ST	3	1,290		
2022 - 2025	491 - 565 BOYLSTON ST, DUXBURY RD and LANTERN LN	4	3,635		
2022 - 2025	11 - 56 CARLETON ST	4	820		
2022 - 2025	347 - 407 CENTRAL ST	6	730		
2022 - 2025	12 - 74 COTTAGE ST, COLUMBIA AVE NUF and CHAMPA ST	4	1,675		
2022 - 2025	9 - 85 CUMMINGS RD and 15 - 92 NORTH ST CTR	4	2,325		
2022 - 2025	14 - 100 ERIE AVE, BOWDOIN ST and HARTFORD ST	4	2,580		
2022 - 2025	33 - 59 GAY ST, FREDERICK ST, HARVARD ST and HARVARD CIR	6	2,895		
2022 - 2025	141 - 192 GROVE ST and MYRTLE AVE	8	1,000		
2022 - 2025	48 - 139 HIGH ST NUF, SUMMER ST and ROCKLAND PL	4	2,485		
2022 - 2025	4 - 49 JASSET ST	4	610		
2022 - 2025	21 - 203 LAKE AVE CTR and LAKE TER	5	2,725		
2022 - 2025	79 - 143 LANGDON ST and 4 - 35 LAUDHOLM RD	4	2,065		
2022 - 2025	256 - 360 LOWELL AVE and 88 - 120 OTIS ST	12	1,875		
2022 - 2025	75 - 171 LOWELL AVE	3	1,535		
2022 - 2025	15 - 56 MOODY ST and 250 HAMMOND POND PKWY	4	780		
2022 - 2025	17 - 117 MOULTON ST and 1 - 15 COLGATE CIR	6	1,930		
2022 - 2025	5 - 90 OLDE FIELD RD, HAGEN RD, PHILBRICK RD and SHELDON RD	2	4,190		
2022 - 2025	9 - 34 RICKER RD and 11 - 20 RICKER TER	6	630		
2022 - 2025	42 - 51 ROCKLAND ST HGH	8	245		
2022 - 2025	337 - 647 WASHINGTON ST	10	3,300		
2022 - 2025	821 - 1251 WASHINGTON ST, DUNSTAN ST, KEMPTON PL and ARMORY ST	10	6,685		
2022 - 2025	112 - 284 WINCHESTER ST	12	2,990		
2023 - 2026	2 - 66 ALEXANDER RD and 67 - 142 WALNUT HILL RD	5	1,965		
2023 - 2026	9 - 28 ARDMORE RD and 7 - 14 ARDMORE TER	4	630		
2023 - 2026	2 - 112 ATHELSTANE RD	6	3,770		
2023 - 2026	150 - 257 AUBURN ST and CENTRAL ST and AUBURN ST	8	2,370		
2023 - 2026	18 - 109 AUBURN ST and CURVE ST	4	1,365		
2023 - 2026	112 - 205 AUBURNDALE AVE	6	3,490		
2023 - 2026	2 - 112 AUBURNDALE AVE, RYAN CT and REBECCA RD	6	1,710		
2023 - 2026	248 - 355 AUBURNDALE AVE	6	3,490		
2023 - 2026	1038 - 1150 BEACON ST	10	2,085		
2023 - 2026	825 - 1013 BEACON ST and LAUREL ST	8	3,365		
2023 - 2026	992 - 1050 BEACON ST, ALBION PL and NEWBURY TER	6	2,275		
2023 - 2026	491 - 565 BOYLSTON ST, DUXBURY RD and LANTERN LN	4	3,635		
2023 - 2026	1 - 73 CANTERBURY RD	8	2,400		
2023 - 2026	11 - 56 CARLETON ST	4	820		

Table L2 Newton GSEP plans					
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028, 2026-2029, and 2027-2030					
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity	Project Driver
2023 - 2026	347 - 407 CENTRAL ST	6	730		
2023 - 2026	1404 - 1542 CENTRE ST	10	3,095		
2023 - 2026	430 - 497 CENTRE ST and MOUNT IDA ST	10	3,150		
2023 - 2026	930 - 1055 CENTRE ST	10	3,570		
2023 - 2026	1 - 22 CHAMBERLAIN RD	6	3,490		
2023 - 2026	32 - 160 CHERRY ST	6	3,020		
2023 - 2026	1 - 68 COLLEGE RD	12	3,445		
2023 - 2026	1063 - 1125 COMMONWEALTH AVE, LOWELL AVE from COMMONWEALTH AVE to WHITTIER RD and WHITTIER RD	8	1,975		
2023 - 2026	12 - 74 COTTAGE ST, THURSTON RD and CHAMPA ST	4	3,205		
2023 - 2026	9 - 85 CUMMINGS RD and 15 - 92 NORTH ST CTR	4	2,325		
2023 - 2026	9 - 305 CYPRESS ST	6	3,855		
2023 - 2026	8 - 160 DAY ST	6	3,910		
2023 - 2026	1 - 120 DEVONSHIRE RD	6	3,670		
2023 - 2026	14 - 100 ERIE AVE, BOWDOIN ST and HARTFORD ST	4	2,580		
2023 - 2026	108 - 229 FULLER ST WAB	10	3,780		
2023 - 2026	242 - 326 FULLER ST WAB	10	3,790		
2023 - 2026	32 - 114 GREENLAWN AVE	6	1,770		
2023 - 2026	1 - 125 GROVE ST	8	3,085		
2023 - 2026	141 - 192 GROVE ST and MYRTLE AVE	8	1,000		
2023 - 2026	240 - 450 HAMMOND ST, RESERVOIR AVE and WOODMAN RD	8	2,990		
2023 - 2026	48 - 139 HIGH ST NUF, SUMMER ST and ROCKLAND PL	4	2,485		
2023 - 2026	50 - 180 HIGHLAND ST	6	3,185		
2023 - 2026	230 - 308 HOMER ST and GARLAND RD	8	2,000		
2023 - 2026	374 - 430 HOMER ST and 1095 - 1125 COMMONWEALTH AVE	12	1,775		
2023 - 2026	6 - 150 ISLINGTON RD	6	2,210		
2023 - 2026	4 - 49 JASSET ST	4	610		
2023 - 2026	79 - 143 LANGDON ST and 4 - 35 LAUDHOLM RD	4	2,065		
2023 - 2026	256 - 360 LOWELL AVE and 88 - 120 OTIS ST	12	1,895		
2023 - 2026	75 - 171 LOWELL AVE	3	1,535		
2023 - 2026	15 - 56 MOODY ST and 250 HAMMOND POND PKWY	4	780		
2023 - 2026	158 - 255 NEWTONVILLE AVE	8	2,780		
2023 - 2026	97 - 200 OAK ST	12	2,160		
2023 - 2026	5 - 90 OLDE FIELD RD, HAGEN RD, PHILBRICK RD and SHELDON RD	2	4,190		
2023 - 2026	1 - 35 OWATONNA ST and KAPOsia ST	6	3,515		
2023 - 2026	3 - 76 PARK LN, TARLETON RD and CHAPIN RD	6	4,325		
2023 - 2026	1 - 75 PELHAM ST and LANGLEY RD and PELHAM ST	10	2,295		
2023 - 2026	17 - 78 PLAINFIELD ST and UPLAND RD WAB	6	1,620		
2023 - 2026	4 - 118 PRINCE ST	4	3,880		
2023 - 2026	110 - 128 PROSPECT ST and 5 - 39 TENNYSON RD	3	940		
2023 - 2026	225 - 293 RIVER ST	8	3,520		
2023 - 2026	42 - 51 ROCKLAND ST HGH	8	245		
2023 - 2026	1 - 98 ROWENA RD	8	3,475		
2023 - 2026	4 - 52 SHAW ST	6	3,300		
2023 - 2026	10 - 203 SPIERS RD, ANTONELLIS CIR and J ROADWAY	8	5,800		
2023 - 2026	5 - 90 SUFFOLK RD	8	1,395		
2023 - 2026	4 - 50 SUMNER ST	4	2,145		
2023 - 2026	34 - 64 WABAN AVE	8	2,660		
2023 - 2026	7 - 80 WADE ST	6	1,020		
2023 - 2026	406 - 506 WALNUT ST	12	1,440		
2023 - 2026	337 - 647 WASHINGTON ST	10	3,300		
2023 - 2026	821 - 1251 WASHINGTON ST, DUNSTAN ST, KEMPTON PL and ARMORY ST	10	6,685		
2023 - 2026	229 - 429 WATERTOWN ST	6	2,910		
2023 - 2026	112 - 284 WINCHESTER ST	12	2,990		
2023 - 2026	7 - 154 WOODCHESTER DR	8	3,110		
2023 - 2026	107 - 230 WOODWARD ST and MAYFLOWER TER	8	3,515		
2024 - 2027	2 - 66 ALEXANDER RD and 67 - 142 WALNUT HILL RD	5	1,965		
2024 - 2027	112 - 205 AUBURNDALe AVE	6	4,010		
2024 - 2027	2 - 112 AUBURNDALe AVE, RYAN CT and REBECCA RD	6	1,710		
2024 - 2027	248 - 355 AUBURNDALe AVE	6	3,490		
2024 - 2027	1038 - 1150 BEACON ST	10	2,085		

Table L2 Newton GSEP plans					
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028, 2026-2029, and 2027-2030					
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity	Project Driver
2024 - 2027	1665 - 1791 BEACON ST	12	3,410		
2024 - 2027	7 - 61 BRUSH HILL RD	6	3,550		
2024 - 2027	1 - 73 CANTERBURY RD	8	2,400		
2024 - 2027	11 - 56 CARLETON ST	4	820		
2024 - 2027	347 - 407 CENTRAL ST	6	730		
2024 - 2027	1404 - 1542 CENTRE ST	10	4,445		
2024 - 2027	430 - 497 CENTRE ST and MOUNT IDA ST	6	2,770		
2024 - 2027	885 - 1055 CENTRE ST, WARD ST and CENTRE ST and NATHAN RD	12	4,245		
2024 - 2027	1 - 22 CHAMBERLAIN RD	6	3,490		
2024 - 2027	1 - 68 COLLEGE RD	12	3,445		
2024 - 2027	9 - 305 CYPRESS ST	6	2,955		
2024 - 2027	8 - 160 DAY ST	6	3,910		
2024 - 2027	1 - 120 DEVONSHIRE RD	6	3,670		
2024 - 2027	1 - 71 DUNCKLEE ST	6	1,265		
2024 - 2027	144 - 251 ELLIOT ST and MECHANIC ST	12	4,185		
2024 - 2027	3 - 144 ELLIOT ST	10	2,315		
2024 - 2027	14 - 100 ERIE AVE, BOWDOIN ST and HARTFORD ST	4	2,580		
2024 - 2027	108 - 229 FULLER ST WAB	10	3,780		
2024 - 2027	242 - 326 FULLER ST WAB	10	3,770		
2024 - 2027	32 - 114 GREENLAWN AVE	6	1,770		
2024 - 2027	240 - 450 HAMMOND ST, RESERVOIR AVE and WOODMAN RD	8	3,000		
2024 - 2027	50 - 180 HIGHLAND ST	6	3,185		
2024 - 2027	10 - 114 HILLSIDE AVE	6	1,045		
2024 - 2027	230 - 308 HOMER ST and GARLAND RD	8	2,000		
2024 - 2027	308 - 374 HOMER ST and WALNUT ST and HOMER ST	12	725		
2024 - 2027	4 - 49 JASSET ST	4	610		
2024 - 2027	79 - 143 LANGDON ST and 4 - 35 LAUDHOLM RD	4	2,065		
2024 - 2027	1 - 99 LENOX ST	6	3,849		
2024 - 2027	158 - 255 NEWTONVILLE AVE	8	3,640		
2024 - 2027	100 - 200 OAK ST	12	2,160		
2024 - 2027	5 - 90 OLDE FIELD RD, HAGEN RD, PHILBRICK RD and SHELDON RD	2	4,190		
2024 - 2027	3 - 76 PARK LN, TARLETON RD and CHAPIN RD	6	4,325		
2024 - 2027	17 - 78 PLAINFIELD ST and UPLAND RD WAB	6	1,620		
2024 - 2027	1 - 180 PLYMOUTH RD	6	6,240		
2024 - 2027	4 - 118 PRINCE ST	4	4,405		
2024 - 2027	42 - 51 ROCKLAND ST HGH	8	245		
2024 - 2027	1 - 98 ROWENA RD	8	3,900		
2024 - 2027	4 - 52 SHAW ST	6	3,300		
2024 - 2027	10 - 203 SPIERS RD, ANTONELLIS CIR and J ROADWAY	8	5,800		
2024 - 2027	5 - 90 SUFFOLK RD	8	1,395		
2024 - 2027	4 - 50 SUMNER ST	4	2,145		
2024 - 2027	34 - 64 WABAN AVE	8	2,660		
2024 - 2027	1080 - 1136 WALNUT ST and COLUMBUS ST	12	4,185		
2024 - 2027	2251 - 2362 WASHINGTON ST	12	1,770		
2024 - 2027	337 - 647 WASHINGTON ST	10	3,300		
2024 - 2027	229 - 429 WATERTOWN ST	6	3,280		
2024 - 2027	111 - 279 WEBSTER ST	8	2,570		
2024 - 2027	112 - 284 WINCHESTER ST	12	2,990		
2024 - 2027	7 - 154 WOODCHESTER DR	8	3,170		
2024 - 2027	107 - 230 WOODWARD ST and MAYFLOWER TER	8	3,515		
2025 - 2028	2 - 112 ATHELSTANE RD	6	2,530		
2025 - 2028	150 - 257 AUBURN ST and CENTRAL ST and AUBURN ST	8	2,370		
2025 - 2028	2 - 112 AUBURNDALE AVE, RYAN CT and REBECCA RD	6	1,710		
2025 - 2028	1038 - 1150 BEACON ST	10	2,200		
2025 - 2028	1665 - 1791 BEACON ST	12	3,410		
2025 - 2028	805 - 991 BEACON ST and LAUREL ST	8	3,465		
2025 - 2028	96 - 342 BEACON ST	12	3,015		
2025 - 2028	992 - 1050 BEACON ST	8	2,175		
2025 - 2028	616 - 692 BOYLSTON ST and 5 - 16 WALNUT HILL RD	6	1,250		
2025 - 2028	8 - 150 CEDAR ST	8	3,500		
2025 - 2028	430 - 497 CENTRE ST and MOUNT IDA ST	6	2,770		

Table L2 Newton GSEP plans**Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028, 2026-2029, and 2027-2030**

Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity	Project Driver
2025 - 2028	885 - 1055 CENTRE ST, WARD ST and CENTRE ST and NATHAN RD	12	4,245		
2025 - 2028	32 - 160 CHERRY ST	6	3,450		
2025 - 2028	50 - 275 CONCORD ST	6	3,915		
2025 - 2028	23 - 88 ELINOR RD	6	1,380		
2025 - 2028	144 - 251 ELLIOT ST and MECHANIC ST	12	4,255		
2025 - 2028	1 - 113 GROVE ST	8	3,055		
2025 - 2028	240 - 450 HAMMOND ST, RESERVOIR AVE and WOODMAN RD	8	3,000		
2025 - 2028	1 - 134 HANSON RD	4	3,900		
2025 - 2028	308 - 374 HOMER ST and WALNUT ST and HOMER ST	12	725		
2025 - 2028	100 - 200 OAK ST	12	2,160		
2025 - 2028	5 - 100 OLDE FIELD RD, HAGEN RD, PHILBRICK RD and SHELDON RD	4	4,280		
2025 - 2028	3 - 76 PARK LN, TARLETON RD and CHAPIN RD	6	4,325		
2025 - 2028	1 - 124 PARKER AVE	8	3,925		
2025 - 2028	225 - 293 RIVER ST	8	3,770		
2025 - 2028	85 - 240 VALENTINE ST	8	2,480		
2025 - 2028	1136 - 1208 WALNUT ST and HYDE ST	10	3,340		
2025 - 2028	1750 - 1940 WASHINGTON ST and SETON HILL RD	10	4,815		
2025 - 2028	2251 - 2362 WASHINGTON ST	12	1,770		
2025 - 2028	821 - 1251 WASHINGTON ST, DUNSTAN ST, KEMPTON PL and ARMORY ST	10	6,685		
2025 - 2028	229 - 429 WATERTOWN ST	6	3,280		
2025 - 2028	107 - 230 WOODWARD ST and MAYFLOWER TER	8	3,515		
2026 - 2029	9-305 CYPRESS ST, NEW	6	2,955	No - Critical Main	
2026 - 2029	96-342 BEACON ST, NEW	12	3,015	No - Critical Main	
2026 - 2029	1038-1150 BEACON ST, NEW	10	2,200	No - Impact to System Integration	
2026 - 2029	1046-1267 CENTRE ST, NEW, PELHAM ST, LANGLEY RD	10	5,750	No - Impact to System Integration	
2026 - 2029	1-124 PARKER AV, NEW	8	3,925	No - Impact to System Integration	
2026 - 2029	1-18 BACON ST, NEW	4	380	No - Impact to System Integration	
2026 - 2029	150-257 AUBURN ST, NEW, CENTRAL ST	8	2,370	No - Impact to System Integration	
2026 - 2029	1-67 CHASE ST, NEW	8	2,465	No - Impact to System Integration	
2026 - 2029	2-112 ATHELSTANE RD, NEW	6	2,530	No - Impact to System Integration	
2026 - 2029	2251-2362 WASHINGTON ST, NEW	12	1,770	No - Impact to System Integration	
2026 - 2029	225-293 RIVER ST, NEW	8	3,770	No - Impact to System Integration	
2026 - 2029	229-429 WATERTOWN ST, NEW	6	3,280	No - Impact to System Integration	
2026 - 2029	240-450 HAMMOND ST, NEW, RESERVOIR AV, WOODMAN RD	8	3,000	No - Impact to System Integration	
2026 - 2029	406-506 WALNUT ST, NEW	12	1,450	No - Impact to System Integration	
2026 - 2029	4-100 OAK ST, NEW	12	4,810	No - Impact to System Integration	
2026 - 2029	50-275 CONCORD ST, NEW	6	3,915	No - Impact to System Integration	
2026 - 2029	504-528 BOYLSTON ST, NEW	3	1,010	No - Impact to System Integration	
2026 - 2029	8-150 CEDAR ST, NEW	8	3,500	No - Impact to System Integration	
2026 - 2029	900-991 BEACON ST, NEW	8	2,500	No - Impact to System Integration	
2026 - 2029	107-230 WOODWARD ST, NEW, MAYFLOWER TERR	8	3,515	Yes - Potential NPA	
2026 - 2029	1080-1136 WALNUT ST, NEW, COLUMBUS ST	12	4,185	Yes - Potential NPA	
2026 - 2029	1-35 OWATONNA ST, NEW, KAPOZIA ST	6	3,515	Yes - Potential NPA	
2026 - 2029	1-73 CANTERBURY RD, NEW	8	3,310	Yes - Potential NPA	
2026 - 2029	26-188 CHERRY ST, NEW	8	3,800	Yes - Potential NPA	
2026 - 2029	4-248 WINDSOR RD, NEW	8	4,045	Yes - Potential NPA	
2026 - 2029	11-56 CARLETON ST, NEW	4	820	Yes - Potential NPA, entire scope	
2026 - 2029	15-56 MOODY ST, NEW, & 250 HAMMOND POND PKWY	4	780	Yes - Potential NPA, entire scope	
2026 - 2029	100-200 OAK ST, NEW	12	2,160	Yes - Potential NPA, partial scope	
2026 - 2029	112-284 WINCHESTER ST, NEW	12	2,990	Yes - Potential NPA, partial scope	
2026 - 2029	1136-1208 WALNUT ST, NEW, HYDE ST	10	3,255	Yes - Potential NPA, partial scope	
2026 - 2029	144-251 ELLIOT ST, NEW, MECHANIC ST	12	4,255	Yes - Potential NPA, partial scope	
2026 - 2029	158-255 NEWTONVILLE AV, NEW	8	3,640	Yes - Potential NPA, partial scope	
2026 - 2029	1750-1940 WASHINGTON ST, NEW, SETON HILL RD	10	4,815	Yes - Potential NPA, partial scope	
2026 - 2029	1958-2150 WASHINGTON ST, NEW	10	5,000	Yes - Potential NPA, partial scope	
2026 - 2029	347-407 CENTRAL ST, NEW	6	730	Yes - Potential NPA, partial scope	
2026 - 2029	3-76 PARK LN, NEW, TARLETON RD, CHAPIN RD	6	4,325	Yes - Potential NPA, partial scope	
2026 - 2029	430-497 CENTRE ST, NEW, MT IDA ST	6	4,070	Yes - Potential NPA, partial scope	
2026 - 2029	5-100 OLDE FIELD RD, NEW, HAGEN,PHILBRICK,SHELDON	4	4,280	Yes - Potential NPA, partial scope	

Table L2 Newton GSEP plans					
Lookahead Years 2020-2023, 2021-2024, 2022-2025, 2023-2026, 2024-2027, 2025-2028, 2026-2029, and 2027-2030					
Years	Street address	Old pipe size (in)	GSEP footage (ft)	NPA opportunity	Project Driver
2026 - 2029	821-1251 WASHINGTON ST, NEW, DUNSTAN,KEMPTON,ARMOR	10	6,685	Yes - Potential NPA, partial scope	
2026 - 2029	92-157 LANGLEY RD, NEW	8	1,275	Yes - Potential NPA, partial scope	
2027 - 2030	100-200 OAK ST, NEW	12	2,160		
2027 - 2030	1038-1150 BEACON ST, NEW	10	2,220		
2027 - 2030	1046-1267 CENTRE ST, NEW, PELHAM ST, LANGLEY RD	10	5,750		
2027 - 2030	1080-1136 WALNUT ST, NEW, COLUMBUS ST	12	4,185		
2027 - 2030	111-279 WEBSTER ST, NEW	8	2,570		
2027 - 2030	1-113 GROVE ST, NEW	8	3,055		
2027 - 2030	112-284 WINCHESTER ST, NEW	12	2,990		
2027 - 2030	1-124 PARKER AV, NEW	8	3,925		
2027 - 2030	1136-1208 WALNUT ST, NEW	10	1,320		
2027 - 2030	11-56 CARLETON ST, NEW	4	820		
2027 - 2030	1-180 PLYMOUTH RD, NEW	6	6,240		
2027 - 2030	1-56 CHAPIN RD NEW & STAFFORD RD	6	2,015		
2027 - 2030	1-66 SOLON ST, NEW	6	800		
2027 - 2030	1-67 CHASE ST, NEW	8	2,465		
2027 - 2030	1750-1940 WASHINGTON ST, NEW, SETON HILL RD	10	4,815		
2027 - 2030	1958-2150 WASHINGTON ST, NEW	10	5,000		
2027 - 2030	200-291 DERBY ST, NEW	6	3,115		
2027 - 2030	2-112 ATHELSTANE RD, NEW	6	2,530		
2027 - 2030	221-294 DORSET RD, NEW, BONAIRE CIR & LORRAINE CIR	8	1,260		
2027 - 2030	2251-2362 WASHINGTON ST, NEW	12	1,770		
2027 - 2030	225-293 RIVER ST, NEW	8	3,770		
2027 - 2030	229-344 WATERTOWN ST, NEW	6	2,565	Yes - Potential NPA	Failed Hydraulic Testing
2027 - 2030	240-450 HAMMOND ST, NEW, RESERVOIR AV, WOODMAN RD	8	3,000		
2027 - 2030	26-188 CHERRY ST, NEW	8	3,800		
2027 - 2030	337-647 WASHINGTON ST, NEW	10	3,300	No - Critical Main	Critical Main
2027 - 2030	347-407 CENTRAL ST, NEW	6	730		
2027 - 2030	3-76 PARK LN, NEW, CHARLOTTE RD	6	3,395		
2027 - 2030	4-248 WINDSOR RD, NEW	8	4,045		
2027 - 2030	42-51 ROCKLAND ST, NEW	8	245	Yes - Potential NPA	Failed Hydraulic Testing
2027 - 2030	50-275 CONCORD ST, NEW	6	3,915		
2027 - 2030	5-152 GORDON RD, NEW	8	2,535		
2027 - 2030	740-890 WALNUT ST, NEW	12	3,155		
2027 - 2030	8-150 CEDAR ST, NEW	8	3,500		
2027 - 2030	821-1251 WASHINGTON ST, NEW, DUNSTAN,KEMPTON,ARMOR	10	6,395		
2027 - 2030	848-889 BEACON ST, NEW	4	745		
2027 - 2030	92-157 LANGLEY RD, NEW	8	1,275		
2027 - 2030	9-305 CYPRESS ST, NEW	6	2,955		
2027 - 2030	96-342 BEACON ST, NEW	12	3,015	No - Critical Main	Critical Main

Table L3 Pipe replacement projects charged to GSEP in 2025

Work Order	"DESCRIPTION"	Included in Plan List	Actual Project Cost through 12/31/2025	Prioritization Factor	Status as of 12/31/2025	Program ID	Project Approval Date	Project Start Date	Project Completion Date	2025 Project Costs Included in GSEP Filing	Earliest GSEP plan	Latest GSEP plan	Report Category (A-E)	Newton GOL docket	Actual installed footage
1298776	425 - Centre St	ADDED	\$3,524,570		WO# 1298776 added to CY25 plan to address moderate to heavy corrosion at both abutment walls that was causing an active leak at the south abutment wall. The leaking main was replaced with a new 12-inch coated steel main	BRIDGES	04/18/2024	06/03/2024	03/04/2025	\$3,505,720	2021 lookahead (liner, not new CS main)	2021 lookahead (liner, not new CS main)	D	#250-24	465
1384498	616-692 BOYLSTON ST, NEW, & 5-16 WALNUT HILL RD	YES	\$1,289,926	32.8	Completed project in CY25 as planned	CIMNRPL<10	09/12/2023	01/13/2025	08/27/2025	\$1,232,667	2022 plan	2025 plan	A	none	1223
1426947	885-1055 CENTRE ST, NEW, WARD ST & NATHAN RD	YES	\$5,965,291	13.7	Completed project in CY25 as planned	CIRE101214	03/21/2024	05/19/2024	07/30/2025	\$5,891,533	2022 lookahead	2025 plan	A	none	4238
1444170	144 - 251 Elliot St Mechanic St	ADDED	\$3,205,088	37.7	WO#1444170 omitted from CY25 proactive GSEP filing with project completion originally anticipated within CY24.	CIRE101214	01/02/2024	09/30/2024	10/31/2025	\$2,554,585	2023 lookahead	2025 lookahead	B	none	4776
1458805	1549-1649 BEACON ST, NEW	YES	\$2,105,296	31.5	Completed project in CY25 as planned	CIRE101214	08/21/2023	09/26/2024	12/16/2025	\$1,456,563	2023 plan	2025 plan	A	none	4020
1470154	44 - Woodland Rd	ADDED	\$595,465		WO# 1470154 added to CY25 plan to address heavy corrosion at the north abutment of the bridge. It was abandoned and removed from the bridge structure.	BRIDGES	03/24/2025	10/08/2025	12/10/2025	\$595,465	2022 plan (wo #1395791)	2022 plan (wo #1395791)	B	#276-22	0
1505036	1-109 ESSEX RD, NEW	YES	\$1,991,232	27.5	Completed project in CY25 as planned	CIMNRPL<10	04/23/2024	05/12/2025	12/19/2025	\$1,934,882	2024 plan	2025 plan	A	#321-23	4418
1554563	1-134 HANSON RD, NEW	YES	\$2,408,379	24.1	Completed project in CY25 as planned	BSMNRPL	11/06/2023	10/02/2024	06/29/2025	\$2,393,966	2024 lookahead	2025 plan	A		3913
1578640	574-687 GROVE ST, NEW, COLGATE RD & HAGAR ST	YES	\$791,421	18.6	Completed project in CY25 as planned	CIMNRPL<10	04/04/2024	09/04/2025	11/04/2025	\$437,420	2025 plan	2025 plan	A	#199-25	1922
1579076	1 - 200 Allen Av	REACTIVE	\$628,452		WO#1579076 added to the CY25 work plan due to request from Field Ops in reaction to service interruption caused by water intrusion to low pressure (LP) system. Added to CY25 work plan based on deferral of CY25 proactive filing planned projects in the Waltham division under WO#s 1429118 (ARL), 1429088 (ARL), 1343767 (ARL), 1506674 (BEL), 1429616 (NEW), 1384741 (NEW), 1567947 (WAL), 764475 (WAT).	H2OINT	07/17/2025	07/28/2025	10/09/2025	\$374,705			C	none	1595
1588181	1-85 CRESCENT AV, NEW	YES	\$1,102,619	24.0	Completed project in CY25 as planned	CIMNRPL<10	06/03/2024	04/22/2025	07/30/2025	\$1,095,938	2020 lookahead	2025 plan	A	none	1365
1600970	1 - 18 Bacon St	ADDED	\$320,491	30.3	WO#1600970 omitted from CY25 work plan as filed based on need for MWRA permit. Project added to schedule when special permit received.	CIMNRPL<10	05/01/2025	09/17/2025	11/13/2025	\$320,178	2020 lookahead	2025 lookahead	B	#198-25	400
1617036	Dunstan St	CSC	\$157,303		Completed PW - Encroachment - Sewer	ENCRCHMTPL	12/05/2024	01/08/2025	01/30/2025	\$157,303	2021 lookahead	2025 lookahead	B	none	276
1617075	440 - Newtonville Ave	CSC	\$318,810		Completed PW - Encroachment - Sewer	ENCRCHMTUM	12/11/2024	02/25/2025	03/29/2025	\$318,810			C	none	391
1618003	12 - 24 Manemet Rd	CSC	\$181,455		Completed PW - Encroachment - Water	ENCRCHMTUM	12/20/2024	03/05/2025	03/21/2025	\$181,455			C	none	286
1618989	79 - Alban Rd	CSC	\$40,251		Completed PW - Encroachment - Sewer	ENCRCHMTPL	12/30/2024	02/24/2025	02/26/2025	\$40,251			C	none	58

Table L3 Pipe replacement projects charged to GSEP in 2025

Work Order	"DESCRIPTION"	Included in Plan List	Actual Project Cost through 12/31/2025	Prioritization Factor	Status as of 12/31/2025	Program ID	Project Approval Date	Project Start Date	Project Completion Date	2025 Project Costs Included in GSEP Filing	Earliest GSEP plan	Latest GSEP plan	Report Category (A-E)	Newton GOL docket	Actual installed footage
1623700	105 - Adams Av	CSC	\$29,167		Completed PW - Encroachment - Sewer	ENCRCHMTUM	03/06/2025	03/27/2025	03/29/2025	\$29,167			C	none	50
1627840	10 - Crescent St	CSC	\$41,035		Completed PW - Encroachment - Sewer	ENCRCHMTPL	04/24/2025	06/05/2025	06/07/2025	\$41,035			C	none	54
1630829	219 - 242 Melrose St	CSC	\$263,771		Completed PW - Encroachment - Water	ENCRCHMTUM	05/22/2025	07/28/2025	09/24/2025	\$256,392	2020 lookahead	2020 lookahead	B	none	270
1631936	Crystal St	CSC	\$65,951		Completed PW - Third Party Trenching - Drain	PWNONREIM	06/12/2025	07/15/2025	07/27/2025	\$64,817	2020 lookahead	2021 lookahead (likely WO #1325241)	B	none	81
15030879	48-668 GRAFTON ST, NEW	CSC	\$30,350		Completed PW - Third Party Trenching - Water	PWNONREIM	11/06/2025	12/04/2025	12/23/2025	\$28,536			E	none	405

Table L4 Leaks at replacement sites

"DESCRIPTION"	Work Order	Leak ID	Grade	Leak Extent at time of repair (sq. ft.)	Historical Maximum Leak Extent	Program ID	Leak Classification Date	Leak Repair Date	Project Start Date	Project Completion Date	Leak first recorded before, during, or after Replacement	Elimination Status
425 - Centre St 616-692 BOYLSTON ST, NEW, & 5-16 WALNUT HILL RD	1298776					BRIDGES			06/03/2024	03/04/2025		
	1384498					CIMNRPL<10			01/13/2025	08/27/2025		
622 Boylston St		5361925	3		200		3/14/2026				After replacement	Pending
640 Boylston St		5360591	2				3/9/2026				After replacement	Pending
653 Boylston St		5361303	3		8,400		11/6/2025				After replacement	Pending
616 Boylston St		5314418	1				9/5/2025	9/15/2025			After replacement	Repaired
636 Boylston st		5331961	1				2/25/2026	3/4/2026			After replacement	Repaired
636 Boylston St		5360264	1				3/7/2026	3/16/2026			After replacement	Repaired
5 Walnut Hill Rd		5360612	1				3/9/2026	3/17/2026			After replacement	Repaired
885-1055 CENTRE ST, NEW, WARD ST & NATHAN RD	1426947					CIRE101214			05/19/2024	07/30/2025		
904 Centre St		12006062	2				5/12/2025	6/3/2025			Before replacement	Repaired
933 Centre St		7386559	3				3/12/2024	11/14/2024			Before replacement	Repaired, other leak repair
933 Centre St		7390797	1				11/18/2024	11/18/2024			During replacement	Repaired
949 Centre St		7391643	1				1/15/2025	1/16/2025			During replacement	Repaired
955 Centre St		7391098	1				12/5/2024	12/5/2024			During replacement	Repaired
989 Centre St		7389705	1				9/20/2024	9/20/2024			During replacement	Repaired
1011 Centre St		7390261	1				10/18/2024	10/24/2024			During replacement	Repaired
30 Nathan Rd		7392652	3		25		2/18/2025	5/19/2025			During replacement	Eliminated other: system issue
30 Nathan Rd		12006072	3		1		2/28/2025				During replacement	Pending
494 Ward St		7391282	1				12/24/2024	12/27/2024			During replacement	Repaired
507 Ward St		5302261	1				6/11/2025	6/12/2025			During replacement	Repaired
507 Ward t		7393853	1				5/14/2025	5/14/2025			During replacement	Repaired
144 - 251 Elliot St Mechanic St	1444170					CIRE101214			09/30/2024	10/31/2025		
144 Elliot St		5304932	1				7/1/2025	7/3/2025			During replacement	Repaired
144 Elliot St		5305018	1				7/2/2025	8/7/2025			During replacement	Repaired
192 Elliot ST		5318330	1				9/29/2025	9/30/2025			During replacement	Repaired
248 Elliot St		5333330	1				11/23/2025	11/26/2025			After replacement	Repaired
45 Mechanic St		7391872					1/16/2025	2/23/2025			During replacement	Repaired
45 Mechanic St		7392466	1				2/22/2025	2/24/2025			During replacement	Repaired
21 Cheney St.		7393060	1				3/31/2025	3/31/2025			During replacement	Repaired
Cheney St. and Cheney Ct.		7393120	2				3/30/2025	4/7/2026			During replacement	Repaired, other leak repair
8 Whetherell St		5301294	1				6/4/2025	7/9/2025			During replacement	Repaired
23 Wetherell St		5312456	3		90		8/22/2025	11/4/2025			During replacement	Repaired
1549-1649 BEACON ST, NEW	1458805					CIRE101214			09/26/2024	12/16/2025		
1608 Beacon St		5318412	3		6,500		9/29/2025				During replacement	Pending
44 - Woodland Rd	1470154					BRIDGES			10/08/2025	12/10/2025		

Table L4 Leaks at replacement sites

"DESCRIPTION"	Work Order	Leak ID	Grade	Leak Extent at time of repair (sq. ft.)	Historical Maximum Leak Extent	Program ID	Leak Classification Date	Leak Repair Date	Project Start Date	Project Completion Date	Leak first recorded before, during, or after Replacement	Elimination Status
1-109 ESSEX RD, NEW	1505036					CIMNRPL<10			05/12/2025	12/19/2025		
36 Chestnut Hill Ter		7393859	1				5/14/2025	5/14/2025			During replacement	Repaired
1-134 HANSON RD, NEW	1554563					BSMNRPL			10/02/2024	06/29/2025		
105 Hanson Rd		12002323	3	460	1,850		9/5/2019				Before replacement	Pending
9 T Roadway		12000406	3	275	1,440		8/6/2007	10/6/2025			Before replacement	Repaired after replacement
574-687 GROVE ST, NEW, COLGATE RD & HAGAR ST	1578640					CIMNRPL<10			09/04/2025	11/04/2025		
620 Grove St		12006016	3	300	300		5/2/2025	2/18/2026			Before replacement	Data entry error
620 Grove St		12004380	3	300	1,650		2/21/2024				Before replacement	Pending
1 - 200 Allen Av	1579076					H2OINT			07/28/2025	10/09/2025		
82 Allen Av		5309030	1				7/31/2025	8/1/2025			During replacement	Repaired
98 Allen Av		5319074	1				10/2/2025	10/3/2025			During replacement	Repaired
1-85 CRESCENT AV, NEW	1588181					CIMNRPL<10			04/22/2025	07/30/2025		
1 - 18 Bacon St	1600970					CIMNRPL<10			09/17/2025	11/13/2025		
Dunstan St	1617036					ENCRCHMTPL			01/08/2025	01/30/2025		
440 - Newtonville Ave	1617075					ENCRCHMTUM			02/25/2025	03/29/2025		
12 - 24 Manemet Rd	1618003					ENCRCHMTUM			03/05/2025	03/21/2025		
79 - Alban Rd	1618989					ENCRCHMTPL			02/24/2025	02/26/2025		
76 Alban Rd		5313511	3		4,224		8/29/2025				After replacement	Pending
105 - Adams Av	1623700					ENCRCHMTUM			03/27/2025	03/29/2025		
10 - Crescent St	1627840					ENCRCHMTPL			06/05/2025	06/07/2025		
219 - 242 Melrose St	1630829					ENCRCHMTUM			07/28/2025	09/24/2025		
Crystal St	1631936					PWNONREIM			07/15/2025	07/27/2025		
48-668 GRAFTON ST, NEW	1503087					PWNONREIM			12/04/2025	12/23/2025		

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024				Name of Operator: <i>Boston & Colonial Gas Company</i>			
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5866391	HAMMOND ST & COLLEGE RD	3	12/14/2015	8/6/2024	Carried Forward	Eliminated Otherwise		12/5/2023	25,000	Leak Extent	NO READS
7382271	2322 WASHINGTON ST	3	6/20/2023	10/28/2024	Carried Forward	Repaired		4/23/2024	14,400	Leak Extent	
7377815	2096 WASHINGTON ST	3	8/13/2022	11/7/2024	Carried Forward	Repaired		4/25/2024	12,600	Leak Extent	
7325996	1 NONANTUM ST	3	5/10/2016		Carried Forward	Pending		5/6/2024	12,000	Leak Extent	
7374844	1974 WASHINGTON ST	3	4/27/2022	2/20/2024	Carried Forward	Repaired		12/19/2023	11,016	Leak Extent	
7375162	33 OAK HILL ST	3	5/19/2022		Carried Forward	Pending		10/11/2024	8,000	Leak Extent	
1065939	53 CHARLESBANK RD	3	8/30/2012	1/20/2024	Carried Forward	Eliminated Otherwise		8/31/2023	7,500	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7387162	546 PARKER ST	3	4/10/2024		Newly Identified	Pending		11/20/2024	6,600	Leak Extent	
7383506	CALIFORNIA ST & BRIDGE ST	3	8/30/2023		Carried Forward	Pending		6/26/2024	6,400	Leak Extent	
7391375	1802 BEACON ST	3	12/22/2024		Newly Identified	Pending		12/22/2024	5,610	Leak Extent	
7382337	264 WINCHESTER ST	3	6/9/2023		Carried Forward	Pending		4/23/2024	5,500	Leak Extent	
7353121	95 PINE GROVE AVE	3	5/8/2019		Carried Forward	Pending		8/28/2024	5,075	Leak Extent	
6592025	142 GORDON RD	3	9/8/2015	3/6/2024	Carried Forward	Repaired		11/7/2023	5,040	Leak Extent	
5620596	832 DEDHAM ST	3	8/27/2015	9/12/2024	Carried Forward	Eliminated Otherwise		12/19/2023	4,550	Leak Extent	NO READS
7387878	103 COLLINS RD	3	5/13/2024	8/15/2024	Newly Identified	Eliminated by Replacement		5/13/2024	4,320	Leak Extent	
278687	HAMMOND ST & MIDDLESEX RD	3	8/8/2005	10/8/2024	Carried Forward	Repaired		8/8/2024	4,200	Leak Extent	
270745	WALNUT ST & BACON RD	3	8/6/2004	10/3/2024	Carried Forward	Repaired		7/29/2024	4,000	Leak Extent	
343469	PARKER ST & BOYLSTON ST	3	11/19/2024		Carried Forward	Pending		11/19/2024	4,000	Leak Extent	
6980988	83 CARVER RD	3	5/28/2019		Carried Forward	Pending		8/5/2024	3,800	Leak Extent	
693516	1 QUINOBEQUIN RD	3	12/15/2011		Carried Forward	Pending		8/20/2024	3,750	Leak Extent	
7383027	26 PARKER ST	3	8/2/2023	8/14/2024	Carried Forward	Repaired		5/21/2024	3,750	Leak Extent	
7355422	1466 COMMONWEALTH AVE	3	7/24/2019	10/1/2024	Carried Forward	Repaired		8/28/2024	3,500	Leak Extent	
337228	DORSET RD & METACOMET RD	3	8/19/2010	7/26/2024	Carried Forward	Repaired		11/16/2023	3,360	Leak Extent	
7324254	70 OAKDALE RD	3	3/27/2016		Carried Forward	Pending		8/14/2024	3,000	Leak Extent	
7335809	1319 CENTRE ST	3	6/23/2017		Carried Forward	Pending		7/29/2024	3,000	Leak Extent	
7365477	8 BACON RD	3	11/9/2020		Carried Forward	Pending		5/6/2024	3,000	Leak Extent	
6722656	69 PRINCE ST	3	9/29/2015		Carried Forward	Pending		8/13/2024	2,750	Leak Extent	
1217681	206 CONCORD ST	3	5/6/2013		Carried Forward	Pending		8/13/2024	2,720	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
316528	64 FULLER ST	3	9/8/2008		Carried Forward	Pending		8/22/2024	2,550	Leak Extent	
839499	220 WOODWARD ST	3	6/29/2016		Carried Forward	Pending		8/20/2024	2,520	Leak Extent	
7378581	HAGAR ST & CONCORD ST	3	11/4/2022		Carried Forward	Pending		6/26/2024	2,500	Leak Extent	
7336365	23 DAVIS ST	3	7/15/2017		Carried Forward	Pending		11/20/2024	2,400	Leak Extent	
7383025	DAVIS ST & HIGHLAND ST	3	7/26/2023		Carried Forward	Pending		5/21/2024	2,400	Leak Extent	
7336297	327 DEDHAM ST	3	7/12/2017		Carried Forward	Pending		9/3/2024	2,310	Leak Extent	
7376816	45 SHERIDAN ST	3	8/18/2022		Carried Forward	Pending		4/25/2024	2,310	Leak Extent	
7354554	81 CHURCH ST	3	7/9/2019		Carried Forward	Pending		8/9/2024	2,280	Leak Extent	
7379847	1818 BEACON ST	3	2/13/2023		Carried Forward	Pending		8/8/2024	2,250	Leak Extent	
1593092	1629 BEACON ST	3	2/19/2014	4/1/2024	Carried Forward	Repaired		12/19/2023	2,200	Leak Extent	
7354553	7 BUSWELL PIKE	3	7/9/2019	12/18/2024	Carried Forward	Repaired		8/9/2024	2,200	Leak Extent	
7382908	100 OLDEFIELD RD	3	7/14/2023		Carried Forward	Pending		5/7/2024	2,200	Leak Extent	
338429	30 ELLIS RD	3	10/13/2010	8/7/2024	Carried Forward	Repaired		11/17/2023	2,132	Leak Extent	
4339243	130 BEACON ST	3	6/4/2015	7/30/2024	Carried Forward	Repaired		12/19/2023	2,016	Leak Extent	
7388306	1119 WALNUT ST	3	6/13/2024		Newly Identified	Pending		6/13/2024	1,968	Leak Extent	
1337093	40 WINDSOR RD	3	8/19/2013		Carried Forward	Pending		8/13/2024	1,950	Leak Extent	
7325718	8 WHITE OAK RD	3	5/10/2016	4/17/2024	Carried Forward	Repaired		3/21/2024	1,914	Leak Extent	
304662	19 FENWICK RD	3	9/12/2007		Carried Forward	Pending		8/27/2024	1,870	Leak Extent	
7388906	212 TEMPLE ST	3	7/24/2024		Newly Identified	Pending		7/24/2024	1,863	Leak Extent	
7376632	227 CHERRY ST	3	8/25/2022		Carried Forward	Pending		5/6/2024	1,850	Leak Extent	
7364130	109 CABOT ST	3	7/15/2020		Carried Forward	Pending		9/23/2024	1,802	Leak Extent	
296483	10 LANGLEY RD	3	12/7/2006		Carried Forward	Pending		7/29/2024	1,800	Leak Extent	
7356438	741 SAWMILL BROOK PKY	3	9/26/2019	8/28/2024	Carried Forward	Repaired		2/16/2024	1,800	Leak Extent	
7371042	305 COMMONWEALTH AVE	3	10/6/2021	2/17/2024	Carried Forward	Repaired		6/23/2023	1,800	Leak Extent	
7381198	899 WALNUT ST	3	11/14/2023		Carried Forward	Pending		8/21/2024	1,800	Leak Extent	
7383501	34 BROOKSIDE AVE	3	8/17/2023		Carried Forward	Pending		5/29/2024	1,800	Leak Extent	
7387351	29 LINDEN ST	3	4/18/2024		Newly Identified	Pending		11/19/2024	1,760	Leak Extent	
294276	64 PUTNAM ST	3	9/25/2006		Carried Forward	Pending		8/5/2024	1,750	Leak Extent	
304766	6 SUMNER ST	3	8/28/2007		Carried Forward	Pending		8/27/2024	1,750	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7325803	640 GROVE ST	3	4/22/2016	10/24/2024	Carried Forward	Eliminated Otherwise		8/20/2024	1,750	Leak Extent	DUPLICATE LEAK
7355556	205 MILL ST	3	8/22/2019		Carried Forward	Pending		9/23/2024	1,750	Leak Extent	
7379909	152 UPLAND RD	3	2/1/2023		Carried Forward	Pending		8/22/2024	1,750	Leak Extent	
7382270	53 HIGH ST	3	6/7/2023		Carried Forward	Pending		4/23/2024	1,675	Leak Extent	
7386489	620 GROVE ST	3	2/21/2024		Newly Identified	Pending		11/6/2024	1,650	Leak Extent	
7353084	3 AUSTIN ST	3	5/15/2019		Carried Forward	Pending		7/29/2024	1,620	Leak Extent	
1230260	62 OLDEFIELD RD	3	5/7/2013		Carried Forward	Pending		8/20/2024	1,600	Leak Extent	
7356372	569 SAWMILL BROOK PKY	3	9/25/2019	10/24/2024	Carried Forward	Eliminated Otherwise		2/16/2024	1,600	Leak Extent	DUPLICATE LEAK
7383029	140 WINDERMERE RD	3	7/24/2023	12/17/2024	Carried Forward	Repaired		11/22/2024	1,600	Leak Extent	
7386827	65 WILDE RD	3	4/1/2024		Newly Identified	Pending		11/20/2024	1,596	Leak Extent	
7354269	62 WALNUT PIKE	3	6/26/2019		Carried Forward	Pending		8/28/2024	1,540	Leak Extent	
7354716	16 KENYON ST	3	7/19/2019		Carried Forward	Pending		8/28/2024	1,536	Leak Extent	
7382267	78 FARLOW RD	3	6/21/2023		Carried Forward	Pending		4/25/2024	1,536	Leak Extent	
3900011	18 ALDEN ST	3	4/24/2015	8/6/2024	Carried Forward	Repaired		11/16/2023	1,530	Leak Extent	
7390654	391 DEDHAM ST	3	10/28/2024		Newly Identified	Pending		10/28/2024	1,505	Leak Extent	
7324469	16 SOMERSET RD	3	4/1/2016		Carried Forward	Pending		8/14/2024	1,500	Leak Extent	
1337088	4 GAY ST	3	8/20/2013		Carried Forward	Pending		9/3/2024	1,488	Leak Extent	
305109	32 WESSEX RD	3	8/28/2007		Carried Forward	Pending		8/13/2024	1,485	Leak Extent	
7376828	216 PLEASANT ST	3	4/3/2022		Carried Forward	Pending		8/28/2024	1,472	Leak Extent	
7335500	35 LLEWELLYN RD	3	6/13/2017		Carried Forward	Pending		8/21/2024	1,440	Leak Extent	
7353088	238 DORSET RD	3	5/6/2019		Carried Forward	Pending		8/14/2024	1,440	Leak Extent	
7379545	105 ANNAWAN RD	3	1/19/2023	12/19/2024	Carried Forward	Repaired		8/20/2024	1,440	Leak Extent	
796835	11 VIRGINIA RD	3	2/6/2012	6/27/2024	Carried Forward	Eliminated Otherwise		12/19/2023	1,426	Leak Extent	NO READS
3869342	212 GRANT AVE	3	4/9/2015		Carried Forward	Pending		8/27/2024	1,410	Leak Extent	
275900	544 QUINOBEQUIN RD	3	6/8/2005	11/12/2024	Carried Forward	Repaired		8/5/2024	1,400	Leak Extent	
7324470	22 PURITAN RD	3	3/30/2016		Carried Forward	Pending		8/14/2024	1,400	Leak Extent	
7327702	111 HOBART RD	3	7/7/2016		Carried Forward	Pending		7/29/2024	1,400	Leak Extent	
7336530	6 SAMOSET RD	3	7/21/2017		Carried Forward	Pending		11/20/2024	1,400	Leak Extent	
7376631	224 ADAMS AVE	3	8/22/2022		Carried Forward	Pending		4/30/2024	1,400	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7354709	20 CLAREMONT ST	3	7/16/2019		Carried Forward	Pending		9/4/2024	1,380	Leak Extent	
7354252	2 KINGSTON RD	3	6/27/2019		Carried Forward	Pending		8/28/2024	1,350	Leak Extent	
7388305	ELLIOT ST & RIVER AVE	3	6/13/2024		Newly Identified	Pending		6/13/2024	1,350	Leak Extent	
7355545	11 ANTONELLIS CIR	3	8/22/2019	12/17/2024	Carried Forward	Repaired		9/27/2024	1,332	Leak Extent	
7379278	280 CENTRAL ST	3	1/9/2023		Carried Forward	Pending		8/5/2024	1,330	Leak Extent	
7379914	750 BOYLSTON ST	3	2/25/2023		Carried Forward	Pending		11/12/2024	1,330	Leak Extent	
7338745	67 OAKCLIFF RD	3	9/27/2017		Carried Forward	Pending		9/27/2024	1,320	Leak Extent	
7354547	443 WOLCOTT ST	3	7/9/2019		Carried Forward	Pending		8/28/2024	1,316	Leak Extent	
6722810	75 GROVE HILL AVE	3	9/29/2015		Carried Forward	Pending		8/13/2024	1,302	Leak Extent	
307752	176 WABAN AVE	3	11/7/2007		Carried Forward	Pending		5/15/2024	1,292	Leak Extent	
7376829	126 EASTBOURNE RD	3	4/12/2022		Carried Forward	Pending		9/27/2024	1,280	Leak Extent	
7355431	1928 COMMONWEALTH AVE	3	8/5/2019		Carried Forward	Pending		9/27/2024	1,276	Leak Extent	
270681	131 COUNTRY CLUB RD	3	8/3/2004		Carried Forward	Pending		9/12/2024	1,260	Leak Extent	
7376774	232 DERBY ST	3	8/24/2022		Carried Forward	Pending		4/30/2024	1,260	Leak Extent	
7354542	190 TEMPLE ST	3	7/11/2019		Carried Forward	Pending		9/3/2024	1,250	Leak Extent	
7367241	46 CEDAR ST	3	3/1/2021	7/1/2024	Carried Forward	Eliminated Otherwise		5/21/2024	1,250	Leak Extent	NO READS
7376321	137 GARLAND RD	3	7/29/2022		Carried Forward	Pending		11/20/2024	1,248	Leak Extent	
7355564	51 SHERBROOKE RD	3	8/21/2019		Carried Forward	Pending		9/23/2024	1,230	Leak Extent	
304745	4 JANET RD	3	8/23/2007		Carried Forward	Pending		9/27/2024	1,216	Leak Extent	
7326621	116 OXFORD RD	3	6/10/2016		Carried Forward	Pending		5/15/2024	1,216	Leak Extent	
7387599	405 WOLCOTT ST	3	4/21/2024		Newly Identified	Pending		11/19/2024	1,209	Leak Extent	
1206963	41 BRUSH HILL RD	3	4/25/2013	12/16/2024	Carried Forward	Repaired		8/13/2024	1,200	Leak Extent	
7326197	145 HIGHLAND ST	3	5/11/2016	9/3/2024	Carried Forward	Repaired		4/25/2024	1,200	Leak Extent	
7336456	12 BERTRAND RD	3	7/18/2017		Carried Forward	Pending		7/29/2024	1,200	Leak Extent	
7337016	214 CONCORD ST	3	8/1/2017		Carried Forward	Pending		9/3/2024	1,200	Leak Extent	
7377631	364 WOODWARD ST	3	9/12/2022		Carried Forward	Pending		5/7/2024	1,200	Leak Extent	
7379906	35 KELVEDEN RD	3	3/1/2023		Carried Forward	Pending		8/9/2024	1,200	Leak Extent	
7383510	43 PHILBRICK RD	3	9/5/2023		Carried Forward	Pending		6/26/2024	1,200	Leak Extent	
7385305	937 DEDHAM ST	3	12/9/2023		Carried Forward	Pending		9/12/2024	1,200	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7355549	200 COTTON ST	3	8/22/2019		Carried Forward	Pending		9/27/2024	1,116	Leak Extent	
3205205	60 HIGHLAND ST	3	3/4/2015		Carried Forward	Pending		9/12/2024	1,104	Leak Extent	
1246024	242 WABAN AVE	3	7/31/2017		Carried Forward	Pending		8/13/2024	1,092	Leak Extent	
303110	40 CENTRAL TER	3	7/3/2007		Carried Forward	Pending		4/30/2024	1,080	Leak Extent	
7336302	42 ANNAWAN RD	3	7/1/2017		Carried Forward	Pending		7/29/2024	1,080	Leak Extent	
7376707	200 DERBY ST	3	8/24/2022		Carried Forward	Pending		4/30/2024	1,080	Leak Extent	
7376812	36 NEWELL RD	3	8/19/2022		Carried Forward	Pending		4/30/2024	1,080	Leak Extent	
7356850	HIGHLAND ST & DAVIS ST	3	10/15/2019		Carried Forward	Pending		11/7/2024	1,073	Leak Extent	
1286057	26 HOLMAN RD	3	6/12/2013		Carried Forward	Pending		8/5/2024	1,050	Leak Extent	
1362684	131 WINDSOR RD	3	9/30/2013		Carried Forward	Pending		9/3/2024	1,050	Leak Extent	
7330111	28 CONSIDINE RD	3	11/3/2016	10/12/2024	Carried Forward	Eliminated Otherwise		9/12/2024	1,050	Leak Extent	NO READS
7379082	9 NARDELL RD	3	1/5/2023		Carried Forward	Pending		8/5/2024	1,050	Leak Extent	
270655	100 SUFFOLK RD	3	8/19/2004		Carried Forward	Pending		11/4/2024	1,000	Leak Extent	
304763	8 LANCASTER RD	3	6/21/2016		Carried Forward	Pending		11/19/2024	1,000	Leak Extent	
5217418	499 WINCHESTER ST	3	6/16/2015	7/1/2024	Carried Forward	Eliminated Otherwise		5/7/2024	1,000	Leak Extent	NO READS
7371044	178 PRINCE ST	3	9/27/2021		Carried Forward	Pending		5/6/2024	1,000	Leak Extent	
7374851	24 LESLIE RD	3	5/11/2022		Carried Forward	Pending		9/30/2024	990	Leak Extent	
7380677	324 WINCHESTER ST	3	2/22/2023		Carried Forward	Pending		8/28/2024	960	Leak Extent	
42522	3 COLUMBUS ST	3	5/21/1993		Carried Forward	Pending		8/9/2024	952	Leak Extent	
307614	499 CRAFTS ST	3	9/4/2007		Carried Forward	Pending		8/8/2024	952	Leak Extent	
7389638	379 HAMMOND ST	3	9/16/2024		Newly Identified	Pending		9/16/2024	952	Leak Extent	
7387164	91 CARL ST	3	4/11/2024		Newly Identified	Pending		11/20/2024	950	Leak Extent	
1363304	321 HAMMOND ST	3	9/9/2013		Carried Forward	Pending		8/27/2024	945	Leak Extent	
854114	712 SAWMILL BROOK PKY	3	4/24/2012		Carried Forward	Pending		8/13/2024	912	Leak Extent	
230386	LANGDON ST & BELLEVUE ST	3	2/26/2002		Carried Forward	Pending		8/7/2024	900	Leak Extent	
270390	PLYMOUTH RD & WOODWARD ST	3	4/27/2004		Carried Forward	Pending		8/7/2024	900	Leak Extent	
1282579	239 WOODLAND RD	3	6/28/2013	8/20/2024	Carried Forward	Repaired		1/11/2024	900	Leak Extent	
7336460	1746 BEACON ST	3	7/19/2017	10/10/2024	Carried Forward	Eliminated by Replacement		11/6/2023	900	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024				Name of Operator: <i>Boston & Colonial Gas Company</i>			
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7345717	85 COMMONWEALTH AVE	3	7/14/2018	8/7/2024	Carried Forward	Repaired		2/21/2024	900	Leak Extent	
7355582	284 WOODWARD ST	3	8/19/2019	8/27/2024	Carried Forward	Repaired		1/11/2024	900	Leak Extent	
7376813	32 NOBLE ST	3	8/24/2022		Carried Forward	Pending		4/30/2024	900	Leak Extent	
7379298	64 PROSPECT AVE	3	1/10/2023		Carried Forward	Pending		8/7/2024	900	Leak Extent	
7379880	31 FOX HILL RD	3	2/18/2023	5/29/2024	Carried Forward	Eliminated by Replacement		11/13/2023	900	Leak Extent	
7383512	5 SHELDON RD	3	8/29/2023	11/27/2024	Carried Forward	Eliminated Otherwise		6/26/2024	900	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7385309	20 GREENLAWN AVE	3	12/20/2023		Carried Forward	Pending		11/12/2024	900	Leak Extent	
6624524	14 SAMOSET RD	3	9/21/2015	6/27/2024	Carried Forward	Eliminated Otherwise		3/20/2024	875	Leak Extent	NO READS
7378467	316 CENTRAL ST	3	5/15/2024		Carried Forward	Pending	2	11/14/2023	875	Leak Extent	
1363546	295 DUDLEY RD	3	9/19/2013		Carried Forward	Pending		9/30/2024	860	Leak Extent	
304862	30 PEARL ST	3	8/14/2007		Carried Forward	Pending		8/9/2024	840	Leak Extent	
7326999	169 FULLER ST	3	6/23/2016		Carried Forward	Pending		5/21/2024	800	Leak Extent	
7378477	LOWELL AVE & WASHINGTON ST	3	12/1/2022		Carried Forward	Pending		7/11/2024	800	Leak Extent	
7379917	1010 BOYLSTON ST	3	2/15/2023		Carried Forward	Pending		9/9/2024	780	Leak Extent	
7361466	109 PRINCE ST	3	6/9/2020		Carried Forward	Pending		8/9/2024	760	Leak Extent	
1363313	110 CEDAR ST	3	9/10/2013		Carried Forward	Pending		9/12/2024	750	Leak Extent	
7353089	65 GROVE ST	3	5/8/2019		Carried Forward	Pending		8/14/2024	750	Leak Extent	
7355430	32 SMITH AVE	3	7/25/2019		Carried Forward	Pending		9/27/2024	750	Leak Extent	
7356220	27 EVELYN RD	3	9/4/2019	8/28/2024	Carried Forward	Repaired		1/4/2024	750	Leak Extent	
7386043	19 COLUMBUS ST	3	1/31/2024		Newly Identified	Pending		10/30/2024	750	Leak Extent	
7365113	110 ADELINE RD	3	10/9/2020	8/12/2024	Carried Forward	Repaired		3/21/2024	748	Leak Extent	
1217964	68 WYOMING RD	3	4/30/2013		Carried Forward	Pending		8/20/2024	720	Leak Extent	
7371382	212 CHESTNUT ST	3	10/9/2021		Carried Forward	Pending		4/30/2024	720	Leak Extent	
7387598	56 UPLAND RD	3	4/17/2024		Newly Identified	Pending		11/19/2024	684	Leak Extent	
284375	59 WACHUSETT RD	3	1/25/2006		Carried Forward	Pending		8/8/2024	680	Leak Extent	
7375170	275 AUBURN ST	3	6/3/2022		Carried Forward	Pending		10/30/2024	680	Leak Extent	
7372371	28 MOODY ST	3	12/3/2021		Carried Forward	Pending		5/21/2024	675	Leak Extent	
7325711	5 AGAWAM RD	3	5/10/2016	12/17/2024	Carried Forward	Repaired		9/12/2024	660	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7374854	5 ANGLIER CIR	3	5/11/2022	12/18/2024	Carried Forward	Repaired		9/30/2024	660	Leak Extent	
7379918	1088 BOYLSTON ST	3	2/15/2023		Carried Forward	Pending		9/9/2024	660	Leak Extent	
7345718	DEDHAM ST & MEADOWBROOK RD	3	7/13/2018		Carried Forward	Pending		11/6/2024	650	Leak Extent	
7355359	41 ORCHARD AVE	3	8/12/2019		Carried Forward	Pending		9/27/2024	620	Leak Extent	
121969	CRAFTS ST & FESSENDEN RD	3	4/8/1998		Carried Forward	Pending		8/22/2024	600	Leak Extent	
347021	160 COMMONWEALTH AVE	3	5/25/2011	7/25/2024	Carried Forward	Repaired		1/11/2024	600	Leak Extent	
2349834	109 ALLERTON RD	3	12/26/2014	12/16/2024	Carried Forward	Repaired		8/22/2024	600	Leak Extent	
7342376	3 DANIEL ST	3	3/6/2018		Carried Forward	Pending		11/20/2024	600	Leak Extent	
7347782	2044 BEACON ST	3	9/23/2018	3/27/2024	Carried Forward	Repaired		5/12/2023	600	Leak Extent	
7356355	146 HAMMOND ST	3	9/25/2019		Carried Forward	Pending		10/11/2024	600	Leak Extent	
7356450	10 SPIERS RD	3	9/27/2019	9/12/2024	Carried Forward	Eliminated Otherwise		2/21/2024	600	Leak Extent	NO READS
7364409	170 OTIS ST	3	7/15/2020		Carried Forward	Pending		10/9/2024	600	Leak Extent	
7375165	49 GROVE ST	3	5/27/2022	8/29/2024	Carried Forward	Repaired		1/12/2024	600	Leak Extent	
7380675	MASSACHUSETTS TPKE & LOWELL AVE	3	3/18/2023		Carried Forward	Pending		10/1/2024	580	Leak Extent	
7325492	135 BIGELOW RD	3	4/21/2016	8/19/2024	Carried Forward	Eliminated Otherwise		8/14/2024	560	Leak Extent	NO READS
7391265	300 BOYLSTON ST	3	12/5/2024		Newly Identified	Pending		12/5/2024	560	Leak Extent	
7355552	8 EXMOOR RD	3	8/21/2019		Carried Forward	Pending		9/27/2024	550	Leak Extent	
7356134	105 OSBORNE PATH	3	9/3/2019		Carried Forward	Pending		10/11/2024	550	Leak Extent	
305355	36 MAGNOLIA AVE	3	8/29/2007	8/15/2024	Carried Forward	Repaired		8/5/2024	540	Leak Extent	
7382268	243 ISLINGTON RD	3	6/20/2023		Carried Forward	Pending		4/23/2024	540	Leak Extent	
1283461	21 WALNUT ST	3	9/29/2014	6/25/2024	Carried Forward	Repaired		9/13/2023	500	Leak Extent	
1338973	5 CHANNING RD	3	8/30/2013		Carried Forward	Pending		9/30/2024	500	Leak Extent	
1362600	45 PARK LN	3	9/25/2013		Carried Forward	Pending		11/6/2024	500	Leak Extent	
2725982	BEACON ST & RESERVOIR AVE	3	12/4/2014		Carried Forward	Pending		10/9/2024	500	Leak Extent	
4788254	8 CENTRAL AVE	3	7/10/2015		Carried Forward	Pending		11/6/2024	500	Leak Extent	
7378794	1370 WALNUT ST	3	11/10/2022		Carried Forward	Pending		7/11/2024	500	Leak Extent	
7383023	1261 CENTRE ST	3	8/4/2023		Carried Forward	Pending		5/21/2024	500	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2024						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7383509	118 LANGLEY RD	3	8/15/2023		Carried Forward	Pending		5/29/2024	500	Leak Extent	
7387880	24 OAKCLIFF RD	3	5/14/2024		Newly Identified	Pending		5/14/2024	500	Leak Extent	
7355351	57 COOK ST	3	8/12/2019		Carried Forward	Pending		9/27/2024	484	Leak Extent	
258079	2004 BEACON ST	3	3/2/2004		Carried Forward	Pending		8/22/2024	480	Leak Extent	
7386041	37 CHAPIN RD	3	2/1/2024		Newly Identified	Pending		10/30/2024	480	Leak Extent	
7386487	43 ELM ST	3	2/15/2024		Newly Identified	Pending		11/1/2024	470	Leak Extent	
7356225	105 HANSON RD	3	9/5/2019		Carried Forward	Pending		9/30/2024	460	Leak Extent	
7375134	380 WINCHESTER ST	3	5/16/2022		Carried Forward	Pending		10/1/2024	460	Leak Extent	
230055	1046 CHESTNUT ST	3	10/24/2017		Carried Forward	Pending		9/30/2024	450	Leak Extent	
7379271	255 BOYLSTON ST	3	1/6/2023		Carried Forward	Pending		11/9/2023	450	Leak Extent	
7379279	1438 COMMONWEALTH AVE	3	1/11/2023	9/26/2024	Carried Forward	Repaired		8/8/2024	450	Leak Extent	
7390711	168 RIVER ST	3	11/2/2024		Newly Identified	Pending		11/2/2024	450	Leak Extent	
7356420	24 OROURKE PATH	3	9/26/2019		Carried Forward	Pending		11/4/2024	420	Leak Extent	
7386037	249 ADAMS ST	3	1/30/2024	12/19/2024	Newly Identified	Repaired		10/30/2024	420	Leak Extent	
7386490	12 MURRAY RD	3	2/15/2024		Newly Identified	Pending		11/1/2024	420	Leak Extent	
7327002	1395 COMMONWEALTH AVE	3	6/23/2016	2/21/2024	Carried Forward	Eliminated Otherwise		7/31/2023	400	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7356347	40 JANE RD	3	9/25/2019		Carried Forward	Pending		9/30/2024	400	Leak Extent	
7369309	129 DORSET RD	3	6/11/2021	7/11/2024	Carried Forward	Eliminated Otherwise		1/11/2024	400	Leak Extent	DUPLICATE LEAK
7371866	1292 WALNUT ST	3	11/9/2021	1/3/2024	Carried Forward	Repaired		7/12/2023	400	Leak Extent	
7378202	904 BOYLSTON ST	3	11/16/2022		Carried Forward	Pending		8/12/2024	400	Leak Extent	
7378650	NONANTUM RD & MAPLE ST	3	11/7/2022		Carried Forward	Pending		7/25/2024	400	Leak Extent	
7379000	BEACON ST & OWAISA RD	3	12/17/2022	8/5/2024	Carried Forward	Repaired		7/25/2024	400	Leak Extent	
7379081	497 BOYLSTON ST	3	1/4/2023		Carried Forward	Pending		2/7/2024	400	Leak Extent	
7379274	1607 CENTRE ST	3	12/28/2022		Carried Forward	Pending		7/25/2024	400	Leak Extent	
7379461	184 WINDSOR RD	3	1/10/2023		Carried Forward	Pending		8/7/2024	400	Leak Extent	
7380670	122 CARVER RD	3	4/13/2023	2/26/2024	Carried Forward	Repaired		4/13/2023	400	Leak Extent	
7383832	59 PONTIAC RD	3	9/21/2023		Carried Forward	Pending		7/11/2024	400	Leak Extent	
7326638	89 WINDSOR RD	3	6/10/2016		Carried Forward	Pending		5/15/2024	390	Leak Extent	
7355442	361 THORNTON ST	3	8/1/2019		Carried Forward	Pending		9/27/2024	390	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7374843	1994 BEACON ST	3	5/29/2022		Carried Forward	Pending		10/30/2024	380	Leak Extent	
302760	60 WHITE OAK RD	3	7/13/2007	4/18/2024	Carried Forward	Repaired		7/31/2023	375	Leak Extent	
303666	78 WOODBINE ST	3	8/1/2007		Carried Forward	Pending		11/19/2024	375	Leak Extent	
7323096	11 RIDGEWAY TER	3	1/21/2016		Carried Forward	Pending		8/14/2024	375	Leak Extent	
7326997	21 LAUDHOLM RD	3	6/17/2016		Carried Forward	Pending		5/21/2024	375	Leak Extent	
7325813	32 MELVILLE AVE	3	4/29/2016		Carried Forward	Pending		8/21/2024	360	Leak Extent	
7386044	112 EXETER ST	3	1/30/2024		Newly Identified	Pending		10/30/2024	360	Leak Extent	
270413	1812 COMMONWEALTH AV	3	5/18/2004		Carried Forward	Pending		8/7/2024	350	Leak Extent	
1150031	1957 BEACON ST	3	2/13/2013		Carried Forward	Pending		10/9/2024	350	Leak Extent	
7348312	393 LOWELL AVE	3	10/13/2018		Carried Forward	Pending		11/4/2024	350	Leak Extent	
7356212	500 DEDHAM ST	3	9/5/2019		Carried Forward	Pending		10/9/2024	350	Leak Extent	
7356357	12 WACHUSETT RD	3	9/25/2019		Carried Forward	Pending		10/11/2024	340	Leak Extent	
7386040	141 CEDAR ST	3	2/1/2024		Newly Identified	Pending		10/30/2024	340	Leak Extent	
7375135	341 CABOT ST	3	5/23/2022		Carried Forward	Pending		10/11/2024	320	Leak Extent	
270381	55 WINDSOR RD	3	4/29/2004	10/18/2024	Carried Forward	Eliminated Otherwise		8/7/2024	300	Leak Extent	NO READS
303661	315 CRAFTS ST	3	8/6/2007		Carried Forward	Pending		8/22/2024	300	Leak Extent	
335508	15 ROTHERWOOD RD	3	7/10/2010		Carried Forward	Pending		5/7/2024	300	Leak Extent	
427378	692 COMMONWEALTH AVE	3	10/7/2011		Carried Forward	Pending		11/19/2024	300	Leak Extent	
1065965	32 RICHARDSON ST	3	11/29/2012		Carried Forward	Pending		11/4/2024	300	Leak Extent	
1337305	108 WINDSOR RD	3	8/21/2013		Carried Forward	Pending		11/1/2024	300	Leak Extent	
5337636	330 CENTRAL ST	3	7/6/2015		Carried Forward	Pending		5/15/2024	300	Leak Extent	
7326329	121 DICKERMAN RD	3	6/1/2016		Carried Forward	Pending		11/19/2024	300	Leak Extent	
7338634	6 VAUGHAN AVE	3	9/9/2017	12/3/2024	Carried Forward	Eliminated Otherwise		11/1/2024	300	Leak Extent	NO READS
7355559	96 NORTH ST	3	8/19/2019		Carried Forward	Pending		9/23/2024	300	Leak Extent	
7356214	471 DEDHAM ST	3	9/5/2019		Carried Forward	Pending		10/9/2024	300	Leak Extent	
7378589	242 LEXINGTON ST	3	11/23/2022		Carried Forward	Pending		7/25/2024	300	Leak Extent	
7383021	146 ALBEMARLE RD	3	8/4/2023		Carried Forward	Pending		11/22/2024	300	Leak Extent	
7384348	38 MORELAND AVE	3	9/28/2023		Carried Forward	Pending		7/25/2024	300	Leak Extent	
7384585	22 BERWICK RD	3	10/15/2023		Carried Forward	Pending		7/25/2024	300	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7326625	129 PARKER ST	3	6/10/2016		Carried Forward	Pending		5/15/2024	280	Leak Extent	
303702	9 T ROADWAY	3	8/6/2007		Carried Forward	Pending		11/6/2024	275	Leak Extent	
7369056	935 WASHINGTON ST	3	9/8/2021		Carried Forward	Pending		11/12/2024	275	Leak Extent	
7387912	1042 BOYLSTON ST	3	11/6/2024		Newly Identified	Pending	2	11/6/2024	270	Leak Extent	
7390821	569 SAWMILL BROOK PKY	3	11/17/2024		Newly Identified	Pending		11/17/2024	270	Leak Extent	
304860	167 PARKER ST	3	8/14/2007		Carried Forward	Pending		8/22/2024	264	Leak Extent	
7370900	11 CLOVELLY RD	3	9/20/2021	1/19/2024	Carried Forward	Repaired		6/20/2023	264	Leak Extent	
329904	25 MORSE RD	3	12/8/2009		Carried Forward	Pending		11/19/2024	250	Leak Extent	
1363357	647 COMMONWEALTH AVE	3	9/12/2013	10/16/2024	Carried Forward	Eliminated by Replacement		6/26/2024	250	Leak Extent	
7325430	9 KIRKSTALL RD	3	4/20/2016		Carried Forward	Pending		8/14/2024	250	Leak Extent	
7348100	63 OAKDALE RD	3	10/12/2018		Carried Forward	Pending		11/6/2024	250	Leak Extent	
7350513	15 OAK ST	3	2/1/2019		Carried Forward	Pending		11/12/2024	250	Leak Extent	
7375988	146 INTERVALE RD	3	6/16/2022		Carried Forward	Pending		11/4/2024	250	Leak Extent	
7376814	222 PLEASANT ST	3	8/25/2022		Carried Forward	Pending		5/6/2024	250	Leak Extent	
7379240	494 WATERTOWN ST	3	1/4/2023	8/13/2024	Carried Forward	Eliminated Otherwise		11/7/2023	250	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7379456	34 WARE RD	3	2/1/2023	7/11/2024	Carried Forward	Repaired		11/16/2023	250	Leak Extent	
7388309	6 WESSEX RD	3	6/17/2023	7/2/2024	Carried Forward	Eliminated Otherwise		6/17/2023	250	Leak Extent	SYSTEM ISSUE
7343321	15 G ROADWAY	3	4/6/2018		Carried Forward	Pending		9/17/2024	240	Leak Extent	
7364831	5 PHILBRICK RD	3	8/17/2020		Carried Forward	Pending		11/6/2024	240	Leak Extent	
7365526	36 METACOMET RD	3	11/20/2020		Carried Forward	Pending		5/6/2024	240	Leak Extent	
7375161	262 OTIS ST	3	5/18/2022	10/24/2024	Carried Forward	Eliminated Otherwise		10/11/2024	230	Leak Extent	DUPLICATE LEAK
7323097	14 ROKEBY RD	3	1/14/2016	8/21/2024	Carried Forward	Repaired		8/14/2024	225	Leak Extent	
7327750	OAKLAND ST & CHURCH ST	3	6/2/2016	7/1/2024	Carried Forward	Eliminated Otherwise		5/7/2024	225	Leak Extent	NO READS
7349163	CYPRESS ST & PARKER ST	3	11/15/2018		Carried Forward	Pending		11/1/2024	225	Leak Extent	
7370901	38 BARNSTABLE RD	3	9/24/2021		Carried Forward	Pending		4/25/2024	225	Leak Extent	
7375099	750 COMMONWEALTH AVE	3	4/26/2022	7/22/2024	Carried Forward	Repaired		1/11/2024	225	Leak Extent	
7379021	9 FOREST ST	3	8/9/2022		Carried Forward	Pending		4/23/2024	225	Leak Extent	
7380669	1880 BEACON ST	3	3/27/2023		Carried Forward	Pending		11/1/2024	225	Leak Extent	
7386038	138 CEDAR ST	3	2/1/2024		Newly Identified	Pending		10/30/2024	225	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7386050	20 WOODSIDE RD	3	2/1/2024		Newly Identified	Pending		11/1/2024	225	Leak Extent	
338426	61 CENTRAL ST	3	9/17/2015		Carried Forward	Pending		8/8/2024	220	Leak Extent	
42571	1418 COMMONWEALTH AV	3	7/7/1995	9/23/2024	Carried Forward	Repaired		1/11/2024	200	Leak Extent	
270598	16-25 BROADLAWN DR	3	7/27/2004		Carried Forward	Pending		7/11/2024	200	Leak Extent	
271180	63 AVONDALE RD	3	2/1/2005		Carried Forward	Pending		8/7/2024	200	Leak Extent	
303660	43 WALNUT ST	3	11/18/2014		Carried Forward	Pending		8/8/2024	200	Leak Extent	
304327	ALBEMARLE RD & WATERTOWN ST	3	8/15/2007		Carried Forward	Pending		7/11/2024	200	Leak Extent	
4788513	22 AUBURN ST	3	7/9/2015	10/17/2024	Carried Forward	Eliminated Otherwise		5/7/2024	200	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7327021	20 HOLDEN RD	3	6/28/2016		Carried Forward	Pending		11/19/2024	200	Leak Extent	
7365118	10 LOCKE RD	3	9/24/2020		Carried Forward	Pending		11/12/2024	200	Leak Extent	
7376315	1013 BEACON ST	3	7/18/2022		Carried Forward	Pending		11/4/2024	200	Leak Extent	
7378750	116 LEXINGTON ST	3	11/8/2022		Carried Forward	Pending		6/26/2024	200	Leak Extent	
7379022	1499 WASHINGTON ST	3	12/13/2022		Carried Forward	Pending		7/25/2024	200	Leak Extent	
7379295	416 NEWTONVILLE AVE	3	1/9/2023		Carried Forward	Pending		8/7/2024	200	Leak Extent	
7379915	760 BOYLSTON ST	3	1/30/2023		Carried Forward	Pending		8/7/2024	200	Leak Extent	
338734	6 SUN HILL LN	3	10/21/2010		Carried Forward	Pending		10/9/2024	190	Leak Extent	
7356361	52 G ROADWAY	3	9/25/2019		Carried Forward	Pending		10/9/2024	190	Leak Extent	
7386142	315 TREMONT ST	3	2/7/2024		Newly Identified	Pending		11/1/2024	190	Leak Extent	
317344	116 RIDGE AVE	3	12/12/2008		Carried Forward	Pending		10/9/2024	180	Leak Extent	
6625370	27 CAMDEN RD	3	9/22/2015		Carried Forward	Pending		8/20/2024	175	Leak Extent	
7369059	415 LOWELL AVE	3	8/8/2021		Carried Forward	Pending		11/12/2024	175	Leak Extent	
7371865	4 RANDOLPH ST	3	11/9/2021		Carried Forward	Pending		5/7/2024	170	Leak Extent	
7390551	DALTON RD & BEACON ST	3	10/9/2024		Newly Identified	Pending		10/9/2024	168	Leak Extent	
270652	55 JEFFERSON ST	3	8/13/2004		Carried Forward	Pending		11/1/2024	165	Leak Extent	
270388	50 DORSET RD	3	4/29/2004		Carried Forward	Pending		8/9/2024	160	Leak Extent	
303659	470 CALIFORNIA ST	3	8/3/2007		Carried Forward	Pending		10/11/2024	160	Leak Extent	
7375133	46 BEMIS ST	3	5/17/2022	5/9/2024	Carried Forward	Repaired		12/20/2023	160	Leak Extent	
7380673	205 HOMER ST	3	4/11/2023		Carried Forward	Pending		11/1/2024	160	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024				Name of Operator: <i>Boston & Colonial Gas Company</i>			
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7322014	83 DEVONSHIRE RD	3	12/8/2015	7/1/2024	Carried Forward	Eliminated Otherwise		11/9/2023	150	Leak Extent	NO READS
7356210	15 LEEWOOD RD	3	9/5/2019	4/17/2024	Carried Forward	Repaired		12/20/2023	150	Leak Extent	
7357654	143 RIVER ST	3	10/16/2019	1/29/2024	Carried Forward	Repaired		5/16/2023	150	Leak Extent	
7383022	74 BRIDGE ST	3	8/3/2023		Carried Forward	Pending		5/21/2024	150	Leak Extent	
7376041	14 HOMESTEAD ST	3	7/13/2022		Carried Forward	Pending		11/12/2024	125	Leak Extent	
7358412	LOS ANGELES ST & CALIFORNIA ST	3	12/26/2019		Carried Forward	Pending		11/12/2024	115	Leak Extent	
270560	9 STRATFORD RD	3	7/1/2004		Carried Forward	Pending		8/22/2024	112	Leak Extent	
7353577	73 DEDHAM ST	3	5/24/2019	9/16/2024	Carried Forward	Eliminated Otherwise		8/8/2024	112	Leak Extent	NO READS
7384931	BROOKSIDE AVE & ALBEMARLE RD	3	11/10/2023		Carried Forward	Pending		8/9/2024	112	Leak Extent	
258085	WABAN AV & VARICK RD	3	2/24/2004		Carried Forward	Pending		8/7/2024	100	Leak Extent	
329373	320 NEEDHAM ST	3	10/11/2009	9/12/2024	Carried Forward	Eliminated Otherwise		5/7/2024	100	Leak Extent	NO READS
329823	41 BERKELEY ST	3	12/4/2009		Carried Forward	Pending		6/26/2024	100	Leak Extent	
1338980	66 COMMONWEALTH PIKE W	3	8/29/2013	10/14/2024	Carried Forward	Repaired		6/26/2024	100	Leak Extent	
7326889	89 WALTHAM ST	3	6/15/2016		Carried Forward	Pending		5/7/2024	100	Leak Extent	
7327405	DAVIS AVE & EDEN AVE	3	6/27/2016	10/19/2024	Carried Forward	Eliminated Otherwise		6/26/2024	100	Leak Extent	NO READS
7354257	254 WEBSTER ST	3	12/31/2019		Carried Forward	Pending		4/23/2024	100	Leak Extent	
7356133	151 VALENTINE ST	3	8/6/2019	8/8/2024	Carried Forward	Eliminated by Replacement		12/13/2023	100	Leak Extent	
7359897	26 COOK ST	3	3/30/2020		Carried Forward	Pending		7/11/2024	100	Leak Extent	
7365115	1364 WALNUT ST	3	10/9/2020		Carried Forward	Pending		4/23/2024	100	Leak Extent	
7365406	48 PRINCE ST	3	12/19/2020		Carried Forward	Pending		5/6/2024	100	Leak Extent	
7365408	NORTH ST & ALBEMARLE RD	3	10/28/2020		Carried Forward	Pending		4/23/2024	100	Leak Extent	
7365478	50 MANEMET RD	3	11/14/2020	6/27/2024	Carried Forward	Eliminated Otherwise		5/6/2024	100	Leak Extent	NO READS
7373592	11 ASHCROFT RD	3	2/22/2022	12/18/2024	Carried Forward	Repaired		8/22/2024	100	Leak Extent	
7378586	8 EARLY PATH	3	11/15/2022		Carried Forward	Pending		7/25/2024	100	Leak Extent	
7378677	138 LEXINGTON ST	3	11/8/2022		Carried Forward	Pending		6/26/2024	100	Leak Extent	
7379023	HIGHLAND ST & DAVIS ST	3	12/18/2022	1/17/2024	Carried Forward	Eliminated Otherwise		9/26/2023	100	Leak Extent	DUPLICATE LEAK
7383833	WASHINGTON ST & CENTRE ST	3	9/13/2023		Carried Forward	Pending		7/11/2024	100	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7384586	80 WOODCHESTER DR	3	10/12/2023	8/9/2024	Carried Forward	Repaired		7/25/2024	100	Leak Extent	
7388304	1216 CHESTNUT ST	3	6/11/2024	7/19/2024	Newly Identified	Repaired		6/11/2024	100	Leak Extent	
7335811	78 NONANTUM ST	3	6/10/2017	7/1/2024	Carried Forward	Eliminated Otherwise		5/15/2024	84	Leak Extent	NO READS
7353086	43 CENTRAL ST	3	5/8/2019		Carried Forward	Pending		8/14/2024	80	Leak Extent	
7385311	23 DAVIS ST	3	12/19/2023	1/24/2024	Carried Forward	Eliminated Otherwise		12/19/2023	80	Leak Extent	DUPLICATE LEAK
7354890	33 THE LEDGES RD	3	7/24/2019		Carried Forward	Pending		8/9/2024	70	Leak Extent	
7343320	30 E ROADWAY	3	4/6/2018		Carried Forward	Pending		4/25/2024	64	Leak Extent	
7324253	15 JACKSON ST	3	3/23/2016	9/12/2024	Carried Forward	Eliminated Otherwise		8/14/2024	50	Leak Extent	NO READS
7356428	37 TRUMAN RD	3	9/26/2019	4/18/2024	Carried Forward	Repaired		2/16/2024	50	Leak Extent	
7332931	COMMONWEALTH AVE & BEAUMONT AVE	3	3/23/2017		Carried Forward	Pending		8/8/2024	49	Leak Extent	
7374842	6 LINCOLN ST	3	4/22/2022		Carried Forward	Pending		9/30/2024	41	Leak Extent	
270653	HAMMOND ST & RESERVOIR AV	3	8/20/2004	1/2/2024	Carried Forward	Eliminated Otherwise		11/14/2023	25	Leak Extent	NO READS
340420	167 NEHOIDEN RD	3	12/25/2010	7/1/2024	Carried Forward	Eliminated Otherwise		3/20/2024	25	Leak Extent	NO READS
7326611	26 MAPLE ST	3	6/6/2016	7/1/2024	Carried Forward	Eliminated Otherwise		3/20/2024	25	Leak Extent	NO READS
7329882	BEACON ST & HAMMOND ST	3	10/28/2016	1/4/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7331915	150 SPIERS RD	3	2/2/2017	1/2/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7354042	130 NEEDHAM ST	3	6/21/2019	1/2/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7354258	369 LEXINGTON ST	3	6/24/2019	1/4/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7368124	650 CENTRE ST	3	4/22/2021	1/4/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7368508	97 ATWOOD AVE	3	4/26/2021	1/4/2024	Carried Forward	Eliminated Otherwise		11/16/2023	25	Leak Extent	NO READS
7373593	BOYLSTON ST & HURLEY PL	3	2/22/2022		Carried Forward	Pending		9/9/2024	25	Leak Extent	
7375164	8 BALDPATE HILL RD	3	4/26/2022	8/5/2024	Carried Forward	Eliminated Otherwise		12/19/2023	25	Leak Extent	NO READS
7377628	23 LONGMEADOW RD	3	9/28/2022		Carried Forward	Pending		5/15/2024	25	Leak Extent	
7379276	10 MOODY ST	3	12/22/2022		Carried Forward	Pending		7/25/2024	25	Leak Extent	
7384346	45 HOLMAN RD	3	9/28/2023		Carried Forward	Pending		7/25/2024	25	Leak Extent	
7336764	CENTRAL AVE & WASHINGTON ST	3	7/26/2017		Carried Forward	Pending		8/9/2024	24	Leak Extent	
258065	122 WARD ST	3	1/22/2004		Carried Forward	Pending		8/20/2024	9	Leak Extent	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
343629	37 SHAW ST	3	2/15/2011		Carried Forward	Pending		8/20/2024	9	Leak Extent	
7325491	604 WALNUT ST	3	4/19/2016		Carried Forward	Pending		8/20/2024	9	Leak Extent	
7351646	20 SUN HILL LN	3	3/8/2019	6/27/2024	Carried Forward	Eliminated Otherwise		4/30/2024	9	Leak Extent	NO READS
7354555	11 OWAISA RD	3	6/10/2019		Carried Forward	Pending		8/21/2024	9	Leak Extent	
7382336	24 PHILBRICK RD	3	6/26/2023		Carried Forward	Pending		4/30/2024	9	Leak Extent	
7386865	991 BOYLSTON ST	3	6/13/2024		Newly Identified	Pending		6/13/2024	9	Leak Extent	
7353562	401 WINCHESTER ST	3	5/22/2019		Carried Forward	Pending		8/5/2024	4	Leak Extent	
7364119	23 MAPLE ST	3	5/13/2020		Carried Forward	Pending		8/21/2024	4	Leak Extent	
7376820	96 WESTLAND AVE	3	8/19/2022		Carried Forward	Pending		4/30/2024	4	Leak Extent	
7379849	249 CYPRESS ST	3	2/16/2023		Carried Forward	Pending		8/20/2024	4	Leak Extent	
7321944	120 FARWELL ST	3	12/4/2015		Carried Forward	Pending		5/15/2024	1	Leak Extent	
7327360	A ROADWAY & SPIERS RD	3	6/14/2017		Carried Forward	Pending		7/11/2024	1	Leak Extent	
7336232	566 SAWMILL BROOK PKY	3	7/14/2017		Carried Forward	Pending		11/19/2024	1	Leak Extent	
7354021	25 HAYNES RD	3	6/4/2019		Carried Forward	Pending		8/14/2024	1	Leak Extent	
7355411	47 ESTY FARM RD	3	8/2/2019		Carried Forward	Pending		8/9/2024	1	Leak Extent	
7364121	34 FENNO RD	3	6/17/2020	10/19/2024	Carried Forward	Eliminated Otherwise		9/27/2024	1	Leak Extent	NO READS
7376323	4 GRAY CLIFF RD	3	7/24/2022		Carried Forward	Pending		11/7/2024	1	Leak Extent	
7378752	271 CYPRESS ST	3	11/9/2022	7/30/2024	Carried Forward	Eliminated by Replacement		6/26/2024	1	Leak Extent	
7387349	57 DEVONSHIRE RD	3	4/18/2024		Newly Identified	Pending		11/19/2024	1	Leak Extent	
230384	41 LAKEVIEW AV	3	8/7/2000	11/27/2024	Carried Forward	Eliminated Otherwise		11/6/2024	-	No CGI reading	NO READS
263170	207 WALTHAM ST	3	10/13/2004		Carried Forward	Pending		10/11/2024	-	No CGI reading	
270389	128 WOODWARD ST	3	4/27/2004		Carried Forward	Pending		5/7/2024	-	No CGI reading	
270538	522 COMMONWEALTH AV	3	6/29/2004	6/12/2024	Carried Forward	Repaired		2/16/2024	-	No CGI reading	
270590	35-45 MCCARTHY RD	3	7/22/2004	6/27/2024	Carried Forward	Eliminated Otherwise		11/6/2023	-	No CGI reading	NO READS
271927	NESHOBE RD & WASHINGTON ST	3	2/14/2005		Carried Forward	Pending		8/28/2024	-	No CGI reading	
290176	38 LOCKSLEY RD	3	12/6/2006		Carried Forward	Pending		5/7/2024	-	No CGI reading	
303390	167 MELROSE ST	3	7/31/2007		Carried Forward	Pending		11/19/2024	-	No CGI reading	
305519	50 CHESTNUT HILL RD	3	8/23/2007		Carried Forward	Pending		8/27/2024	-	No CGI reading	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
307615	24 CENTRAL AVE	3	9/10/2007	12/2/2024	Carried Forward	Eliminated Otherwise		8/13/2024	-	No CGI reading	NO READS
329984	216 WINSLOW RD	3	11/30/2009		Carried Forward	Pending		10/1/2024	-	No CGI reading	
332258	30 ROLAND ST	3	4/8/2010		Carried Forward	Pending		9/23/2024	-	No CGI reading	
332435	30 K ROADWAY	3	4/13/2010	10/12/2024	Carried Forward	Eliminated Otherwise		9/3/2024	-	No CGI reading	NO READS
332674	15 HARTMAN RD	3	12/20/2010		Carried Forward	Pending		8/27/2024	-	No CGI reading	
336992	881 DEDHAM ST	3	9/1/2010	10/19/2024	Carried Forward	Eliminated Otherwise		8/13/2024	-	No CGI reading	NO READS
338427	65 ELINOR RD	3	10/9/2010	10/8/2024	Carried Forward	Eliminated by Replacement		9/30/2024	-	No CGI reading	
345666	1234 COMMONWEALTH AVE	3	4/14/2011	7/30/2024	Carried Forward	Eliminated Otherwise		2/21/2024	-	No CGI reading	NO READS
839999	115 ELLIOT ST	3	3/23/2012		Carried Forward	Pending		9/3/2024	-	No CGI reading	
871400	23 FREDANA RD	3	5/4/2012		Carried Forward	Pending		9/3/2024	-	No CGI reading	
949724	8 HAMMOND ST	3	8/1/2012	9/12/2024	Carried Forward	Eliminated Otherwise		8/13/2024	-	No CGI reading	NO READS
1018521	12 VINEYARD RD	3	10/12/2012	9/12/2024	Carried Forward	Eliminated Otherwise		9/3/2024	-	No CGI reading	NO READS
1229009	WALNUT ST & HOMER ST	3	5/17/2013		Carried Forward	Pending		8/27/2024	-	No CGI reading	
1230002	WALNUT ST & LAKEWOOD RD	3	5/17/2013		Carried Forward	Pending		10/1/2024	-	No CGI reading	
1237078	94 DEVONSHIRE RD	3	10/9/2015	10/19/2024	Carried Forward	Eliminated Otherwise		10/9/2024	-	No CGI reading	NO READS
1317702	91 PICKWICK RD	3	8/16/2013	6/27/2024	Carried Forward	Eliminated Otherwise		2/16/2024	-	No CGI reading	NO READS
1338217	102 RIDGE AVE	3	8/20/2013		Carried Forward	Pending		10/9/2024	-	No CGI reading	
1428283	191 GROVE ST	3	10/8/2013	11/27/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
2720300	61 SHARPE RD	3	1/23/2015		Carried Forward	Pending		8/13/2024	-	No CGI reading	
2834933	2401 COMMONWEALTH AVE	3	11/7/2014		Carried Forward	Pending		8/27/2024	-	No CGI reading	
3023506	COMMONWEALTH AVE & COMMONWEALTH PIKE	3	11/6/2014	7/1/2024	Carried Forward	Eliminated Otherwise		11/9/2023	-	No CGI reading	NO READS
3093950	43 SEWALL ST	3	2/9/2015	11/27/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
3869246	877 CHESTNUT ST	3	4/7/2015	7/1/2024	Carried Forward	Eliminated Otherwise		2/21/2024	-	No CGI reading	NO READS
4497451	60 HIGHLAND AVE	3	3/4/2015		Carried Forward	Pending		9/12/2024	-	No CGI reading	
4787400	300 ADAMS ST	3	7/7/2015	7/1/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
5620468	121 PARKER AVE	3	8/27/2015	1/2/2024	Carried Forward	Eliminated Otherwise		11/13/2023	-	No CGI reading	NO READS
6591350	22 OLDEFIELD RD	3	9/12/2015	12/2/2024	Carried Forward	Eliminated Otherwise		9/9/2024	-	No CGI reading	NO READS
7322832	49 ASHMONT AVE	3	4/25/2016	8/5/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7323736	35 BELLEVUE ST	3	2/2/2016	7/2/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
7323783	38 PUTNAM ST	3	2/1/2016	4/12/2024	Carried Forward	Eliminated Otherwise		2/16/2024	-	No CGI reading	NO READS
7325806	4 PEMBROKE ST	3	4/22/2016	12/3/2024	Carried Forward	Eliminated Otherwise		11/19/2024	-	No CGI reading	NO READS
7325992	269 JACKSON ST	3	5/12/2016	9/12/2024	Carried Forward	Eliminated Otherwise		4/25/2024	-	No CGI reading	NO READS
7326630	39 COURT ST	3	6/9/2016	10/12/2024	Carried Forward	Eliminated Otherwise		5/7/2024	-	No CGI reading	NO READS
7326636	NORTH ST & ALBEMARLE RD	3	6/13/2016	10/24/2024	Carried Forward	Eliminated Otherwise		5/7/2024	-	No CGI reading	DUPLICATE LEAK
7329507	263 HAMMOND ST	3	11/7/2016	11/27/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
7330385	75 SUMNER ST	3	11/16/2016	12/9/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
7331474	71 COMMONWEALTH AVE	3	1/3/2017		Carried Forward	Pending		11/19/2024	-	No CGI reading	
7332282	NONANTUM RD & CHARLESBANK RD	3	2/1/2017		Carried Forward	Pending		11/4/2024	-	No CGI reading	
7332762	ISLINGTON RD & KINGSWOOD RD	3	3/21/2017		Carried Forward	Pending		9/12/2024	-	No CGI reading	
7337028	100 CONCORD ST	3	8/1/2017		Carried Forward	Pending		9/3/2024	-	No CGI reading	
7339913	58 AUBURN ST	3	11/15/2017	12/3/2024	Carried Forward	Eliminated by Replacement		9/30/2024	-	No CGI reading	
7340358	246 BEACON ST	3	12/12/2017		Carried Forward	Pending		11/6/2024	-	No CGI reading	
7341496	COMMONWEALTH AVE & AUBURN ST	3	1/12/2018		Carried Forward	Pending		11/4/2024	-	No CGI reading	
7341526	224 JACKSON ST	3	2/27/2018	9/12/2024	Carried Forward	Eliminated Otherwise		2/20/2024	-	No CGI reading	NO READS
7341653	457 WASHINGTON ST	3	1/28/2018	12/3/2024	Carried Forward	Eliminated Otherwise		11/6/2024	-	No CGI reading	NO READS
7347783	69 EVELYN RD	3	9/16/2018	12/7/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
7347784	12 NONANTUM ST	3	9/15/2018		Carried Forward	Pending		11/7/2024	-	No CGI reading	
7347786	DEDHAM ST & MEADOWBROOK RD	3	9/29/2018		Carried Forward	Pending		11/7/2024	-	No CGI reading	
7348310	95 DORSET RD	3	10/11/2018	11/22/2024	Carried Forward	Eliminated Otherwise		11/20/2024	-	No CGI reading	NO READS
7348728	283 MELROSE ST	3	6/29/2018	12/3/2024	Carried Forward	Eliminated Otherwise		11/4/2024	-	No CGI reading	NO READS
7349893	240 VALENTINE ST	3	12/17/2018	8/8/2024	Carried Forward	Eliminated by Replacement		2/5/2024	-	No CGI reading	
7353079	1870 COMMONWEALTH AVE	3	5/13/2019	10/12/2024	Carried Forward	Eliminated Otherwise		8/21/2024	-	No CGI reading	NO READS
7353083	1830 COMMONWEALTH AVE	3	5/13/2019	9/21/2024	Carried Forward	Eliminated Otherwise		8/21/2024	-	No CGI reading	NO READS
7353115	150 WOODLAND RD	3	5/8/2019		Carried Forward	Pending		8/27/2024	-	No CGI reading	

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7353118	207 AUBURN ST	3	5/17/2019		Carried Forward	Pending		8/27/2024	-	No CGI reading	
7353512	47 CHANDLER PL	3	5/23/2019	1/4/2024	Carried Forward	Eliminated Otherwise		11/13/2023	-	No CGI reading	NO READS
7354041	66 NEEDHAM ST	3	10/20/2021		Carried Forward	Pending		11/20/2024	-	No CGI reading	
7354147	9 HIGH ST	3	6/27/2019		Carried Forward	Pending		8/28/2024	-	No CGI reading	
7354263	1932 COMMONWEALTH AVE	3	6/24/2019		Carried Forward	Pending		8/28/2024	-	No CGI reading	
7354537	10 DAY ST	3	7/15/2019		Carried Forward	Pending		9/3/2024	-	No CGI reading	
7354698	559 CENTRE ST	3	7/16/2019		Carried Forward	Pending		9/4/2024	-	No CGI reading	
7354711	86 COMMONWEALTH AVE	3	7/16/2019	11/15/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	REPAIRED UNDER OTHER LEAK REPAIR
7354712	31 DEVONSHIRE RD	3	7/19/2019	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7354715	6 EDGEWOOD RD	3	7/19/2019	8/19/2024	Carried Forward	Eliminated Otherwise		11/16/2023	-	No CGI reading	NO READS
7355547	85 BROOKSIDE AVE	3	8/20/2019	11/27/2024	Carried Forward	Eliminated Otherwise		11/1/2024	-	No CGI reading	NO READS
7355555	68 LITTLEFIELD RD	3	8/19/2019		Carried Forward	Pending		9/23/2024	-	No CGI reading	
7355561	117 NORTH ST	3	8/19/2019		Carried Forward	Pending		9/23/2024	-	No CGI reading	
7355668	34 BROADLAWN DR	3	8/23/2019		Carried Forward	Pending		9/23/2024	-	No CGI reading	
7355674	188 DEDHAM ST	3	8/23/2019	1/4/2024	Carried Forward	Eliminated Otherwise		12/14/2023	-	No CGI reading	NO READS
7356139	344 BROOKLINE ST	3	9/3/2019	8/5/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
7356142	26 HARWICH RD	3	9/4/2019		Carried Forward	Pending		10/9/2024	-	No CGI reading	
7356203	17 WAYNE RD	3	9/4/2019	6/27/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
7356207	36 WISWALL RD	3	9/5/2019	6/27/2024	Carried Forward	Eliminated Otherwise		1/4/2024	-	No CGI reading	NO READS
7356211	84 RACHEL RD	3	9/5/2019		Carried Forward	Pending		10/11/2024	-	No CGI reading	
7356362	29 F ROADWAY	3	9/25/2019	11/27/2024	Carried Forward	Eliminated Otherwise		10/30/2024	-	No CGI reading	NO READS
7356371	80 HANSON RD	3	9/25/2019	12/3/2024	Carried Forward	Eliminated Otherwise		11/4/2024	-	No CGI reading	NO READS
7356852	WATERTOWN ST & CRAFTS ST	3	10/15/2019		Carried Forward	Pending		5/6/2024	-	No CGI reading	
7357139	48 LANTERN LN	3	10/25/2019	12/3/2024	Carried Forward	Eliminated Otherwise		11/7/2024	-	No CGI reading	NO READS
7364115	33 WARREN RD	3	5/24/2020	12/9/2024	Carried Forward	Eliminated Otherwise		11/20/2024	-	No CGI reading	NO READS
7364120	43 SHERBROOKE RD	3	6/15/2020	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7364450	60 FAIRLEE RD	3	8/26/2020	11/27/2024	Carried Forward	Eliminated Otherwise		11/12/2024	-	No CGI reading	NO READS
7365082	35 WHITTIER RD	3	9/1/2020	7/11/2024	Carried Forward	Eliminated Otherwise		2/20/2024	-	No CGI reading	NO READS
7365094	160 PARKER ST	3	10/15/2020	10/19/2024	Carried Forward	Eliminated Otherwise		4/23/2024	-	No CGI reading	NO READS

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7368505	87 ATWOOD AVE	3	5/4/2021	12/19/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7368733	17 COCHITUATE RD	3	5/19/2021		Carried Forward	Pending		9/23/2024	-	No CGI reading	
7370889	375 AUBURN ST	3	9/19/2021	12/3/2024	Carried Forward	Eliminated Otherwise		11/20/2024	-	No CGI reading	NO READS
7371043	34 EMERSON ST	3	10/7/2021	8/19/2024	Carried Forward	Eliminated Otherwise		4/30/2024	-	No CGI reading	NO READS
7371864	465 CENTRE ST	3	10/23/2021		Carried Forward	Pending		5/6/2024	-	No CGI reading	
7374830	21 MARSHFIELD RD	3	3/15/2022	9/12/2024	Carried Forward	Eliminated Otherwise		8/8/2024	-	No CGI reading	NO READS
7374831	75 ELMHURST RD	3	4/5/2022	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7374857	265 OTIS ST	3	5/15/2022		Carried Forward	Pending		9/30/2024	-	No CGI reading	
7375136	15 ELMWOOD PIKE	3	5/24/2022	11/27/2024	Carried Forward	Eliminated Otherwise		10/11/2024	-	No CGI reading	NO READS
7375986	11 EDGE HILL RD	3	5/23/2022		Carried Forward	Pending		10/11/2024	-	No CGI reading	
7375989	38 VERNDAL RD	3	6/17/2022	12/3/2024	Carried Forward	Eliminated Otherwise		11/6/2024	-	No CGI reading	NO READS
7376318	39 BILLINGS PIKE	3	8/3/2022	12/7/2024	Carried Forward	Eliminated Otherwise		11/12/2024	-	No CGI reading	NO READS
7376811	195 MORTON ST	3	8/26/2022		Carried Forward	Pending		5/6/2024	-	No CGI reading	
7376826	12 COPLEY ST	3	4/15/2022	8/19/2024	Carried Forward	Eliminated Otherwise		1/11/2024	-	No CGI reading	NO READS
7379850	54 DUXBURY RD	3	2/7/2023	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7379883	228 HIGHLAND AVE	3	2/28/2023	9/12/2024	Carried Forward	Eliminated Otherwise		9/4/2024	-	No CGI reading	NO READS
7380672	31 GARDNER ST	3	3/23/2023	8/19/2024	Carried Forward	Eliminated Otherwise		1/12/2024	-	No CGI reading	NO READS
7380674	10 LOWELL AVE	3	2/24/2023	9/12/2024	Carried Forward	Eliminated Otherwise		8/28/2024	-	No CGI reading	NO READS
7382899	298 CYPRESS ST	3	7/8/2023	8/19/2024	Carried Forward	Eliminated Otherwise		5/6/2024	-	No CGI reading	NO READS
7384691	320 WASHINGTON ST	3	11/15/2023	6/27/2024	Carried Forward	Eliminated Otherwise		2/13/2024	-	No CGI reading	NO READS
7385308	55 FOREST AVE	3	12/9/2023		Carried Forward	Pending		9/12/2024	-	No CGI reading	
7385843	299 WOODLAND RD	3	1/11/2024		Newly Identified	Pending		10/9/2024	-	No CGI reading	
7385972	5 MARSHALL ST	3	2/1/2024	12/3/2024	Newly Identified	Eliminated Otherwise		10/30/2024	-	No CGI reading	NO READS
7386046	17 CHESTER ST	3	1/31/2024		Newly Identified	Pending		10/30/2024	-	No CGI reading	
7386138	11 CANTERBURY RD	3	2/11/2024	11/27/2024	Newly Identified	Eliminated Otherwise		11/1/2024	-	No CGI reading	NO READS
7390988	22 TRAVERSE ST	3	11/22/2024		Newly Identified	Pending		11/22/2024	-	No CGI reading	
7391266	46 CEDAR ST	3	12/11/2024		Newly Identified	Pending		12/11/2024	-	No CGI reading	
7391275	54 BALLARD ST	3	12/9/2024		Newly Identified	Pending		12/9/2024	-	No CGI reading	
7382741	263 HAMMOND ST	1	8/3/2023	3/21/2024	Carried Forward	Eliminated Otherwise					CALLLED OFF BY SUPERVISOR

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7384926	55 MURRAY RD	1	12/10/2023	3/21/2024	Carried Forward	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7385225	12 WASHBURN ST	1	1/2/2024	1/2/2024	Newly Identified	Repaired					
7385254	898 CHESTNUT ST	1	1/4/2024	1/4/2024	Newly Identified	Repaired					
7385256	45 SEWALL ST	1	1/4/2024	1/4/2024	Newly Identified	Repaired					
7385276	228 HIGHLAND AVE	1	1/5/2024	1/5/2024	Newly Identified	Repaired					
7385351	178 NEHOIDEN RD	1	1/11/2024	1/11/2024	Newly Identified	Repaired					
7385364	206 WINSLOW RD	1	1/11/2024	1/11/2024	Newly Identified	Repaired					
7385367	19 WOODBINE ST	1	1/11/2024	1/11/2024	Newly Identified	Repaired					
7385393	37 MONTROSE ST	1	1/14/2024	1/15/2024	Newly Identified	Repaired					
7385398	12 ELLIOT PL	1	1/15/2024	1/15/2024	Newly Identified	Repaired					
7385399	21 JASSET ST	1	1/15/2024	1/16/2024	Newly Identified	Repaired					
7385407	101 VERNON ST	1	1/16/2024	1/16/2024	Newly Identified	Repaired					
7385408	55 WETHERELL ST	1	1/16/2024	1/17/2024	Newly Identified	Repaired					
7385426	24 LEE RD	1	1/17/2024	1/18/2024	Newly Identified	Repaired					
7385427	12 BROADLAWN DR	1	1/17/2024	1/17/2024	Newly Identified	Repaired					
7385462	28 ISLINGTON RD	1	1/19/2024	1/19/2024	Newly Identified	Repaired					
7385463	350 WOODWARD ST	1	1/20/2024	1/20/2024	Newly Identified	Repaired					
7385487	458 LOWELL AVE	1	1/22/2024	1/22/2024	Newly Identified	Repaired					
7385518	256 WATERTOWN ST	1	1/23/2024	1/23/2024	Newly Identified	Repaired					
7385527	28 GEORGE ST	1	1/23/2024	2/6/2024	Newly Identified	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7385528	28 GEORGE ST	1	1/23/2024	1/24/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7385532	263 PEARL ST	1	1/24/2024	1/25/2024	Newly Identified	Repaired					
7385551	213 NAHANTON ST	1	1/24/2024	1/25/2024	Newly Identified	Repaired					
7385614	95 ALLEN AVE	1	1/28/2024	1/28/2024	Newly Identified	Repaired					
7385615	215 NAHANTON ST	1	1/28/2024	1/28/2024	Newly Identified	Repaired					
7385616	215 NAHANTON ST	1	1/28/2024	1/28/2024	Newly Identified	Repaired					
7385638	2014 WASHINGTON ST	1	1/29/2024	1/29/2024	Newly Identified	Repaired					
7385654	139 CALIFORNIA ST	1	1/30/2024	1/30/2024	Newly Identified	Repaired					
7385663	25 AVALON RD	1	1/31/2024	1/31/2024	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7385671	616 BOYLSTON ST	1	1/31/2024	2/2/2024	Newly Identified	Repaired					
7385703	204 NORTH ST	1	2/1/2024	2/2/2024	Newly Identified	Repaired					
7385814	18 PRISCILLA RD	1	2/6/2024	2/6/2024	Newly Identified	Repaired					
7385821	103 WABAN AVE	1	2/6/2024	2/7/2024	Newly Identified	Repaired					
7385872	28 HIBBARD RD	1	2/8/2024	2/8/2024	Newly Identified	Repaired					
7385874	22 FAIRWAY DR	1	2/8/2024	2/9/2024	Newly Identified	Repaired					
7385884	109 ADAMS ST	1	2/9/2024	2/9/2024	Newly Identified	Repaired					
7385888	384 NEWTONVILLE AVE	1	2/9/2024	2/9/2024	Newly Identified	Repaired					
7385944	1395 COMMONWEALTH AVE	1	2/14/2024	2/14/2024	Newly Identified	Repaired					
7385971	305 COMMONWEALTH AVE	1	2/15/2024	2/15/2024	Newly Identified	Repaired					
7385979	14 MARGARET RD	1	2/15/2024	2/16/2024	Newly Identified	Repaired					
7386005	14 PARK PL	1	2/17/2024	2/19/2024	Newly Identified	Repaired					
7386010	5 MARSHALL ST	1	2/17/2024	2/17/2024	Newly Identified	Repaired					
7386154	160 NEEDHAM ST	1	2/27/2024	2/27/2024	Newly Identified	Repaired					
7386159	69 LOS ANGELES ST	1	2/28/2024	2/28/2024	Newly Identified	Repaired					
7386202	53 CRESCENT AVE	1	3/3/2024	3/3/2024	Newly Identified	Repaired					
7386313	1888 COMMONWEALTH AVE	1	3/11/2024	3/13/2024	Newly Identified	Repaired					
7386320	40 THE LEDGES RD	1	3/12/2024	3/13/2024	Newly Identified	Repaired					
7386330	380 WABAN AVE	1	3/12/2024	3/13/2024	Newly Identified	Repaired					
7386372	50 QUINCY RD	1	3/14/2024	3/15/2024	Newly Identified	Repaired					
7386381	21 CHANDLER PL	1	3/15/2024	3/15/2024	Newly Identified	Repaired					
7386395	19 SYLVESTER RD	1	3/16/2024	3/16/2024	Newly Identified	Repaired					
7386433	4 MEREDITH AVE	1	3/19/2024	3/20/2024	Newly Identified	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7386453	1251 WASHINGTON ST	1	3/20/2024	3/21/2024	Newly Identified	Repaired					
7386555	427 LEXINGTON ST	1	3/28/2024	3/29/2024	Newly Identified	Repaired					
7386569	427 LEXINGTON ST	1	3/28/2024	3/29/2024	Newly Identified	Repaired					
7386609	23 RESERVOIR AVE	1	4/2/2024	4/2/2024	Newly Identified	Repaired					
7386617	826 WATERTOWN ST	1	4/2/2024	4/3/2024	Newly Identified	Repaired					
7386630	51 WILDWOOD AVE	1	4/3/2024	4/4/2024	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7386656	320 WASHINGTON ST	1	4/5/2024	4/7/2024	Newly Identified	Repaired					
7386658	21 CLOELIA TER	1	4/5/2024	4/6/2024	Newly Identified	Repaired					
7386671	15 WOODCLIFF RD	1	4/8/2024	4/8/2024	Newly Identified	Repaired					
7386912	1224 BOYLSTON ST	1	4/18/2024	5/1/2024	Newly Identified	Repaired					
7386949	1197 CENTRE ST	1	4/20/2024	4/22/2024	Newly Identified	Repaired					
7386979	461 WOLCOTT ST	1	4/22/2024	4/22/2024	Newly Identified	Repaired					
7387022	137 PINE RIDGE RD	1	4/23/2024	4/23/2024	Newly Identified	Repaired					
7387036	1564 BEACON ST	1	4/24/2024	4/25/2024	Newly Identified	Repaired					
7387052	300 PRINCE ST	1	4/24/2024	4/24/2024	Newly Identified	Repaired					
7387082	105 TOLMAN ST	1	4/25/2024	4/25/2024	Newly Identified	Repaired					
7387122	8 SHELDON RD	1	4/28/2024	5/2/2024	Newly Identified	Repaired					
7387128	420 WALTHAM ST	1	4/29/2024	4/29/2024	Newly Identified	Repaired					
7387168	320 WASHINGTON ST	1	4/30/2024	6/3/2024	Newly Identified	Repaired					
7387171	1310 CENTRE ST	1	4/30/2024	4/30/2024	Newly Identified	Repaired					
7387201	77 HALCYON RD	1	5/1/2024	5/1/2024	Newly Identified	Repaired					
7387243	2240 COMMONWEALTH AVE	1	5/3/2024	5/6/2024	Newly Identified	Repaired					
7387253	665 WATERTOWN ST	1	5/4/2024	5/8/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7387254	665 WATERTOWN ST	1	5/4/2024	5/4/2024	Newly Identified	Repaired					
7387260	90 HIGHLAND AVE	1	5/5/2024	5/6/2024	Newly Identified	Repaired					
7387299	51 GORDON RD	1	5/7/2024	5/7/2024	Newly Identified	Repaired					
7387303	3 CARL ST	1	5/7/2024	5/7/2024	Newly Identified	Repaired					
7387326	5 MARGARET RD	1	5/7/2024	5/10/2024	Newly Identified	Repaired					
7387337	9 MARGARET RD	1	5/7/2024	5/7/2024	Newly Identified	Repaired					
7387339	84 HAMMONDSWOOD RD	1	5/7/2024	5/7/2024	Newly Identified	Repaired					
7387378	60 DWHINDA RD	1	5/9/2024	5/9/2024	Newly Identified	Repaired					
7387407	112 AUBURNDAL AVE	1	5/10/2024	5/10/2024	Newly Identified	Repaired					
7387464	61 WINTHROP ST	1	5/13/2024	5/13/2024	Newly Identified	Repaired					
7387484	528 BOYLSTON ST	1	5/14/2024	5/21/2024	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7387504	WINDERMERE RD & WOODLAND RD	1	5/15/2024	5/15/2024	Newly Identified	Repaired					
7387664	176 BOYLSTON ST	1	5/22/2024	5/22/2024	Newly Identified	Repaired					
7387665	176 BOYLSTON ST	1	5/23/2024	12/30/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7387982	12 GEORGE ST	1	6/7/2024	6/7/2024	Newly Identified	Repaired					
7388022	22 WALSH RD	1	6/11/2024	6/12/2024	Newly Identified	Repaired					
7388114	728 WALNUT ST	1	6/17/2024	6/17/2024	Newly Identified	Repaired					
7388177	300 HAMMOND ST	1	6/22/2024	6/22/2024	Newly Identified	Repaired					
7388276	432 WATERTOWN ST	1	6/27/2024	6/27/2024	Newly Identified	Repaired					
7388323	1009 BOYLSTON ST	1	7/1/2024	7/1/2024	Newly Identified	Repaired					
7388359	146 LINCOLN ST	1	7/2/2024	7/3/2024	Newly Identified	Repaired					
7388489	22 BONMAR CIR	1	7/12/2024	7/12/2024	Newly Identified	Repaired					
7388530	1 RIDGE RD	1	7/16/2024	7/16/2024	Newly Identified	Repaired					
7388577	GILBERT ST & AUBURN ST	1	7/19/2024	7/19/2024	Newly Identified	Repaired					
7388623	11 CLEARWATER RD	1	7/22/2024	7/22/2024	Newly Identified	Repaired					
7388654	500 DUDLEY RD	1	7/24/2024	7/24/2024	Newly Identified	Repaired					
7388809	494 WATERTOWN ST	1	8/5/2024		Newly Identified	Pending					
7388841	83 MORRILL ST	1	8/6/2024	8/6/2024	Newly Identified	Repaired					
7388879	100 WOODCHESTER DR	1	8/8/2024	8/8/2024	Newly Identified	Repaired					
7388951	628 BOYLSTON ST	1	8/12/2024	8/16/2024	Newly Identified	Repaired					
7388988	78 WALKER ST	1	8/13/2024	8/13/2024	Newly Identified	Repaired					
7389106	866 BEACON ST	1	8/12/2024	8/19/2024	Newly Identified	Repaired					
7389107	7 WADE ST	1	8/19/2024	8/19/2024	Newly Identified	Repaired					
7389135	567 WALNUT ST	1	8/20/2024	8/21/2024	Newly Identified	Repaired					
7389156	1042 BOYLSTON ST	1	8/21/2024	8/23/2024	Newly Identified	Repaired					
7389172	WESTBOURNE RD & EASTBOURNE RD	1	8/21/2024	8/21/2024	Newly Identified	Repaired					
7389264	949 CENTRE ST	1	8/27/2024	8/27/2024	Newly Identified	Repaired					
7389409	202 AUBURNDAL AVE	1	9/6/2024	9/6/2024	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7389575	14 SHORNECLIFFE RD	1	9/13/2024	9/13/2024	Newly Identified	Repaired					
7389682	1039 WALNUT ST	1	9/19/2024	9/19/2024	Newly Identified	Repaired					
7389705	989 CENTRE ST	1	9/20/2024	9/20/2024	Newly Identified	Repaired					
7389793	CURVE ST & AUBURN ST	1	9/25/2024	9/25/2024	Newly Identified	Repaired					
7389801	796 CHESTNUT ST	1	9/25/2024	9/25/2024	Newly Identified	Repaired					
7389806	98 ANNAWAN RD	1	9/26/2024	9/26/2024	Newly Identified	Repaired					
7389938	961 WALNUT ST	1	10/4/2024	10/4/2024	Newly Identified	Repaired					
7390136	6 DORCAR RD	1	10/17/2024	10/17/2024	Newly Identified	Repaired					
7390261	1011 CENTRE ST	1	10/18/2024	10/24/2024	Newly Identified	Repaired					
7390304	60 ELLIOT ST	1	10/22/2024	10/22/2024	Newly Identified	Repaired					
7390630	27 METACOMET RD	1	11/5/2024	11/6/2024	Newly Identified	Repaired					
7390704	6 ALBAN RD	1	11/12/2024	11/12/2024	Newly Identified	Repaired					
7390779	49 MILLER RD	1	11/17/2024	11/18/2024	Newly Identified	Repaired					
7390783	16 MANEMET RD	1	11/18/2024	11/18/2024	Newly Identified	Repaired					
7390797	933 CENTRE ST	1	11/18/2024	11/18/2024	Newly Identified	Repaired					
7390874	5 SHELDON RD	1	11/22/2024	11/26/2024	Newly Identified	Repaired					
7390876	116 FAIRWAY DR	1	11/22/2024	11/25/2024	Newly Identified	Repaired					
7390889	35 DRUMLIN RD	1	11/24/2024	11/24/2024	Newly Identified	Repaired					
7391093	74 WALKER ST	1	12/5/2024	12/5/2024	Newly Identified	Repaired					
7391098	955 CENTRE ST	1	12/5/2024	12/5/2024	Newly Identified	Repaired					
7391104	15 SIMPSON ST	1	12/5/2024		Newly Identified	Pending					
7391215	123 SPIERS RD	1	12/17/2024		Newly Identified	Pending					
7391282	494 WARD ST	1	12/24/2024	12/27/2024	Newly Identified	Repaired					
7391286	268 DORSET RD	1	12/26/2024	12/26/2024	Newly Identified	Repaired					
7391330	OAK ST & CHESTNUT ST	1	12/29/2024	12/30/2024	Newly Identified	Repaired					
7391334	865 BEACON ST	1	12/29/2024	12/30/2024	Newly Identified	Repaired					
42479	52 SEWALL ST	2	7/25/2024	8/30/2024	Carried Forward	Repaired	3				
155801	KENDALL RD & WALNUT HILL RD	2	6/27/2024	9/4/2024	Carried Forward	Repaired	3				

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024				Name of Operator: <i>Boston & Colonial Gas Company</i>			
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
337057	327 CHERRY ST	2	4/30/2024		Carried Forward	Pending	3				
1215753	52 ELLIOT ST	2	2/15/2023	9/24/2024	Carried Forward	Repaired					
1336115	156 OAK ST	2	4/17/2020	10/30/2024	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7325494	4 MARLBORO ST	2	9/6/2024	9/18/2024	Carried Forward	Repaired	3				
7327022	74 HOMESTEAD ST	2	6/26/2024	8/19/2024	Carried Forward	Eliminated Otherwise	3				NO READS
7336761	425 WATERTOWN ST	2	2/14/2023	2/14/2024	Carried Forward	Repaired					
7345014	7 CURTIS ST	2	11/20/2024		Carried Forward	Pending	3				
7352431	54 TEMPLE ST	2	2/14/2024	3/14/2024	Carried Forward	Repaired	3				
7353522	8 WETHERELL ST	2	6/26/2024	8/23/2024	Carried Forward	Repaired	3				
7354043	170 NEEDHAM ST	2	5/21/2020	11/20/2020	Carried Forward	Eliminated by Replacement					
7354261	MELROSE AVE & MELROSE ST	2	11/16/2023	1/11/2024	Carried Forward	Repaired					
7354538	5 MARSHALL ST	2	11/16/2023	1/9/2024	Carried Forward	Repaired					
7354888	624 BEACON ST	2	6/17/2020	10/1/2024	Carried Forward	Repaired					
7355977	173 HIGHLAND ST	2	9/18/2024	9/30/2024	Carried Forward	Repaired	3				
7356367	350 WINCHESTER ST	2	12/4/2023	1/2/2024	Carried Forward	Repaired					
7356436	317 PARKER ST	2	7/27/2021	9/25/2024	Carried Forward	Repaired					
7368736	1330 BOYLSTON ST	2	11/20/2024		Carried Forward	Pending	3				
7371859	214 BEACON ST	2	5/15/2024	6/14/2024	Carried Forward	Eliminated Otherwise	3				SYSTEM ISSUE
7374832	366 ELLIOT ST	2	12/20/2023	1/12/2024	Carried Forward	Repaired					
7374845	2055 WASHINGTON ST	2	1/21/2024	4/23/2024	Carried Forward	Eliminated Otherwise	3				NO READS
7374856	1750 COMMONWEALTH AVE	2	2/15/2024	3/11/2024	Carried Forward	Repaired	3				
7375160	64 HILLSIDE AVE	2	6/26/2024	10/1/2024	Carried Forward	Eliminated by Replacement	3				
7375985	66 PELHAM ST	2	7/6/2024	8/28/2024	Carried Forward	Repaired	3				
7376438	281 HOMER ST	2	7/29/2022	9/26/2024	Carried Forward	Repaired					
7376827	120 CORNELL ST	2	11/22/2024	12/6/2024	Carried Forward	Repaired	3				
7378193	4 JUDITH RD	2	11/8/2022	9/10/2024	Carried Forward	Repaired					
7379171	74 FAIRMONT AVE	2	11/22/2024	12/12/2024	Carried Forward	Repaired	3				
7379277	234 CENTRAL ST	2	8/5/2024	9/11/2024	Carried Forward	Repaired	3				
7379290	25 OLD ENGLAND RD	2	10/6/2024	11/4/2024	Carried Forward	Repaired	3				

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7379459	839 WASHINGTON ST	2	7/26/2024	8/29/2024	Carried Forward	Repaired	3				
7380676	923 WALNUT ST	2	1/29/2024	3/11/2024	Carried Forward	Repaired	3				
7382122	207 WASHINGTON ST	2	6/6/2023	6/6/2024	Carried Forward	Repaired					
7382536	74 EDDY ST	2	6/29/2023	7/25/2024	Carried Forward	Eliminated Otherwise					NO READS
7382898	160 BOYLSTON ST	2	5/6/2024		Carried Forward	Pending	3				
7383497	2084 BEACON ST	2	5/24/2024	7/25/2024	Carried Forward	Repaired	3				
7383508	HIGH ST & ELLIOT ST	2	11/22/2024	12/13/2024	Carried Forward	Repaired	3				
7383831	250 ALBEMARLE RD	2	7/11/2024	9/6/2024	Carried Forward	Repaired	3				
7384775	628 BOYLSTON ST	2	10/24/2023	2/6/2024	Carried Forward	Eliminated Otherwise					CALLED OFF BY SUPERVISOR
7385304	35 LEXINGTON ST	2	12/24/2023	2/14/2024	Carried Forward	Repaired					
7385348	17 WARE RD	2	12/22/2023	1/31/2024	Carried Forward	Repaired					
7385438	72 ALLEN AVE	2	1/2/2024	1/30/2024	Newly Identified	Repaired					
7385439	384 LINWOOD AVE	2	1/3/2024	2/21/2024	Newly Identified	Repaired					
7385512	86 ALLEN AVE	2	12/31/2023	1/30/2024	Carried Forward	Repaired					
7385629	4 CAPITAL ST	2	1/22/2024	3/25/2024	Newly Identified	Repaired					
7385715	15 HICKORY CLIFF RD	2	1/23/2024	6/3/2024	Newly Identified	Eliminated by Replacement					
7385716	30 KILBURN RD	2	1/25/2024	3/20/2024	Newly Identified	Repaired					
7385717	12 PLEASANT ST	2	1/25/2024	3/20/2024	Newly Identified	Repaired					
7385809	580 WASHINGTON ST	2	12/20/2023	2/22/2024	Carried Forward	Repaired					
7385861	67 CHERRY ST	2	1/30/2024	2/21/2024	Newly Identified	Repaired					
7385862	53 CRESCENT ST	2	1/31/2024	2/26/2024	Newly Identified	Repaired					
7385864	48 NATHAN RD	2	2/1/2024	2/22/2024	Newly Identified	Repaired					
7385940	346 WINCHESTER ST	2	2/6/2024	2/16/2024	Newly Identified	Repaired					
7385941	87 ALLEN AVE	2	2/6/2024	2/15/2024	Newly Identified	Repaired					
7385960	CYPRESS ST & PARKER ST	2	2/6/2024	2/29/2024	Newly Identified	Repaired					
7385961	20 MALIA TER	2	2/4/2024	4/24/2024	Newly Identified	Repaired					
7386019	5 SWAN AVE	2	2/6/2024	3/6/2024	Newly Identified	Repaired					
7386051	316 WOODWARD ST	2	4/8/2024	7/1/2024	Newly Identified	Repaired	3				
7386104	228 WEBSTER ST	2	2/15/2024	4/24/2024	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024				Name of Operator: <i>Boston & Colonial Gas Company</i>			
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7386106	56 MILLER RD	2	10/9/2024	10/25/2024	Newly Identified	Repaired	3				
7386383	1730 WASHINGTON ST	2	2/7/2024	5/16/2024	Newly Identified	Repaired					
7386420	138 COTTON ST	2	3/6/2024	4/1/2024	Newly Identified	Repaired					
7386423	5 OLDFIELD RD	2	3/6/2024	4/10/2024	Newly Identified	Repaired					
7386574	528 BOYLSTON ST	2	3/3/2024	5/16/2024	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7386863	47 WINCHESTER RD	2	4/18/2024	5/1/2024	Newly Identified	Repaired					
7387138	1774 COMMONWEALTH AVE	2	12/2/2024		Newly Identified	Pending	3				
7387188	28 ARAPAHOE RD	2	3/18/2024	6/14/2024	Newly Identified	Repaired					
7387447	115 ALLEN AVE	2	4/22/2024	10/2/2024	Newly Identified	Repaired					
7387449	208 LEXINGTON ST	2	4/29/2024	8/20/2024	Newly Identified	Repaired					
7387451	26 NOBLE ST	2	4/30/2024	6/14/2024	Newly Identified	Repaired					
7387453	122 CARVER RD	2	4/22/2024	6/13/2024	Newly Identified	Repaired					
7387519	477 GROVE ST	2	4/19/2024		Newly Identified	Pending					
7387874	100 VALENTINE ST	2	5/3/2024	7/24/2024	Newly Identified	Eliminated by Replacement					
7387884	336 BOYLSTON ST	2	5/16/2024		Newly Identified	Pending					
7387910	1026 BOYLSTON ST	2	5/13/2024		Newly Identified	Pending					
7387914	1310 CENTRE ST	2	5/13/2024	9/10/2024	Newly Identified	Repaired					
7387916	3 CHANDLER ST	2	5/13/2024	7/25/2024	Newly Identified	Repaired					
7387919	169 CYPRESS ST	2	5/28/2024	7/18/2024	Newly Identified	Repaired					
7387922	2096 WASHINGTON ST	2	5/24/2024		Newly Identified	Pending					
7387994	300 HAMMOND ST	2	5/31/2024	6/24/2024	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7388266	8 BROWNING RD	2	5/30/2024	7/11/2024	Newly Identified	Repaired					
7388349	6 WESSEX RD	2	10/13/2024	10/30/2024	Newly Identified	Repaired	3				
7388430	7 WADE ST	2	5/14/2024	8/22/2024	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7388519	368 BOYLSTON ST	2	6/12/2024		Newly Identified	Pending					
7388683	195 NORTH ST	2	7/7/2024	10/9/2024	Newly Identified	Repaired					
7388831	440 LEXINGTON ST	2	7/23/2024		Newly Identified	Pending					
7388903	1185 WALNUT ST	2	7/25/2024	10/23/2024	Newly Identified	Repaired					
7388975	449 NEWTONVILLE AVE	2	7/26/2024	8/30/2024	Newly Identified	Repaired					

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7389123	100 BOYLSTON ST	2	8/14/2024		Newly Identified	Pending					
7389152	44 WAVERLY AVE	2	8/18/2024	9/10/2024	Newly Identified	Repaired					
7389267	33 ORIENT AVE	2	8/26/2024		Newly Identified	Pending					
7389363	10 WINDSOR RD	2	8/27/2024	9/11/2024	Newly Identified	Repaired					
7389498	275 MILL ST	2	9/6/2024	9/24/2024	Newly Identified	Repaired					
7389504	109 CABOT ST	2	9/5/2024	9/17/2024	Newly Identified	Repaired					
7389508	427 LEXINGTON ST	2	9/4/2024	10/2/2024	Newly Identified	Repaired					
7389974	11 CLEARWATER RD	2	9/30/2024	10/16/2024	Newly Identified	Repaired					
7389975	1097 CENTRE ST	2	9/23/2024	10/16/2024	Newly Identified	Repaired					
7389976	64 BISHOPSGATE RD	2	10/1/2024	10/23/2024	Newly Identified	Repaired					
7390003	85 MONTVALE RD	2	10/4/2024	10/28/2024	Newly Identified	Repaired					
7390093	835 WASHINGTON ST	2	10/13/2024	11/4/2024	Newly Identified	Repaired					
7390373	961 WALNUT ST	2	10/17/2024	10/23/2024	Newly Identified	Repaired					
7390421	111 PARKER AVE	2	10/23/2024	11/12/2024	Newly Identified	Repaired					
7390652	1197 CENTRE ST	2	10/9/2024	11/21/2024	Newly Identified	Repaired					
7390710	75 WALKER ST	2	11/2/2024	12/4/2024	Newly Identified	Repaired					
7390737	38 PRINCE ST	2	11/2/2024	12/2/2024	Newly Identified	Repaired					
7390899	7 CURTIS ST	2	11/20/2024	12/4/2024	Newly Identified	Repaired					
7391075	3 NARDONE RD	2	11/24/2024	12/16/2024	Newly Identified	Repaired					
7391374	26 BEACON ST	2	12/12/2024		Newly Identified	Pending					
7391505	15 LARCHMONT AVE	2	12/31/2024		Newly Identified	Pending					
7374799	1730 WASHINGTON ST	3	4/5/2023	3/15/2024	Carried Forward	Eliminated Otherwise					SYSTEM ISSUE
7376329	1595 WASHINGTON ST	3	7/28/2022	6/5/2024	Carried Forward	Repaired					
7380668	10 ANNAWAN RD	3	3/27/2023	2/22/2024	Carried Forward	Repaired					
7385845	200 JACKSON RD	3	1/18/2024	7/29/2024	Newly Identified	Repaired					
7386000	83 FAXON ST	3	2/16/2024	2/16/2024	Newly Identified	Repaired					
7386047	25 GREENLAWN AVE	3	2/1/2024	10/24/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7386471	100 VARICK RD	3	3/21/2024	3/21/2024	Newly Identified	Repaired					
7386559	933 CENTRE ST	3	3/12/2024	11/14/2024	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR

Table L5 Newton Leak Report Dec 31, 2024

Detailed Quarterly Information (Rev. 7/2019)				QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>				
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designati on Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7387353	77 WOOD END RD	3	4/22/2024		Newly Identified	Pending					Survey to be provided
7387493	1750 COMMONWEALTH AVE	3	5/8/2024	11/20/2024	Newly Identified	Repaired					
7387593	40 CHASKE AVE	3	4/22/2024		Newly Identified	Pending					Survey to be provided
7387594	40 CHASKE AVE	3	4/22/2024	5/30/2024	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7387597	9 ELLIOT ST	3	4/29/2024		Newly Identified	Pending					Survey to be provided
7387765	156 OAK ST	3	5/14/2024		Newly Identified	Pending					Survey to be provided
7387777	82 ALBEMARLE RD	3	5/2/2024		Newly Identified	Pending					Survey to be provided
7387779	20 BEAUMONT AVE	3	5/6/2024		Newly Identified	Pending					Survey to be provided
7387993	AUBURNDAL E AVE & HAROLD TER	3	5/31/2024	7/23/2024	Newly Identified	Eliminated by Replacement					
7388450	320 WASHINGTON ST	3	6/25/2024		Newly Identified	Pending					Survey to be provided
7388454	74 ERIE AVE	3	7/2/2024		Newly Identified	Pending					Survey to be provided
7388455	318 CABOT ST	3	6/25/2024		Newly Identified	Pending					Survey to be provided
7388521	255 PARKER ST	3	10/1/2024	9/25/2024	Newly Identified	Repaired	2				
7388900	425 WARD ST	3	7/23/2024	8/15/2024	Newly Identified	Repaired					
7389125	32 SUFFOLK RD	3	8/13/2024		Newly Identified	Pending					Survey to be provided
7389144	39 NEHOIDEN RD	3	8/17/2024		Newly Identified	Pending					Survey to be provided
7389263	269 HIGHLAND ST	3	8/21/2024		Newly Identified	Pending					Survey to be provided
7389268	15 UPLAND RD	3	8/25/2024		Newly Identified	Pending					Survey to be provided
7389395	92 WALKER ST	3	9/2/2024		Newly Identified	Pending					Survey to be provided
7389589	7 WADE ST	3	9/11/2024	12/9/2024	Newly Identified	Repaired					
7389618	20 WOODCHESTER DR	3	9/13/2024		Newly Identified	Pending					Survey to be provided
7389619	15 LAWRENCE RD	3	9/15/2024		Newly Identified	Pending					Survey to be provided
7389634	1297 WALNUT ST	3	9/12/2024		Newly Identified	Pending					Survey to be provided
7389706	87 CHARLEMONT ST	3	9/18/2024		Newly Identified	Pending					Survey to be provided
7389707	1063 COMMONWEALTH AVE	3	9/17/2024		Newly Identified	Pending					Survey to be provided
7389759	130 NONANTUM RD	3	9/24/2024	9/25/2024	Newly Identified	Repaired					
7389765	23 HIGH ST	3	8/12/2024		Newly Identified	Pending					Survey to be provided
7389987	37 CLARK ST	3	9/12/2024		Newly Identified	Pending					Survey to be provided

Table L5 Newton Leak Report Dec 31, 2024											
Detailed Quarterly Information (Rev. 7/2019)					QUARTER 4 - 2024			Name of Operator: <i>Boston & Colonial Gas Company</i>			
Leak ID	Street Number and Name	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
								Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7389989	40 ROYCE RD	3	9/23/2024		Newly Identified	Pending				Survey to be provided	
7390129	573 WASHINGTON ST	3	10/16/2024	10/16/2024	Newly Identified	Repaired					
7390404	1669 CENTRE ST	3	10/23/2024		Newly Identified	Pending				Survey to be provided	
7390407	160 PARKER ST	3	10/23/2024		Newly Identified	Pending				Survey to be provided	
7391223	6 ANGIER CIR	3	12/17/2024	12/18/2024	Newly Identified	Repaired					
7391274	54 BALLARD ST	3	12/9/2024		Newly Identified	Pending				Survey to be provided	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/Barhole]	
258065	122 WARD ST	3	1/22/2004	4/1/2025	Carried Forward	Eliminated by Replacement		2/7/2025		No CGI reading	CLOSED DUE TO MAIN REPLACEMENT
258085	WABAN AV & VARICK RD	3	2/24/2004	4/17/2025	Carried Forward	Repaired		8/7/2024	100	Leak Extent	
270389	128 WOODWARD ST	2	4/14/2025	5/7/2025	Carried Forward	Repaired	3				
270413	1812 COMMONWEALTH AV	3	5/18/2004	4/25/2025	Carried Forward	Eliminated Otherwise		8/7/2024	350	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
270681	131 COUNTRY CLUB RD	3	8/3/2004	2/14/2025	Carried Forward	Repaired		9/12/2024	1,260	Leak Extent	
271180	63 AVONDALE RD	3	2/1/2005	3/5/2025	Carried Forward	Repaired		8/7/2024	200	Leak Extent	
304327	ALBEMARLE RD & WATERTOWN ST	3	8/15/2007	4/25/2025	Carried Forward	Repaired		7/11/2024	200	Leak Extent	
329823	41 BERKELEY ST	3	12/4/2009	1/13/2025	Carried Forward	Repaired		6/26/2024	100	Leak Extent	
337057	327 CHERRY ST	2	4/30/2024	3/21/2025	Carried Forward	Repaired					
427378	692 COMMONWEALTH AVE	3	10/7/2011	3/17/2025	Carried Forward	Eliminated Otherwise		2/11/2025	-	No CGI reading	NO READS
1217681	206 CONCORD ST	3	5/6/2013	3/12/2025	Carried Forward	Eliminated Otherwise		8/13/2024	2,720	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
1362600	45 PARK LN	2	1/11/2025	2/4/2025	Carried Forward	Repaired					
1363546	295 DUDLEY RD	3	9/19/2013	3/21/2025	Carried Forward	Repaired		9/30/2024	860	Leak Extent	
5290582	267 PEARL ST	1	5/26/2025	5/26/2025	Newly Identified	Repaired					
5291666	9 OLD ORCHARD RD	2	5/27/2025	11/20/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5291930	10 DEXTER RD	3	5/28/2025		Newly Identified	Pending		5/28/2025	100	Leak Extent	
5291932	14 KEWADIN RD	1	5/28/2025	5/30/2025	Newly Identified	Repaired					
5291938	380 ELLIOT ST	3	5/28/2025		Newly Identified	Pending		5/28/2025	1,944	Leak Extent	
5291957	553 WALNUT ST	3	5/28/2025		Newly Identified	Pending		5/28/2025	225	Leak Extent	
5292119	90 ELM ST	3	5/29/2025		Newly Identified	Pending		5/29/2025	4,480	Leak Extent	
5299963	267 PEARL ST	1	6/2/2025	6/6/2025	Newly Identified	Repaired					
5300051	15 TEMPLE STREET	3	6/2/2025		Newly Identified	Pending		6/2/2025	150	Leak Extent	
5300870	110 HULL ST	3	6/2/2025		Newly Identified	Pending		6/2/2025	-	No CGI reading	
5301022	165 LINWOOD AVE	3	6/3/2025		Newly Identified	Pending		6/30/2025	1,650	Leak Extent	
5301183	1105 WASHINGTON STREET	3	6/3/2025		Newly Identified	Pending		6/3/2025	100	Leak Extent	
5301264	34 ANTHONY RD	2	6/4/2025	8/20/2025	Newly Identified	Repaired					
5301294	8 WETHERELL ST	1	6/4/2025	7/9/2025	Newly Identified	Repaired					
5301310	1180 WASHINGTON ST	2	6/4/2025	9/17/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)		QUARTER 4 - 2025		Name of Operator: <i>Boston & Colonial Gas Company</i>							
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5301318	1235 WASHINGTON ST	3	6/4/2025		Newly Identified	Pending		6/4/2025	900	Leak Extent	
5301443	28 CHARLEMONT ST	3	6/5/2025		Newly Identified	Pending		6/5/2025	400	Leak Extent	
5301467	351 WINCHESTER STREET	3	6/5/2025	9/23/2025	Newly Identified	Repaired		6/5/2025	100	Leak Extent	
5301469	561 WARD ST	1	6/5/2025	6/9/2025	Newly Identified	Repaired					
5301479	454 WALNUT ST	1	6/5/2025	6/7/2025	Newly Identified	Repaired					
5301481	11 WAYNE RD	3	6/5/2025		Newly Identified	Pending		6/5/2025	2,520	Leak Extent	
5301493	364 CABOT ST	3	6/5/2025		Newly Identified	Pending		6/5/2025	25	Leak Extent	
5301497	300 HARTMAN RD	3	6/5/2025		Newly Identified	Pending		6/5/2025	1,600	Leak Extent	
5301505	321 WINCHESTER ST	3	6/5/2025	9/25/2025	Newly Identified	Repaired		6/5/2025	100	Leak Extent	
5301507	315 WINCHESTER ST	3	6/5/2025	9/26/2025	Newly Identified	Repaired		6/5/2025	225	Leak Extent	
5301581	1119 WALNUT STREET	2	6/5/2025	8/14/2025	Newly Identified	Repaired					
5301597	315 ALBEMARLE RD	3	6/6/2025		Newly Identified	Pending		12/29/2025	2,275	Leak Extent	
5301667	489 WALNUT ST	2	6/6/2025	7/29/2025	Newly Identified	Repaired					
5301710	36 MELVILLE AVE	1	6/6/2025	6/6/2025	Newly Identified	Repaired					
5301734	1119 WALNUT ST, NEWTON	2	6/6/2025	7/18/2025	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
5301826	450 LEXINGTON ST	1	6/9/2025	6/27/2025	Newly Identified	Repaired					
5301858	131 COUNTRY CLUB RD	2	6/9/2025	8/18/2025	Newly Identified	Repaired					
5301878	1148 BEACON ST	3	6/9/2025		Newly Identified	Pending		6/9/2025	50	Leak Extent	
5301912	951 WALNUT ST	2	6/9/2025	10/22/2025	Newly Identified	Repaired					
5301950	658 DEDHAM ST	1	6/9/2025	6/10/2025	Newly Identified	Repaired					
5302038	790 CENTRE ST	1	6/10/2025	6/10/2025	Newly Identified	Repaired					
5302140	11 FOREST AVE	1	6/11/2025	7/10/2025	Newly Identified	Repaired					
5302149	23 WOODMAN RD	3	6/11/2025		Newly Identified	Pending		6/11/2025	600	Leak Extent	
5302210	965 DEDHAM STREET	2	6/11/2025	7/22/2025	Newly Identified	Repaired					
5302261	507 WARD ST	1	6/11/2025	6/12/2025	Newly Identified	Repaired					
5302282	389 CENTRAL ST	2	6/11/2025	8/29/2025	Newly Identified	Repaired					
5302419	WASHINGTON ST INTERSECTION	2	6/12/2025		Newly Identified	Pending					
5302665	127 ELLIOT ST	2	6/13/2025	8/21/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5302829	34 GROVELAND ST	2	5/14/2025	7/22/2025	Newly Identified	Repaired					
5302852	19 NEEDHAM STREET	3	6/16/2025		Newly Identified	Pending		6/16/2025	3,000	Leak Extent	
5302894	19 STONELEIGH RD	3	6/16/2025		Newly Identified	Pending		6/16/2025	25	Leak Extent	
5302902	516 LOWELL AVE	3	5/27/2025		Newly Identified	Pending		5/27/2025	100	Leak Extent	
5302910	299 ELLIOT ST	3	5/20/2025		Newly Identified	Pending		5/20/2025	100	Leak Extent	
5302915	76 WALDEN ST	3	5/27/2025		Newly Identified	Pending		5/27/2025	100	Leak Extent	
5302923	129 BEAUMONT AVE	3	5/23/2025		Newly Identified	Pending		5/23/2025	225	Leak Extent	
5302931	330 ELLIOT ST	2	5/21/2025	7/16/2025	Newly Identified	Repaired					
5302967	23 HIGH ST	3	6/16/2025	7/1/2025	Newly Identified	Eliminated Otherwise		6/16/2025	736	Leak Extent	DUPLICATE LEAK
5303001	180 WINCHESTER ST	2	6/17/2025	8/6/2025	Newly Identified	Repaired					
5303005	7 HUNTER ST	2	5/14/2025	8/15/2025	Newly Identified	Repaired					
5303266	831 BOYLSTON ST	1	6/18/2025	6/19/2025	Newly Identified	Repaired					
5303494	9 OLD ORCHARD RD	2	6/20/2025	7/18/2025	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
5303680	113 NORTH ST	3	6/23/2025		Newly Identified	Pending		6/23/2025	100	Leak Extent	
5304050	20 PIERREPONT RD	3	6/25/2025		Newly Identified	Pending		6/25/2025	100	Leak Extent	
5304218	7 CHAPEL ST	3	6/26/2025		Newly Identified	Pending		6/26/2025	25	Leak Extent	
5304314	409 NEWTONVILLE AVE	1	6/26/2025	6/27/2025	Newly Identified	Repaired					
5304356	306 CALIFORNIA ST	3	6/27/2025		Newly Identified	Pending		6/27/2025	200	Leak Extent	
5304382	63 CHAPEL ST	2	6/27/2025	8/14/2025	Newly Identified	Repaired					
5304498	440 WOLCOTT ST	3	6/28/2025		Newly Identified	Pending		6/28/2025	2,500	Leak Extent	
5304580	165 LINWOOD AVE	3	6/29/2025	7/12/2025	Newly Identified	Eliminated Otherwise		6/30/2025	1,650	Leak Extent	DUPLICATE LEAK
5304694	18 PUTNAM ST	2	5/14/2025	8/27/2025	Newly Identified	Repaired					
5304932	144 ELLIOT ST	1	7/1/2025	7/3/2025	Newly Identified	Repaired					
5305018	144 ELLIOT ST NEWTON MA	1	7/2/2025	8/7/2025	Newly Identified	Repaired					
5305444	256 WATERTOWN ST	2	7/7/2025	8/20/2025	Newly Identified	Repaired					
5306371	430 LANGLEY RD	1	7/11/2025	7/25/2025	Newly Identified	Repaired					
5306393	5 HARRINGTON ST	3	7/11/2025		Newly Identified	Pending		7/12/2025	225	Leak Extent	
5306819	897 WASHINGTON ST	2	7/15/2025	7/22/2025	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
5306852	1019 WASHINGTON ST	1	7/15/2025	7/25/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5306863	75 WESTMINSTER RD	3	7/15/2025	8/7/2025	Newly Identified	Eliminated Otherwise		7/15/2025	100	Leak Extent	DUPLICATE LEAK
5307104	264 PEARL ST	2	7/16/2025	8/29/2025	Newly Identified	Repaired					
5307354	26 SPIERS RD	1	7/18/2025	7/18/2025	Newly Identified	Repaired					
5307362	945 BEACON ST	1	7/18/2025	7/25/2025	Newly Identified	Repaired					
5307486	549 CRAFTS ST	1	7/20/2025	7/25/2025	Newly Identified	Repaired					
5307526	1900 WASHINGTON ST	3	7/20/2025		Newly Identified	Pending		7/20/2025	5,610	Leak Extent	
5307572	32 HURLEY PL	3	7/21/2025		Newly Identified	Pending		7/21/2025	26,750	Leak Extent	
5307589	34 BROOKSIDE AVE	3	7/21/2025		Newly Identified	Pending		9/29/2025	50	Leak Extent	
5307650	945 BEACON ST	2	7/21/2025	9/11/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5307674	1317 CENTRE ST	2	7/21/2025	9/11/2025	Newly Identified	Repaired					
5307680	182 LEXINGTON ST	2	7/21/2025	9/8/2025	Newly Identified	Repaired					
5307682	152 LEXINGTON STREET	2	7/22/2025	9/2/2025	Newly Identified	Repaired					
5307684	166 LEXINGTON ST	3	7/22/2025		Newly Identified	Pending		7/22/2025	625	Leak Extent	
5307717	370 WOLCOTT ST	3	7/22/2025		Newly Identified	Pending		7/22/2025	25	Leak Extent	
5307881	392 BOYLSTON STREET	1	7/22/2025	7/25/2025	Newly Identified	Repaired					
5307953	118 CLARK ST	3	7/23/2025		Newly Identified	Pending		7/23/2025	336	Leak Extent	
5308011	304 LEXINGTON ST	3	7/23/2025		Newly Identified	Pending		7/23/2025	1,200	Leak Extent	
5308019	252 LEXINGTON ST	2	7/23/2025	9/5/2025	Newly Identified	Repaired					
5308172	929 BEACON ST	2	7/23/2025	8/21/2025	Newly Identified	Repaired					
5308218	44 THORNTON ST	2	7/24/2025	8/15/2025	Newly Identified	Repaired					
5308267	287 AUBURN ST1	2	7/24/2025		Newly Identified	Pending					
5308290	85 BROOKSIDE AVE	2	7/24/2025	8/28/2025	Newly Identified	Repaired					
5308304	882 WATERTOWN ST	2	7/24/2025	9/2/2025	Newly Identified	Repaired					
5308376	50 DUDLEY RD	3	7/25/2025		Newly Identified	Pending		7/25/2025	1,600	Leak Extent	
5308386	25 DUDLEY RD	3	7/25/2025		Newly Identified	Pending		7/25/2025	650	Leak Extent	
5308688	26 CEDAR ST	2	7/28/2025	8/30/2025	Newly Identified	Repaired					
5308917	175 TEMPLE ST	1	7/30/2025	7/30/2025	Newly Identified	Repaired					
5308970	435 CENTRE ST	3	10/9/2025		Newly Identified	Pending	2	10/9/2025	1	Leak Extent	
5309024	796 WALNUT ST	3	7/31/2025		Newly Identified	Pending		7/31/2025	2,700	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)		QUARTER 4 - 2025		Name of Operator: <i>Boston & Colonial Gas Company</i>							
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5309030	82 ALLEN AVE	1	7/31/2025	8/1/2025	Newly Identified	Repaired					
5309430	515 CRAFTS STREET	3	8/3/2025		Newly Identified	Pending		8/3/2025	1,800	Leak Extent	
5309511	31 STERLING ST	3	8/4/2025		Newly Identified	Pending		8/4/2025	100	Leak Extent	
5309687	1633 COMMONWEALTH AVE	1	8/5/2025	8/7/2025	Newly Identified	Repaired					
5309697	50 COLLEGE RD	2	8/5/2025	9/24/2025	Newly Identified	Repaired					
5309699	1671 BEACON ST	2	8/5/2025	8/28/2025	Newly Identified	Repaired					
5309782	38 PRINCE ST	2	8/6/2025	10/10/2025	Newly Identified	Repaired					
5309784	28 MANITOBA RD	2	8/6/2025	9/17/2025	Newly Identified	Repaired					
5309872	10 DAY ST	3	8/6/2025	12/9/2025	Newly Identified	Repaired		8/6/2025	100	Leak Extent	
5309897	4 ARAPAHOE RD	2	8/6/2025	9/2/2025	Newly Identified	Repaired					
5309901	316 HOMER ST	3	8/6/2025		Newly Identified	Pending		8/6/2025	1,140	Leak Extent	
5309935	41 COMMONWEALTH AVE	1	8/6/2025	8/13/2025	Newly Identified	Repaired					
5310034	942 BEACON ST	2	8/7/2025	9/11/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5310041	215 AUBURNDAL AVE	2	8/7/2025	11/5/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5310049	60 WASHBURN AVENUE	2	8/7/2025	9/3/2025	Newly Identified	Repaired					
5310085	MILE 45.3 STATE RTE 16 W	1	8/7/2025	8/8/2025	Newly Identified	Repaired					
5310208	351 CRAFTS ST	2	8/8/2025	9/5/2025	Newly Identified	Repaired					
5310214	12 MURRAY RD	3	8/8/2025		Newly Identified	Pending		8/8/2025	900	Leak Extent	
5310352	316 CENTRAL ST	3	8/9/2025		Newly Identified	Pending		8/9/2025	740	Leak Extent	
5310511	38 GLEN AVE	3	8/11/2025		Newly Identified	Pending		8/11/2025	2,662	Leak Extent	
5310563	250 FULLER ST	2	8/11/2025	10/8/2025	Newly Identified	Repaired					
5310637	152 FULLER STREET	3	8/5/2025	9/15/2025	Newly Identified	Repaired		8/5/2025	200	Leak Extent	
5310694	471 WASHINGTON ST	2	8/12/2025	9/16/2025	Newly Identified	Repaired					
5310947	32 CHESLEY RD	2	8/13/2025	10/2/2025	Newly Identified	Repaired					
5310998	30 KILBURN ROAD	3	8/13/2025		Newly Identified	Pending		8/13/2025	7,482	Leak Extent	
5311198	575 WASHINGTON ST	3	8/14/2025	11/17/2025	Newly Identified	Repaired		8/14/2025	300	Leak Extent	
5311218	229 CYPRESS ST	3	8/14/2025		Newly Identified	Pending		8/14/2025	25	Leak Extent	
5311420	41 GLEN AVE	3	8/15/2025		Newly Identified	Pending		8/15/2025	500	Leak Extent	
5311422	210 EVELYN RD	3	8/15/2025		Newly Identified	Pending		8/15/2025	100	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)		QUARTER 4 - 2025		Name of Operator: <i>Boston & Colonial Gas Company</i>							
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5311505	ALBEMARLE RD	1	8/15/2025	9/15/2025	Newly Identified	Repaired					
5311631	572 CRAFTS ST	3	8/17/2025		Newly Identified	Pending		8/17/2025	75	Leak Extent	
5311679	24 HILLTOP ST	3	8/18/2025		Newly Identified	Pending		8/18/2025	600	Leak Extent	
5311697	262 PEARL ST	2	8/18/2025	9/2/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5311743	464 DUDLEY ROAD	3	8/18/2025		Newly Identified	Pending		8/18/2025	50	Leak Extent	
5311839	47 WINCHESTER RD	3	8/19/2025	12/11/2025	Newly Identified	Repaired		8/19/2025	400	Leak Extent	
5311841	122 EAST SIDE PARKWAY	3	8/19/2025	12/18/2025	Newly Identified	Repaired		8/19/2025	100	Leak Extent	
5311844	76 LEWIS ST	3	8/19/2025		Newly Identified	Pending		8/19/2025	200	Leak Extent	
5311882	1395 COMMONWEALTH AVE	3	8/19/2025		Newly Identified	Pending		8/19/2025	1,400	Leak Extent	
5311891	339 CHESTNUT ST	3	8/19/2025		Newly Identified	Pending		8/19/2025	3,200	Leak Extent	
5311893	776 BEACON ST	1	8/19/2025	8/19/2025	Newly Identified	Repaired					
5311899	353 WATERTOWN ST NEWTON MA	2	8/19/2025		Newly Identified	Pending					
5311914	1 WEBSTER CT	2	8/19/2025	11/19/2025	Newly Identified	Repaired					
5312069	96 WABAN ST	2	9/10/2025	10/13/2025	Newly Identified	Repaired					
5312121	3 TROY LANE	3	8/20/2025	9/24/2025	Newly Identified	Repaired		8/20/2025	1,700	Leak Extent	
5312123	299 PRINCE ST	3	8/20/2025		Newly Identified	Pending		8/20/2025	900	Leak Extent	
5312293	5 ADAMS AVENUE	2	8/21/2025	9/24/2025	Newly Identified	Repaired					
5312301	9 ADAMS AVE	3	8/21/2025		Newly Identified	Pending		8/21/2025	100	Leak Extent	
5312376	34 BROOKSIDE AVENUE	3	8/22/2025	8/27/2025	Newly Identified	Eliminated Otherwise		8/22/2025	648	Leak Extent	DUPLICATE LEAK
5312456	23 WETHERELL ST	3	8/22/2025	11/4/2025	Newly Identified	Repaired		8/22/2025	90	Leak Extent	
5312474	24 LEXINGTON STREET	3	8/22/2025		Newly Identified	Pending		8/22/2025	375	Leak Extent	
5312482	12 LEXINGTON ST	3	8/22/2025		Newly Identified	Pending		8/22/2025	25	Leak Extent	
5312510	326 RIVER ST	3	11/10/2025	11/5/2025	Newly Identified	Repaired	2	11/10/2025	1	Leak Extent	
5312516	79 FOUNTAIN ST	3	8/22/2025		Newly Identified	Pending		8/22/2025	400	Leak Extent	
5312664	1784 WASHINGTON ST	2	10/15/2025		Newly Identified	Pending	3				
5312712	543 CENTRE STREET	1	8/25/2025	8/25/2025	Newly Identified	Repaired					
5312800	75 WESTMINSTER RD	2	8/22/2025	9/19/2025	Newly Identified	Repaired					
5312841	389 CENTRAL ST	1	8/25/2025	8/29/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5312891	221 PRINCE ST	3	8/26/2025		Newly Identified	Pending		8/26/2025	3,400	Leak Extent	
5312988	260 CHESTNUT ST	3	8/26/2025		Newly Identified	Pending		8/26/2025	300	Leak Extent	
5313046	11 BARBARA RD	3	8/27/2025		Newly Identified	Pending		8/27/2025	1,200	Leak Extent	
5313275	290 DERBY ST	2	8/28/2025	10/10/2025	Newly Identified	Repaired					
5313488	116 TOLMAN ST	2	8/29/2025	9/23/2025	Newly Identified	Repaired					
5313511	76 ALBAN RD	3	8/29/2025		Newly Identified	Pending		8/29/2025	4,224	Leak Extent	
5313634	472 LOWELL AVE	1	8/31/2025	9/3/2025	Newly Identified	Repaired					
5313669	145 POND BROOK RD	1	9/1/2025	9/2/2025	Newly Identified	Repaired					
5313716	51 PONTIAC RD	2	9/2/2025	11/3/2025	Newly Identified	Repaired					
5313783	194 MILL ST	3	9/2/2025		Newly Identified	Pending		9/2/2025	2,714	Leak Extent	
5313787	7 FREDETTE RD	3	9/2/2025		Newly Identified	Pending		9/2/2025	150	Leak Extent	
5313789	17 MORTON ST	3	9/2/2025		Newly Identified	Pending		9/2/2025	1,800	Leak Extent	
5313815	303 HARTMAN RD	3	9/2/2025	9/22/2025	Newly Identified	Repaired		9/2/2025	225	Leak Extent	
5313827	54 WINDSOR RD	3	9/2/2025		Newly Identified	Pending		9/2/2025	2,400	Leak Extent	
5313829	24 FREDANA RD	3	9/2/2025		Newly Identified	Pending		9/2/2025	1,125	Leak Extent	
5313859	49 DALBY STREET	3	9/2/2025	9/24/2025	Newly Identified	Eliminated Otherwise		9/2/2025	1,584	Leak Extent	CLOSED DUE TO ANOTHER LEAK REPAIR
5313872	54 ARAPAHOE RD	3	9/2/2025		Newly Identified	Pending		9/2/2025	28	Leak Extent	
5313878	314 LANGLEY RD	2	9/28/2025	12/30/2025	Newly Identified	Repaired	3				
5314282	484 CALIFORNIA ST	1	9/4/2025	9/5/2025	Newly Identified	Repaired					
5314336	52 DALBY ST	2	9/4/2025	9/11/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5314374	57 MORRILL ST	3	9/5/2025		Newly Identified	Pending		9/5/2025	300	Leak Extent	
5314392	20 EVELYN RD	2	9/5/2025	9/17/2025	Newly Identified	Repaired					
5314418	616 BOYLSTON ST	1	9/5/2025	9/15/2025	Newly Identified	Repaired					
5314420	154 WALTHAM ST	1	9/5/2025	9/6/2025	Newly Identified	Repaired					
5314537	2088 COMMONWEALTH AVE	1	9/7/2025	9/10/2025	Newly Identified	Repaired					
5314606	256 ALBEMARLE RD	3	9/8/2025		Newly Identified	Pending		9/8/2025	800	Leak Extent	
5314830	92 BEETHOVEN AVE	3	9/9/2025		Newly Identified	Pending		9/9/2025	100	Leak Extent	
5314846	49 DALBY ST	1	9/9/2025	9/11/2025	Newly Identified	Repaired					
5314870	472 LOWELL AVE	1	8/31/2025	10/1/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)		QUARTER 4 - 2025		Name of Operator: <i>Boston & Colonial Gas Company</i>							
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5315045	96 WABAN ST	3	9/10/2025	9/15/2025	Newly Identified	Eliminated Otherwise		9/10/2025	1,800	Leak Extent	DUPLICATE LEAK
5315070	1400 WALNUT ST	3	9/10/2025		Newly Identified	Pending		9/10/2025	4,200	Leak Extent	
5315160	15 STONELEIGH RD	3	9/10/2025		Newly Identified	Pending		9/11/2025	100	Leak Extent	
5315440	23 HIGH ST	3	9/12/2025	9/15/2025	Newly Identified	Eliminated Otherwise		9/12/2025	736	Leak Extent	DUPLICATE LEAK
5315510	20 EVELYN RD	2	9/12/2025	10/1/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5315522	105 RUMFORD AVE	1	9/12/2025	9/12/2025	Newly Identified	Repaired					
5315651	50 DALBY ST	2	9/13/2025	9/24/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5315672	42 BRENTWOOD AVE	2	9/14/2025	9/30/2025	Newly Identified	Repaired					
5315901	141 GORDON RD	3	9/16/2025	11/21/2025	Newly Identified	Repaired		9/16/2025	12,925	Leak Extent	
5315931	275 GROVE ST	3	9/16/2025		Newly Identified	Pending		9/16/2025	1,575	Leak Extent	
5315977	92 DARTMOUTH STREET	2	9/16/2025	10/13/2025	Newly Identified	Repaired					
5315979	160 LINCOLN ST	1	9/16/2025	10/3/2025	Newly Identified	Repaired					
5316023	327 DEDHAM STREET	3	9/16/2025	10/1/2025	Newly Identified	Eliminated Otherwise		9/16/2025	4,550	Leak Extent	DUPLICATE LEAK
5316130	8 BRAELAND AVENUE	3	9/17/2025		Newly Identified	Pending		9/17/2025	100	Leak Extent	
5316147	49 DALBY ST	1	9/15/2025	9/19/2025	Newly Identified	Repaired					
5316155	49 DALBY ST	1	9/17/2025	9/24/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5316177	155 WOODWARD ST	3	9/17/2025		Newly Identified	Pending		9/17/2025	5,874	Leak Extent	
5316185	88 CARVER RD	3	9/17/2025		Newly Identified	Pending		9/17/2025	1,750	Leak Extent	
5316634	244 NEEDHAM ST	1	9/19/2025	9/22/2025	Newly Identified	Repaired					
5316644	155 OAK ST	3	9/19/2025	10/3/2025	Newly Identified	Eliminated Otherwise		9/19/2025	-	No CGI reading	DATA ENTRY ERROR
5316800	12 MURRAY RD	3	9/20/2025	9/29/2025	Newly Identified	Eliminated Otherwise		9/20/2025	640	Leak Extent	DUPLICATE LEAK
5317010	750 BOYLSTON ST	1	9/22/2025	9/24/2025	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
5317682	503 BOYLSTON ST	2	9/24/2025		Newly Identified	Pending					
5318036	1466 COMMONWEALTH AVE	3	9/26/2025		Newly Identified	Pending		9/26/2025	50	Leak Extent	
5318190	20 BEACON ST	3	9/27/2025		Newly Identified	Pending		9/27/2025	273	Leak Extent	
5318236	314 LANGLEY RD	2	9/28/2025	10/3/2025	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
5318240	549 CRAFTS ST	2	9/28/2025	12/11/2025	Newly Identified	Repaired					
5318250	20 GRANT AVE	3	9/28/2025	10/6/2025	Newly Identified	Eliminated Otherwise		9/28/2025	2,760	Leak Extent	DUPLICATE LEAK
5318269	1087 BEACON ST	1	9/28/2025	10/14/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)		QUARTER 4 - 2025		Name of Operator: <i>Boston & Colonial Gas Company</i>							
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5318304	62 GREEN ST	2	9/29/2025	10/13/2025	Newly Identified	Repaired					
5318312	1377 WALNUT ST	2	9/29/2025		Newly Identified	Pending					
5318320	22 BERWICK RD	3	9/29/2025		Newly Identified	Pending		9/29/2025	55	Leak Extent	
5318330	192 ELLIOT ST	1	9/29/2025	9/30/2025	Newly Identified	Repaired					
5318338	172 KIRKSTALL RD	3	9/29/2025		Newly Identified	Pending		9/29/2025	120	Leak Extent	
5318412	1608 BEACON ST	3	9/29/2025		Newly Identified	Pending		9/29/2025	6,500	Leak Extent	
5318427	34 BROOKSIDE AVE	3	9/29/2025	10/13/2025	Newly Identified	Eliminated Otherwise		9/29/2025	50	Leak Extent	DUPLICATE LEAK
5318435	74 PLEASANT ST	1	9/29/2025	10/2/2025	Newly Identified	Repaired					
5318578	11 FLORENCE STREET	3	9/30/2025		Newly Identified	Pending		9/30/2025	100	Leak Extent	
5319074	98 ALLEN AVE	1	10/2/2025	10/3/2025	Newly Identified	Repaired					
5319194	5 PHILBRICK RD	2	10/2/2025		Newly Identified	Pending					
5319230	280 CENTRAL ST	2	10/3/2025		Newly Identified	Pending					
5319256	217 PLYMOUTH RD	3	10/3/2025		Newly Identified	Pending		10/3/2025	1,386	Leak Extent	
5319368	5 MARGARET RD	2	10/4/2025		Newly Identified	Pending					
5319370	14 UPLAND RD	3	10/4/2025		Newly Identified	Pending		10/4/2025	200	Leak Extent	
5319589	325 BEACON ST	2	10/6/2025	11/19/2025	Newly Identified	Repaired					
5319638	559 CENTRE ST	3	10/6/2025	10/13/2025	Newly Identified	Eliminated Otherwise		10/6/2025	4,050	Leak Extent	DUPLICATE LEAK
5319766	190 TEMPLE ST	3	10/7/2025	10/13/2025	Newly Identified	Eliminated Otherwise		10/7/2025	1,680	Leak Extent	DUPLICATE LEAK
5319825	15 HARTMAN RD	3	10/7/2025	10/14/2025	Newly Identified	Eliminated Otherwise		10/7/2025	638	Leak Extent	DUPLICATE LEAK
5319895	326 CHERRY ST	3	10/7/2025		Newly Identified	Pending		10/8/2025	25	Leak Extent	
5319930	115 ELLIOT ST	3	10/8/2025	10/14/2025	Newly Identified	Eliminated Otherwise		10/8/2025	2,275	Leak Extent	DUPLICATE LEAK
5319972	150 WOODLAND RD	3	10/8/2025	10/14/2025	Newly Identified	Eliminated Otherwise		10/8/2025	400	Leak Extent	DUPLICATE LEAK
5320440	220 BOYLSTON ST	2	10/10/2025		Newly Identified	Pending					
5320442	250 BOYLSTON ST	2	10/10/2025		Newly Identified	Pending					
5320444	181 FLORENCE ST	2	10/10/2025	12/11/2025	Newly Identified	Repaired					
5320446	47 MOODY ST	3	10/10/2025		Newly Identified	Pending		10/10/2025	200	Leak Extent	
5320471	308 HOMER ST	3	10/10/2025		Newly Identified	Pending		10/10/2025	375	Leak Extent	
5321374	18 W PINE ST	1	10/15/2025	10/15/2025	Newly Identified	Repaired					
5321394	1784 WASHINGTON ST	2	10/15/2025	11/13/2025	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classificati on Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificat ion)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designati on Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5321499	99 ORRIS ST	3	10/16/2025		Newly Identified	Pending		10/16/2025	625	Leak Extent	
5321539	345 BOYLSTON STREET , NEWTON ..ALL MEASUREMENTS OFF THIS ADDRESS	1	10/17/2025	11/3/2025	Newly Identified	Repaired					
5321585	32 NEWELL RD	1	10/19/2025	10/17/2025	Newly Identified	Repaired					
5321587	POLE 85 NONANTUM RD	3	10/16/2025		Newly Identified	Pending		10/16/2025	400	Leak Extent	
5321618	845 WASHINGTON ST	2	10/16/2025	11/19/2025	Newly Identified	Repaired					
5321831	65 ROKEBY RD	3	10/17/2025	10/23/2025	Newly Identified	Eliminated Otherwise		10/17/2025	750	Leak Extent	DUPLICATE LEAK
5322088	1326 WASHINGTON ST	3	10/19/2025		Newly Identified	Pending		10/19/2025	768	Leak Extent	
5322344	170 AUBURNDALE AVE	1	10/22/2025	10/21/2025	Newly Identified	Repaired					
5322525	9 OLD ORCHARD RD	2	10/22/2025	11/7/2025	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
5322651	49 PRAIRIE AVE	1	10/22/2025	11/5/2025	Newly Identified	Repaired					
5322780	1535 BEACON ST	1	10/23/2025	10/23/2025	Newly Identified	Repaired					
5322867	7 ARAPAHOE RD	3	10/23/2025		Newly Identified	Pending		10/23/2025	5,850	Leak Extent	
5322995	1 RIVER AVE	3	10/23/2025		Newly Identified	Pending		10/23/2025	900	Leak Extent	
5325038	100 WALNUT ST	3	10/28/2025	11/17/2025	Newly Identified	Repaired		10/28/2025	200	Leak Extent	
5325130	516 GROVE ST	3	10/28/2025		Newly Identified	Pending		10/28/2025	900	Leak Extent	
5325152	70 GAMMONS RD	3	10/28/2025		Newly Identified	Pending		10/28/2025	250	Leak Extent	
5325469	805 COMMONWEALTH AVE	1	10/29/2025	11/3/2025	Newly Identified	Repaired					
5325615	2391 COMMONWEALTH AVE	3	10/29/2025		Newly Identified	Pending		10/26/2025	1,325	Leak Extent	
5326075	13 WINONA ST	1	10/30/2025	10/30/2025	Newly Identified	Repaired					
5326307	125 GRASMERE ST	1	10/30/2025	11/4/2025	Newly Identified	Repaired					
5326450	215 AUBURNDALE AVE	1	10/30/2025	11/3/2025	Newly Identified	Repaired					
5327226	264 PEARL ST	3	11/2/2025		Newly Identified	Pending		11/2/2025	100	Leak Extent	
5327609	98 WINCHESTER ST	1	10/24/2025	11/6/2025	Newly Identified	Repaired					
5327634	89 JACKSON RD	3	11/4/2025	11/24/2025	Newly Identified	Repaired		11/4/2025	100	Leak Extent	
5327990	BOYLSTON ST X HURLEY PL	3	11/4/2025		Newly Identified	Pending		11/4/2025	1,355	Leak Extent	
5328702	835 WASHINGTON ST	2	11/6/2025	12/9/2025	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/Barhole]	
5328779	474 CENTER ST	1	11/6/2025	11/10/2025	Newly Identified	Repaired					
5329178	80 ELM ST	1	11/8/2025	11/17/2025	Newly Identified	Repaired					
5329344	70 ELLIOT STREET	1	11/8/2025	11/19/2025	Newly Identified	Repaired					
5329924	60 CAPITAL ST	2	11/12/2025	11/24/2025	Newly Identified	Repaired					
5330064	66 WARWICK RD	1	11/12/2025	11/18/2025	Newly Identified	Repaired					
5330102	37 PLEASANT ST	3	11/12/2025		Newly Identified	Pending		11/12/2025	1,200	Leak Extent	
5330118	548 CENTRE ST	1	11/16/2025	11/18/2025	Newly Identified	Repaired					
5330157	25 CHURCH ST	1	11/13/2025	11/18/2025	Newly Identified	Repaired					
5330941	322 KENRICK ST	3	11/14/2025		Newly Identified	Pending		11/14/2025	5,250	Leak Extent	
5331250	4 ARAPAHOE RD	3	11/15/2025		Newly Identified	Pending		11/15/2025	200	Leak Extent	
5331619	45 BELMORE PARK	1	11/17/2025	11/18/2025	Newly Identified	Repaired					
5331932	255 PARKER ST	2	11/18/2025	11/24/2025	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
5331936	207 AUBURN ST	3	11/19/2025		Newly Identified	Pending		11/19/2025	350	Leak Extent	
5331961	636 BOYLSTON ST	2	11/19/2025		Newly Identified	Pending					
5332355	6 RANGELEY RD	3	11/19/2025		Newly Identified	Pending		11/20/2025	1	Leak Extent	
5332583	150 GORDON RD	2	11/20/2025		Newly Identified	Pending					
5332974	20 SOMERSET RD	3	10/27/2025		Newly Identified	Pending		10/27/2025	2,500	Leak Extent	
5333316	50 OLDE FIELD RD	3	11/23/2025	12/19/2025	Newly Identified	Eliminated Otherwise		11/23/2025	400	Leak Extent	DUPLICATE LEAK
5333330	248 ELLIOT ST	1	11/23/2025	11/26/2025	Newly Identified	Repaired					
5333795	30 LESLIE RD	2	11/25/2025	12/18/2025	Newly Identified	Repaired					
5334105	833 WASHINGTON ST	1	11/26/2025	12/2/2025	Newly Identified	Repaired					
5334452	ALBEMARLE RD	3	11/29/2025		Newly Identified	Pending		11/30/2025	2,013	Leak Extent	
5334478	907 CHESTNUT ST	2	11/30/2025	12/30/2025	Newly Identified	Repaired					
5334600	33 SCHOOL ST	1	12/1/2025	12/1/2025	Newly Identified	Repaired					
5334666	396 LEXINGTON ST	1	12/1/2025	12/2/2025	Newly Identified	Repaired					
5335075	33 SCHOOL ST	1	12/2/2025	12/3/2025	Newly Identified	Repaired					
5335111	221 PRINCE ST	3	12/2/2025		Newly Identified	Pending		12/2/2025	1,680	Leak Extent	
5335719	39 NEHOIDEN RD	1	12/3/2025	12/9/2025	Newly Identified	Repaired					
5335777	39 NEHOIDEN RD	1	12/3/2025	12/5/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)		QUARTER 4 - 2025		Name of Operator: <i>Boston & Colonial Gas Company</i>							
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
5336104	39 NEHOIDEN RD	1	12/4/2025	12/6/2025	Newly Identified	Repaired					
5336864	77 HAGEN RD	3	12/8/2025		Newly Identified	Pending		12/8/2025	600	Leak Extent	
5337346	2344 WASHINGTON ST	2	12/9/2025		Newly Identified	Pending					
5338597	250 ALBEMARLE RD	3	12/12/2025		Newly Identified	Pending		12/13/2025	2,120	Leak Extent	
5338755	580 WASHINGTON ST	3	12/14/2025		Newly Identified	Pending		12/23/2025	4,200	Leak Extent	
5339318	95 HIGHLAND AVE	1	12/16/2025	12/17/2025	Newly Identified	Repaired					
5340665	26 GEORGE ST	3	12/20/2025		Newly Identified	Pending		12/25/2025	2,187	Leak Extent	
5341057	556 QUINOBEGUM RD	3	12/21/2025		Newly Identified	Pending		12/21/2025	100	Leak Extent	
5341348	18 CLOVELLY RD	2	12/22/2025	12/29/2025	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
5341487	583 WASHINGTON ST	3	12/23/2025	12/24/2025	Newly Identified	Eliminated Otherwise		12/23/2025	4,200	Leak Extent	DUPLICATE LEAK
5341848	19 GEORGE ST	3	12/25/2025	12/31/2025	Newly Identified	Eliminated Otherwise		12/25/2025	2,187	Leak Extent	DUPLICATE LEAK
5341940	131 SARGENT ST	2	12/26/2025		Newly Identified	Pending					
5341992	47 LOS ANGELES ST	3	12/27/2025		Newly Identified	Pending		12/27/2025	96	Leak Extent	
5341994	121 WARD ST	3	12/27/2025		Newly Identified	Pending		12/27/2025	400	Leak Extent	
5342215	18 CLOVELLY RD	1	12/29/2025		Newly Identified	Pending					
5342274	315 ALBEMARLE RD	3	12/29/2025	12/31/2025	Newly Identified	Eliminated Otherwise		12/29/2025	2,275	Leak Extent	DUPLICATE LEAK
5342321	63 NEHOIDEN RD	1	12/29/2025	12/30/2025	Newly Identified	Repaired					
5342638	218 BROOKLINE ST	2	12/30/2025		Newly Identified	Pending					
6625370	27 CAMDEN RD	3	9/22/2015	1/10/2025	Carried Forward	Repaired		8/20/2024	175	Leak Extent	
6980988	83 CARVER RD	3	5/28/2019	2/4/2025	Carried Forward	Repaired		8/5/2024	3,800	Leak Extent	
7325430	9 KIRKSTALL RD	2	3/5/2025	3/18/2025	Carried Forward	Repaired					
7326329	121 DICKERMAN RD	3	6/1/2016	2/19/2025	Carried Forward	Repaired		11/19/2024	300	Leak Extent	
7326889	89 WALTHAM ST	3	6/15/2016	5/10/2025	Carried Forward	Eliminated Otherwise		3/5/2025	-	No CGI reading	NO READS
7331474	71 COMMONWEALTH AVE	3	1/3/2017	3/3/2025	Carried Forward	Repaired		11/19/2024		No CGI reading	
7336302	42 ANNAWAN RD	3	7/1/2017	1/6/2025	Carried Forward	Repaired		7/29/2024	1,080	Leak Extent	
7336365	23 DAVIS ST	3	7/15/2017	2/27/2025	Carried Forward	Repaired		11/20/2024	2,400	Leak Extent	
7336764	CENTRAL AVE & WASHINGTON ST	2	3/5/2025	4/22/2025	Carried Forward	Repaired					
7337028	100 CONCORD ST	3	8/1/2017	4/22/2025	Carried Forward	Repaired		9/3/2024	-	No CGI reading	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/Barhole]	
7341496	COMMONWEALTH AVE & AUBURN ST	3	1/12/2018	4/8/2025	Carried Forward	Repaired		11/4/2024	-	No CGI reading	
7342376	3 DANIEL ST	3	3/6/2018	2/12/2025	Carried Forward	Repaired		11/20/2024	600	Leak Extent	
7345014	7 CURTIS ST	2	11/20/2024	4/22/2025	Carried Forward	Eliminated Otherwise					DUPLICATE LEAK
7349163	CYPRESS ST & PARKER ST	3	11/15/2018	5/10/2025	Carried Forward	Eliminated Otherwise		3/5/2025	-	No CGI reading	NO READS
7353088	238 DORSET RD	3	5/6/2019	3/11/2025	Carried Forward	Repaired		8/14/2024	1,440	Leak Extent	
7354041	66 NEEDHAM ST	3	10/20/2021	4/2/2025	Carried Forward	Eliminated Otherwise		11/20/2024	-	No CGI reading	NO READS
7354537	10 DAY ST	3	7/15/2019	2/14/2025	Carried Forward	Repaired		9/3/2024	-	No CGI reading	
7354554	81 CHURCH ST	3	7/9/2019	2/12/2025	Carried Forward	Repaired		8/9/2024	2,280	Leak Extent	
7354709	20 CLAREMONT ST	3	7/16/2019	3/26/2025	Carried Forward	Repaired		9/4/2024	1,380	Leak Extent	
7355668	34 BROADLAWN DR	3	8/23/2019	2/25/2025	Carried Forward	Repaired		9/23/2024	-	No CGI reading	
7356357	12 WACHUSETT RD	3	9/25/2019	3/26/2025	Carried Forward	Repaired		2/11/2025	25	Leak Extent	
7370901	38 BARNSTABLE RD	3	9/24/2021	1/10/2025	Carried Forward	Repaired		4/25/2024	225	Leak Extent	
7371044	178 PRINCE ST	3	9/27/2021	5/10/2025	Carried Forward	Eliminated Otherwise		4/17/2025	-	No CGI reading	NO READS
7371382	212 CHESTNUT ST	3	10/9/2021	2/14/2025	Carried Forward	Repaired		4/30/2024	720	Leak Extent	
7375135	341 CABOT ST	3	5/23/2022	1/13/2025	Carried Forward	Repaired		10/11/2024	320	Leak Extent	
7376631	224 ADAMS AVE	3	8/22/2022	1/3/2025	Carried Forward	Repaired		4/30/2024	1,400	Leak Extent	
7376707	200 DERBY ST	3	8/24/2022	2/19/2025	Carried Forward	Repaired		4/30/2024	1,080	Leak Extent	
7376820	96 WESTLAND AVE	3	8/19/2022	5/10/2025	Carried Forward	Eliminated Otherwise		4/17/2025	-	No CGI reading	NO READS
7377631	364 WOODWARD ST	3	9/12/2022	4/30/2025	Carried Forward	Repaired		4/14/2025	150	Leak Extent	
7378581	HAGAR ST & CONCORD ST	3	11/4/2022	3/12/2025	Carried Forward	Repaired		6/26/2024	2,500	Leak Extent	
7378794	1370 WALNUT ST	2	4/10/2025	4/28/2025	Carried Forward	Repaired	3				
7379022	1499 WASHINGTON ST	3	12/13/2022	3/5/2025	Carried Forward	Repaired		7/25/2024	200	Leak Extent	
7379847	1818 BEACON ST	3	2/13/2023	5/7/2025	Carried Forward	Repaired		8/8/2024	2,250	Leak Extent	
7382270	53 HIGH ST	2	1/6/2025	1/27/2025	Carried Forward	Repaired					
7383501	34 BROOKSIDE AVE	3	8/17/2023	1/13/2025	Carried Forward	Repaired		5/29/2024	1,800	Leak Extent	
7383510	43 PHILBRICK RD	3	9/5/2023	5/13/2025	Carried Forward	Repaired		6/26/2024	1,200	Leak Extent	
7384585	22 BERWICK RD	3	10/15/2023	1/10/2025	Carried Forward	Repaired		7/25/2024	300	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7384931	BROOKSIDE AVE & ALBEMARLE RD	3	11/10/2023	1/16/2025	Carried Forward	Repaired		8/9/2024	112	Leak Extent	
7385308	55 FOREST AVE	3	12/9/2023	5/10/2025	Carried Forward	Eliminated Otherwise		3/5/2025	-	No CGI reading	NO READS
7385843	299 WOODLAND RD	3	1/11/2024	3/20/2025	Carried Forward	Eliminated Otherwise		10/9/2024	-	No CGI reading	NO READS
7386487	43 ELM ST	3	2/15/2024	3/26/2025	Carried Forward	Repaired		11/1/2024	470	Leak Extent	
7387138	1774 COMMONWEALTH AVE	2	12/2/2024	2/24/2025	Carried Forward	Repaired					
7387162	546 PARKER ST	3	4/10/2024	1/30/2025	Carried Forward	Repaired		11/20/2024	6,600	Leak Extent	
7387164	91 CARL ST	3	4/11/2024	2/12/2025	Carried Forward	Repaired		11/20/2024	950	Leak Extent	
7387349	57 DEVONSHIRE RD	3	4/18/2024	2/18/2025	Carried Forward	Repaired		11/19/2024	1	Leak Extent	
7387353	77 WOOD END RD	2	4/11/2025	4/24/2025	Carried Forward	Repaired	3				
7387519	477 GROVE ST	2	4/19/2024	3/19/2025	Carried Forward	Repaired					
7387779	20 BEAUMONT AVE	3	5/6/2024	1/13/2025	Carried Forward	Repaired					
7387884	336 BOYLSTON ST	2	5/16/2024	4/29/2025	Carried Forward	Eliminated Otherwise					NO READS
7387910	1026 BOYLSTON ST	2	5/13/2024	4/1/2025	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7387922	2096 WASHINGTON ST	2	5/24/2024	4/2/2025	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7388455	318 CABOT ST	3	6/25/2024	2/12/2025	Carried Forward	Repaired					
7388831	440 LEXINGTON ST	2	7/23/2024	1/2/2025	Carried Forward	Repaired					
7389707	1063 COMMONWEALTH AVE	3	9/17/2024	3/17/2025	Carried Forward	Eliminated Otherwise					NO READS
7389987	37 CLARK ST	3	9/12/2024	3/19/2025	Carried Forward	Repaired					
7390551	DALTON RD & BEACON ST	3	10/9/2024	2/14/2025	Carried Forward	Repaired		10/9/2024	168	Leak Extent	
7391104	15 SIMPSON ST	1	12/5/2024	1/15/2025	Carried Forward	Eliminated Otherwise					NOT UNDERGROUND LEAK
7391215	123 SPIERS RD	1	12/17/2024	1/3/2025	Carried Forward	Eliminated Otherwise					NO READS
7391274	54 BALLARD ST	3	12/9/2024	3/19/2025	Carried Forward	Eliminated Otherwise					SYSTEM ISSUE
7391275	54 BALLARD ST	3	12/9/2024	3/14/2025	Carried Forward	Eliminated Otherwise		12/9/2024		No CGI reading	DUPLICATE LEAK
7391374	26 BEACON ST	2	12/12/2024	5/16/2025	Carried Forward	Eliminated Otherwise					WRONG ADDRESS
7391418	700 COMMONWEALTH AVE	1	1/4/2025	1/4/2025	Newly Identified	Repaired					
7391500	58 RANGELEY RD	1	1/9/2025	1/9/2025	Newly Identified	Repaired					
7391505	15 LARCHMONT AVE	2	12/31/2024	1/28/2025	Carried Forward	Repaired					
7391530	5 ROTHERWOOD RD	1	1/10/2025	1/10/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)		QUARTER 4 - 2025		Name of Operator: <i>Boston & Colonial Gas Company</i>							
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7391537	43 RIVERDALE AVE	1	1/10/2025	1/10/2025	Newly Identified	Repaired					
7391545	43 RIVERDALE AVE	1	1/12/2025	1/12/2025	Newly Identified	Repaired					
7391596	464 CRAFTS ST	2	1/6/2025	2/5/2024	Newly Identified	Repaired					LMS Repair Date error
7391599	18 CLIFF RD	2	12/29/2024	1/27/2025	Carried Forward	Repaired					
7391602	368 ELLIOT ST	2	12/28/2024	1/28/2025	Carried Forward	Repaired					
7391606	115 ALLEN AVE	2	1/7/2025	1/30/2025	Newly Identified	Repaired					
7391609	43 RIVERDALE AVE	1	1/14/2025	1/14/2025	Newly Identified	Repaired					
7391643	949 CENTRE ST	1	1/15/2025	1/16/2025	Newly Identified	Repaired					
7391645	833 BOYLSTON ST	1	1/15/2025	1/16/2025	Newly Identified	Repaired					
7391646	5 MARGARET RD	1	1/16/2025	1/17/2025	Newly Identified	Repaired					
7391669	34 STAFFORD RD	1	1/16/2025	1/17/2025	Newly Identified	Repaired					
7391676	833 BOYLSTON ST	1	1/17/2025	1/17/2025	Newly Identified	Repaired					
7391694	45 WHITTEMORE RD	1	1/17/2025	1/17/2025	Newly Identified	Repaired					
7391696	40 HAMPSHIRE ST	1	1/17/2025	1/17/2025	Newly Identified	Repaired					
7391807	ABERDEEN ST & BOYLSTON ST	1	1/23/2025	1/24/2025	Newly Identified	Repaired					
7391842	221 WALNUT ST	1	1/24/2025	1/24/2025	Newly Identified	Repaired					
7391870	6 FOREST AVE	1	1/27/2025	1/28/2025	Newly Identified	Repaired					
7391872	45 MECHANIC ST	2	1/16/2025	2/23/2025	Newly Identified	Repaired					
7391877	18 CLIFF RD	1	1/27/2025	1/27/2025	Newly Identified	Repaired					
7391932	34 WATERSTON RD	1	1/29/2025	1/29/2025	Newly Identified	Repaired					
7391969	218 WALNUT ST	1	1/30/2025	1/31/2025	Newly Identified	Repaired					
7391987	15 ELIOT MEMORIAL RD	1	1/31/2025	2/2/2025	Newly Identified	Repaired					
7392004	454 WALNUT ST	1	1/31/2025	1/31/2025	Newly Identified	Repaired					
7392014	66 MYERSON LN	1	2/1/2025	2/2/2025	Newly Identified	Repaired					
7392035	37 RANDLETT PIKE	1	2/3/2025	2/4/2025	Newly Identified	Repaired					
7392045	451 CRAFTS ST	1	2/3/2025	2/4/2025	Newly Identified	Repaired					
7392076	956 WALNUT ST	1	2/4/2025	2/5/2025	Newly Identified	Repaired					
7392106	12 INDIAN RIDGE RD	1	2/5/2025	2/5/2025	Newly Identified	Repaired					
7392110	18 PUTNAM ST	2	1/22/2025	3/19/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classificati on Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificat ion)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designati on Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7392158	795 WASHINGTON ST	2	12/29/2024	3/19/2025	Carried Forward	Repaired					
7392175	96 OLDEFIELD RD	1	2/7/2025	2/7/2025	Newly Identified	Repaired					
7392215	15 INDIAN RIDGE RD	1	2/10/2025	2/10/2025	Newly Identified	Repaired					
7392255	64 OAKWOOD RD	1	2/11/2025	2/11/2025	Newly Identified	Repaired					
7392273	1784 WASHINGTON ST	1	2/12/2025	2/12/2025	Newly Identified	Repaired					
7392276	47 RANDLETT PIKE	2	2/2/2025	2/26/2025	Newly Identified	Repaired					
7392305	115 DORSET RD	1	2/13/2025	2/13/2025	Newly Identified	Repaired					
7392310	64 OAKWOOD RD	1	2/13/2025	2/13/2025	Newly Identified	Repaired					
7392346	62 HAWTHORN ST	1	2/16/2025	2/17/2025	Newly Identified	Repaired					
7392371	1466 COMMONWEALTH AVE	3	2/15/2025	3/7/2025	Newly Identified	Repaired					
7392389	284 WEBSTER ST	1	2/18/2025	2/20/2025	Newly Identified	Repaired					
7392460	103 HIGH ST	1	2/22/2025	2/22/2025	Newly Identified	Repaired					
7392466	45 MECHANIC ST	1	2/22/2025	2/24/2025	Newly Identified	Repaired					
7392501	130 WALTHAM ST	1	2/24/2025	2/25/2025	Newly Identified	Repaired					
7392514	24 BRAELAND AVE	1	2/25/2025	2/25/2025	Newly Identified	Repaired					
7392573	1784 WASHINGTON ST	1	2/26/2025	2/28/2025	Newly Identified	Repaired					
7392581	7 CURTIS ST	1	2/27/2025	2/27/2025	Newly Identified	Repaired					
7392583	1730 WASHINGTON ST	3	2/26/2025	3/11/2025	Newly Identified	Repaired					
7392603	BYRON RD & LAGRANGE ST	1	2/27/2025	2/27/2025	Newly Identified	Repaired					
7392638	23 WOODMAN RD	1	3/3/2025	3/1/2025	Newly Identified	Repaired					
7392640	58 GREEN PIKE	1	3/3/2025	3/1/2025	Newly Identified	Repaired					
7392648	839 WASHINGTON ST	2	2/20/2025	3/21/2025	Newly Identified	Repaired					
7392651	14 KEWADIN RD	2	2/28/2025	3/18/2025	Newly Identified	Repaired					
7392652	30 NATHAN RD	3	2/18/2025	5/19/2025	Newly Identified	Eliminated Otherwise		2/18/2025	25	Leak Extent	SYSTEM ISSUE
7392754	23 BELMORE PIKE	2	3/2/2025	3/18/2025	Newly Identified	Repaired					
7392766	326 FULLER ST	1	3/10/2025	3/10/2025	Newly Identified	Repaired					
7392769	56 VALENTINE ST	1	3/10/2025	3/11/2025	Newly Identified	Repaired					
7392772	330 WASHINGTON ST	2	3/4/2025	5/13/2025	Newly Identified	Eliminated Otherwise					NO READS
7392774	2096 WASHINGTON ST	3	2/28/2025	4/1/2025	Newly Identified	Repaired		2/28/2025	1,000	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)		QUARTER 4 - 2025		Name of Operator: <i>Boston & Colonial Gas Company</i>							
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7392858	64 CRAFTS ST	1	3/17/2025	3/17/2025	Newly Identified	Repaired					
7392875	244 NEEDHAM ST	1	3/18/2025	3/18/2025	Newly Identified	Repaired					
7392899	45 SHEFFIELD RD	1	3/19/2025	3/19/2025	Newly Identified	Repaired					
7392908	BALLARD ST & WARD ST	3	3/4/2025	4/2/2025	Newly Identified	Repaired					
7392929	290 ALBEMARLE RD	3	2/6/2025	4/2/2025	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7392933	1404 WALNUT ST	2	2/4/2025	4/24/2025	Newly Identified	Repaired					
7392936	466 LOWELL AVE	2	2/11/2025	4/1/2025	Newly Identified	Repaired					
7392937	77 HAGEN RD	2	3/4/2025	4/17/2025	Newly Identified	Repaired					
7392938	1197 WALNUT ST	2	3/12/2025	4/16/2025	Newly Identified	Repaired					
7392939	1047 WALNUT ST	2	3/14/2025	4/30/2025	Newly Identified	Repaired					
7392954	687 WATERTOWN ST	3	3/9/2025	4/25/2025	Newly Identified	Repaired		3/9/2025	5,092	Leak Extent	
7392955	256 ALBEMARLE RD	3	3/9/2025	4/4/2025	Newly Identified	Repaired		3/9/2025	4,256	Leak Extent	
7392969	367 ALBEMARLE RD	3	3/19/2025	4/25/2025	Newly Identified	Repaired		3/19/2025	2,016	Leak Extent	
7392977	1385 WALNUT ST	2	3/25/2025	4/24/2025	Newly Identified	Repaired					
7393053	1024 BOYLSTON ST	1	3/30/2025	4/4/2025	Newly Identified	Repaired					
7393060	21 CHENEY ST	1	3/31/2025	3/31/2025	Newly Identified	Repaired					
7393073	50 HIGH ST	2	3/20/2025	4/11/2025	Newly Identified	Repaired					
7393094	15 CHESTNUT TER	1	4/2/2025	4/2/2025	Newly Identified	Repaired					
7393115	25 BROADLAWN DR	1	4/3/2025	4/3/2025	Newly Identified	Repaired					
7393120	CHENEY ST & CHENEY CT	2	3/30/2025	4/7/2025	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7393162	325 WOODWARD ST	1	4/8/2025	4/8/2025	Newly Identified	Repaired					
7393200	427 LEXINGTON ST	1	4/3/2025	4/11/2025	Newly Identified	Repaired					
7393208	65 WAUWINET RD	1	4/11/2025	4/11/2025	Newly Identified	Repaired					
7393210	290 ALBEMARLE RD	3	4/4/2025	4/25/2025	Newly Identified	Repaired					
7393213	100 UPLAND RD	1	4/11/2025	4/11/2025	Newly Identified	Repaired					
7393304	38 LANGLEY RD	1	4/16/2025	4/17/2025	Newly Identified	Repaired					
7393337	138 COTTON ST	2	4/10/2025	5/7/2025	Newly Identified	Repaired					
7393500	PLEASANT ST & CHERRY ST	1	4/28/2025	4/28/2025	Newly Identified	Repaired					
7393512	155 JACKSON RD	1	4/28/2025	4/28/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
7393562	5 NORTH ST	1	4/30/2025	4/30/2025	Newly Identified	Repaired					
7393575	193 OAK ST	1	5/1/2025	5/2/2025	Newly Identified	Repaired					
7393578	12 STONELEIGH RD	1	5/1/2025	5/1/2025	Newly Identified	Repaired					
7393584	1455 BEACON ST	2	4/25/2025	5/1/2025	Newly Identified	Eliminated Otherwise					WRONG ADDRESS
7393655	193 OAK ST	1	5/5/2025	5/5/2025	Newly Identified	Repaired					
7393731	170 CHESTNUT ST	1	5/7/2025	5/8/2025	Newly Identified	Repaired					
7393830	6 CALDON PATH	1	5/13/2025	5/13/2025	Newly Identified	Repaired					
7393839	125 PRINCE ST	1	5/13/2025	5/13/2025	Newly Identified	Repaired					
7393853	507 WARD ST	1	5/14/2025	5/14/2025	Newly Identified	Repaired					
7393859	36 CHESTNUT HILL TER	1	5/14/2025	5/14/2025	Newly Identified	Repaired					
12000007	3 COLUMBUS ST	3	5/21/1993	7/11/2025	Carried Forward	Repaired		7/8/2025	250	Leak Extent	
12000033	CRAFTS ST & FESSENDEN RD	2	7/23/2025	9/29/2025	Carried Forward	Repaired	3				
12000131	1046 CHESTNUT ST	3	6/7/2017		Carried Forward	Pending		8/22/2025	375	Leak Extent	
12000132	LANGDON ST & BELLEVUE ST	3	2/26/2002	7/2/2025	Carried Forward	Repaired		8/7/2024	900	Leak Extent	
12000215	2004 BEACON ST	3	3/2/2004	7/10/2025	Carried Forward	Repaired		8/22/2024	480	Leak Extent	
12000247	207 WALTHAM ST	3	10/13/2004		Carried Forward	Pending	2	9/5/2025	25	Leak Extent	
12000280	50 DORSET RD	3	4/29/2004		Carried Forward	Pending		7/9/2025	1,800	Leak Extent	
12000281	PLYMOUTH RD & WOODWARD ST	3	4/27/2004	12/4/2025	Carried Forward	Repaired		7/8/2025	5,400	Leak Extent	
12000282	9 STRATFORD RD	3	7/1/2004		Carried Forward	Pending		11/6/2025	-	No CGI reading	
12000283	16-25 BROADLAWN DR	3	7/27/2004		Carried Forward	Pending		5/6/2025	150	Leak Extent	
12000284	55 JEFFERSON ST	3	8/13/2004		Carried Forward	Pending		9/16/2025	9	Leak Extent	
12000285	100 SUFFOLK RD	2	9/16/2025	10/21/2025	Carried Forward	Repaired	3				
12000287	124 NESHOBIE RD	3	2/14/2005		Carried Forward	Pending		11/7/2025	-	No CGI reading	
12000328	59 WACHUSETT RD	3	1/25/2006		Carried Forward	Pending	1	7/8/2025	1,400	Leak Extent	
12000353	38 LOCKSLEY RD	3	12/6/2006		Carried Forward	Pending	2	11/20/2025	1	Leak Extent	
12000367	64 PUTNAM ST	3	9/25/2006	6/30/2025	Carried Forward	Repaired		6/16/2025	1,620	Leak Extent	
12000373	10 LANGLEY RD	3	12/7/2006	6/23/2025	Carried Forward	Repaired		6/9/2025	700	Leak Extent	
12000399	40 CENTRAL TER	3	7/3/2007		Carried Forward	Pending		11/10/2025	480	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classificati on Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificat ion)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designati on Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12000400	167 MELROSE ST	3	7/31/2007	7/9/2025	Carried Forward	Repaired		2/11/2025	240	Leak Extent	
12000402	470 CALIFORNIA ST	3	8/3/2007	7/11/2025	Carried Forward	Repaired		10/11/2024	160	Leak Extent	
12000403	43 WALNUT ST	3	11/18/2014	10/3/2025	Carried Forward	Repaired	2	7/8/2025	400	Leak Extent	
12000404	315 CRAFTS ST	3	8/6/2007		Carried Forward	Pending		7/23/2025	1,500	Leak Extent	
12000405	78 WOODBINE ST	3	8/1/2007	5/30/2025	Carried Forward	Repaired		11/19/2024	375	Leak Extent	
12000406	9 T ROADWAY	3	8/6/2007	10/6/2025	Carried Forward	Repaired		9/18/2025	25	Leak Extent	
12000411	19 FENWICK RD	3	9/12/2007		Carried Forward	Pending		7/28/2025	100	Leak Extent	
12000412	4 JANET RD	3	8/23/2007	7/7/2025	Carried Forward	Repaired		9/27/2024	1,216	Leak Extent	
12000413	8 LANCASTER RD	3	8/27/2007		Carried Forward	Pending		11/6/2025	440	Leak Extent	
12000414	6 SUMNER ST	3	8/28/2007	7/9/2025	Carried Forward	Repaired		8/27/2024	1,750	Leak Extent	
12000415	167 PARKER ST	3	8/14/2007		Carried Forward	Pending		11/6/2025	150	Leak Extent	
12000416	30 PEARL ST	3	8/14/2007	7/2/2025	Carried Forward	Repaired		8/9/2024	840	Leak Extent	
12000418	32 WESSEX RD	3	8/28/2007	6/3/2025	Carried Forward	Repaired		8/13/2024	1,485	Leak Extent	
12000423	50 CHESTNUT HILL RD	3	8/23/2007		Carried Forward	Pending		7/28/2025	50	Leak Extent	
12000426	499 CRAFTS ST	3	9/4/2007		Carried Forward	Pending		7/9/2025	400	Leak Extent	
12000427	176 WABAN AVE	3	11/7/2007		Carried Forward	Pending		4/22/2025	800	Leak Extent	
12000476	64 FULLER ST	3	9/8/2008	5/30/2025	Carried Forward	Repaired		8/22/2024	2,550	Leak Extent	
12000482	116 RIDGE AVE	3	12/12/2008	7/1/2025	Carried Forward	Repaired		2/11/2025	-	No CGI reading	
12000583	25 MORSE RD	3	12/8/2009		Carried Forward	Pending		10/2/2025	1,800	Leak Extent	
12000584	216 WINSLOW RD	3	11/30/2009		Carried Forward	Pending		8/22/2025	250	Leak Extent	
12000592	15 HARTMAN RD	3	12/20/2010		Carried Forward	Pending	2	11/5/2025	-	No CGI reading	
12000630	15 ROTHERWOOD RD	3	7/10/2010	7/16/2025	Carried Forward	Eliminated by Replacement		4/14/2025	-	No CGI reading	CLOSED DUE TO MAIN REPLACEMENT
12000670	61 CENTRAL ST	3	10/8/2010		Carried Forward	Pending		7/9/2025	2,700	Leak Extent	
12000672	6 SUN HILL LN	3	10/21/2010		Carried Forward	Pending		8/22/2025	100	Leak Extent	
12000695	PARKER ST & BOYLSTON ST	3	11/19/2024		Carried Forward	Pending	2	11/6/2025	9,900	Leak Extent	
12000697	37 SHAW ST	3	2/15/2011		Carried Forward	Pending	1	11/7/2025	105	Leak Extent	
12000764	1 QUINOBEQUIN RD	3	12/15/2011		Carried Forward	Pending		11/10/2025	1,638	Leak Extent	
12000776	220 WOODWARD ST	3	3/26/2012	12/31/2025	Carried Forward	Repaired		7/15/2025	3,750	Leak Extent	
12000778	115 ELLIOT ST	1	11/4/2025	11/10/2025	Carried Forward	Repaired	3				

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classificati on Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificat ion)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designati on Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12000784	712 SAWMILL BROOK PKY	3	4/24/2012	12/23/2025	Carried Forward	Repaired		7/9/2025	2,880	Leak Extent	
12000789	23 FREDANA RD	3	5/4/2012		Carried Forward	Pending		8/4/2025	400	Leak Extent	
12000837	32 RICHARDSON ST	3	11/29/2012	12/17/2025	Carried Forward	Repaired		9/18/2025	25	Leak Extent	
12000845	1957 BEACON ST	3	2/13/2013	6/11/2025	Carried Forward	Repaired		10/9/2024	350	Leak Extent	
12000861	68 WYOMING RD	3	4/30/2013	12/19/2025	Carried Forward	Repaired		7/15/2025	2,250	Leak Extent	
12000870	WALNUT ST & HOMER ST	3	5/17/2013	7/7/2025	Carried Forward	Repaired		3/6/2025	25	Leak Extent	
12000871	WALNUT ST & LAKEWOOD RD	3	5/17/2013		Carried Forward	Pending		8/22/2025	25	Leak Extent	
12000872	62 OLDEFIELD RD	3	5/7/2013		Carried Forward	Pending		7/15/2025	3,300	Leak Extent	
12000874	242 WABAN AVE	3	5/31/2013		Carried Forward	Pending		7/9/2025	25	Leak Extent	
12000884	26 HOLMAN RD	3	6/12/2013	12/24/2025	Carried Forward	Repaired		6/16/2025	225	Leak Extent	
12000902	4 GAY ST	3	8/20/2013		Carried Forward	Pending		8/4/2025	400	Leak Extent	
12000903	40 WINDSOR RD	3	8/19/2013		Carried Forward	Pending		7/9/2025	6,300	Leak Extent	
12000904	108 WINDSOR RD	3	8/21/2013		Carried Forward	Pending		9/16/2025	1,200	Leak Extent	
12000906	102 RIDGE AVE	3	8/20/2013		Carried Forward	Pending		12/1/2025	736	Leak Extent	
12000910	5 CHANNING RD	3	8/30/2013		Carried Forward	Pending		8/21/2025	1,200	Leak Extent	
12000921	131 WINDSOR RD	3	9/30/2013		Carried Forward	Pending		8/4/2025	400	Leak Extent	
12000924	321 HAMMOND ST	3	9/9/2013		Carried Forward	Pending		7/28/2025	2,600	Leak Extent	
12000925	110 CEDAR ST	3	9/10/2013	7/10/2025	Carried Forward	Repaired		9/12/2024	750	Leak Extent	
12001065	61 SHARPE RD	3	1/23/2015		Carried Forward	Pending		7/9/2025	3,400	Leak Extent	
12001066	BEACON ST & RESERVOIR AVE	3	12/4/2014	6/27/2025	Carried Forward	Repaired		10/9/2024	500	Leak Extent	
12001075	2401 COMMONWEALTH AVE	3	11/7/2014		Carried Forward	Pending		7/28/2025	25	Leak Extent	
12001081	60 HIGHLAND ST	3	3/4/2015		Carried Forward	Pending		8/14/2025	1,350	Leak Extent	
12001100	212 GRANT AVE	3	4/9/2015		Carried Forward	Pending		7/28/2025	200	Leak Extent	
12001144	60 HIGHLAND AVE	3	3/4/2015		Carried Forward	Pending		8/14/2025	750	Leak Extent	
12001183	8 CENTRAL AVE	3	9/16/2020		Carried Forward	Pending	2	11/5/2025	-	No CGI reading	
12001240	330 CENTRAL ST	3	7/6/2015		Carried Forward	Pending		4/22/2025	250	Leak Extent	
12001264	69 PRINCE ST	3	9/29/2015		Carried Forward	Pending		7/9/2025	3,250	Leak Extent	
12001265	75 GROVE HILL AVE	3	9/29/2015		Carried Forward	Pending		7/9/2025	1,830	Leak Extent	
12001281	120 FARWELL ST	3	12/4/2015		Carried Forward	Pending		4/22/2025	1	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12001300	11 RIDGEWAY TER	3	1/21/2016		Carried Forward	Pending		7/15/2025	2,680	Leak Extent	
12001321	70 OAKDALE RD	3	3/27/2016		Carried Forward	Pending		7/15/2025	1,350	Leak Extent	
12001331	16 SOMERSET RD	2	5/29/2025	8/7/2025	Carried Forward	Repaired	3				
12001332	22 PURITAN RD	3	3/30/2016		Carried Forward	Pending		7/15/2025	1,665	Leak Extent	
12001358	604 WALNUT ST	3	4/19/2016		Carried Forward	Pending		12/1/2025	2,968	Leak Extent	
12001364	32 MELVILLE AVE	3	4/29/2016		Carried Forward	Pending		7/23/2025	1,470	Leak Extent	
12001369	1 NONANTUM ST	3	5/10/2016		Carried Forward	Pending		11/19/2025	1,475	Leak Extent	
12001392	116 OXFORD RD	3	6/10/2016		Carried Forward	Pending		4/22/2025	1,428	Leak Extent	
12001393	129 PARKER ST	3	6/10/2016		Carried Forward	Pending		4/22/2025	300	Leak Extent	
12001394	89 WINDSOR RD	3	6/10/2016		Carried Forward	Pending		4/22/2025	1,400	Leak Extent	
12001405	21 LAUDHOLM RD	3	6/17/2016		Carried Forward	Pending		4/22/2025	240	Leak Extent	
12001406	169 FULLER ST	3	6/23/2016		Carried Forward	Pending		4/22/2025	2,100	Leak Extent	
12001407	20 HOLDEN RD	3	6/28/2016		Carried Forward	Pending		10/2/2025	1,800	Leak Extent	
12001429	A ROADWAY & SPIERS RD	3	6/22/2016		Carried Forward	Pending		11/7/2025	1	Leak Extent	
12001448	111 HOBART RD	3	7/7/2016		Carried Forward	Pending		6/9/2025	1,400	Leak Extent	
12001574	NONANTUM RD & CHARLESBANK RD	3	2/1/2017		Carried Forward	Pending		9/16/2025	15,000	Leak Extent	
12001580	85 ISLINGTON RD	3	3/21/2017		Carried Forward	Pending		11/7/2025	-	No CGI reading	
12001581	COMMONWEALTH AVE & BEAUMONT AVE	3	3/23/2017		Carried Forward	Pending		6/3/2025	150	Leak Extent	
12001669	35 LLEWELLYN RD	3	6/13/2017		Carried Forward	Pending		7/23/2025	2,040	Leak Extent	
12001674	1319 CENTRE ST	3	6/23/2017		Carried Forward	Pending		6/9/2025	525	Leak Extent	
12001683	566 SAWMILL BROOK PKY	3	7/14/2017		Carried Forward	Pending		4/25/2025	4	Leak Extent	
12001687	327 DEDHAM ST	3	7/12/2017		Carried Forward	Pending		9/16/2025	4,550	Leak Extent	
12001695	12 BERTRAND RD	3	7/18/2017		Carried Forward	Pending		6/9/2025	200	Leak Extent	
12001702	6 SAMOSET RD	3	7/21/2017		Carried Forward	Pending		10/2/2025	1,600	Leak Extent	
12001726	214 CONCORD ST	3	8/1/2017		Carried Forward	Pending		8/4/2025	400	Leak Extent	
12001798	67 OAKCLIFF RD	3	9/27/2017		Carried Forward	Pending		8/8/2025	400	Leak Extent	
12001894	30 E ROADWAY	3	4/6/2018		Carried Forward	Pending		11/20/2025	1,184	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12001895	15 G ROADWAY	3	4/6/2018		Carried Forward	Pending		8/8/2025	1,380	Leak Extent	
12001958	DEDHAM ST & MEADOWBROOK RD	3	7/13/2018		Carried Forward	Pending		9/18/2025	25	Leak Extent	
12002016	12 NONANTUM ST	3	9/15/2018		Carried Forward	Pending		9/22/2025	100	Leak Extent	
12002029	63 OAKDALE RD	3	10/12/2018		Carried Forward	Pending		9/18/2025	225	Leak Extent	
12002032	393 LOWELL AVE	3	10/13/2018		Carried Forward	Pending		9/18/2025	500	Leak Extent	
12002104	15 OAK ST	3	2/1/2019		Carried Forward	Pending		9/22/2025	250	Leak Extent	
12002160	3 AUSTIN ST	3	5/15/2019		Carried Forward	Pending		6/9/2025	375	Leak Extent	
12002161	43 CENTRAL ST	3	5/8/2019		Carried Forward	Pending		7/15/2025	2,000	Leak Extent	
12002162	65 GROVE ST	3	5/8/2019		Carried Forward	Pending		7/15/2025	4,125	Leak Extent	
12002163	150 WOODLAND RD	3	5/8/2019	12/30/2025	Carried Forward	Eliminated Otherwise		11/20/2025	1	Leak Extent	NO READS PRESENT
12002164	207 AUBURN ST	3	5/17/2019	6/26/2025	Carried Forward	Repaired		8/27/2024	-	No CGI reading	
12002165	95 PINE GROVE AVE	3	5/8/2019		Carried Forward	Pending		7/28/2025	1,000	Leak Extent	
12002193	401 WINCHESTER ST	3	5/22/2019	6/20/2025	Carried Forward	Repaired		6/16/2025	1	Leak Extent	
12002224	25 HAYNES RD	3	6/4/2019	6/16/2025	Carried Forward	Repaired		8/14/2024	1	Leak Extent	
12002227	9 HIGH ST	3	6/27/2019	12/30/2025	Carried Forward	Eliminated Otherwise		11/4/2025	-	No CGI reading	NO READS PRESENT
12002232	2 KINGSTON RD	3	6/27/2019		Carried Forward	Pending		7/28/2025	2,800	Leak Extent	
12002233	254 WEBSTER ST	3	12/31/2019		Carried Forward	Pending	2	11/10/2025	1,035	Leak Extent	
12002234	1932 COMMONWEALTH AVE	3	6/24/2019		Carried Forward	Pending		7/28/2025	100	Leak Extent	
12002235	62 WALNUT PIKE	3	6/26/2019		Carried Forward	Pending		7/28/2025	25	Leak Extent	
12002251	190 TEMPLE ST	3	7/11/2019		Carried Forward	Pending		11/4/2025	-	No CGI reading	
12002252	443 WOLCOTT ST	3	7/9/2019		Carried Forward	Pending		8/4/2025	420	Leak Extent	
12002254	11 OWAISA RD	3	6/10/2019		Carried Forward	Pending		7/23/2025	2,100	Leak Extent	
12002256	559 CENTRE ST	3	7/16/2019		Carried Forward	Pending		11/20/2025	1	Leak Extent	
12002257	16 KENYON ST	3	7/19/2019		Carried Forward	Pending		8/4/2025	150	Leak Extent	
12002260	33 THE LEDGES RD	3	7/24/2019		Carried Forward	Pending		7/9/2025	5,600	Leak Extent	
12002272	57 COOK ST	3	8/12/2019		Carried Forward	Pending		8/21/2025	9	Leak Extent	
12002273	41 ORCHARD AVE	3	8/12/2019		Carried Forward	Pending		8/21/2025	1,600	Leak Extent	
12002275	47 ESTY FARM RD	3	8/2/2019		Carried Forward	Pending		7/9/2025	100	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12002277	32 SMITH AVE	3	7/25/2019		Carried Forward	Pending		8/21/2025	1,050	Leak Extent	
12002278	1928 COMMONWEALTH AVE	2	8/21/2025	9/24/2025	Carried Forward	Repaired	3				
12002279	361 THORNTON ST	2	8/21/2025	12/11/2025	Carried Forward	Repaired	3				
12002283	200 COTTON ST	3	8/22/2019		Carried Forward	Pending		8/21/2025	4,500	Leak Extent	
12002284	8 EXMOOR RD	3	8/21/2019		Carried Forward	Pending		8/21/2025	1,440	Leak Extent	
12002285	68 LITTLEFIELD RD	3	8/19/2019		Carried Forward	Pending		8/8/2025	450	Leak Extent	
12002286	205 MILL ST	3	8/22/2019		Carried Forward	Pending		8/8/2025	2,680	Leak Extent	
12002287	96 NORTH ST	3	8/19/2019		Carried Forward	Pending		8/8/2025	120	Leak Extent	
12002288	117 NORTH ST	3	8/19/2019		Carried Forward	Pending		8/8/2025	1,350	Leak Extent	
12002290	51 SHERBROOKE RD	3	8/21/2019		Carried Forward	Pending		8/8/2025	560	Leak Extent	
12002313	105 OSBORNE PATH	3	9/3/2019		Carried Forward	Pending		9/5/2025	25	Leak Extent	
12002314	26 HARWICH RD	3	9/4/2019		Carried Forward	Pending		8/22/2025	200	Leak Extent	
12002318	84 RACHEL RD	3	9/5/2019	7/22/2025	Carried Forward	Eliminated by Replacement		10/11/2024	-	No CGI reading	CLOSED DUE TO MAIN REPLACEMENT
12002319	500 DEDHAM ST	3	9/5/2019		Carried Forward	Pending		8/22/2025	100	Leak Extent	
12002320	471 DEDHAM ST	3	9/5/2019		Carried Forward	Pending		8/22/2025	25	Leak Extent	
12002323	105 HANSON RD	3	9/5/2019		Carried Forward	Pending		11/6/2025	250	Leak Extent	
12002325	40 JANE RD	3	9/25/2019		Carried Forward	Pending		8/25/2025	100	Leak Extent	
12002326	146 HAMMOND ST	3	9/25/2019		Carried Forward	Pending		9/5/2025	50	Leak Extent	
12002327	52 G ROADWAY	2	10/30/2025	12/16/2025	Carried Forward	Repaired	3				
12002329	24 OROURKE PATH	3	9/26/2019		Carried Forward	Pending		10/20/2025	448	Leak Extent	
12002345	HIGHLAND ST & DAVIS ST	3	10/15/2019		Carried Forward	Pending		9/18/2025	25	Leak Extent	
12002346	WATERTOWN ST & CRAFTS ST	3	11/19/2020		Carried Forward	Pending	2	11/19/2025	1,064	Leak Extent	
12002407	LOS ANGELES ST & CALIFORNIA ST	3	12/26/2019		Carried Forward	Pending		9/22/2025	400	Leak Extent	
12002439	26 COOK ST	3	3/30/2020		Carried Forward	Pending		5/6/2025	100	Leak Extent	
12002530	109 PRINCE ST	3	6/9/2020		Carried Forward	Pending		7/9/2025	600	Leak Extent	
12002692	23 MAPLE ST	3	5/13/2020		Carried Forward	Pending		7/15/2025	1,890	Leak Extent	
12002693	109 CABOT ST	3	7/15/2020		Carried Forward	Pending		8/8/2025	100	Leak Extent	
12002702	170 OTIS ST	3	7/15/2020		Carried Forward	Pending		9/5/2025	4,000	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)		QUARTER 4 - 2025		Name of Operator: <i>Boston & Colonial Gas Company</i>							
Leak ID	Location	Grade	Classificati on Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificat ion)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designati on Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12002720	5 PHILBRICK RD	2	3/19/2025	6/5/2025	Carried Forward	Repaired	3				
12002727	1364 WALNUT ST	3	10/9/2020		Carried Forward	Pending		4/25/2025	1	Leak Extent	
12002728	10 LOCKE RD	3	9/24/2020		Carried Forward	Pending		11/5/2025	-	No CGI reading	
12002746	48 PRINCE ST	3	12/19/2020		Carried Forward	Pending		11/19/2025	540	Leak Extent	
12002747	NORTH ST & ALBEMARLE RD	3	10/28/2020		Carried Forward	Pending		11/7/2025	100	Leak Extent	
12002749	8 BACON RD	3	11/9/2020		Carried Forward	Pending		11/19/2025	609	Leak Extent	
12002753	36 METACOMET RD	3	11/20/2020		Carried Forward	Pending		4/17/2025	100	Leak Extent	
12002937	17 COCHITUATE RD	3	5/19/2021	12/3/2025	Carried Forward	Repaired		8/8/2025	100	Leak Extent	
12002938	1330 BOYLSTON ST	2	11/20/2024	10/14/2025	Carried Forward	Repaired	3				
12002956	935 WASHINGTON ST	3	9/8/2021		Carried Forward	Pending	2	9/22/2025	3,200	Leak Extent	
12002957	415 LOWELL AVE	3	8/8/2021		Carried Forward	Pending	2	9/22/2025	200	Leak Extent	
12003106	465 CENTRE ST	3	10/23/2021		Carried Forward	Pending		12/1/2025	3,248	Leak Extent	
12003107	4 RANDOLPH ST	3	11/9/2021		Carried Forward	Pending		11/19/2025	585	Leak Extent	
12003141	28 MOODY ST	3	12/3/2021		Carried Forward	Pending		4/22/2025	100	Leak Extent	
12003181	BOYLSTON ST & HURLEY PL	3	2/22/2022		Carried Forward	Pending		8/14/2025	100	Leak Extent	
12003280	6 LINCOLN ST	2	8/21/2025	9/20/2025	Carried Forward	Repaired	3				
12003281	1994 BEACON ST	3	5/29/2022	6/12/2025	Carried Forward	Repaired		10/30/2024	380	Leak Extent	
12003282	24 LESLIE RD	3	5/11/2022		Carried Forward	Pending		8/21/2025	4	Leak Extent	
12003283	265 OTIS ST	3	5/15/2022		Carried Forward	Pending		8/22/2025	200	Leak Extent	
12003317	380 WINCHESTER ST	3	5/16/2022	6/20/2025	Carried Forward	Repaired		2/11/2025	100	Leak Extent	
12003318	33 OAK HILL ST	3	5/19/2022		Carried Forward	Pending		8/22/2025	300	Leak Extent	
12003319	275 AUBURN ST	3	6/3/2022	6/26/2025	Carried Forward	Repaired		10/30/2024	680	Leak Extent	
12003405	11 EDGE HILL RD	3	5/23/2022		Carried Forward	Pending		8/22/2025	80	Leak Extent	
12003406	146 INTERVALE RD	3	6/16/2022		Carried Forward	Pending		9/19/2025	25	Leak Extent	
12003408	14 HOMESTEAD ST	3	7/13/2022		Carried Forward	Pending		9/22/2025	1,100	Leak Extent	
12003444	1013 BEACON ST	3	7/18/2022		Carried Forward	Pending		9/18/2025	25	Leak Extent	
12003445	137 GARLAND RD	3	7/29/2022		Carried Forward	Pending		10/2/2025	1,600	Leak Extent	
12003446	4 GRAY CLIFF RD	3	7/24/2022		Carried Forward	Pending		9/18/2025	25	Leak Extent	
12003473	227 CHERRY ST	3	8/25/2022		Carried Forward	Pending		11/20/2025	578	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classificati on Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificat ion)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designati on Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12003489	232 DERBY ST	3	8/24/2022	11/25/2025	Carried Forward	Repaired		11/19/2025	1,792	Leak Extent	
12003491	195 MORTON ST	3	8/26/2022		Carried Forward	Pending		11/19/2025	629	Leak Extent	
12003492	36 NEWELL RD	3	8/19/2022		Carried Forward	Pending		11/19/2025	703	Leak Extent	
12003493	32 NOBLE ST	3	8/24/2022		Carried Forward	Pending		11/19/2025	672	Leak Extent	
12003494	222 PLEASANT ST	3	8/25/2022		Carried Forward	Pending		11/20/2025	476	Leak Extent	
12003495	45 SHERIDAN ST	3	8/18/2022		Carried Forward	Pending		11/20/2025	408	Leak Extent	
12003497	216 PLEASANT ST	3	4/3/2022		Carried Forward	Pending		8/4/2025	300	Leak Extent	
12003498	126 EASTBOURNE RD	3	4/12/2022		Carried Forward	Pending		8/21/2025	1,400	Leak Extent	
12003580	23 LONGMEADOW RD	3	9/28/2022		Carried Forward	Pending		4/22/2025	49	Leak Extent	
12003635	904 BOYLSTON ST	3	11/16/2022		Carried Forward	Pending		7/15/2025	1,440	Leak Extent	
12003664	316 CENTRAL ST	3	11/14/2023		Carried Forward	Pending		4/22/2025	450	Leak Extent	
12003668	LOWELL AVE & WASHINGTON ST	3	12/1/2022		Carried Forward	Pending		5/6/2025	125	Leak Extent	
12003690	8 EARLY PATH	3	11/15/2022		Carried Forward	Pending		5/29/2025	600	Leak Extent	
12003691	342 LEXINGTON ST	3	11/23/2022		Carried Forward	Pending		6/16/2025	2,100	Leak Extent	
12003706	138 LEXINGTON ST	2	7/23/2025	9/9/2025	Carried Forward	Repaired	3				
12003721	116 LEXINGTON ST	3	11/8/2022		Carried Forward	Pending		5/6/2025	100	Leak Extent	
12003747	9 FOREST ST	3	8/9/2022		Carried Forward	Pending		11/20/2025	800	Leak Extent	
12003750	497 BOYLSTON ST	2	11/7/2023	6/3/2025	Carried Forward	Repaired	3				
12003751	9 NARDELL RD	3	1/5/2023		Carried Forward	Pending		7/8/2025	250	Leak Extent	
12003766	255 BOYLSTON ST	2	4/30/2025	9/17/2025	Carried Forward	Repaired	1				
12003767	1607 CENTRE ST	3	12/28/2022		Carried Forward	Pending		6/16/2025	1,120	Leak Extent	
12003768	10 MOODY ST	3	12/22/2022		Carried Forward	Pending		6/16/2025	100	Leak Extent	
12003769	280 CENTRAL ST	3	1/9/2023	12/9/2025	Carried Forward	Eliminated Otherwise		6/16/2025	1,400	Leak Extent	DATA ENTRY ERROR
12003770	416 NEWTONVILLE AVE	3	1/9/2023		Carried Forward	Pending		7/8/2025	896	Leak Extent	
12003771	64 PROSPECT AVE	3	1/10/2023		Carried Forward	Pending		7/8/2025	1,700	Leak Extent	
12003779	184 WINDSOR RD	3	1/10/2023		Carried Forward	Pending		7/8/2025	2,400	Leak Extent	
12003802	249 CYPRESS ST	3	2/16/2023		Carried Forward	Pending		7/15/2025	1,400	Leak Extent	
12003806	35 KELVEDEN RD	3	3/1/2023		Carried Forward	Pending		7/9/2025	400	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12003807	152 UPLAND RD	3	2/1/2023		Carried Forward	Pending		7/23/2025	1,225	Leak Extent	
12003808	750 BOYLSTON ST	1	9/22/2025	10/14/2025	Carried Forward	Repaired	3				
12003809	760 BOYLSTON ST	3	8/7/2024		Carried Forward	Pending	1	7/8/2025	1,200	Leak Extent	
12003810	1010 BOYLSTON ST	3	2/15/2023		Carried Forward	Pending		8/14/2025	1,040	Leak Extent	
12003811	1088 BOYLSTON ST	3	2/15/2023		Carried Forward	Pending		8/14/2025	990	Leak Extent	
12003839	1880 BEACON ST	3	3/27/2023		Carried Forward	Pending		11/4/2025	81	Leak Extent	
12003840	205 HOMER ST	3	4/11/2023	9/22/2025	Carried Forward	Repaired		11/1/2024	160	Leak Extent	
12003841	MASSACHUSETTS TPKE & LOWELL AVE	3	3/18/2023		Carried Forward	Pending		8/22/2025	50	Leak Extent	
12003842	324 WINCHESTER ST	3	2/22/2023	6/30/2025	Carried Forward	Repaired		8/28/2024	960	Leak Extent	
12003884	899 WALNUT ST	3	11/14/2023		Carried Forward	Pending	2	7/23/2025	1,350	Leak Extent	
12003991	78 FARLOW RD	3	6/21/2023		Carried Forward	Pending		11/20/2025	324	Leak Extent	
12003992	243 ISLINGTON RD	3	6/20/2023		Carried Forward	Pending		11/20/2025	1,944	Leak Extent	
12004001	24 PHILBRICK RD	3	6/26/2023		Carried Forward	Pending		11/19/2025	736	Leak Extent	
12004002	264 WINCHESTER ST	3	6/9/2023	6/20/2025	Carried Forward	Repaired		4/25/2025	600	Leak Extent	
12004054	160 BOYLSTON ST	2	5/6/2024	8/28/2025	Carried Forward	Repaired	3				
12004059	100 OLDEFIELD RD	3	7/14/2023		Carried Forward	Pending		11/20/2025	3,850	Leak Extent	
12004072	146 ALBEMARLE RD	3	8/4/2023		Carried Forward	Pending		10/30/2025	225	Leak Extent	
12004073	74 BRIDGE ST	3	8/3/2023		Carried Forward	Pending		4/22/2025	100	Leak Extent	
12004074	1261 CENTRE ST	3	8/4/2023		Carried Forward	Pending		11/6/2025	480	Leak Extent	
12004075	DAVIS ST & HIGHLAND ST	3	7/26/2023		Carried Forward	Pending		4/22/2025	120	Leak Extent	
12004116	118 LANGLEY RD	3	5/12/2025	7/10/2025	Carried Forward	Repaired		5/6/2025	75	Leak Extent	
12004140	59 PONTIAC RD	3	9/21/2023		Carried Forward	Pending		5/7/2025	-	No CGI reading	
12004141	WASHINGTON ST & CENTRE ST	3	9/13/2023		Carried Forward	Pending		5/7/2025	2,500	Leak Extent	
12004209	45 HOLMAN RD	3	9/28/2023		Carried Forward	Pending		6/16/2025	200	Leak Extent	
12004210	38 MORELAND AVE	3	9/28/2023		Carried Forward	Pending		6/9/2025	300	Leak Extent	
12004285	937 DEDHAM ST	3	12/9/2023		Carried Forward	Pending		8/14/2025	1,200	Leak Extent	
12004286	20 GREENLAWN AVE	3	12/20/2023		Carried Forward	Pending		9/22/2025	4,200	Leak Extent	
12004335	69 MIDDLESEX RD	2	5/13/2025	10/14/2025	Carried Forward	Repaired	3				

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classificati on Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classificat ion)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designati on Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12004340	138 CEDAR ST	2	9/16/2025	11/17/2025	Carried Forward	Repaired	3				
12004341	141 CEDAR ST	3	2/1/2024		Carried Forward	Pending		9/5/2025	50	Leak Extent	
12004342	37 CHAPIN RD	3	2/1/2024		Carried Forward	Pending		9/24/2025	4,400	Leak Extent	
12004343	19 COLUMBUS ST	3	1/31/2024	7/1/2025	Carried Forward	Repaired		10/30/2024	750	Leak Extent	
12004344	112 EXETER ST	3	1/30/2024		Carried Forward	Pending		4/25/2025	4,800	Leak Extent	
12004345	17 CHESTER ST	3	1/31/2024		Carried Forward	Pending		9/16/2025	2,450	Leak Extent	
12004346	20 WOODSIDE RD	3	2/1/2024		Carried Forward	Pending		9/16/2025	1,050	Leak Extent	
12004353	315 TREMONT ST	3	2/7/2024		Carried Forward	Pending		9/16/2025	9	Leak Extent	
12004380	620 GROVE ST	3	2/21/2024		Carried Forward	Pending		9/18/2025	300	Leak Extent	
12004381	12 MURRAY RD	2	9/20/2025	10/15/2025	Carried Forward	Repaired	3				
12004438	65 WILDE RD	3	4/1/2024		Carried Forward	Pending		10/2/2025	2,250	Leak Extent	
12004445	991 BOYLSTON ST	3	6/13/2024		Carried Forward	Pending		5/6/2025	24	Leak Extent	
12004519	29 LINDEN ST	3	4/18/2024		Carried Forward	Pending		9/22/2025	1,200	Leak Extent	
12004572	40 CHASKE AVE	3	4/22/2024		Carried Forward	Pending		11/10/2025	3,953	Leak Extent	
12004573	9 ELLIOT ST	3	4/29/2024		Carried Forward	Pending		11/10/2025	2,115	Leak Extent	
12004574	56 UPLAND RD	3	4/17/2024	5/29/2025	Carried Forward	Repaired		11/19/2024	684	Leak Extent	
12004575	405 WOLCOTT ST	3	4/21/2024		Carried Forward	Pending		9/22/2025	375	Leak Extent	
12004600	156 OAK ST	3	5/14/2024		Carried Forward	Pending		11/20/2025	648	Leak Extent	
12004607	82 ALBEMARLE RD	3	5/2/2024		Carried Forward	Pending		11/19/2025	2,256	Leak Extent	
12004629	24 OAKCLIFF RD	3	5/14/2024		Carried Forward	Pending		11/20/2025	868	Leak Extent	
12004637	1042 BOYLSTON ST	2	11/3/2025		Carried Forward	Pending	3				
12004691	ELLIOT ST & RIVER AVE	3	6/13/2024		Carried Forward	Pending		5/6/2025	95	Leak Extent	
12004692	1119 WALNUT ST	3	6/13/2024		Carried Forward	Pending		5/6/2025	115	Leak Extent	
12004712	320 WASHINGTON ST	3	6/25/2024		Carried Forward	Pending		5/6/2025	-	No CGI reading	
12004714	74 ERIE AVE	2	5/6/2025	6/12/2025	Carried Forward	Repaired	3				
12004724	368 BOYLSTON ST	3	9/23/2024	7/22/2025	Carried Forward	Eliminated Otherwise		9/23/2024	495	Leak Extent	CLOSED DUE TO CISBOT
12004796	212 TEMPLE ST	3	7/24/2024		Carried Forward	Pending		5/29/2025	800	Leak Extent	
12004844	100 BOYLSTON ST	2	8/14/2024	8/27/2025	Carried Forward	Repaired					
12004845	32 SUFFOLK RD	3	8/13/2024		Carried Forward	Pending		7/15/2025	1,225	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12004851	39 NEHOIDEN RD	3	8/17/2024		Carried Forward	Pending		7/15/2025	1,400	Leak Extent	
12004871	269 HIGHLAND ST	3	8/21/2024		Carried Forward	Pending		11/6/2025	-	No CGI reading	
12004872	33 ORIENT AVE	2	8/26/2024	7/31/2025	Carried Forward	Repaired					
12004873	15 UPLAND RD	3	8/25/2024		Carried Forward	Pending		9/5/2025	25	Leak Extent	
12004894	92 WALKER ST	3	9/2/2024		Carried Forward	Pending		8/14/2025	1,170	Leak Extent	
12004947	20 WOODCHESTER DR	3	9/13/2024	6/16/2025	Carried Forward	Repaired					
12004948	15 LAWRENCE RD	3	9/15/2024		Carried Forward	Pending		11/7/2025	-	No CGI reading	
12004953	1297 WALNUT ST	2	8/14/2025	9/17/2025	Carried Forward	Repaired	3				
12004956	379 HAMMOND ST	3	9/16/2024		Carried Forward	Pending		8/8/2025	945	Leak Extent	
12004976	87 CHARLEMONT ST	3	9/18/2024		Carried Forward	Pending		8/8/2025	1,125	Leak Extent	
12004991	23 HIGH ST	3	8/12/2024		Carried Forward	Pending		9/12/2025	736	Leak Extent	
12005025	40 ROYCE RD	3	9/23/2024		Carried Forward	Pending		8/8/2025	400	Leak Extent	
12005131	1669 CENTRE ST	3	10/23/2024		Carried Forward	Pending		9/5/2025	25	Leak Extent	
12005133	160 PARKER ST	3	10/23/2024		Carried Forward	Pending		9/5/2025	25	Leak Extent	
12005248	391 DEDHAM ST	3	10/28/2024		Carried Forward	Pending		9/5/2025	25	Leak Extent	
12005255	168 RIVER ST	3	11/2/2024		Carried Forward	Pending		9/16/2025	2,200	Leak Extent	
12005279	569 SAWMILL BROOK PKY	3	11/17/2024		Carried Forward	Pending		9/22/2025	270	Leak Extent	
12005307	22 TRAVERSE ST	3	11/22/2024		Carried Forward	Pending		10/2/2025	4	Leak Extent	
12005345	300 BOYLSTON ST	3	12/5/2024		Carried Forward	Pending		11/10/2025	400	Leak Extent	
12005346	46 CEDAR ST	3	12/11/2024		Carried Forward	Pending		10/2/2025	2,200	Leak Extent	
12005355	1802 BEACON ST	3	12/22/2024		Carried Forward	Pending		10/2/2025	3,000	Leak Extent	
12005411	24 SOLON ST	3	4/25/2025	6/9/2025	Carried Forward	Repaired	2	4/25/2025	1,600	Leak Extent	
12005418	5 SHELDON RD	2	1/12/2025	9/11/2025	Newly Identified	Repaired					
12005421	101 WALKER ST	3	12/28/2024		Carried Forward	Pending		10/2/2025	1,600	Leak Extent	
12005448	187 VARICK RD	3	1/15/2025		Newly Identified	Pending		10/20/2025	375	Leak Extent	
12005449	25 PINE GROVE AVE	3	1/15/2025		Newly Identified	Pending		10/20/2025	1,000	Leak Extent	
12005471	129 DORSET RD	3	1/16/2025		Newly Identified	Pending		10/20/2025	450	Leak Extent	
12005477	25 WAUWINET RD	3	1/17/2025	11/19/2025	Newly Identified	Repaired		10/20/2025	800	Leak Extent	
12005490	316 WOODWARD ST	3	1/24/2025		Newly Identified	Pending		10/20/2025	400	Leak Extent	

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12005492	337 CALIFORNIA ST	3	1/25/2025		Newly Identified	Pending		10/20/2025	400	Leak Extent	
12005501	221 CYPRESS ST	3	1/24/2025		Newly Identified	Pending		10/20/2025	800	Leak Extent	
12005510	15 LARCHMONT AVE	3	1/30/2025		Newly Identified	Pending		10/20/2025	200	Leak Extent	
12005511	150 WINCHESTER ST	3	1/31/2025	9/25/2025	Newly Identified	Repaired		1/31/2025	100	Leak Extent	
12005512	91 CORNELL ST	3	1/31/2025		Newly Identified	Pending		10/20/2025	200	Leak Extent	
12005514	43 FALMOUTH RD	3	2/4/2025	7/2/2025	Newly Identified	Repaired		2/4/2025	25	Leak Extent	
12005531	1400 CENTRE ST	3	2/10/2025		Newly Identified	Pending		10/30/2025	4,154	Leak Extent	
12005532	180 WINDSOR RD	3	2/6/2025		Newly Identified	Pending		11/4/2025	2,060	Leak Extent	
12005533	37 BALDPATE HILL RD	3	2/10/2025		Newly Identified	Pending		10/30/2025	2,511	Leak Extent	
12005565	180 WINCHESTER ST	3	2/14/2025	6/20/2025	Newly Identified	Repaired					
12005580	16 FARINA RD	3	2/21/2025		Newly Identified	Pending		10/30/2025	1,221	Leak Extent	
12005608	77 CORNELL ST	3	3/6/2025		Newly Identified	Pending		12/18/2025	2,000	Leak Extent	
12005631	54 BALLARD ST	3	12/9/2024		Carried Forward	Pending		4/25/2025	450	Leak Extent	
12005634	179 WASHINGTON ST	3	3/13/2025		Newly Identified	Pending		11/7/2025	100	Leak Extent	
12005640	487 BOYLSTON ST	2	2/11/2025	7/22/2025	Newly Identified	Eliminated by Replacement					CLOSED DUE TO MAIN REPLACEMENT
12005642	WOODSIDE RD & MILL ST	3	3/5/2025		Newly Identified	Pending		4/25/2025	1,200	Leak Extent	
12005643	11 GARRISON ST	3	3/10/2025		Newly Identified	Pending		11/6/2025	750	Leak Extent	
12005648	206 WINSLOW RD	3	3/15/2025		Newly Identified	Pending		11/6/2025	300	Leak Extent	
12005667	346 WINCHESTER ST	3	3/26/2025	9/22/2025	Newly Identified	Repaired		3/26/2025	120	Leak Extent	
12005675	21 CHERRY ST	2	3/30/2025	7/14/2025	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
12005677	20 GRANT AVE	3	3/31/2025		Newly Identified	Pending		11/10/2025	2,303	Leak Extent	
12005678	75 WESTMINSTER RD	3	3/28/2025		Newly Identified	Pending		11/10/2025	1,296	Leak Extent	
12005725	127 WOODLAND RD	3	4/10/2025		Newly Identified	Pending		11/10/2025	4,836	Leak Extent	
12005736	65 ROKEBY RD	3	4/16/2025		Newly Identified	Pending		11/19/2025	782	Leak Extent	
12005738	161 DICKERMAN RD	3	4/10/2025		Newly Identified	Pending		11/10/2025	1	Leak Extent	
12005805	53 LINDEN ST	3	4/17/2025		Newly Identified	Pending		11/19/2025	2,912	Leak Extent	
12005843	85 MONTVALE RD	3	4/24/2025		Newly Identified	Pending				Survey to be provided	
12005858	1392 BEACON ST	3	4/24/2025		Newly Identified	Pending		4/24/2025	5,500	Leak Extent	
12005859	61 WALNUT HILL RD	2	4/30/2025	5/29/2025	Newly Identified	Repaired					

Table L6 Newton Leak Report Dec 31, 2025

Detailed Quarterly Information (Rev. 7/2019)											
QUARTER 4 - 2025						Name of Operator: <i>Boston & Colonial Gas Company</i>					
Leak ID	Location	Grade	Classification Date	Repair Date	Carried Forward/ Newly Identified	Status at End of Quarter	Prior Grade (if change in classification)	For G3SEI Leaks			Notes/Explanations
	Street Number and Name							Survey Designation Date	Leak Extent or Barhole Reading	Method Used [Leak Extent/ Barhole]	
12005860	52 ATHELSTANE RD	2	4/29/2025	5/29/2025	Newly Identified	Repaired					
12005862	19 STONELEIGH RD	3	4/27/2025		Newly Identified	Pending		4/27/2025	920	Leak Extent	
12005864	81 CHURCH ST	3	4/28/2025	10/6/2025	Newly Identified	Repaired		4/28/2025	1,950	Leak Extent	
12005866	14 KEWADIN RD	2	4/24/2025	5/29/2025	Newly Identified	Repaired					
12005944	710 WALNUT ST	3	5/1/2025	7/7/2025	Newly Identified	Repaired		5/1/2025	4,400	Leak Extent	
12006006	23 WOODMAN RD	3	5/7/2025		Newly Identified	Pending				Survey to be provided	
12006010	5 ANGLIER CIR	3	5/12/2025		Newly Identified	Pending				Survey to be provided	
12006012	WOODLAND RD & WINDERMERE RD	3	5/13/2025		Newly Identified	Pending				Survey to be provided	
12006014	5 VISTA AVE	3	5/13/2025		Newly Identified	Pending				Survey to be provided	
12006016	620 GROVE ST	3	5/2/2025		Newly Identified	Pending				Survey to be provided	
12006021	192 LINCOLN ST	3	5/7/2025		Newly Identified	Pending				Survey to be provided	
12006051	1730 WASHINGTON ST	2	5/12/2025	5/29/2025	Newly Identified	Repaired					
12006059	1022 BEACON ST	1	5/16/2025	7/3/2025	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
12006062	904 CENTRE ST	2	5/12/2025	6/3/2025	Newly Identified	Repaired					
12006063	118 LANGLEY RD	2	5/11/2025	7/10/2025	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
12006072	30 NATHAN RD	3	2/28/2025		Newly Identified	Pending		10/30/2025	1	Leak Extent	
12006084	77 HAGEN RD	3	5/12/2025		Newly Identified	Pending				Survey to be provided	
12006085	9 WOODMAN RD	1	5/20/2025	5/30/2025	Newly Identified	Repaired					
12006086	26 HURLEY PL	3	5/6/2025		Newly Identified	Pending				Survey to be provided	
12006094	37 MAYFLOWER RD	1	5/20/2025	5/30/2025	Newly Identified	Repaired					
12006102	267 PEARL ST	1	5/20/2025	5/26/2025	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7391807	ABERDEEN ST & BOYLSTON ST	1	2025-01-23	2025-01-24	Newly Identified	Repaired					
5312293	5 ADAMS AVENUE	2	2025-08-21	2025-09-24	Newly Identified	Repaired					
7376631	224 ADAMS AVE	3	2022-08-22	2025-01-03	Carried Forward	Repaired		2024-04-30	1400	Leak Extent	
304327	ALBEMARLE RD & WATERTOWN ST	3	2007-08-15	2025-04-25	Carried Forward	Repaired		2024-07-11	200	Leak Extent	
5311505	ALBEMARLE RD	1	2025-08-15	2025-09-15	Newly Identified	Repaired					
7392955	256 ALBEMARLE RD	3	2025-03-09	2025-04-04	Newly Identified	Repaired		2025-03-09	4256	Leak Extent	
7392929	290 ALBEMARLE RD	3	2025-02-06	2025-04-02	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7393210	290 ALBEMARLE RD	3	2025-04-04	2025-04-25	Newly Identified	Repaired					
5342274	315 ALBEMARLE RD	3	2025-12-29	2025-12-31	Newly Identified	Eliminated Otherwise		2025-12-29	2275	Leak Extent	DUPLICATE LEAK
7392969	367 ALBEMARLE RD	3	2025-03-19	2025-04-25	Newly Identified	Repaired		2025-03-19	2016	Leak Extent	
5309030	82 ALLEN AVE	1	2025-07-31	2025-08-01	Newly Identified	Repaired					
5319074	98 ALLEN AVE	1	2025-10-02	2025-10-03	Newly Identified	Repaired					
7391606	115 ALLEN AVE	2	2025-01-07	2025-01-30	Newly Identified	Repaired					
7336302	42 ANNAWAN RD	3	2017-07-01	2025-01-06	Carried Forward	Repaired		2024-07-29	1080	Leak Extent	
5301264	34 ANTHONY RD	2	2025-06-04	2025-08-20	Newly Identified	Repaired					
5309897	4 ARAPAHOE RD	2	2025-08-06	2025-09-02	Newly Identified	Repaired					
12005860	52 ATHELSTANE RD	2	2025-04-29	2025-05-29	Newly Identified	Repaired					
12002164	207 AUBURN ST	3	2019-05-17	2025-06-26	Carried Forward	Repaired		2024-08-27	0	No CGI reading	
12003319	275 AUBURN ST	3	2022-06-03	2025-06-26	Carried Forward	Repaired		2024-10-30	680	Leak Extent	
5322344	170 AUBURNDALE AVE	1	2025-10-22	2025-10-21	Newly Identified	Repaired					
5310041	215 AUBURNDALE AVE	2	2025-08-07	2025-11-05	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5326450	215 AUBURNDALE AVE	1	2025-10-30	2025-11-03	Newly Identified	Repaired					
271180	63 AVONDALE RD	3	2005-02-01	2025-03-05	Carried Forward	Repaired		2024-08-07	200	Leak Extent	
7392908	BALLARD ST & WARD ST	3	2025-03-04	2025-04-02	Newly Identified	Repaired					
7391274	54 BALLARD ST	3	2024-12-09	2025-03-19	Carried Forward	Eliminated Otherwise					SYSTEM ISSUE
7391275	54 BALLARD ST	3	2024-12-09	2025-03-14	Carried Forward	Eliminated Otherwise		2024-12-09		No CGI reading	DUPLICATE LEAK
7370901	38 BARNSTABLE RD	3	2021-09-24	2025-01-10	Carried Forward	Repaired		2024-04-25	225	Leak Extent	
12001066	BEACON ST & RESERVOIR AVE	3	2014-12-04	2025-06-27	Carried Forward	Repaired		2024-10-09	500	Leak Extent	
7391374	26 BEACON ST	2	2024-12-12	2025-05-16	Carried Forward	Eliminated Otherwise					WRONG ADDRESS
5319589	325 BEACON ST	2	2025-10-06	2025-11-19	Newly Identified	Repaired					
5311893	776 BEACON ST	1	2025-08-19	2025-08-19	Newly Identified	Repaired					
5308172	929 BEACON ST	2	2025-07-23	2025-08-21	Newly Identified	Repaired					
5310034	942 BEACON ST	2	2025-08-07	2025-09-11	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5307362	945 BEACON ST	1	2025-07-18	2025-07-25	Newly Identified	Repaired					
5307650	945 BEACON ST	2	2025-07-21	2025-09-11	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
12006059	1022 BEACON ST	1	2025-05-16	2025-07-03	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
5318269	1087 BEACON ST	1	2025-09-28	2025-10-14	Newly Identified	Repaired					
7393584	1455 BEACON ST	2	2025-04-25	2025-05-01	Newly Identified	Eliminated Otherwise					WRONG ADDRESS
5322780	1535 BEACON ST	1	2025-10-23	2025-10-23	Newly Identified	Repaired					
5309699	1671 BEACON ST	2	2025-08-05	2025-08-28	Newly Identified	Repaired					
7379847	1818 BEACON ST	3	2023-02-13	2025-05-07	Carried Forward	Repaired		2024-08-08	2250	Leak Extent	
12000845	1957 BEACON ST	3	2013-02-13	2025-06-11	Carried Forward	Repaired		2024-10-09	350	Leak Extent	
12003281	1994 BEACON ST	3	2022-05-29	2025-06-12	Carried Forward	Repaired		2024-10-30	380	Leak Extent	
12000215	2004 BEACON ST	3	2004-03-02	2025-07-10	Carried Forward	Repaired		2024-08-22	480	Leak Extent	
7387779	20 BEAUMONT AVE	3	2024-05-06	2025-01-13	Carried Forward	Repaired					
7392754	23 BELMORE PIKE	2	2025-03-02	2025-03-18	Newly Identified	Repaired					
5331619	45 BELMORE PARK	1	2025-11-17	2025-11-18	Newly Identified	Repaired					
329823	41 BERKELEY ST	3	2009-12-04	2025-01-13	Carried Forward	Repaired		2024-06-26	100	Leak Extent	
7384585	22 BERWICK RD	3	2023-10-15	2025-01-10	Carried Forward	Repaired		2024-07-25	300	Leak Extent	
12004844	100 BOYLSTON ST	2	2024-08-14	2025-08-27	Carried Forward	Repaired					
12004054	160 BOYLSTON ST	2	2024-05-06	2025-08-28	Carried Forward	Repaired	3				
12003766	255 BOYLSTON ST	2	2025-04-30	2025-09-17	Carried Forward	Repaired	1				
7387884	336 BOYLSTON ST	2	2024-05-16	2025-04-29	Carried Forward	Eliminated Otherwise					NO READS
5321539	345 BOYLSTON STREET , NEWTON ..ALL MEASUREMENTS OFF THIS ADDRESS	1	2025-10-17	2025-11-03	Newly Identified	Repaired					
12004724	368 BOYLSTON ST	3	2024-09-23	2025-07-22	Carried Forward	Eliminated Otherwise		2024-09-23	495	Leak Extent	CLOSED DUE TO CISBOT
5307881	392 BOYLSTON STREET	1	2025-07-22	2025-07-25	Newly Identified	Repaired					
12005640	487 BOYLSTON ST	2	2025-02-11	2025-07-22	Newly Identified	Eliminated by Replacement					CLOSED DUE TO MAIN REPLACEMENT
12003750	497 BOYLSTON ST	2	2023-11-07	2025-06-03	Carried Forward	Repaired	3				
5314418	616 BOYLSTON ST	1	2025-09-05	2025-09-15	Newly Identified	Repaired					
12003808	750 BOYLSTON ST	1	2025-09-22	2025-10-14	Carried Forward	Repaired	3				
5317010	750 BOYLSTON ST	1	2025-09-22	2025-09-24	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
5303266	831 BOYLSTON ST	1	2025-06-18	2025-06-19	Newly Identified	Repaired					
7391645	833 BOYLSTON ST	1	2025-01-15	2025-01-16	Newly Identified	Repaired					
7391676	833 BOYLSTON ST	1	2025-01-17	2025-01-17	Newly Identified	Repaired					
7393053	1024 BOYLSTON ST	1	2025-03-30	2025-04-04	Newly Identified	Repaired					
7387910	1026 BOYLSTON ST	2	2024-05-13	2025-04-01	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
12002938	1330 BOYLSTON ST	2	2024-11-20	2025-10-14	Carried Forward	Repaired	3				
7392514	24 BRAELAND AVE	1	2025-02-25	2025-02-25	Newly Identified	Repaired					
5315672	42 BRENTWOOD AVE	2	2025-09-14	2025-09-30	Newly Identified	Repaired					
7393115	25 BROADLAWN DR	1	2025-04-03	2025-04-03	Newly Identified	Repaired					
7355668	34 BROADLAWN DR	3	2019-08-23	2025-02-25	Carried Forward	Repaired		2024-09-23	0	No CGI reading	

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7384931	BROOKSIDE AVE & ALBEMARLE RD	3	2023-11-10	2025-01-16	Carried Forward	Repaired		2024-08-09	112	Leak Extent	
7383501	34 BROOKSIDE AVE	3	2023-08-17	2025-01-13	Carried Forward	Repaired		2024-05-29	1800	Leak Extent	
5312376	34 BROOKSIDE AVENUE	3	2025-08-22	2025-08-27	Newly Identified	Eliminated Otherwise		2025-08-22	648	Leak Extent	DUPLICATE LEAK
5318427	34 BROOKSIDE AVE	3	2025-09-29	2025-10-13	Newly Identified	Eliminated Otherwise		2025-09-29	50	Leak Extent	DUPLICATE LEAK
5308290	85 BROOKSIDE AVE	2	2025-07-24	2025-08-28	Newly Identified	Repaired					
7392603	BYRON RD & LAGRANGE ST	1	2025-02-27	2025-02-27	Newly Identified	Repaired					
7388455	318 CABOT ST	3	2024-06-25	2025-02-12	Carried Forward	Repaired					
7375135	341 CABOT ST	3	2022-05-23	2025-01-13	Carried Forward	Repaired		2024-10-11	320	Leak Extent	
7393830	6 CALDON PATH	1	2025-05-13	2025-05-13	Newly Identified	Repaired					
12000402	470 CALIFORNIA ST	3	2007-08-03	2025-07-11	Carried Forward	Repaired		2024-10-11	160	Leak Extent	
5314282	484 CALIFORNIA ST	1	2025-09-04	2025-09-05	Newly Identified	Repaired					
6625370	27 CAMDEN RD	3	2015-09-22	2025-01-10	Carried Forward	Repaired		2024-08-20	175	Leak Extent	
5329924	60 CAPITAL ST	2	2025-11-12	2025-11-24	Newly Identified	Repaired					
7387164	91 CARL ST	3	2024-04-11	2025-02-12	Carried Forward	Repaired		2024-11-20	950	Leak Extent	
6980988	83 CARVER RD	3	2019-05-28	2025-02-04	Carried Forward	Repaired		2024-08-05	3800	Leak Extent	
5308688	26 CEDAR ST	2	2025-07-28	2025-08-30	Newly Identified	Repaired					
12000925	110 CEDAR ST	3	2013-09-10	2025-07-10	Carried Forward	Repaired		2024-09-12	750	Leak Extent	
12004340	138 CEDAR ST	2	2025-09-16	2025-11-17	Carried Forward	Repaired	3				
7336764	CENTRAL AVE & WASHINGTON ST	2	2025-03-05	2025-04-22	Carried Forward	Repaired					
12003769	280 CENTRAL ST	3	2023-01-09	2025-12-09	Carried Forward	Eliminated Otherwise		2025-06-16	1400	Leak Extent	DATA ENTRY ERROR
5302282	389 CENTRAL ST	2	2025-06-11	2025-08-29	Newly Identified	Repaired					
5312841	389 CENTRAL ST	1	2025-08-25	2025-08-29	Newly Identified	Repaired					
5328779	474 CENTER ST	1	2025-11-06	2025-11-10	Newly Identified	Repaired					
5312712	543 CENTRE STREET	1	2025-08-25	2025-08-25	Newly Identified	Repaired					
5330118	548 CENTRE ST	1	2025-11-16	2025-11-18	Newly Identified	Repaired					
5319638	559 CENTRE ST	3	2025-10-06	2025-10-13	Newly Identified	Eliminated Otherwise		2025-10-06	4050	Leak Extent	DUPLICATE LEAK
5302038	790 CENTRE ST	1	2025-06-10	2025-06-10	Newly Identified	Repaired					
12006062	904 CENTRE ST	2	2025-05-12	2025-06-03	Newly Identified	Repaired					
7391643	949 CENTRE ST	1	2025-01-15	2025-01-16	Newly Identified	Repaired					
5307674	1317 CENTRE ST	2	2025-07-21	2025-09-11	Newly Identified	Repaired					
5304382	63 CHAPEL ST	2	2025-06-27	2025-08-14	Newly Identified	Repaired					
7393120	CHENEY ST & CHENEY CT	2	2025-03-30	2025-04-07	Newly Identified	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7393060	21 CHENEY ST	1	2025-03-31	2025-03-31	Newly Identified	Repaired					
12005675	21 CHERRY ST	2	2025-03-30	2025-07-14	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
337057	327 CHERRY ST	2	2024-04-30	2025-03-21	Carried Forward	Repaired					
5310947	32 CHESLEY RD	2	2025-08-13	2025-10-02	Newly Identified	Repaired					
7393859	36 CHESTNUT HILL TER	1	2025-05-14	2025-05-14	Newly Identified	Repaired					

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7393731	170 CHESTNUT ST	1	2025-05-07	2025-05-08	Newly Identified	Repaired					
7371382	212 CHESTNUT ST	3	2021-10-09	2025-02-14	Carried Forward	Repaired		2024-04-30	720	Leak Extent	
5334478	907 CHESTNUT ST	2	2025-11-30	2025-12-30	Newly Identified	Repaired					
7393094	15 CHESTNUT TER	1	2025-04-02	2025-04-02	Newly Identified	Repaired					
5330157	25 CHURCH ST	1	2025-11-13	2025-11-18	Newly Identified	Repaired					
7354554	81 CHURCH ST	3	2019-07-09	2025-02-12	Carried Forward	Repaired		2024-08-09	2280	Leak Extent	
12005864	81 CHURCH ST	3	2025-04-28	2025-10-06	Newly Identified	Repaired		2025-04-28	1950	Leak Extent	
7354709	20 CLAREMONT ST	3	2019-07-16	2025-03-26	Carried Forward	Repaired		2024-09-04	1380	Leak Extent	
7389987	37 CLARK ST	3	2024-09-12	2025-03-19	Carried Forward	Repaired					
7391599	18 CLIFF RD	2	2024-12-29	2025-01-27	Carried Forward	Repaired					
7391877	18 CLIFF RD	1	2025-01-27	2025-01-27	Newly Identified	Repaired					
5341348	18 CLOVELLY RD	2	2025-12-22	2025-12-29	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
12002937	17 COCHITUATE RD	3	2021-05-19	2025-12-03	Carried Forward	Repaired		2025-08-08	100	Leak Extent	
5309697	50 COLLEGE RD	2	2025-08-05	2025-09-24	Newly Identified	Repaired					
12000007	3 COLUMBUS ST	3	1993-05-21	2025-07-11	Carried Forward	Repaired		2025-07-08	250	Leak Extent	
12004343	19 COLUMBUS ST	3	2024-01-31	2025-07-01	Carried Forward	Repaired		2024-10-30	750	Leak Extent	
7341496	COMMONWEALTH AVE & AUBURN ST	3	2018-01-12	2025-04-08	Carried Forward	Repaired		2024-11-04	0	No CGI reading	
5309935	41 COMMONWEALTH AVE	1	2025-08-06	2025-08-13	Newly Identified	Repaired					
7331474	71 COMMONWEALTH AVE	3	2017-01-03	2025-03-03	Carried Forward	Repaired		2024-11-19		No CGI reading	
427378	692 COMMONWEALTH AVE	3	2011-10-07	2025-03-17	Carried Forward	Eliminated Otherwise		2025-02-11	0	No CGI reading	NO READS
7391418	700 COMMONWEALTH AVE	1	2025-01-04	2025-01-04	Newly Identified	Repaired					
5325469	805 COMMONWEALTH AVE	1	2025-10-29	2025-11-03	Newly Identified	Repaired					
7389707	1063 COMMONWEALTH AVE	3	2024-09-17	2025-03-17	Carried Forward	Eliminated Otherwise					NO READS
7392371	1466 COMMONWEALTH AVE	3	2025-02-15	2025-03-07	Newly Identified	Repaired					
5309687	1633 COMMONWEALTH AVE	1	2025-08-05	2025-08-07	Newly Identified	Repaired					
7387138	1774 COMMONWEALTH AVE	2	2024-12-02	2025-02-24	Carried Forward	Repaired					
270413	1812 COMMONWEALTH AV	3	2004-05-18	2025-04-25	Carried Forward	Eliminated Otherwise		2024-08-07	350	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
12002278	1928 COMMONWEALTH AVE	2	2025-08-21	2025-09-24	Carried Forward	Repaired	3				
5314537	2088 COMMONWEALTH AVE	1	2025-09-07	2025-09-10	Newly Identified	Repaired					
7337028	100 CONCORD ST	3	2017-08-01	2025-04-22	Carried Forward	Repaired		2024-09-03	0	No CGI reading	
1217681	206 CONCORD ST	3	2013-05-06	2025-03-12	Carried Forward	Eliminated Otherwise		2024-08-13	2720	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
7393337	138 COTTON ST	2	2025-04-10	2025-05-07	Newly Identified	Repaired					
270681	131 COUNTRY CLUB RD	3	2004-08-03	2025-02-14	Carried Forward	Repaired		2024-09-12	1260	Leak Extent	
5301858	131 COUNTRY CLUB RD	2	2025-06-09	2025-08-18	Newly Identified	Repaired					
12000033	CRAFTS ST & FESSENDEN RD	2	2025-07-23	2025-09-29	Carried Forward	Repaired	3				
7392858	64 CRAFTS ST	1	2025-03-17	2025-03-17	Newly Identified	Repaired					
5310208	351 CRAFTS ST	2	2025-08-08	2025-09-05	Newly Identified	Repaired					
7392045	451 CRAFTS ST	1	2025-02-03	2025-02-04	Newly Identified	Repaired					

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7391596	464 CRAFTS ST	2	2025-01-06	2024-02-05	Newly Identified	Repaired					LMS Repair Date error
5307486	549 CRAFTS ST	1	2025-07-20	2025-07-25	Newly Identified	Repaired					
5318240	549 CRAFTS ST	2	2025-09-28	2025-12-11	Newly Identified	Repaired					
7345014	7 CURTIS ST	2	2024-11-20	2025-04-22	Carried Forward	Eliminated Otherwise					DUPLICATE LEAK
7392581	7 CURTIS ST	1	2025-02-27	2025-02-27	Newly Identified	Repaired					
7349163	CYPRESS ST & PARKER ST	3	2018-11-15	2025-05-10	Carried Forward	Eliminated Otherwise		2025-03-05	0	No CGI reading	NO READS
5313859	49 DALBY STREET	3	2025-09-02	2025-09-24	Newly Identified	Eliminated Otherwise		2025-09-02	1584	Leak Extent	CLOSED DUE TO ANOTHER LEAK REPAIR
5314846	49 DALBY ST	1	2025-09-09	2025-09-11	Newly Identified	Repaired					
5316147	49 DALBY ST	1	2025-09-15	2025-09-19	Newly Identified	Repaired					
5316155	49 DALBY ST	1	2025-09-17	2025-09-24	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5315651	50 DALBY ST	2	2025-09-13	2025-09-24	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5314336	52 DALBY ST	2	2025-09-04	2025-09-11	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
7390551	DALTON RD & BEACON ST	3	2024-10-09	2025-02-14	Carried Forward	Repaired		2024-10-09	168	Leak Extent	
7342376	3 DANIEL ST	3	2018-03-06	2025-02-12	Carried Forward	Repaired		2024-11-20	600	Leak Extent	
5315977	92 DARTMOUTH STREET	2	2025-09-16	2025-10-13	Newly Identified	Repaired					
7336365	23 DAVIS ST	3	2017-07-15	2025-02-27	Carried Forward	Repaired		2024-11-20	2400	Leak Extent	
7354537	10 DAY ST	3	2019-07-15	2025-02-14	Carried Forward	Repaired		2024-09-03	0	No CGI reading	
5309872	10 DAY ST	3	2025-08-06	2025-12-09	Newly Identified	Repaired		2025-08-06	100	Leak Extent	
5316023	327 DEDHAM STREET	3	2025-09-16	2025-10-01	Newly Identified	Eliminated Otherwise		2025-09-16	4550	Leak Extent	DUPLICATE LEAK
5301950	658 DEDHAM ST	1	2025-06-09	2025-06-10	Newly Identified	Repaired					
5302210	965 DEDHAM STREET	2	2025-06-11	2025-07-22	Newly Identified	Repaired					
7376707	200 DERBY ST	3	2022-08-24	2025-02-19	Carried Forward	Repaired		2024-04-30	1080	Leak Extent	
12003489	232 DERBY ST	3	2022-08-24	2025-11-25	Carried Forward	Repaired		2025-11-19	1792	Leak Extent	
5313275	290 DERBY ST	2	2025-08-28	2025-10-10	Newly Identified	Repaired					
7387349	57 DEVONSHIRE RD	3	2024-04-18	2025-02-18	Carried Forward	Repaired		2024-11-19	1	Leak Extent	
7326329	121 DICKERMAN RD	3	2016-06-01	2025-02-19	Carried Forward	Repaired		2024-11-19	300	Leak Extent	
7392305	115 DORSET RD	1	2025-02-13	2025-02-13	Newly Identified	Repaired					
7353088	238 DORSET RD	3	2019-05-06	2025-03-11	Carried Forward	Repaired		2024-08-14	1440	Leak Extent	
1363546	295 DUDLEY RD	3	2013-09-19	2025-03-21	Carried Forward	Repaired		2024-09-30	860	Leak Extent	
5311841	122 EAST SIDE PARKWAY	3	2025-08-19	2025-12-18	Newly Identified	Repaired		2025-08-19	100	Leak Extent	
7391987	15 ELIOT MEMORIAL RD	1	2025-01-31	2025-02-02	Newly Identified	Repaired					
5329344	70 ELLIOT STREET	1	2025-11-08	2025-11-19	Newly Identified	Repaired					
12000778	115 ELLIOT ST	1	2025-11-04	2025-11-10	Carried Forward	Repaired	3				
5319930	115 ELLIOT ST	3	2025-10-08	2025-10-14	Newly Identified	Eliminated Otherwise		2025-10-08	2275	Leak Extent	DUPLICATE LEAK
5302665	127 ELLIOT ST	2	2025-06-13	2025-08-21	Newly Identified	Repaired					
5304932	144 ELLIOT ST	1	2025-07-01	2025-07-03	Newly Identified	Repaired					
5305018	144 ELLIOT ST NEWTON MA	1	2025-07-02	2025-08-07	Newly Identified	Repaired					
5318330	192 ELLIOT ST	1	2025-09-29	2025-09-30	Newly Identified	Repaired					

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
5333330	248 ELLIOT ST	1	2025-11-23	2025-11-26	Newly Identified	Repaired					
5302931	330 ELLIOT ST	2	2025-05-21	2025-07-16	Newly Identified	Repaired					
7391602	368 ELLIOT ST	2	2024-12-28	2025-01-28	Carried Forward	Repaired					
7386487	43 ELM ST	3	2024-02-15	2025-03-26	Carried Forward	Repaired		2024-11-01	470	Leak Extent	
5329178	80 ELM ST	1	2025-11-08	2025-11-17	Newly Identified	Repaired					
12004714	74 ERIE AVE	2	2025-05-06	2025-06-12	Carried Forward	Repaired	3				
5314392	20 EVELYN RD	2	2025-09-05	2025-09-17	Newly Identified	Repaired					
5315510	20 EVELYN RD	2	2025-09-12	2025-10-01	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
12005514	43 FALMOUTH RD	3	2025-02-04	2025-07-02	Newly Identified	Repaired		2025-02-04	25	Leak Extent	
5320444	181 FLORENCE ST	2	2025-10-10	2025-12-11	Newly Identified	Repaired					
7391870	6 FOREST AVE	1	2025-01-27	2025-01-28	Newly Identified	Repaired					
5302140	11 FOREST AVE	1	2025-06-11	2025-07-10	Newly Identified	Repaired					
7385308	55 FOREST AVE	3	2023-12-09	2025-05-10	Carried Forward	Eliminated Otherwise		2025-03-05	0	No CGI reading	NO READS
12000476	64 FULLER ST	3	2008-09-08	2025-05-30	Carried Forward	Repaired		2024-08-22	2550	Leak Extent	
5310637	152 FULLER STREET	3	2025-08-05	2025-09-15	Newly Identified	Repaired		2025-08-05	200	Leak Extent	
5310563	250 FULLER ST	2	2025-08-11	2025-10-08	Newly Identified	Repaired					
7392766	326 FULLER ST	1	2025-03-10	2025-03-10	Newly Identified	Repaired					
12002327	52 G ROADWAY	2	2025-10-30	2025-12-16	Carried Forward	Repaired	3				
5341848	19 GEORGE ST	3	2025-12-25	2025-12-31	Newly Identified	Eliminated Otherwise		2025-12-25	2187	Leak Extent	DUPLICATE LEAK
5315901	141 GORDON RD	3	2025-09-16	2025-11-21	Newly Identified	Repaired		2025-09-16	12925	Leak Extent	
5318250	20 GRANT AVE	3	2025-09-28	2025-10-06	Newly Identified	Eliminated Otherwise		2025-09-28	2760	Leak Extent	DUPLICATE LEAK
5326307	125 GRASMERE ST	1	2025-10-30	2025-11-04	Newly Identified	Repaired					
7392640	58 GREEN PIKE	1	2025-03-03	2025-03-01	Newly Identified	Repaired					
5318304	62 GREEN ST	2	2025-09-29	2025-10-13	Newly Identified	Repaired					
7387519	477 GROVE ST	2	2024-04-19	2025-03-19	Carried Forward	Repaired					
5302829	34 GROVELAND ST	2	2025-05-14	2025-07-22	Newly Identified	Repaired					
7378581	HAGAR ST & CONCORD ST	3	2022-11-04	2025-03-12	Carried Forward	Repaired		2024-06-26	2500	Leak Extent	
7392937	77 HAGEN RD	2	2025-03-04	2025-04-17	Newly Identified	Repaired					
7391696	40 HAMPSHIRE ST	1	2025-01-17	2025-01-17	Newly Identified	Repaired					
5319825	15 HARTMAN RD	3	2025-10-07	2025-10-14	Newly Identified	Eliminated Otherwise		2025-10-07	638	Leak Extent	DUPLICATE LEAK
5313815	303 HARTMAN RD	3	2025-09-02	2025-09-22	Newly Identified	Repaired		2025-09-02	225	Leak Extent	
7392346	62 HAWTHORN ST	1	2025-02-16	2025-02-17	Newly Identified	Repaired					
12002224	25 HAYNES RD	3	2019-06-04	2025-06-16	Carried Forward	Repaired		2024-08-14	1	Leak Extent	
12002227	9 HIGH ST	3	2019-06-27	2025-12-30	Carried Forward	Eliminated Otherwise		2025-11-04	0	No CGI reading	NO READS PRESENT
5302967	23 HIGH ST	3	2025-06-16	2025-07-01	Newly Identified	Eliminated Otherwise		2025-06-16	736	Leak Extent	DUPLICATE LEAK
5315440	23 HIGH ST	3	2025-09-12	2025-09-15	Newly Identified	Eliminated Otherwise		2025-09-12	736	Leak Extent	DUPLICATE LEAK
7393073	50 HIGH ST	2	2025-03-20	2025-04-11	Newly Identified	Repaired					
7382270	53 HIGH ST	2	2025-01-06	2025-01-27	Carried Forward	Repaired					

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7392460	103 HIGH ST	1	2025-02-22	2025-02-22	Newly Identified	Repaired					
5339318	95 HIGHLAND AVE	1	2025-12-16	2025-12-17	Newly Identified	Repaired					
12000884	26 HOLMAN RD	3	2013-06-12	2025-12-24	Carried Forward	Repaired		2025-06-16	225	Leak Extent	
12003840	205 HOMER ST	3	2023-04-11	2025-09-22	Carried Forward	Repaired		2024-11-01	160	Leak Extent	
5303005	7 HUNTER ST	2	2025-05-14	2025-08-15	Newly Identified	Repaired					
7392106	12 INDIAN RIDGE RD	1	2025-02-05	2025-02-05	Newly Identified	Repaired					
7392215	15 INDIAN RIDGE RD	1	2025-02-10	2025-02-10	Newly Identified	Repaired					
5327634	89 JACKSON RD	3	2025-11-04	2025-11-24	Newly Identified	Repaired		2025-11-04	100	Leak Extent	
7393512	155 JACKSON RD	1	2025-04-28	2025-04-28	Newly Identified	Repaired					
12000412	4 JANET RD	3	2007-08-23	2025-07-07	Carried Forward	Repaired		2024-09-27	1216	Leak Extent	
7392651	14 KEWADIN RD	2	2025-02-28	2025-03-18	Newly Identified	Repaired					
5291932	14 KEWADIN RD	1	2025-05-28	2025-05-30	Newly Identified	Repaired					
12005866	14 KEWADIN RD	2	2025-04-24	2025-05-29	Newly Identified	Repaired					
7325430	9 KIRKSTALL RD	2	2025-03-05	2025-03-18	Carried Forward	Repaired					
12000132	LANGDON ST & BELLEVUE ST	3	2002-02-26	2025-07-02	Carried Forward	Repaired		2024-08-07	900	Leak Extent	
12000373	10 LANGLEY RD	3	2006-12-07	2025-06-23	Carried Forward	Repaired		2025-06-09	700	Leak Extent	
7393304	38 LANGLEY RD	1	2025-04-16	2025-04-17	Newly Identified	Repaired					
12004116	118 LANGLEY RD	3	2025-05-12	2025-07-10	Carried Forward	Repaired		2025-05-06	75	Leak Extent	
12006063	118 LANGLEY RD	2	2025-05-11	2025-07-10	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
5313878	314 LANGLEY RD	2	2025-09-28	2025-12-30	Newly Identified	Repaired	3				
5318236	314 LANGLEY RD	2	2025-09-28	2025-10-03	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
5306371	430 LANGLEY RD	1	2025-07-11	2025-07-25	Newly Identified	Repaired					
7391505	15 LARCHMONT AVE	2	2024-12-31	2025-01-28	Carried Forward	Repaired					
5333795	30 LESLIE RD	2	2025-11-25	2025-12-18	Newly Identified	Repaired					
12003706	138 LEXINGTON ST	2	2025-07-23	2025-09-09	Carried Forward	Repaired	3				
5307682	152 LEXINGTON STREET	2	2025-07-22	2025-09-02	Newly Identified	Repaired					
5307680	182 LEXINGTON ST	2	2025-07-21	2025-09-08	Newly Identified	Repaired					
5308019	252 LEXINGTON ST	2	2025-07-23	2025-09-05	Newly Identified	Repaired					
5334666	396 LEXINGTON ST	1	2025-12-01	2025-12-02	Newly Identified	Repaired					
7393200	427 LEXINGTON ST	1	2025-04-03	2025-04-11	Newly Identified	Repaired					
7388831	440 LEXINGTON ST	2	2024-07-23	2025-01-02	Carried Forward	Repaired					
5301826	450 LEXINGTON ST	1	2025-06-09	2025-06-27	Newly Identified	Repaired					
12003280	6 LINCOLN ST	2	2025-08-21	2025-09-20	Carried Forward	Repaired	3				
5315979	160 LINCOLN ST	1	2025-09-16	2025-10-03	Newly Identified	Repaired					
5304580	165 LINWOOD AVE	3	2025-06-29	2025-07-12	Newly Identified	Eliminated Otherwise		2025-06-30	1650	Leak Extent	DUPLICATE LEAK
7392936	466 LOWELL AVE	2	2025-02-11	2025-04-01	Newly Identified	Repaired					
5313634	472 LOWELL AVE	1	2025-08-31	2025-09-03	Newly Identified	Repaired					
5314870	472 LOWELL AVE	1	2025-08-31	2025-10-01	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
5309784	28 MANITOBA RD	2	2025-08-06	2025-09-17	Newly Identified	Repaired					
7391646	5 MARGARET RD	1	2025-01-16	2025-01-17	Newly Identified	Repaired					
12006094	37 MAYFLOWER RD	1	2025-05-20	2025-05-30	Newly Identified	Repaired					
7391872	45 MECHANIC ST	2	2025-01-16	2025-02-23	Newly Identified	Repaired					
7392466	45 MECHANIC ST	1	2025-02-22	2025-02-24	Newly Identified	Repaired					
12000400	167 MELROSE ST	3	2007-07-31	2025-07-09	Carried Forward	Repaired		2025-02-11	240	Leak Extent	
5301710	36 MELVILLE AVE	1	2025-06-06	2025-06-06	Newly Identified	Repaired					
12004335	69 MIDDLESEX RD	2	2025-05-13	2025-10-14	Carried Forward	Repaired	3				
12004381	12 MURRAY RD	2	2025-09-20	2025-10-15	Carried Forward	Repaired	3				
5316800	12 MURRAY RD	3	2025-09-20	2025-09-29	Newly Identified	Eliminated Otherwise		2025-09-20	640	Leak Extent	DUPLICATE LEAK
7392014	66 MYERSON LN	1	2025-02-01	2025-02-02	Newly Identified	Repaired					
7392652	30 NATHAN RD	3	2025-02-18	2025-05-19	Newly Identified	Eliminated Otherwise		2025-02-18	25	Leak Extent	SYSTEM ISSUE
7354041	66 NEEDHAM ST	3	2021-10-20	2025-04-02	Carried Forward	Eliminated Otherwise		2024-11-20	0	No CGI reading	NO READS
7392875	244 NEEDHAM ST	1	2025-03-18	2025-03-18	Newly Identified	Repaired					
5316634	244 NEEDHAM ST	1	2025-09-19	2025-09-22	Newly Identified	Repaired					
5335777	39 NEHOIDEN RD	1	2025-12-03	2025-12-05	Newly Identified	Repaired					
5336104	39 NEHOIDEN RD	1	2025-12-04	2025-12-06	Newly Identified	Repaired					
5335719	39 NEHOIDEN RD	1	2025-12-03	2025-12-09	Newly Identified	Repaired					
5342321	63 NEHOIDEN RD	1	2025-12-29	2025-12-30	Newly Identified	Repaired					
5321585	32 NEWELL RD	1	2025-10-19	2025-10-17	Newly Identified	Repaired					
5304314	409 NEWTONVILLE AVE	1	2025-06-26	2025-06-27	Newly Identified	Repaired					
7393562	5 NORTH ST	1	2025-04-30	2025-04-30	Newly Identified	Repaired					
5316644	155 OAK ST	3	2025-09-19	2025-10-03	Newly Identified	Eliminated Otherwise		2025-09-19	0	No CGI reading	DATA ENTRY ERROR
7393575	193 OAK ST	1	2025-05-01	2025-05-02	Newly Identified	Repaired					
7393655	193 OAK ST	1	2025-05-05	2025-05-05	Newly Identified	Repaired					
7392255	64 OAKWOOD RD	1	2025-02-11	2025-02-11	Newly Identified	Repaired					
7392310	64 OAKWOOD RD	1	2025-02-13	2025-02-13	Newly Identified	Repaired					
5291666	9 OLD ORCHARD RD	2	2025-05-27	2025-11-20	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
5303494	9 OLD ORCHARD RD	2	2025-06-20	2025-07-18	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
5322525	9 OLD ORCHARD RD	2	2025-10-22	2025-11-07	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
5333316	50 OLDE FIELD RD	3	2025-11-23	2025-12-19	Newly Identified	Eliminated Otherwise		2025-11-23	400	Leak Extent	DUPLICATE LEAK
7392175	96 OLDEFIELD RD	1	2025-02-07	2025-02-07	Newly Identified	Repaired					
12004872	33 ORIENT AVE	2	2024-08-26	2025-07-31	Carried Forward	Repaired					
1362600	45 PARK LN	2	2025-01-11	2025-02-04	Carried Forward	Repaired					
5331932	255 PARKER ST	2	2025-11-18	2025-11-24	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
7387162	546 PARKER ST	3	2024-04-10	2025-01-30	Carried Forward	Repaired		2024-11-20	6600	Leak Extent	
12000416	30 PEARL ST	3	2007-08-14	2025-07-02	Carried Forward	Repaired		2024-08-09	840	Leak Extent	
5311697	262 PEARL ST	2	2025-08-18	2025-09-02	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
5307104	264 PEARL ST	2	2025-07-16	2025-08-29	Newly Identified	Repaired					
5290582	267 PEARL ST	1	2025-05-26	2025-05-26	Newly Identified	Repaired					
5299963	267 PEARL ST	1	2025-06-02	2025-06-06	Newly Identified	Repaired					
12006102	267 PEARL ST	1	2025-05-20	2025-05-26	Newly Identified	Eliminated Otherwise					DATA ENTRY ERROR
12002720	5 PHILBRICK RD	2	2025-03-19	2025-06-05	Carried Forward	Repaired	3				
7383510	43 PHILBRICK RD	3	2023-09-05	2025-05-13	Carried Forward	Repaired		2024-06-26	1200	Leak Extent	
7393500	PLEASANT ST & CHERRY ST	1	2025-04-28	2025-04-28	Newly Identified	Repaired					
5318435	74 PLEASANT ST	1	2025-09-29	2025-10-02	Newly Identified	Repaired					
12000281	PLYMOUTH RD & WOODWARD ST	3	2004-04-27	2025-12-04	Carried Forward	Repaired		2025-07-08	5400	Leak Extent	
5313669	145 POND BROOK RD	1	2025-09-01	2025-09-02	Newly Identified	Repaired					
5313716	51 PONTIAC RD	2	2025-09-02	2025-11-03	Newly Identified	Repaired					
5322651	49 PRAIRIE AVE	1	2025-10-22	2025-11-05	Newly Identified	Repaired					
5309782	38 PRINCE ST	2	2025-08-06	2025-10-10	Newly Identified	Repaired					
7393839	125 PRINCE ST	1	2025-05-13	2025-05-13	Newly Identified	Repaired					
7371044	178 PRINCE ST	3	2021-09-27	2025-05-10	Carried Forward	Eliminated Otherwise		2025-04-17	0	No CGI reading	NO READS
7392110	18 PUTNAM ST	2	2025-01-22	2025-03-19	Newly Identified	Repaired					
5304694	18 PUTNAM ST	2	2025-05-14	2025-08-27	Newly Identified	Repaired					
12000367	64 PUTNAM ST	3	2006-09-25	2025-06-30	Carried Forward	Repaired		2025-06-16	1620	Leak Extent	
12002318	84 RACHEL RD	3	2019-09-05	2025-07-22	Carried Forward	Eliminated by Replacement		2024-10-11	0	No CGI reading	CLOSED DUE TO MAIN REPLACEMENT
7392035	37 RANDLETT PIKE	1	2025-02-03	2025-02-04	Newly Identified	Repaired					
7392276	47 RANDLETT PIKE	2	2025-02-02	2025-02-26	Newly Identified	Repaired					
7391500	58 RANGELEY RD	1	2025-01-09	2025-01-09	Newly Identified	Repaired					
12000837	32 RICHARDSON ST	3	2012-11-29	2025-12-17	Carried Forward	Repaired		2025-09-18	25	Leak Extent	
12000482	116 RIDGE AVE	3	2008-12-12	2025-07-01	Carried Forward	Repaired		2025-02-11	0	No CGI reading	
5312510	326 RIVER ST	3	2025-11-10	2025-11-05	Newly Identified	Repaired	2	2025-11-10	1	Leak Extent	
7391537	43 RIVERDALE AVE	1	2025-01-10	2025-01-10	Newly Identified	Repaired					
7391545	43 RIVERDALE AVE	1	2025-01-12	2025-01-12	Newly Identified	Repaired					
7391609	43 RIVERDALE AVE	1	2025-01-14	2025-01-14	Newly Identified	Repaired					
5321831	65 ROKEBY RD	3	2025-10-17	2025-10-23	Newly Identified	Eliminated Otherwise		2025-10-17	750	Leak Extent	DUPLICATE LEAK
7391530	5 ROTHERWOOD RD	1	2025-01-10	2025-01-10	Newly Identified	Repaired					
12000630	15 ROTHERWOOD RD	3	2010-07-10	2025-07-16	Carried Forward	Eliminated by Replacement		2025-04-14	0	No CGI reading	CLOSED DUE TO MAIN REPLACEMENT
5315522	105 RUMFORD AVE	1	2025-09-12	2025-09-12	Newly Identified	Repaired					
12000784	712 SAWMILL BROOK PKY	3	2012-04-24	2025-12-23	Carried Forward	Repaired		2025-07-09	2880	Leak Extent	
5334600	33 SCHOOL ST	1	2025-12-01	2025-12-01	Newly Identified	Repaired					
5335075	33 SCHOOL ST	1	2025-12-02	2025-12-03	Newly Identified	Repaired					
7392899	45 SHEFFIELD RD	1	2025-03-19	2025-03-19	Newly Identified	Repaired					
12005418	5 SHELDON RD	2	2025-01-12	2025-09-11	Newly Identified	Repaired					
7391104	15 SIMPSON ST	1	2024-12-05	2025-01-15	Carried Forward	Eliminated Otherwise					NOT UNDERGROUND LEAK

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
12005411	24 SOLON ST	3	2025-04-25	2025-06-09	Carried Forward	Repaired	2	2025-04-25	1600	Leak Extent	
12001331	16 SOMERSET RD	2	2025-05-29	2025-08-07	Carried Forward	Repaired	3				
5307354	26 SPIERS RD	1	2025-07-18	2025-07-18	Newly Identified	Repaired					
7391215	123 SPIERS RD	1	2024-12-17	2025-01-03	Carried Forward	Eliminated Otherwise					NO READS
7391669	34 STAFFORD RD	1	2025-01-16	2025-01-17	Newly Identified	Repaired					
7393578	12 STONELEIGH RD	1	2025-05-01	2025-05-01	Newly Identified	Repaired					
12000285	100 SUFFOLK RD	2	2025-09-16	2025-10-21	Carried Forward	Repaired	3				
12000414	6 SUMNER ST	3	2007-08-28	2025-07-09	Carried Forward	Repaired		2024-08-27	1750	Leak Extent	
12000406	9 T ROADWAY	3	2007-08-06	2025-10-06	Carried Forward	Repaired		2025-09-18	25	Leak Extent	
5308917	175 TEMPLE ST	1	2025-07-30	2025-07-30	Newly Identified	Repaired					
5319766	190 TEMPLE ST	3	2025-10-07	2025-10-13	Newly Identified	Eliminated Otherwise		2025-10-07	1680	Leak Extent	DUPLICATE LEAK
5308218	44 THORNTON ST	2	2025-07-24	2025-08-15	Newly Identified	Repaired					
5313488	116 TOLMAN ST	2	2025-08-29	2025-09-23	Newly Identified	Repaired					
5312121	3 TROY LANE	3	2025-08-20	2025-09-24	Newly Identified	Repaired		2025-08-20	1700	Leak Extent	
12004574	56 UPLAND RD	3	2024-04-17	2025-05-29	Carried Forward	Repaired		2024-11-19	684	Leak Extent	
7393213	100 UPLAND RD	1	2025-04-11	2025-04-11	Newly Identified	Repaired					
7392769	56 VALENTINE ST	1	2025-03-10	2025-03-11	Newly Identified	Repaired					
258085	WABAN AV & VARICK RD	3	2004-02-24	2025-04-17	Carried Forward	Repaired		2024-08-07	100	Leak Extent	
5312069	96 WABAN ST	2	2025-09-10	2025-10-13	Newly Identified	Repaired					
5315045	96 WABAN ST	3	2025-09-10	2025-09-15	Newly Identified	Eliminated Otherwise		2025-09-10	1800	Leak Extent	DUPLICATE LEAK
7356357	12 WACHUSETT RD	3	2019-09-25	2025-03-26	Carried Forward	Repaired		2025-02-11	25	Leak Extent	
12005859	61 WALNUT HILL RD	2	2025-04-30	2025-05-29	Newly Identified	Repaired					
12000870	WALNUT ST & HOMER ST	3	2013-05-17	2025-07-07	Carried Forward	Repaired		2025-03-06	25	Leak Extent	
12000403	43 WALNUT ST	3	2014-11-18	2025-10-03	Carried Forward	Repaired	2	2025-07-08	400	Leak Extent	
5325038	100 WALNUT ST	3	2025-10-28	2025-11-17	Newly Identified	Repaired		2025-10-28	200	Leak Extent	
7391969	218 WALNUT ST	1	2025-01-30	2025-01-31	Newly Identified	Repaired					
7391842	221 WALNUT ST	1	2025-01-24	2025-01-24	Newly Identified	Repaired					
7392004	454 WALNUT ST	1	2025-01-31	2025-01-31	Newly Identified	Repaired					
5301479	454 WALNUT ST	1	2025-06-05	2025-06-07	Newly Identified	Repaired					
5301667	489 WALNUT ST	2	2025-06-06	2025-07-29	Newly Identified	Repaired					
12005944	710 WALNUT ST	3	2025-05-01	2025-07-07	Newly Identified	Repaired		2025-05-01	4400	Leak Extent	
5301912	951 WALNUT ST	2	2025-06-09	2025-10-22	Newly Identified	Repaired					
7392076	956 WALNUT ST	1	2025-02-04	2025-02-05	Newly Identified	Repaired					
7392939	1047 WALNUT ST	2	2025-03-14	2025-04-30	Newly Identified	Repaired					
5301581	1119 WALNUT STREET	2	2025-06-05	2025-08-14	Newly Identified	Repaired					
5301734	1119 WALNUT ST, NEWTON	2	2025-06-06	2025-07-18	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7392938	1197 WALNUT ST	2	2025-03-12	2025-04-16	Newly Identified	Repaired					
12004953	1297 WALNUT ST	2	2025-08-14	2025-09-17	Carried Forward	Repaired	3				

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7378794	1370 WALNUT ST	2	2025-04-10	2025-04-28	Carried Forward	Repaired	3				
7392977	1385 WALNUT ST	2	2025-03-25	2025-04-24	Newly Identified	Repaired					
7392933	1404 WALNUT ST	2	2025-02-04	2025-04-24	Newly Identified	Repaired					
7326889	89 WALTHAM ST	3	2016-06-15	2025-05-10	Carried Forward	Eliminated Otherwise		2025-03-05	0	No CGI reading	NO READS
7392501	130 WALTHAM ST	1	2025-02-24	2025-02-25	Newly Identified	Repaired					
5314420	154 WALTHAM ST	1	2025-09-05	2025-09-06	Newly Identified	Repaired					
258065	122 WARD ST	3	2004-01-22	2025-04-01	Carried Forward	Eliminated by Replacement		2025-02-07		No CGI reading	CLOSED DUE TO MAIN REPLACEMENT
5302261	507 WARD ST	1	2025-06-11	2025-06-12	Newly Identified	Repaired					
7393853	507 WARD ST	1	2025-05-14	2025-05-14	Newly Identified	Repaired					
5301469	561 WARD ST	1	2025-06-05	2025-06-09	Newly Identified	Repaired					
5330064	66 WARWICK RD	1	2025-11-12	2025-11-18	Newly Identified	Repaired					
5310049	60 WASHBURN AVENUE	2	2025-08-07	2025-09-03	Newly Identified	Repaired					
7392772	330 WASHINGTON ST	2	2025-03-04	2025-05-13	Newly Identified	Eliminated Otherwise					NO READS
12002279	361 THORNTON ST	2	2025-08-21	2025-12-11	Carried Forward	Repaired	3				
5310694	471 WASHINGTON ST	2	2025-08-12	2025-09-16	Newly Identified	Repaired					
5311198	575 WASHINGTON ST	3	2025-08-14	2025-11-17	Newly Identified	Repaired		2025-08-14	300	Leak Extent	
5341487	583 WASHINGTON ST	3	2025-12-23	2025-12-24	Newly Identified	Eliminated Otherwise		2025-12-23	4200	Leak Extent	DUPLICATE LEAK
7392158	795 WASHINGTON ST	2	2024-12-29	2025-03-19	Carried Forward	Repaired					
5334105	833 WASHINGTON ST	1	2025-11-26	2025-12-02	Newly Identified	Repaired					
5328702	835 WASHINGTON ST	2	2025-11-06	2025-12-09	Newly Identified	Eliminated Otherwise					CLOSED DUE TO ANOTHER LEAK REPAIR
7392648	839 WASHINGTON ST	2	2025-02-20	2025-03-21	Newly Identified	Repaired					
5321618	845 WASHINGTON ST	2	2025-10-16	2025-11-19	Newly Identified	Repaired					
5306819	897 WASHINGTON ST	2	2025-07-15	2025-07-22	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
5306852	1019 WASHINGTON ST	1	2025-07-15	2025-07-25	Newly Identified	Repaired					
5301310	1180 WASHINGTON ST	2	2025-06-04	2025-09-17	Newly Identified	Repaired					
7379022	1499 WASHINGTON ST	3	2022-12-13	2025-03-05	Carried Forward	Repaired		2024-07-25	200	Leak Extent	
7392583	1730 WASHINGTON ST	3	2025-02-26	2025-03-11	Newly Identified	Repaired					
12006051	1730 WASHINGTON ST	2	2025-05-12	2025-05-29	Newly Identified	Repaired					
7392273	1784 WASHINGTON ST	1	2025-02-12	2025-02-12	Newly Identified	Repaired					
7392573	1784 WASHINGTON ST	1	2025-02-26	2025-02-28	Newly Identified	Repaired					
5321394	1784 WASHINGTON ST	2	2025-10-15	2025-11-13	Newly Identified	Eliminated Otherwise					DUPLICATE LEAK
7387922	2096 WASHINGTON ST	2	2024-05-24	2025-04-02	Carried Forward	Eliminated Otherwise					REPAIRED UNDER OTHER LEAK REPAIR
7392774	2096 WASHINGTON ST	3	2025-02-28	2025-04-01	Newly Identified	Repaired		2025-02-28	1000	Leak Extent	
7391932	34 WATERSTON RD	1	2025-01-29	2025-01-29	Newly Identified	Repaired					
5310085	MILE 45.3 STATE RTE 16 W	1	2025-08-07	2025-08-08	Newly Identified	Repaired					
5305444	256 WATERTOWN ST	2	2025-07-07	2025-08-20	Newly Identified	Repaired					
7388809	494 WATERTOWN ST	1	2024-08-05	2024-08-02	Carried Forward	Repaired					
7392954	687 WATERTOWN ST	3	2025-03-09	2025-04-25	Newly Identified	Repaired		2025-03-09	5092	Leak Extent	

Table L7 All eliminated Newton leaks in 2025

Listed alphabetically by street											
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
5308304	882 WATERTOWN ST	2	2025-07-24	2025-09-02	Newly Identified	Repaired					
12005477	25 WAUWINET RD	3	2025-01-17	2025-11-19	Newly Identified	Repaired		2025-10-20	800	Leak Extent	
7393208	65 WAUWINET RD	1	2025-04-11	2025-04-11	Newly Identified	Repaired					
5311914	1 WEBSTER CT	2	2025-08-19	2025-11-19	Newly Identified	Repaired					
7392389	284 WEBSTER ST	1	2025-02-18	2025-02-20	Newly Identified	Repaired					
12000418	32 WESSEX RD	3	2007-08-28	2025-06-03	Carried Forward	Repaired		2024-08-13	1485	Leak Extent	
5321374	18 W PINE ST	1	2025-10-15	2025-10-15	Newly Identified	Repaired					
7376820	96 WESTLAND AVE	3	2022-08-19	2025-05-10	Carried Forward	Eliminated Otherwise		2025-04-17	0	No CGI reading	NO READS
5306863	75 WESTMINSTER RD	3	2025-07-15	2025-08-07	Newly Identified	Eliminated Otherwise		2025-07-15	100	Leak Extent	DUPLICATE LEAK
5312800	75 WESTMINSTER RD	2	2025-08-22	2025-09-19	Newly Identified	Repaired					
5301294	8 WETHERELL ST	1	2025-06-04	2025-07-09	Newly Identified	Repaired					
5312456	23 WETHERELL ST	3	2025-08-22	2025-11-04	Newly Identified	Repaired		2025-08-22	90	Leak Extent	
7391694	45 WHITTEMORE RD	1	2025-01-17	2025-01-17	Newly Identified	Repaired					
5311839	47 WINCHESTER RD	3	2025-08-19	2025-12-11	Newly Identified	Repaired		2025-08-19	400	Leak Extent	
5327609	98 WINCHESTER ST	1	2025-10-24	2025-11-06	Newly Identified	Repaired					
12005511	150 WINCHESTER ST	3	2025-01-31	2025-09-25	Newly Identified	Repaired		2025-01-31	100	Leak Extent	
12005565	180 WINCHESTER ST	3	2025-02-14	2025-06-20	Newly Identified	Repaired					
5303001	180 WINCHESTER ST	2	2025-06-17	2025-08-06	Newly Identified	Repaired					
12004002	264 WINCHESTER ST	3	2023-06-09	2025-06-20	Carried Forward	Repaired		2025-04-25	600	Leak Extent	
5301507	315 WINCHESTER ST	3	2025-06-05	2025-09-26	Newly Identified	Repaired		2025-06-05	225	Leak Extent	
5301505	321 WINCHESTER ST	3	2025-06-05	2025-09-25	Newly Identified	Repaired		2025-06-05	100	Leak Extent	
12003842	324 WINCHESTER ST	3	2023-02-22	2025-06-30	Carried Forward	Repaired		2024-08-28	960	Leak Extent	
12005667	346 WINCHESTER ST	3	2025-03-26	2025-09-22	Newly Identified	Repaired		2025-03-26	120	Leak Extent	
5301467	351 WINCHESTER STREET	3	2025-06-05	2025-09-23	Newly Identified	Repaired		2025-06-05	100	Leak Extent	
12003317	380 WINCHESTER ST	3	2022-05-16	2025-06-20	Carried Forward	Repaired		2025-02-11	100	Leak Extent	
12002193	401 WINCHESTER ST	3	2019-05-22	2025-06-20	Carried Forward	Repaired		2025-06-16	1	Leak Extent	
5326075	13 WINONA ST	1	2025-10-30	2025-10-30	Newly Identified	Repaired					
7387353	77 WOOD END RD	2	2025-04-11	2025-04-24	Carried Forward	Repaired	3				
12000405	78 WOODBINE ST	3	2007-08-01	2025-05-30	Carried Forward	Repaired		2024-11-19	375	Leak Extent	
12004947	20 WOODCHESTER DR	3	2024-09-13	2025-06-16	Carried Forward	Repaired					
12002163	150 WOODLAND RD	3	2019-05-08	2025-12-30	Carried Forward	Eliminated Otherwise		2025-11-20	1	Leak Extent	NO READS PRESENT
5319972	150 WOODLAND RD	3	2025-10-08	2025-10-14	Newly Identified	Eliminated Otherwise		2025-10-08	400	Leak Extent	DUPLICATE LEAK
7385843	299 WOODLAND RD	3	2024-01-11	2025-03-20	Carried Forward	Eliminated Otherwise		2024-10-09	0	No CGI reading	NO READS
12006085	9 WOODMAN RD	1	2025-05-20	2025-05-30	Newly Identified	Repaired					
7392638	23 WOODMAN RD	1	2025-03-03	2025-03-01	Newly Identified	Repaired					
270389	128 WOODWARD ST	2	2025-04-14	2025-05-07	Carried Forward	Repaired	3				
12000776	220 WOODWARD ST	3	2012-03-26	2025-12-31	Carried Forward	Repaired		2025-07-15	3750	Leak Extent	
7393162	325 WOODWARD ST	1	2025-04-08	2025-04-08	Newly Identified	Repaired					

Table L7 All eliminated Newton leaks in 2025				Listed alphabetically by street							
Leak ID	Street Address	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Status	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
7377631	364 WOODWARD ST	3	2022-09-12	2025-04-30	Carried Forward	Repaired		2025-04-14	150	Leak Extent	
12000861	68 WYOMING RD	3	2013-04-30	2025-12-19	Carried Forward	Repaired		2025-07-15	2250	Leak Extent	

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
12000007	3 COLUMBUS ST		NEWTON	21-May-93	11-Jul-25	3	250	Non-G3SEI
12000033	CRAFTS ST & FESSENDEN RD	FESSENDEN RD	NEWTON	8-Apr-98	29-Sep-25	2		
12000132	LANGDON ST & BELLEVUE ST	BELLEVUE ST	NEWTON	26-Feb-02	2-Jul-25	3	900	Non-G3SEI
258085	WABAN AV & VARICK RD	VARICK RD	NEWTON	24-Feb-04	17-Apr-25	3	100	Non-G3SEI
12000215	2004 BEACON ST		NEWTON	2-Mar-04	10-Jul-25	3	480	Non-G3SEI
12000281	PLYMOUTH RD & WOODWARD ST	WOODWARD ST	NEWTON	27-Apr-04	4-Dec-25	3	5400	G3SEI
270389	128 WOODWARD ST		NEWTON	27-Apr-04	7-May-25	2		
270681	131 COUNTRY CLUB RD		NEWTON	3-Aug-04	14-Feb-25	3	1260	Non-G3SEI
12000285	100 SUFFOLK RD		NEWTON	19-Aug-04	21-Oct-25	2		
271180	63 AVONDALE RD	COMMONWEALTH AV	NEWTON	1-Feb-05	5-Mar-25	3	200	Non-G3SEI
12000367	64 PUTNAM ST		NEWTON	25-Sep-06	30-Jun-25	3	1620	Non-G3SEI
12000373	10 LANGLEY RD	GREEN ST	NEWTON	7-Dec-06	23-Jun-25	3	700	Non-G3SEI
12000400	167 MELROSE ST	CHASKE AVE	NEWTON	31-Jul-07	9-Jul-25	3	240	Non-G3SEI
12000405	78 WOODBINE ST	BOURNE ST	NEWTON	1-Aug-07	30-May-25	3	375	Non-G3SEI
12000403	43 WALNUT ST	MINOT PL	NEWTON	2-Aug-07	3-Oct-25	3	400	Non-G3SEI
12000402	470 CALIFORNIA ST	WOODROW AVE	NEWTON	3-Aug-07	11-Jul-25	3	160	Non-G3SEI
12000406	9 T ROADWAY	HANSON RD	NEWTON	6-Aug-07	6-Oct-25	3	25	Non-G3SEI
12000416	30 PEARL ST	BACON ST	NEWTON	14-Aug-07	2-Jul-25	3	840	Non-G3SEI
304327	ALBEMARLE RD & WATERTOWN	WATERTOWN ST	NEWTON	15-Aug-07	25-Apr-25	3	200	Non-G3SEI
12000412	4 JANET RD	MILL ST	NEWTON	23-Aug-07	7-Jul-25	3	1216	Non-G3SEI
12000414	6 SUMNER ST	WARD ST	NEWTON	28-Aug-07	9-Jul-25	3	1750	Non-G3SEI
12000418	32 WESSEX RD	WARD ST	NEWTON	28-Aug-07	3-Jun-25	3	1485	Non-G3SEI
12000476	64 FULLER ST	COYNE RD	NEWTON	8-Sep-08	30-May-25	3	2550	G3SEI
12000482	116 RIDGE AVE	GLENWOOD AVE	NEWTON	12-Dec-08	1-Jul-25	3	0	Non-G3SEI
329823	41 BERKELEY ST	PRINCE ST	NEWTON	4-Dec-09	13-Jan-25	3	100	Non-G3SEI
337057	327 CHERRY ST	RAYMOND PL	NEWTON	9-Sep-10	21-Mar-25	2		
12000778	115 ELLIOT ST	CIRCUIT AVE	NEWTON	23-Mar-12	10-Nov-25	1		
12000776	220 WOODWARD ST	ORCHARD AVE	NEWTON	26-Mar-12	31-Dec-25	3	3750	G3SEI

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
12000784	712 SAWMILL BROOK PKY	STEIN CIR	NEWTON	24-Apr-12	23-Dec-25	3	2880	G3SEI
12000845	1957 BEACON ST	WHITE OAK RD	NEWTON	13-Feb-13	11-Jun-25	3	350	Non-G3SEI
12000861	68 WYOMING RD	CALIFORNIA ST	NEWTON	30-Apr-13	19-Dec-25	3	2250	G3SEI
12000870	WALNUT ST & HOMER ST	HOMER ST	NEWTON	17-May-13	7-Jul-25	3	25	Non-G3SEI
12000884	26 HOLMAN RD	BERTRAND RD	NEWTON	12-Jun-13	24-Dec-25	3	225	Non-G3SEI
12000925	110 CEDAR ST	MASON RD	NEWTON	10-Sep-13	10-Jul-25	3	750	Non-G3SEI
1363546	295 DUDLEY RD	STONEWOOD DR	NEWTON	19-Sep-13	21-Mar-25	3	860	Non-G3SEI
1362600	45 PARK LN	CHARLOTTE RD	NEWTON	25-Sep-13	4-Feb-25	2		
12001066	BEACON ST & RESERVOIR AVE	RESERVOIR AVE	NEWTON	4-Dec-14	27-Jun-25	3	500	Non-G3SEI
6625370	27 CAMDEN RD	WOLCOTT ST	NEWTON	22-Sep-15	10-Jan-25	3	175	Non-G3SEI
6980988	83 CARVER RD	DICKERMAN RD	NEWTON	19-Oct-15	4-Feb-25	3	3800	G3SEI
12001331	16 SOMERSET RD	OTIS ST	NEWTON	1-Apr-16	7-Aug-25	2		
7325430	9 KIRKSTALL RD	WALNUT ST	NEWTON	20-Apr-16	18-Mar-25	2		
7326329	121 DICKERMAN RD	RANDOLPH ST	NEWTON	1-Jun-16	19-Feb-25	3	300	Non-G3SEI
7331474	71 COMMONWEALTH AVE	ALGONQUIN RD	NEWTON	3-Jan-17	3-Mar-25	3		Non-G3SEI
7336302	42 ANNAWAN RD	GOULD RD	NEWTON	1-Jul-17	6-Jan-25	3	1080	Non-G3SEI
7336365	23 DAVIS ST	HIGHLAND ST	NEWTON	15-Jul-17	27-Feb-25	3	2400	G3SEI
7336764	CENTRAL AVE & WASHINGTON ST	WASHINGTON ST	NEWTON	26-Jul-17	22-Apr-25	2		
7337028	100 CONCORD ST	LAFAYETTE RD	NEWTON	1-Aug-17	22-Apr-25	3	0	Non-G3SEI
7341496	COMMONWEALTH AVE & AUBURN ST	AUBURN ST	NEWTON	12-Jan-18	8-Apr-25	3	0	Non-G3SEI
7342376	3 DANIEL ST	JACKSON ST	NEWTON	6-Mar-18	12-Feb-25	3	600	Non-G3SEI
7353088	238 DORSET RD	LONGWELL RD	NEWTON	6-May-19	11-Mar-25	3	1440	Non-G3SEI
12002164	207 AUBURN ST	SHERMAN PL	NEWTON	17-May-19	26-Jun-25	3	0	Non-G3SEI
12002193	401 WINCHESTER ST	GODDARD ST	NEWTON	22-May-19	20-Jun-25	3	1	Non-G3SEI
12002224	25 HAYNES RD	OLDEFIELD RD	NEWTON	4-Jun-19	16-Jun-25	3	1	Non-G3SEI
7354554	81 CHURCH ST	WELLINGTON TER	NEWTON	9-Jul-19	12-Feb-25	3	2280	G3SEI
7354537	10 DAY ST	COMMONWEALTH AVE	NEWTON	15-Jul-19	14-Feb-25	3	0	Non-G3SEI
7354709	20 CLAREMONT ST	FAIRMONT AVE	NEWTON	16-Jul-19	26-Mar-25	3	1380	Non-G3SEI

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
12002279	361 THORNTON ST	WASHINGTON ST	NEWTON	1-Aug-19	11-Dec-25	2		
12002278	1928 COMMONWEALTH AVE	AUBURN ST	NEWTON	5-Aug-19	24-Sep-25	2		
7355668	34 BROADLAWN DR	LAGRANGE ST	NEWTON	23-Aug-19	25-Feb-25	3	0	Non-G3SEI
12002327	52 G ROADWAY	SPIERS RD	NEWTON	25-Sep-19	16-Dec-25	2		
7356357	12 WACHUSETT RD	COMMONWEALTH AVE	NEWTON	25-Sep-19	26-Mar-25	3	25	Non-G3SEI
12002720	5 PHILBRICK RD	BOYLSTON ST	NEWTON	17-Aug-20	5-Jun-25	2		
12002938	1330 BOYLSTON ST	ELLIS ST	NEWTON	15-May-21	14-Oct-25	2		
12002937	17 COCHITUATE RD	NANTUCKET RD	NEWTON	19-May-21	3-Dec-25	3	100	Non-G3SEI
7370901	38 BARNSTABLE RD	VALENTINE PIKE	NEWTON	24-Sep-21	10-Jan-25	3	225	Non-G3SEI
7371382	212 CHESTNUT ST	WYKEHAM RD	NEWTON	9-Oct-21	14-Feb-25	3	720	Non-G3SEI
12003280	6 LINCOLN ST	WALNUT ST	NEWTON	22-Apr-22	20-Sep-25	2		
12003317	380 WINCHESTER ST	CHARLEMONT ST	NEWTON	16-May-22	20-Jun-25	3	100	Non-G3SEI
7375135	341 CABOT ST	PARK PL	NEWTON	23-May-22	13-Jan-25	3	320	Non-G3SEI
12003281	1994 BEACON ST	VARICK RD	NEWTON	29-May-22	12-Jun-25	3	380	Non-G3SEI
12003319	275 AUBURN ST	LEXINGTON ST	NEWTON	3-Jun-22	26-Jun-25	3	680	Non-G3SEI
7376631	224 ADAMS AVE	HOWARD ST	NEWTON	22-Aug-22	3-Jan-25	3	1400	Non-G3SEI
12003489	232 DERBY ST	NOBLE ST	NEWTON	24-Aug-22	25-Nov-25	3	1792	Non-G3SEI
7376707	200 DERBY ST	PARMENTER RD	NEWTON	24-Aug-22	19-Feb-25	3	1080	Non-G3SEI
7377631	364 WOODWARD ST	CHESTNUT ST	NEWTON	12-Sep-22	30-Apr-25	3	150	Non-G3SEI
7378581	HAGAR ST & CONCORD ST	CONCORD ST	NEWTON	4-Nov-22	12-Mar-25	3	2500	G3SEI
12003706	138 LEXINGTON ST	ROBERTA RD	NEWTON	8-Nov-22	9-Sep-25	2		
7378794	1370 WALNUT ST	ELINOR RD	NEWTON	10-Nov-22	28-Apr-25	2		
7379022	1499 WASHINGTON ST	ALLEN PL	NEWTON	13-Dec-22	5-Mar-25	3	200	Non-G3SEI
12003750	497 BOYLSTON ST	DUXBURY RD	NEWTON	4-Jan-23	3-Jun-25	2		
12003766	255 BOYLSTON ST	HAMMOND POND PKY	NEWTON	6-Jan-23	17-Sep-25	2		
7379847	1818 BEACON ST	OWAISA RD	NEWTON	13-Feb-23	7-May-25	3	2250	G3SEI
12003842	324 WINCHESTER ST	WINCHESTER PLZ	NEWTON	22-Feb-23	30-Jun-25	3	960	Non-G3SEI
12003808	750 BOYLSTON ST	CLOVERDALE RD	NEWTON	25-Feb-23	14-Oct-25	1		

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7382270	53 HIGH ST	WINTER ST	NEWTON	7-Jun-23	27-Jan-25	2		
12004002	264 WINCHESTER ST	WILLARD ST	NEWTON	9-Jun-23	20-Jun-25	3	600	Non-G3SEI
7383501	34 BROOKSIDE AVE	ALBEMARLE RD	NEWTON	17-Aug-23	13-Jan-25	3	1800	Non-G3SEI
7383510	43 PHILBRICK RD	HAGEN RD	NEWTON	5-Sep-23	13-May-25	3	1200	Non-G3SEI
7384585	22 BERWICK RD	SAXON RD	NEWTON	15-Oct-23	10-Jan-25	3	300	Non-G3SEI
7384931	BROOKSIDE AVE & ALBEMARLE	ALBEMARLE RD	NEWTON	10-Nov-23	16-Jan-25	3	112	Non-G3SEI
12004335	69 MIDDLESEX RD	NORFOLK RD	NEWTON	23-Jan-24	14-Oct-25	2		
12004343	19 COLUMBUS ST	COLUMBUS TER	NEWTON	31-Jan-24	1-Jul-25	3	750	Non-G3SEI
12004340	138 CEDAR ST	ASHTON AVE	NEWTON	1-Feb-24	17-Nov-25	2		
12004381	12 MURRAY RD	AUBURNDALE AVE	NEWTON	15-Feb-24	15-Oct-25	2		
7386487	43 ELM ST	WEBSTER ST	NEWTON	15-Feb-24	26-Mar-25	3	470	Non-G3SEI
7387138	1774 COMMONWEALTH AVE	ARAPAHOE RD	NEWTON	19-Mar-24	24-Feb-25	2		
7387162	546 PARKER ST	DEDHAM ST	NEWTON	10-Apr-24	30-Jan-25	3	6600	G3SEI
7387164	91 CARL ST	CHARLEMONT ST	NEWTON	11-Apr-24	12-Feb-25	3	950	Non-G3SEI
12004574	56 UPLAND RD	WOODHAVEN RD	NEWTON	17-Apr-24	29-May-25	3	684	Non-G3SEI
7387349	57 DEVONSHIRE RD	LARKSPUR RD	NEWTON	18-Apr-24	18-Feb-25	3	1	Non-G3SEI
7387519	477 GROVE ST	SERV TO HOWARD JOH	NEWTON	19-Apr-24	19-Mar-25	2		
7387353	77 WOOD END RD	BURNSIDE RD	NEWTON	22-Apr-24	24-Apr-25	2		
7387779	20 BEAUMONT AVE	PROSPECT PIKE	NEWTON	6-May-24	13-Jan-25	3		Non-G3SEI
7388455	318 CABOT ST	GAY ST	NEWTON	25-Jun-24	12-Feb-25	3		Non-G3SEI
12004714	74 ERIE AVE	BOWDOIN ST	NEWTON	2-Jul-24	12-Jun-25	2		
7388831	440 LEXINGTON ST	MELROSE AVE	NEWTON	23-Jul-24	2-Jan-25	2		
12004844	100 BOYLSTON ST	HAMMOND POND PKY	NEWTON	14-Aug-24	27-Aug-25	2		
12004872	33 ORIENT AVE	ASHTON AVE	NEWTON	26-Aug-24	31-Jul-25	2		
12004953	1297 WALNUT ST	ASHCROFT RD	NEWTON	12-Sep-24	17-Sep-25	2		
7389987	37 CLARK ST	ROWENA RD	NEWTON	12-Sep-24	19-Mar-25	3		Non-G3SEI
12004947	20 WOODCHESTER DR	MANDALAY RD	NEWTON	13-Sep-24	16-Jun-25	3		Non-G3SEI
7390551	DALTON RD & BEACON ST	BEACON ST	NEWTON	9-Oct-24	14-Feb-25	3	168	Non-G3SEI

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7391602	368 ELLIOT ST	CHESTNUT ST	NEWTON	28-Dec-24	28-Jan-25	2		
7391599	18 CLIFF RD	OAK ST	NEWTON	29-Dec-24	27-Jan-25	2		
7392158	795 WASHINGTON ST	CENTRAL AVE	NEWTON	29-Dec-24	19-Mar-25	2		
12005411	24 SOLON ST	STONY BRAE RD	NEWTON	31-Dec-24	9-Jun-25	3	1600	Non-G3SEI
7391505	15 LARCHMONT AVE	WYMAN ST	NEWTON	31-Dec-24	28-Jan-25	2		
7391418	700 COMMONWEALTH AVE	WATER ST	NEWTON	4-Jan-25	4-Jan-25	1		
7391596	464 CRAFTS ST		NEWTON	6-Jan-25	5-Feb-25	2		
7391606	115 ALLEN AVE	PINE RIDGE RD	NEWTON	7-Jan-25	30-Jan-25	2		
7391500	58 RANGELEY RD	N GATE PIKE	NEWTON	9-Jan-25	9-Jan-25	1		
7391530	5 ROTHERWOOD RD	ALLERTON RD	NEWTON	10-Jan-25	10-Jan-25	1		
7391537	43 RIVERDALE AVE	CALIFORNIA ST	NEWTON	10-Jan-25	10-Jan-25	1		
12005418	5 SHELDON RD	BOYLSTON ST	NEWTON	12-Jan-25	11-Sep-25	2		
7391545	43 RIVERDALE AVE	CALIFORNIA ST	NEWTON	12-Jan-25	12-Jan-25	1		
7391609	43 RIVERDALE AVE	CALIFORNIA ST	NEWTON	14-Jan-25	14-Jan-25	1		
7391643	949 CENTRE ST	BALLARD ST	NEWTON	15-Jan-25	16-Jan-25	1		
7391645	833 BOYLSTON ST	WALNUT ST	NEWTON	15-Jan-25	16-Jan-25	1		
7391646	5 MARGARET RD	BOYLSTON ST	NEWTON	16-Jan-25	17-Jan-25	1		
7391669	34 STAFFORD RD	CHAPIN RD	NEWTON	16-Jan-25	17-Jan-25	1		
7391872	45 MECHANIC ST	CHENEY ST	NEWTON	16-Jan-25	23-Feb-25	2		
12005477	25 WAUWINET RD	E COLBERT RD	NEWTON	17-Jan-25	19-Nov-25	3	800	Non-G3SEI
7391676	833 BOYLSTON ST	WALNUT ST	NEWTON	17-Jan-25	17-Jan-25	1		
7391694	45 WHITTEMORE RD	WAVERLY AVE	NEWTON	17-Jan-25	17-Jan-25	1		
7391696	40 HAMPSHIRE ST	BARNSTABLE RD	NEWTON	17-Jan-25	17-Jan-25	1		
7392110	18 PUTNAM ST	HUNTER ST	NEWTON	22-Jan-25	19-Mar-25	2		
7391807	ABERDEEN ST & BOYLSTON ST	BOYLSTON ST	NEWTON	23-Jan-25	24-Jan-25	1		
7391842	221 WALNUT ST	FOSTER ST	NEWTON	24-Jan-25	24-Jan-25	1		
7391870	6 FOREST AVE	MOUNT VERNON ST	NEWTON	27-Jan-25	28-Jan-25	1		
7391877	18 CLIFF RD	OAK ST	NEWTON	27-Jan-25	27-Jan-25	1		

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7391932	34 WATERSTON RD	RUTHVEN RD	NEWTON	29-Jan-25	29-Jan-25	1		
7391969	218 WALNUT ST	FOSTER ST	NEWTON	30-Jan-25	31-Jan-25	1		
12005511	150 WINCHESTER ST	HEATHERLAND RD	NEWTON	31-Jan-25	25-Sep-25	3	100	Non-G3SEI
7391987	15 ELIOT MEMORIAL RD	WAVERLY AVE	NEWTON	31-Jan-25	2-Feb-25	1		
7392004	454 WALNUT ST	CLYDE ST	NEWTON	31-Jan-25	31-Jan-25	1		
7392014	66 MYERSON LN	MCCARTHY RD	NEWTON	1-Feb-25	2-Feb-25	1		
7392276	47 RANDLETT PIKE	BUNKER LN	NEWTON	2-Feb-25	26-Feb-25	2		
7392035	37 RANDLETT PIKE	BUNKER LN	NEWTON	3-Feb-25	4-Feb-25	1		
7392045	451 CRAFTS ST	FESSENDEN LN	NEWTON	3-Feb-25	4-Feb-25	1		
7392076	956 WALNUT ST	KINGMAN RD	NEWTON	4-Feb-25	5-Feb-25	1		
7392933	1404 WALNUT ST	ELINOR RD	NEWTON	4-Feb-25	24-Apr-25	2		
7392106	12 INDIAN RIDGE RD	MARVIN LN	NEWTON	5-Feb-25	5-Feb-25	1		
7392175	96 OLDEFIELD RD	NARDONE RD	NEWTON	7-Feb-25	7-Feb-25	1		
7392215	15 INDIAN RIDGE RD	MARVIN LN	NEWTON	10-Feb-25	10-Feb-25	1		
7392255	64 OAKWOOD RD	VIRGINIA RD	NEWTON	11-Feb-25	11-Feb-25	1		
7392936	466 LOWELL AVE	CRAIGIE TER	NEWTON	11-Feb-25	1-Apr-25	2		
7392273	1784 WASHINGTON ST	MARY MOUNT RD	NEWTON	12-Feb-25	12-Feb-25	1		
7392305	115 DORSET RD	QUIDNIC RD	NEWTON	13-Feb-25	13-Feb-25	1		
7392310	64 OAKWOOD RD	VIRGINIA RD	NEWTON	13-Feb-25	13-Feb-25	1		
12005565	180 WINCHESTER ST	HEATHERLAND RD	NEWTON	14-Feb-25	20-Jun-25	3		Non-G3SEI
7392371	1466 COMMONWEALTH AVE	DARTMOUTH ST	NEWTON	15-Feb-25	7-Mar-25	3		Non-G3SEI
7392346	62 HAWTHORN ST	BURTON AVE	NEWTON	16-Feb-25	17-Feb-25	1		
7392389	284 WEBSTER ST	ROYAL CIR	NEWTON	18-Feb-25	20-Feb-25	1		
7392648	839 WASHINGTON ST	WALNUT ST	NEWTON	20-Feb-25	21-Mar-25	2		
7392460	103 HIGH ST	CHILTON PL	NEWTON	22-Feb-25	22-Feb-25	1		
7392466	45 MECHANIC ST	CHENEY ST	NEWTON	22-Feb-25	24-Feb-25	1		
7392501	130 WALTHAM ST	ANNAPOLIS RD	NEWTON	24-Feb-25	25-Feb-25	1		
7392514	24 BRAELAND AVE	LANGLEY RD	NEWTON	25-Feb-25	25-Feb-25	1		

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7392573	1784 WASHINGTON ST	MARY MOUNT RD	NEWTON	26-Feb-25	28-Feb-25	1		
7392583	1730 WASHINGTON ST	WOODLAND RD	NEWTON	26-Feb-25	11-Mar-25	3		Non-G3SEI
7392581	7 CURTIS ST	RAMSDELL ST	NEWTON	27-Feb-25	27-Feb-25	1		
7392603	BYRON RD & LAGRANGE ST	LAGRANGE ST	NEWTON	27-Feb-25	27-Feb-25	1		
7392651	14 KEWADIN RD	TAMWORTH RD	NEWTON	28-Feb-25	18-Mar-25	2		
7392774	2096 WASHINGTON ST	NESHOBE RD	NEWTON	28-Feb-25	1-Apr-25	3	1000	Non-G3SEI
7392754	23 BELMORE PIKE	WASHINGTON ST	NEWTON	2-Mar-25	18-Mar-25	2		
7392638	23 WOODMAN RD	OLD ORCHARD RD	NEWTON	3-Mar-25	1-Mar-25	1		
7392640	58 GREEN PIKE	WAVERLY AVE	NEWTON	3-Mar-25	1-Mar-25	1		
7392908	BALLARD ST & WARD ST	WARD ST	NEWTON	4-Mar-25	2-Apr-25	3		Non-G3SEI
7392937	77 HAGEN RD	OLDEFIELD RD	NEWTON	4-Mar-25	17-Apr-25	2		
7392954	687 WATERTOWN ST	ALBEMARLE RD	NEWTON	9-Mar-25	25-Apr-25	3	5092	G3SEI
7392955	256 ALBEMARLE RD	ACCESS RD	NEWTON	9-Mar-25	4-Apr-25	3	4256	G3SEI
7392766	326 FULLER ST	TEMPLE ST	NEWTON	10-Mar-25	10-Mar-25	1		
7392769	56 VALENTINE ST	FOUNTAIN ST	NEWTON	10-Mar-25	11-Mar-25	1		
7392938	1197 WALNUT ST	FLORAL ST	NEWTON	12-Mar-25	16-Apr-25	2		
7392939	1047 WALNUT ST	HYDE ST	NEWTON	14-Mar-25	30-Apr-25	2		
7392977	1385 WALNUT ST	ELINOR RD	NEWTON	14-Mar-25	24-Apr-25	2		
7392858	64 CRAFTS ST	CLINTON ST	NEWTON	17-Mar-25	17-Mar-25	1		
7392875	244 NEEDHAM ST	CHARLEMONT ST	NEWTON	18-Mar-25	18-Mar-25	1		
7392899	45 SHEFFIELD RD	HIGHLAND ST	NEWTON	19-Mar-25	19-Mar-25	1		
7392969	367 ALBEMARLE RD	WATERTOWN ST	NEWTON	19-Mar-25	25-Apr-25	3	2016	G3SEI
7393073	50 HIGH ST	WINTER ST	NEWTON	20-Mar-25	11-Apr-25	2		
12005667	346 WINCHESTER ST	SUTCLIFFE PIKE	NEWTON	26-Mar-25	22-Sep-25	3	120	Non-G3SEI
7393053	1024 BOYLSTON ST	DICKERMAN RD	NEWTON	30-Mar-25	4-Apr-25	1		
7393060	21 CHENEY ST	CHENEY CT	NEWTON	31-Mar-25	31-Mar-25	1		
7393094	15 CHESTNUT TER	COMMONWEALTH AVE	NEWTON	2-Apr-25	2-Apr-25	1		
7393115	25 BROADLAWN DR	LAGRANGE ST	NEWTON	3-Apr-25	3-Apr-25	1		

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
7393200	427 LEXINGTON ST	COMMONWEALTH AVE	NEWTON	3-Apr-25	11-Apr-25	1		
7393210	290 ALBEMARLE RD	ACCESS RD	NEWTON	4-Apr-25	25-Apr-25	3		Non-G3SEI
7393162	325 WOODWARD ST	HOMESTEAD ST	NEWTON	8-Apr-25	8-Apr-25	1		
7393337	138 COTTON ST	SUNSET RD	NEWTON	10-Apr-25	7-May-25	2		
7393208	65 WAUWINET RD	ELLIS RD	NEWTON	11-Apr-25	11-Apr-25	1		
7393213	100 UPLAND RD	PLAINFIELD ST	NEWTON	11-Apr-25	11-Apr-25	1		
7393304	38 LANGLEY RD	BEACON ST	NEWTON	16-Apr-25	17-Apr-25	1		
12005866	14 KEWADIN RD	TAMWORTH RD	NEWTON	24-Apr-25	29-May-25	2		
12005864	81 CHURCH ST	WELLINGTON TER	NEWTON	28-Apr-25	6-Oct-25	3	1950	Non-G3SEI
7393500	PLEASANT ST & CHERRY ST	CHERRY ST	NEWTON	28-Apr-25	28-Apr-25	1		
7393512	155 JACKSON RD	WILTSHIRE RD	NEWTON	28-Apr-25	28-Apr-25	1		
12005860	52 ATHELSTANE RD	CEDRIC RD	NEWTON	29-Apr-25	29-May-25	2		
12005859	61 WALNUT HILL RD	KENDALL RD	NEWTON	30-Apr-25	29-May-25	2		
7393562	5 NORTH ST	COMMONWEALTH AVE	NEWTON	30-Apr-25	30-Apr-25	1		
7393575	193 OAK ST	NEEDHAM ST	NEWTON	1-May-25	2-May-25	1		
7393578	12 STONELEIGH RD	ORCHARD AVE	NEWTON	1-May-25	1-May-25	1		
7393655	193 OAK ST	NEEDHAM ST	NEWTON	5-May-25	5-May-25	1		
7393731	170 CHESTNUT ST	HIGHLAND ST	NEWTON	7-May-25	8-May-25	1		
12006063	118 LANGLEY RD	GLAZER RD	NEWTON	11-May-25	28-May-25	2		
12006051	1730 WASHINGTON ST	WOODLAND RD	NEWTON	12-May-25	29-May-25	2		
12006062	904 CENTRE ST	COTTON ST	NEWTON	12-May-25	3-Jun-25	2		
7393830	6 CALDON PATH	HANSON RD	NEWTON	13-May-25	13-May-25	1		
7393839	125 PRINCE ST	BERKELEY ST	NEWTON	13-May-25	13-May-25	1		
5302829	34 GROVELAND ST	GROVE ST	NEWTON	14-May-25	22-Jul-25	2		
5303005	7 HUNTER ST		NEWTON	14-May-25	15-Aug-25	2		
7393853	507 WARD ST	ELMORE ST	NEWTON	14-May-25	14-May-25	1		
7393859	36 CHESTNUT HILL TER	GATE HOUSE RD	NEWTON	14-May-25	14-May-25	1		
12006085	9 WOODMAN RD	HAMMOND ST	NEWTON	20-May-25	30-May-25	1		

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail			Source:	National Grid Service Quality Report 26-SQ-05				
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
12006094	37 MAYFLOWER RD	QUINCY RD	NEWTON	20-May-25	30-May-25	1		
5302931	330 ELLIOT ST	ELLIOT PL	NEWTON	21-May-25	16-Jul-25	2		
5290582	267 PEARL ST		NEWTON	26-May-25	26-May-25	1		
5291666	9 OLD ORCHARD RD	HAMMOND ST	NEWTON	27-May-25	26-Nov-25	2		
5291932	14 KEWADIN RD	TAMWORTH RD	NEWTON	28-May-25	30-May-25	1		
5299963	267 PEARL ST		NEWTON	2-Jun-25	6-Jun-25	1		
5301264	34 ANTHONY RD	ANTHONY CIR	NEWTON	4-Jun-25	20-Aug-25	2		
5301294	8 WETHERELL ST	ELLIOT ST	NEWTON	4-Jun-25	9-Jul-25	1		
5301310	1180 WASHINGTON ST		NEWTON	4-Jun-25	17-Sep-25	2		
5301467	351 WINCHESTER STREET	WINCHESTER PLACE	NEWTON	5-Jun-25	23-Sep-25	3	100	Non-G3SEI
5301469	561 WARD ST	MORSELAND ST	NEWTON	5-Jun-25	9-Jun-25	1		
5301479	454 WALNUT ST	CLYDE ST	NEWTON	5-Jun-25	7-Jun-25	1		
5301505	321 WINCHESTER ST	WINCHESTER PLZ	NEWTON	5-Jun-25	25-Sep-25	3	100	Non-G3SEI
5301507	315 WINCHESTER ST	WINCHESTER PLZ	NEWTON	5-Jun-25	26-Sep-25	3	225	Non-G3SEI
5301581	1119 WALNUT STREET	FOREST ST	NEWTON	5-Jun-25	14-Aug-25	2		
5301667	489 WALNUT ST	KIRKSTALL RD	NEWTON	6-Jun-25	29-Jul-25	2		
5301710	36 MELVILLE AVE	LINWOOD AVE	NEWTON	6-Jun-25	6-Jun-25	1		
5301826	450 LEXINGTON ST	AUBURN	NEWTON	9-Jun-25	27-Jun-25	1		
5301858	131 COUNTRY CLUB RD	GREENWOOD ST	NEWTON	9-Jun-25	18-Aug-25	2		
5301912	951 WALNUT ST	KINGMAN RD	NEWTON	9-Jun-25	22-Oct-25	2		
5301950	658 DEDHAM ST	ROSALIE	NEWTON	9-Jun-25	10-Jun-25	1		
5302038	790 CENTRE ST		NEWTON	10-Jun-25	10-Jun-25	1		
5302140	11 FOREST AVE	MT VERNON ST	NEWTON	11-Jun-25	10-Jul-25	1		
5302210	965 DEDHAM STREET	SPEIRS	NEWTON	11-Jun-25	22-Jul-25	2		
5302261	507 WARD ST	ELMORE ST	NEWTON	11-Jun-25	12-Jun-25	1		
5302282	389 CENTRAL ST	LEIGHTON RD	NEWTON	11-Jun-25	29-Aug-25	2		
5302665	127 ELLIOT ST		NEWTON	13-Jun-25	21-Aug-25	2		
5303001	180 WINCHESTER ST	HEATHERLAND RD	NEWTON	17-Jun-25	6-Aug-25	2		

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
5303266	831 BOYLSTON ST	MULLEN CT	NEWTON	18-Jun-25	19-Jun-25	1		
5304314	409 NEWTONVILLE AVE		NEWTON	26-Jun-25	27-Jun-25	1		
5304382	63 CHAPEL ST	WATERTOWN ST	NEWTON	27-Jun-25	14-Aug-25	2		
5304932	144 ELLIOT ST	COLUMBIA AVE	NEWTON	1-Jul-25	3-Jul-25	1		
5305018	144 ELLIOT ST	ELLIOT ST	NEWTON	2-Jul-25	7-Aug-25	1		
5305444	256 WATERTOWN ST	PEARL ST	NEWTON	7-Jul-25	20-Aug-25	2		
5306371	430 LANGLEY RD	JACKSON STREET	NEWTON	11-Jul-25	25-Jul-25	1		
5306852	1019 WASHINGTON ST	HARRINGTON ST	NEWTON	15-Jul-25	25-Jul-25	1		
5307104	264 PEARL ST		NEWTON	16-Jul-25	29-Aug-25	2		
5307354	26 SPIERS RD	J ROADWAY	NEWTON	18-Jul-25	18-Jul-25	1		
5307362	945 BEACON ST	WEBSTER CT.	NEWTON	18-Jul-25	25-Jul-25	1		
5307486	549 CRAFTS ST	WALTHAM	NEWTON	19-Jul-25	25-Jul-25	1		
5307674	1317 CENTRE ST	RILPEY ST	NEWTON	21-Jul-25	11-Sep-25	2		
5307680	182 LEXINGTON ST	STANIFORD	NEWTON	21-Jul-25	8-Sep-25	2		
5307682	152 LEXINGTON STREET	ROBERTA	NEWTON	22-Jul-25	2-Sep-25	2		
5307881	392 BOYLSTON STREET		NEWTON	22-Jul-25	25-Jul-25	1		
5308019	252 LEXINGTON ST	SCRIBNER	NEWTON	23-Jul-25	5-Sep-25	2		
5308172	929 BEACON ST	BEACON ST / WEBSTER	NEWTON	23-Jul-25	21-Aug-25	2		
5308218	44 THORNTON ST	THORNTON PL & WASH	NEWTON	24-Jul-25	15-Aug-25	2		
5308290	85 BROOKSIDE AVE		NEWTON	24-Jul-25	28-Aug-25	2		
5308304	882 WATERTOWN ST	ADELA RD	NEWTON	24-Jul-25	2-Sep-25	2		
5308688	26 CEDAR ST	CHANNING RD	NEWTON	28-Jul-25	30-Aug-25	2		
5308917	175 TEMPLE ST		NEWTON	30-Jul-25	30-Jul-25	1		
5309030	82 ALLEN AVE	WOODHAVEN RD	NEWTON	31-Jul-25	1-Aug-25	1		
5309687	1633 COMMONWEALTH AVE	TEMPLE STREET	NEWTON	5-Aug-25	7-Aug-25	1		
5309697	50 COLLEGE RD	QUINCY ROAD	NEWTON	5-Aug-25	24-Sep-25	2		
5310637	152 FULLER STREET	DARTMOUTH	NEWTON	5-Aug-25	15-Sep-25	3	200	Non-G3SEI
5309782	38 PRINCE ST	SEWALL	NEWTON	6-Aug-25	10-Oct-25	2		

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
5309784	28 MANITOBA RD	NEHOIDEN	NEWTON	6-Aug-25	17-Sep-25	2		
5309872	10 DAY ST	FULLER	NEWTON	6-Aug-25	9-Dec-25	3	100	Non-G3SEI
5309897	4 ARAPAHOE RD	GREENOUGH	NEWTON	6-Aug-25	2-Sep-25	2		
5309935	41 COMMONWEALTH AVE		NEWTON	6-Aug-25	13-Aug-25	1		
5310049	60 WASHBURN AVENUE	PINE ST	NEWTON	7-Aug-25	3-Sep-25	2		
5310085	MILE 45.3 STATE RTE 16 W	WALNUT	NEWTON	7-Aug-25	8-Aug-25	1		
5310208	351 CRAFTS ST	CALIFORNIA	NEWTON	8-Aug-25	5-Sep-25	2		
5310563	250 FULLER ST	EXETER	NEWTON	11-Aug-25	8-Oct-25	2		
5310694	471 WASHINGTON ST	NEVADA ST	NEWTON	12-Aug-25	16-Sep-25	2		
5310947	32 CHESLEY RD	BEACON	NEWTON	13-Aug-25	2-Oct-25	2		
5311198	575 WASHINGTON ST	LANGLEN	NEWTON	14-Aug-25	17-Nov-25	3	300	Non-G3SEI
5311505	ALBEMARLE RD	WATERTOWN ST	NEWTON	15-Aug-25	15-Sep-25	1		
5311839	47 WINCHESTER RD	E SIDE PARKWAY	NEWTON	19-Aug-25	11-Dec-25	3	400	Non-G3SEI
5311841	122 EAST SIDE PARKWAY	HILLTOP STREET	NEWTON	19-Aug-25	18-Dec-25	3	100	Non-G3SEI
5311893	776 BEACON ST	LANGLEY RD	NEWTON	19-Aug-25	19-Aug-25	1		
5311914	1 WEBSTER CT	WEBSTER CT/ BEACON	NEWTON	19-Aug-25	19-Nov-25	2		
5312069	96 WABAN ST		NEWTON	19-Aug-25	13-Oct-25	2		
5312121	3 TROY LANE	FULLER	WABAN	20-Aug-25	24-Sep-25	3	1700	Non-G3SEI
5312293	5 ADAMS AVENUE	MOODY ST	NEWTON	21-Aug-25	24-Sep-25	2		
5312510	326 RIVER ST	JAMES	NEWTON	22-Aug-25	5-Nov-25	3	1	Non-G3SEI
5312800	75 WESTMINSTER RD	GLEN	NEWTON	22-Aug-25	19-Sep-25	2		
5312712	543 CENTRE STREET	WASHINGTON STREET	NEWTON	25-Aug-25	25-Aug-25	1		
5312841	389 CENTRAL ST		NEWTON	25-Aug-25	29-Aug-25	1		
5313275	290 DERBY ST	TOLMAN ST	NEWTON	28-Aug-25	10-Oct-25	2		
5313488	116 TOLMAN ST	UNDERWOOD AVE	NEWTON	29-Aug-25	23-Sep-25	2		
5313634	472 LOWELL AVE		NEWTON	31-Aug-25	3-Sep-25	1		
5313669	145 POND BROOK RD		NEWTON	1-Sep-25	2-Sep-25	1		
5313716	51 PONTIAC RD	STETSON	NEWTON	2-Sep-25	3-Nov-25	2		

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
5313815	303 HARTMAN RD	CLIFTON RD	NEWTON	2-Sep-25	22-Sep-25	3	225	Non-G3SEI
5313878	314 LANGLEY RD		NEWTON	2-Sep-25	30-Dec-25	2		
5314282	484 CALIFORNIA ST	WOODROW AVE	NEWTON	4-Sep-25	5-Sep-25	1		
5314392	20 EVELYN RD	BEACON STREET	NEWTON	5-Sep-25	17-Sep-25	2		
5314418	616 BOYLSTON ST	PARKER STREET	NEWTON	5-Sep-25	15-Sep-25	1		
5314420	154 WALTHAM ST	LODGE RD	NEWTON	5-Sep-25	6-Sep-25	1		
5314537	2088 COMMONWEALTH AVE	LEXINGTON ST	AUBURNDALE	7-Sep-25	10-Sep-25	1		
5314846	49 DALBY ST		NEWTON	9-Sep-25	11-Sep-25	1		
5315522	105 RUMFORD AVE	RIVERVIEW AVE	NEWTON	12-Sep-25	12-Sep-25	1		
5315672	42 BRENTWOOD AVE	JUDITH RD	NEWTON	14-Sep-25	30-Sep-25	2		
5316147	49 DALBY ST	CALIFORNIA STREET	NEWTON	15-Sep-25	19-Sep-25	1		
5315901	141 GORDON RD	BEACON ST	NEWTON	16-Sep-25	21-Nov-25	3	12925	G3SEI-LVL
5315977	92 DARTMOUTH STREET	FULLER	NEWTON	16-Sep-25	13-Oct-25	2		
5315979	160 LINCOLN ST	MOUNTFIELD ROAD	NEWTON	16-Sep-25	3-Oct-25	1		
5316634	244 NEEDHAM ST	OAK	NEWTON	19-Sep-25	22-Sep-25	1		
5318240	549 CRAFTS ST	CRAFTS ST	NEWTON	28-Sep-25	11-Dec-25	2		
5318269	1087 BEACON ST	WALNUT ST	NEWTON	28-Sep-25	14-Oct-25	1		
5318304	62 GREEN ST	WEST ST	NEWTON	29-Sep-25	13-Oct-25	2		
5318330	192 ELLIOT ST	WETHERELL ST	NEWTON	29-Sep-25	30-Sep-25	1		
5318435	74 PLEASANT ST		NEWTON	29-Sep-25	2-Oct-25	1		
5319074	98 ALLEN AVE		NEWTON	2-Oct-25	3-Oct-25	1		
5320444	181 FLORENCE ST		NEWTON	10-Oct-25	11-Dec-25	2		
5321374	18 W PINE ST	FREEMAN ST	NEWTON	15-Oct-25	15-Oct-25	1		
5321539	345 BOYLSTON ST, NEWTON	JACKSON STREET	CHESTNUT HIL	16-Oct-25	3-Nov-25	1		
5321585	32 NEWELL RD		NEWTON	16-Oct-25	17-Oct-25	1		
5321618	845 WASHINGTON ST	WALNUT ST	NEWTON	16-Oct-25	19-Nov-25	2		
5322344	170 AUBURNDALE AVE		NEWTON	21-Oct-25	21-Oct-25	1		
5322651	49 PRAIRIE AVE	RIVER ST	NEWTON	22-Oct-25	5-Nov-25	1		

Table L8 Newton Leaks Eliminated by Repair 2025 - Detail				Source:	National Grid Service Quality Report 26-SQ-05			
Leak #	Reported Address	Cross Street	Town	Reported Date	Repaired Date	Leak Grade	26-SQ-05 Leak Extent Measurement	Grade 3 Leak Designation
5322780	1535 BEACON ST	MONTCLAIR RD	NEWTON	23-Oct-25	23-Oct-25	1		
5327609	98 WINCHESTER ST		NEWTON	24-Oct-25	6-Nov-25	1		
5325038	100 WALNUT ST	WATERTOWN ST	NEWTON	28-Oct-25	17-Nov-25	3	200	Non-G3SEI
5325469	805 COMMONWEALTH AVE		NEWTON	29-Oct-25	3-Nov-25	1		
5326075	13 WINONA ST	CHASKE AVE	NEWTON	29-Oct-25	30-Oct-25	1		
5326307	125 GRASMERE ST		NEWTON	30-Oct-25	4-Nov-25	1		
5326450	215 AUBURNDALE AVE		NEWTON	30-Oct-25	3-Nov-25	1		
5327634	89 JACKSON RD	CAPITAL ST	NEWTON	4-Nov-25	24-Nov-25	3	100	Non-G3SEI
5328779	474 CENTER ST	CHURCH ST	NEWTON	6-Nov-25	10-Nov-25	1		
5329178	80 ELM ST		NEWTON	7-Nov-25	17-Nov-25	1		
5329344	70 ELLIOT STREET	BOYLSTON STREET	NEWTON	8-Nov-25	19-Nov-25	1		
5330064	66 WARWICK RD		NEWTON	12-Nov-25	18-Nov-25	1		
5330118	548 CENTRE ST	HOLLIS ST	NEWTON	12-Nov-25	18-Nov-25	1		
5330157	25 CHURCH ST	PARK ST	NEWTON	13-Nov-25	18-Nov-25	1		
5331619	45 BELMORE PARK	WASHINGTON ST	NEWTON	17-Nov-25	18-Nov-25	1		
5333330	248 ELLIOT ST	LINDEN ST	NEWTON	23-Nov-25	26-Nov-25	1		
5333795	30 LESLIE RD		NEWTON	25-Nov-25	18-Dec-25	2		
5334105	833 WASHINGTON ST	WALNUT ST	NEWTON	26-Nov-25	2-Dec-25	1		
5334478	907 CHESTNUT ST	ANITA CIR	NEWTON	30-Nov-25	30-Dec-25	2		
5334600	33 SCHOOL ST		NEWTON	1-Dec-25	1-Dec-25	1		
5334666	396 LEXINGTON ST	WALCOTT ST	AUBURNDALE	1-Dec-25	2-Dec-25	1		
5335719	39 NEHOIDEN RD	IRVINGTON ST	NEWTON	3-Dec-25	9-Dec-25	1		
5335777	39 NEHOIDEN RD		NEWTON	3-Dec-25	5-Dec-25	1		
5339318	95 HIGHLAND AVE	ELMWOOD PARK	NEWTON	16-Dec-25	17-Dec-25	1		
5342321	63 NEHOIDEN RD	IRVINGTON ST	NEWTON	29-Dec-25	30-Dec-25	1		

Table L9 leaks eliminated by pipe replacement 2025													
Leak ID	Street Address	Report Date	Classification Date	Grade	Repair Date	Carried Forward or Newly Identified	Prior Grade (if any)	Survey Date	Leak Extent	Method	Appeared in GREC inventory	Repair charged in GREC	Repaired on and by end of work order
12005640	487 BOYLSTON ST		2025-02-11	2	2025-07-22	Newly Identified					No	No	
12002318	84 RACHEL RD	2019-09-05	2019-09-05	3	2025-07-22	Carried Forward		2024-10-11	0	No CGI reading	No	No	
12000630	15 ROTHERWOOD RD	2010-07-10	2010-07-10	3	2025-07-16	Carried Forward		2025-04-14	0	No CGI reading	No	No	
258065	122 WARD ST	2004-01-22	2004-01-22	3	2025-04-01	Carried Forward		2025-02-07		No CGI reading	No	No	
We suspect these leaks were fixed by replacement but not charged in GREC, so the cost is unknown													

Table L10 Newton leaks eliminated otherwise 2025

Leak ID	Street Address	Town or City	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
270413	1812 COMMONWEALTH AV	NEWTON	3	5/18/2004	4/25/2025	Carried Forward		8/7/2024	350	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
427378	692 COMMONWEALTH AVE	NEWTON	3	10/7/2011	3/17/2025	Carried Forward		2/11/2025	0	No CGI reading	NO READS
1217681	206 CONCORD ST	NEWTON	3	5/6/2013	3/12/2025	Carried Forward		8/13/2024	2720	Leak Extent	REPAIRED UNDER OTHER LEAK REPAIR
5291666	9 OLD ORCHARD RD	NEWTON	2	5/27/2025	11/20/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5301734	1119 WALNUT ST, NEWTON	NEWTON	2	6/6/2025	7/18/2025	Newly Identified					DUPLICATE LEAK
5302967	23 HIGH ST	NEWTON	3	6/16/2025	7/1/2025	Newly Identified		6/16/2025	736	Leak Extent	DUPLICATE LEAK
5303494	9 OLD ORCHARD RD	NEWTON	2	6/20/2025	7/18/2025	Newly Identified					DUPLICATE LEAK
5304580	165 LINWOOD AVE	NEWTON	3	6/29/2025	7/12/2025	Newly Identified		6/30/2025	1650	Leak Extent	DUPLICATE LEAK
5306819	897 WASHINGTON ST	NEWTON	2	7/15/2025	7/22/2025	Newly Identified					DUPLICATE LEAK
5306863	75 WESTMINSTER RD	NEWTON	3	7/15/2025	8/7/2025	Newly Identified		7/15/2025	100	Leak Extent	DUPLICATE LEAK
5307650	945 BEACON ST	NEWTON	2	7/21/2025	9/11/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5310034	942 BEACON ST	NEWTON	2	8/7/2025	9/11/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5310041	215 AUBURNDALE AVE	NEWTON	2	8/7/2025	11/5/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5311697	262 PEARL ST	NEWTON	2	8/18/2025	9/2/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5312376	34 BROOKSIDE AVENUE	NEWTON	3	8/22/2025	8/27/2025	Newly Identified		8/22/2025	648	Leak Extent	DUPLICATE LEAK
5313859	49 DALBY STREET	NEWTON	3	9/2/2025	9/24/2025	Newly Identified		9/2/2025	1584	Leak Extent	CLOSED DUE TO ANOTHER LEAK REPAIR
5314336	52 DALBY ST	NEWTON	2	9/4/2025	9/11/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5314870	472 LOWELL AVE	NEWTON	1	8/31/2025	10/1/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5315045	96 WABAN ST	NEWTON	3	9/10/2025	9/15/2025	Newly Identified		9/10/2025	1800	Leak Extent	DUPLICATE LEAK
5315440	23 HIGH ST	NEWTON	3	9/12/2025	9/15/2025	Newly Identified		9/12/2025	736	Leak Extent	DUPLICATE LEAK
5315510	20 EVELYN RD	NEWTON	2	9/12/2025	10/1/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5315651	50 DALBY ST	NEWTON	2	9/13/2025	9/24/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5316023	327 DEDHAM STREET	NEWTON	3	9/16/2025	10/1/2025	Newly Identified		9/16/2025	4550	Leak Extent	DUPLICATE LEAK
5316155	49 DALBY ST	NEWTON	1	9/17/2025	9/24/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5316644	155 OAK ST	NEWTON	3	9/19/2025	10/3/2025	Newly Identified		9/19/2025	0	No CGI reading	DATA ENTRY ERROR
5316800	12 MURRAY RD	NEWTON	3	9/20/2025	9/29/2025	Newly Identified		9/20/2025	640	Leak Extent	DUPLICATE LEAK
5317010	750 BOYLSTON ST	NEWTON	1	9/22/2025	9/24/2025	Newly Identified					DATA ENTRY ERROR
5318236	314 LANGLEY RD	NEWTON	2	9/28/2025	10/3/2025	Newly Identified					DUPLICATE LEAK
5318250	20 GRANT AVE	NEWTON	3	9/28/2025	10/6/2025	Newly Identified		9/28/2025	2760	Leak Extent	DUPLICATE LEAK
5318427	34 BROOKSIDE AVE	NEWTON	3	9/29/2025	10/13/2025	Newly Identified		9/29/2025	50	Leak Extent	DUPLICATE LEAK
5319638	559 CENTRE ST	NEWTON	3	10/6/2025	10/13/2025	Newly Identified		10/6/2025	4050	Leak Extent	DUPLICATE LEAK
5319766	190 TEMPLE ST	NEWTON	3	10/7/2025	10/13/2025	Newly Identified		10/7/2025	1680	Leak Extent	DUPLICATE LEAK
5319825	15 HARTMAN RD	NEWTON	3	10/7/2025	10/14/2025	Newly Identified		10/7/2025	638	Leak Extent	DUPLICATE LEAK
5319930	115 ELLIOT ST	NEWTON	3	10/8/2025	10/14/2025	Newly Identified		10/8/2025	2275	Leak Extent	DUPLICATE LEAK
5319972	150 WOODLAND RD	NEWTON	3	10/8/2025	10/14/2025	Newly Identified		10/8/2025	400	Leak Extent	DUPLICATE LEAK
5321394	1784 WASHINGTON ST	NEWTON	2	10/15/2025	11/13/2025	Newly Identified					DUPLICATE LEAK

Table L10 Newton leaks eliminated otherwise 2025

Leak ID	Street Address	Town or City	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes
5321831	65 ROKEBY RD	NEWTON	3	10/17/2025	10/23/2025	Newly Identified		10/17/2025	750	Leak Extent	DUPLICATE LEAK
5322525	9 OLD ORCHARD RD	NEWTON	2	10/22/2025	11/7/2025	Newly Identified					DUPLICATE LEAK
5328702	835 WASHINGTON ST	NEWTON	2	11/6/2025	12/9/2025	Newly Identified					CLOSED DUE TO ANOTHER LEAK REPAIR
5331932	255 PARKER ST	NEWTON	2	11/18/2025	11/24/2025	Newly Identified					DATA ENTRY ERROR
5333316	50 OLDE FIELD RD	NEWTON	3	11/23/2025	12/19/2025	Newly Identified		11/23/2025	400	Leak Extent	DUPLICATE LEAK
5341348	18 CLOVELLY RD	NEWTON	2	12/22/2025	12/29/2025	Newly Identified					DATA ENTRY ERROR
5341487	583 WASHINGTON ST	NEWTON	3	12/23/2025	12/24/2025	Newly Identified		12/23/2025	4200	Leak Extent	DUPLICATE LEAK
5341848	19 GEORGE ST	NEWTON	3	12/25/2025	12/31/2025	Newly Identified		12/25/2025	2187	Leak Extent	DUPLICATE LEAK
5342274	315 ALBEMARLE RD	NEWTON	3	12/29/2025	12/31/2025	Newly Identified		12/29/2025	2275	Leak Extent	DUPLICATE LEAK
7326889	89 WALTHAM ST	NEWTON	3	6/15/2016	5/10/2025	Carried Forward		3/5/2025	0	No CGI reading	NO READS
7345014	7 CURTIS ST	NEWTON	2	11/20/2024	4/22/2025	Carried Forward					DUPLICATE LEAK
7349163	CYPRESS ST & PARKER S	NEWTON	3	11/15/2018	5/10/2025	Carried Forward		3/5/2025	0	No CGI reading	NO READS
7354041	66 NEEDHAM ST	NEWTON	3	10/20/2021	4/2/2025	Carried Forward		11/20/2024	0	No CGI reading	NO READS
7371044	178 PRINCE ST	NEWTON	3	9/27/2021	5/10/2025	Carried Forward		4/17/2025	0	No CGI reading	NO READS
7376820	96 WESTLAND AVE	NEWTON	3	8/19/2022	5/10/2025	Carried Forward		4/17/2025	0	No CGI reading	NO READS
7385308	55 FOREST AVE	NEWTON	3	12/9/2023	5/10/2025	Carried Forward		3/5/2025	0	No CGI reading	NO READS
7385843	299 WOODLAND RD	NEWTON	3	1/11/2024	3/20/2025	Carried Forward		10/9/2024	0	No CGI reading	NO READS
7387884	336 BOYLSTON ST	NEWTON	2	5/16/2024	4/29/2025	Carried Forward					NO READS
7387910	1026 BOYLSTON ST	NEWTON	2	5/13/2024	4/1/2025	Carried Forward					REPAIRED UNDER OTHER LEAK REPAIR
7387922	2096 WASHINGTON ST	NEWTON	2	5/24/2024	4/2/2025	Carried Forward					REPAIRED UNDER OTHER LEAK REPAIR
7389707	1063 COMMONWEALTH AV	NEWTON	3	9/17/2024	3/17/2025	Carried Forward					NO READS
7391104	15 SIMPSON ST	NEWTON	1	12/5/2024	1/15/2025	Carried Forward					NOT UNDERGROUND LEAK
7391215	123 SPIERS RD	NEWTON	1	12/17/2024	1/3/2025	Carried Forward					NO READS
7391274	54 BALLARD ST	NEWTON	3	12/9/2024	3/19/2025	Carried Forward					SYSTEM ISSUE
7391275	54 BALLARD ST	NEWTON	3	12/9/2024	3/14/2025	Carried Forward		12/9/2024		No CGI reading	DUPLICATE LEAK
7391374	26 BEACON ST	NEWTON	2	12/12/2024	5/16/2025	Carried Forward					WRONG ADDRESS
7392652	30 NATHAN RD	NEWTON	3	2/18/2025	5/19/2025	Newly Identified		2/18/2025	25	Leak Extent	SYSTEM ISSUE
7392772	330 WASHINGTON ST	NEWTON	2	3/4/2025	5/13/2025	Newly Identified					NO READS
7392929	290 ALBEMARLE RD	NEWTON	3	2/6/2025	4/2/2025	Newly Identified					REPAIRED UNDER OTHER LEAK REPAIR
7393120	CHENEY ST & CHENEY CT	NEWTON	2	3/30/2025	4/7/2025	Newly Identified					REPAIRED UNDER OTHER LEAK REPAIR
7393584	1455 BEACON ST	NEWTON	2	4/25/2025	5/1/2025	Newly Identified					WRONG ADDRESS
12002163	150 WOODLAND RD	NEWTON	3	5/8/2019	12/30/2025	Carried Forward		11/20/2025	1	Leak Extent	NO READS PRESENT
12002227	9 HIGH ST	NEWTON	3	6/27/2019	12/30/2025	Carried Forward		11/4/2025	0	No CGI reading	NO READS PRESENT
12003769	280 CENTRAL ST	NEWTON	3	1/9/2023	12/9/2025	Carried Forward		6/16/2025	1400	Leak Extent	DATA ENTRY ERROR
12004724	368 BOYLSTON ST	NEWTON	3	9/23/2024	7/22/2025	Carried Forward		9/23/2024	495	Leak Extent	CLOSED DUE TO CISBOT

Table L10 Newton leaks eliminated otherwise 2025												
Leak ID	Street Address	Town or City	Grade	Classification Date	Repair Date	Carried Forward or Newly Identified	Prior Grade (if any)	Survey Date	Leak Extent	Method	Notes	
12005675	21 CHERRY ST	NEWTON	2	3/30/2025	7/14/2025	Newly Identified					DATA ENTRY ERROR	
12006059	1022 BEACON ST	NEWTON	1	5/16/2025	7/3/2025	Newly Identified					DATA ENTRY ERROR	
12006063	118 LANGLEY RD	NEWTON	2	5/11/2025	7/10/2025	Newly Identified					DATA ENTRY ERROR	
12006102	267 PEARL ST	NEWTON	1	5/20/2025	5/26/2025	Newly Identified					DATA ENTRY ERROR	

Table L11 Aggregation of Leaks Eliminated Otherwise 2025

How Eliminated	Count	Leak extent, sq. ft.
CLOSED DUE TO ANOTHER LEAK REPAIR	12	1,584
CLOSED DUE TO CISBOT	1	495
DATA ENTRY ERROR	9	1,400
DUPLICATE LEAK	28	32,525
NO READS	12	0
NO READS PRESENT	2	1
NOT UNDERGROUND LEAK	1	0
REPAIRED UNDER OTHER LEAK REPAIR	6	3,070
SYSTEM ISSUE	2	25
WRONG ADDRESS	2	0
Total of leaks "eliminated otherwise"	75	39,100